

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/May/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	180.171	3217.530	1) Gujrat	-7.842	-114.259
2) Hydro	23.907	416.635	2) Madhya Pradesh	2.927	108.402
3) Gas	3.250	122.038	3) Chattisgarh	2.890	68.480
Total MSPGCL	207.328	3756.203	4) Maharashtra	198.548	3620.592
B) 1) APLM	60.638	1239.872	5) Goa (Amona)	-0.574	-25.371
2) JSWEL	16.983	359.343	Total	195.949	3657.844
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.117	657.944
4) RPL(AMT)	19.244	508.622	b) Mumbai Drawl	36.292	702.221
5) SWPGPL	6.724	157.912	c) MSEDCL Bilateral *	60.674	1363.190
6) Other IPP	18.074	400.829	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.117	657.823
C) 1) TPCL Thermal	15.398	277.504	Include PX	0.000	0.000
2) TPCL Hydro	7.473	80.065	Standby	0.000	0.121
3) TPCL Gas	0.983	54.157	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.611	216.058	1) MSEDCL	501.336	9858.407
D) STATE			2) Mumbai Discoms	71.757	1329.990
1) Thermal	328.843	6377.670	3) Other Discoms	9.538	178.979
(A1+C1+C4+(B1-B6))			TOTAL STATE	582.631	11367.376
2) Hydro	31.380	496.700			
(A2+C2)					
3) Gas	4.233	176.195			
(A3+B7+C3)					
4) Wind	14.599	488.939			
6) SOLAR	7.627	170.043			
TOTAL STATE	386.682	7709.547			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	7555	7390	7359	7216
MSPGCL Hydro	540	1104	851	689
MSPGCL Gas	130	120	130	140
MSPGCL Total Generation	8225	8614	8340	8045
Central Sector Receipt	9853	9503	7341	7027
WIND	230	426	1036	1090
CPP / IPP Thermal	4968	5135	4918	5143
CPP / IPP Gas	0	0	0	0
SOLAR	1018	809	0	0
Exchange with Mumbai	-2077	-1967	-1476	-1398
MSEDCL DEMAND MET	21786	22110	19722	19496
Load Shedding	0	0	0	0
MSEDCL DEMAND	21786	22110	19722	19496
TPCL GENERATION	878	989	1120	1128
AEML GENERATION	462	497	492	463
MUMBAI DEMAND	3417	3453	3088	2989
OTHER DISCOM DEMAND	431	410	437	411
STATE DEMAND MET	25634	25973	23247	22896
STATE DEMAND	25634	25973	23247	22896
Frequency (Hz)	50.01	50.02	49.93	49.87

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.12 Hz at 07.01 Hrs	49.67 Hz at 00.06 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 19/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.67	75.72	165	125
Unit 7	0.00	0.00	0	0
Unit 8	13.13	251.99	606	463
Unit 9	12.47	231.83	575	416
Unit 10	12.70	246.57	600	450
Total	41.97	806.11		
Bhusawal				
Unit 3	3.43	60.10	150	135
Unit 4	10.24	143.29	480	345
Unit 5	10.20	168.96	475	355
Total	23.87	372.35		
Parli				
Unit 6	3.90	68.21	212	0
Unit 7	5.01	75.54	223	190
Unit 8	3.02	48.49	130	119
Total	11.93	192.24		
Chandrapur				
Unit 3	3.89	71.38	180	138
Unit 4	3.29	66.92	140	131
Unit 5	8.60	162.65	380	350
Unit 6	9.21	151.14	400	335
Unit 7	9.40	172.22	407	372
Unit 8	11.15	186.82	471	455
Unit 9	10.32	191.25	445	413
Total	55.85	1002.38		
Paras				
Unit 3	4.86	80.79	228	143
Unit 4	5.01	84.21	216	201
Total	9.87	165.01		
Khaparkheda				
Unit 1	3.20	55.45	140	105
Unit 2	3.26	67.53	155	85
Unit 3	4.28	65.49	188	170
Unit 4	3.20	65.20	144	125
Unit 5	10.70	211.14	470	425
Total	24.64	464.81		
Nasik				
Unit 3	4.18	73.62	184	160
Unit 4	3.83	73.79	177	0
Unit 5	4.04	67.22	179	150
Total	12.04	214.64		
Uran				
All Units	3.25	122.04	140	120
Total	3.25	122.04		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.38	2.33	27	0
Total	0.38	2.33		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.44	85.41	515	40
Stage 4	9.83	133.21	1005	0
Stage 3	2.97	48.77	282	0
Total	17.23	267.39		
Hydro				
KDPH	0.65	9.62	27	27
VTRNA	0.77	15.75	60	0
TILLARI	0.00	8.24	0	0
BHIRA T.R.	0.36	3.61	80	0
SMLHY_PTN	4.52	102.06	219	176
GHATGHAR	0.00	7.64	0	0
Total	6.30	146.92		
Wind				
Total	14.60	488.94	0	0
Total	14.60	488.94		
CPP				
APML(Mus)	60.64	1239.87	0	0
JSWEL(Mus)	16.98	359.34	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.24	508.62	0	0
SWPGPL-Mus	6.72	157.91	0	0
Other(Mus)	18.07	400.83	0	0
Total	121.66	2666.58		
SOLAR				
Total	7.63	170.04	0	0
Total	7.63	170.04		
Tata				
Trombay 5	9.88	181.70	440	302
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.98	33.08	115	0
Trombay 7B	0.00	21.07	0	0
TATA Hydro	7.47	80.06	442	56
Trombay 8	5.52	95.81	236	225
Total	23.85	411.73		
AEML				
DTPS U-1&2	11.61	216.06	502	415
Total	11.61	216.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	180.17	3217.53	MSPGCL Total	207.33	3756.20
			MSPGCL Thml+Gas	183.42	3339.57	Koyna 1,2 & 4 Total	14.26	218.62
			MSPGCL Hydro	23.91	416.64	State Total	386.68	7709.55

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 19/May/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7806	2013	130	9949	549	5373	0	0	7429	7400	-1326	21601	0	21601	2981	344	24926	49.87
2	7835	1987	140	9962	577	5380	0	0	7318	7070	-1191	21486	0	21486	2777	312	24575	49.96
3	7645	1768	140	9553	654	5409	0	0	7150	7106	-1131	21283	0	21283	2595	308	24186	49.89
4	7715	1673	140	9528	592	5225	0	0	7125	7156	-906	21298	0	21298	2487	297	24082	49.97
5	7805	1533	140	9478	615	5027	0	0	7256	7235	-827	21215	0	21215	2411	313	23939	49.92
6	7704	1782	140	9626	592	5043	0	0	7286	7335	-836	21421	0	21421	2406	339	24166	49.89
7	7569	1658	140	9367	628	4954	0	63	7653	7850	-1005	21474	0	21474	2388	383	24245	50.02
8	7564	743	140	8447	553	4922	0	228	8101	8539	-1327	20951	0	20951	2476	411	23838	50.05
9	7613	520	140	8273	382	4928	0	529	8482	8941	-1755	20852	0	20852	2753	446	24051	50.01
10	7629	437	140	8206	276	4953	0	815	9223	9083	-1859	21034	0	21034	3085	440	24559	50.01
11	7632	419	130	8181	218	4954	0	915	9745	9677	-2028	21481	0	21481	3307	436	25224	49.98
12	7555	540	130	8225	230	4968	0	1018	9960	9853	-2077	21786	0	21786	3417	431	25634	50.01
13	7533	373	130	8036	212	5063	0	1049	9882	9741	-1991	21695	0	21695	3415	415	25525	50.01
14	7429	440	140	8009	264	5156	0	955	9681	9464	-1963	21489	0	21489	3348	396	25233	49.97
15	7390	1104	120	8614	426	5135	0	809	9512	9503	-1967	22110	0	22110	3453	410	25973	50.02
16	7393	1177	140	8710	462	5158	0	639	9127	9103	-1913	21734	0	21734	3507	425	25666	50.01
17	7370	915	130	8415	598	4941	0	401	9022	8972	-1854	21031	0	21031	3419	442	24892	49.99
18	7400	898	120	8418	569	4921	0	170	8436	8222	-1736	20100	0	20100	3286	464	23850	50.00
19	7410	442	140	7992	600	4917	0	36	7831	7708	-1533	19269	0	19269	3114	451	22834	49.98
20	7359	851	130	8340	1036	4918	0	0	7682	7341	-1476	19722	0	19722	3088	437	23247	49.93
21	7265	471	140	7876	1222	4876	0	0	7487	7456	-1407	19600	0	19600	3029	423	23052	49.98
22	7243	421	130	7794	1280	5143	0	0	7069	6879	-1341	19332	0	19332	2972	423	22727	49.95
23	7216	689	140	8045	1090	5143	0	0	7247	7027	-1398	19496	0	19496	2989	411	22896	49.87
24	7091	1053	140	8284	974	5156	0	0	7224	7288	-1445	19876	0	19876	3054	381	23311	49.97
MUs	180.17	23.91	3.25	207.33	14.60	121.66	0.00	7.63	196.93	195.95	-36.29	501.34	0.00	501.34	71.76	9.54	582.63	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/May/2022

Position as on 6.30 Hrs of 20/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 5	108	16/05/2022	12:59		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	16/05/2022	23:53		Continued.	Coal Shortage	
TPC-G	Trombay 7B	60	16/05/2022	23:59		Continued.	Non availability of APM gas.	
IPP	Adani U-2	660	17/05/2022	06:31		Continued.	Withdrawn	22/05/2022
TPC-G	Trombay 7A	120	19/05/2022	02:26	19/05/2022	17:00	Gas shortage	
IPP	SWPGPL U-3	135	19/05/2022	03:00		Continued.	ID Fan Problem	
MSPGCL	Parli Unit 6	250	19/05/2022	20:00		Continued.	Boiler Tube Leakage	21/05/2022
MSPGCL	Nasik Unit 4	210	19/05/2022	22:45		Continued.	condenser tube leakage.	21/05/2022
TPC-G	Trombay 7A	120	20/05/2022	02:45		Continued.	non availability of APM gas	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/May/2022

Statement-VII

Position as on 6.30 Hrs of 20/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TBC Outages/Trippings							
TBC @ LONIKAND	IntraState	19/05/2022	10:05	19/05/2022	17:25	PO	Half Yearly DT & Bay Maintenance.
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	15/05/2022	23:42			HT	For Load Management on Mumbai Supply Lines during the Outage of HVDC Pole-2
JAIGAD - NEW KOYNA CKT - 1	IntraState	16/05/2022	09:23			PO	C.B. Overhauling work Shifting on TBC
TBC @ CHAKAN	IntraState	17/05/2022	20:14			EO	Replacement of R, Y and B phases of 89B PG isolators of 400 KV TBC is to be done as their operating mechanisms are mechanically jammed and are difficult to dislodge.
KHARGHAR - TALEGAON (PG)	IntraState	19/05/2022	03:00	19/05/2022	07:29	EO	Chemical cleaning of insulators in the fog prone region.
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	19/05/2022	05:31	19/05/2022	06:54	T	DP
400 KV ICT Outages/Trippings							
400/220 KV 167MVA SPARE ICT @ LONIKAND 2	IntraState	19/05/2022	08:13	19/05/2022	15:08	PO	Half yearly maintenance and diagnostic testing .
400/220/33 KV 500 MVA ICT - 2 @ NANDED	IntraState	19/05/2022	11:10	19/05/2022	17:05	PO	Pre Manson Maintenance of ICT
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	20/05/2022	00:50	20/05/2022	02:28	T	220KV Bus Fault
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	20/05/2022	00:50	20/05/2022	07:16	T	220KV Bus Fault
400/220/33 KV 500 MVA ICT - 1 @ JEJURI	IntraState	20/05/2022	00:50			T	220KV Bus fault
220 KV MAINBAY Outages/Trippings							
TBC @ FLAGSHIP	IntraState	19/05/2022	09:26	19/05/2022	16:09	PO	Half yearly maintenance work
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
BORIVALI - TARAPUR	IntraState	18/05/2022	14:36			PO	Replacement of existing 0.5 ACSR MOOSE Conductor at loc. No. 11- 28, replacement of heavily Rusted Hardware , heavily rusted earth wire and all insulator strings of the line.
EKLAHARE (GCR) - PIMPALGAON CKT - 1	IntraState	18/05/2022	15:03	19/05/2022	16:42	EO	Disconnection of Main bus isolator jump and Reconnection of jump by Hot line unit Nashik. (Main Bus isolator alignment work to be carried out) work carried out in emergency.
DASTURI-KANDALGAON LINE	IntraState	18/05/2022	18:40	19/05/2022	03:47	PO	Outage tree cutting work at various location and other line premonsoon maintenance work.
TROMBAY CARNAC - 6	IntraState	18/05/2022	23:08	19/05/2022	03:34	EO	for replacement of transfer bus GOD arm
APTA - TALOJA	IntraState	19/05/2022	07:41	19/05/2022	10:47	PO	Replacement of Rusted Suspension plamp & D- sackle at Loc. No. 639, 641
ALEPHATA-PARGAON(KATHAPUR)	IntraState	19/05/2022	09:03	19/05/2022	17:57	PO	To carryout the Work of Replacement of Flashover R Ph Disc Insulator String (DSN) at Loc No 03 & other maintenance work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/May/2022

Statement-VII

Position as on 6.30 Hrs of 20/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NIWALI - PAWAS LINE	IntraState	19/05/2022	09:10	19/05/2022	17:50	PO	For shifting of R, Y, B phs CTs on new equipment structures against existing rusted structure of 220kV Pawas-Niwali line at 220kv Pawas substation.
URAN - ONGC URAN	IntraState	19/05/2022	09:35	19/05/2022	17:18	PO	Backup Relay Replacement at ONGC End & AR Scheme, Diagnostic Testing and R&M works at Uran End.
THEUR- MAGAR PATTI CITY	IntraState	19/05/2022	10:38	19/05/2022	14:44	EO	For attending Hotspot (80.9Degree) at Y Ph T connector of main bus of 220 kV Theur line by hot line method
KANDALGAON - PIRANGUT	IntraState	19/05/2022	18:05			PO	For Attending HOTSPOT of 220 KV Pirangut line R Phase BUS Isolator (CB SIDE) & R Phase Wavetrap Line T.
NIWALI - PAWAS LINE	IntraState	19/05/2022	21:56	20/05/2022	04:12	T	Distance Protection
PADGHE - TEMGHAR - 1	IntraState	20/05/2022	00:13	20/05/2022	06:40	PO	Bunching at Loc no.82 and jumper opening at Loc.no. 80
PADGHE - TEMGHAR - 2	IntraState	20/05/2022	00:22			PO	Bunching at Loc no.82 and jumper opening at Loc.no. 80.
KHAREPATAN -PAWAS LINE	IntraState	20/05/2022	00:31			T	Distance Protection
JEJURI (400 KV)-JEJURI- I	IntraState	20/05/2022	00:50	20/05/2022	02:37	T	220KV Bus Fault
JEJURI-PHURSUNGI 1	IntraState	20/05/2022	00:50			T	220KV Bus Fault
JEJURI-PHURSUNGI 2	IntraState	20/05/2022	00:50	20/05/2022	05:40	T	220KV Bus Fault
JEJURI - KONDHWA	IntraState	20/05/2022	00:50	20/05/2022	02:34	T	220KV Bus Fault
JEJURI - BARAMATI	IntraState	20/05/2022	00:50	20/05/2022	04:09	T	220KV Bus Fault
JEJURI (400 KV)-JEJURI- II	IntraState	20/05/2022	00:50			T	220KV Bus Fault
NIWALI - PAWAS LINE	IntraState	20/05/2022	04:39			T	Distance Protection
BUS SECTION-4 @ TEMGHAR	IntraState	20/05/2022	07:23			EO	For closing 220kv Bus section 3 isolator
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	19/05/2022	09:40	19/05/2022	15:13	PO	For Diagnostic & Pre monsoon Maintenance work
220/132 KV 100 MVA ICT 3 @ RANJANGAON	IntraState	19/05/2022	09:50	19/05/2022	18:20	PO	For checking healthiness of Ballon of conservator tank & Premonsoon work
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	19/05/2022	10:09	19/05/2022	13:51	PO	Pre monsoon & half yearly maintenance, Hot spot attending work
220/132-110 KV 100MVA ICT No-02 @ OGLEWADI	IntraState	19/05/2022	10:23	19/05/2022	13:02	PO	Premonsoon maintenance work
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	19/05/2022	10:25	19/05/2022	14:35	PO	Premonsoon maintenance work
220/33 KV 25MVA PTR NO 2 @ BHIGWAN	IntraState	19/05/2022	14:15	19/05/2022	17:40	PO	TESTING WORK
220/33kv 125 MVA TF 2 @ GORAI	IntraState	19/05/2022	16:25	19/05/2022	18:35	T	TRIPPED ON BUCHHOLZ RELAY
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	19/05/2022	17:20	19/05/2022	18:58	EO	Emergency work of attending oil leakage from LV side Rph & Bph Bushing of ICT-1.
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/May/2022

Statement-VII

Position as on 6.30 Hrs of 20/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage