

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 19/May/2023 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 171.348        | 3121.191        | 1) Gujrat                      | -5.859         | -67.764          |
| 2) Hydro            | 33.935         | 393.360         | 2) Madhya Pradesh              | 7.328          | 131.729          |
| 3) Gas              | 2.740          | 105.409         | 3) Chattisgarh                 | 5.510          | 100.470          |
| <b>Total MSPGCL</b> | <b>208.023</b> | <b>3619.960</b> | 4) Maharashtra                 | 197.486        | 3835.357         |
| B) 1) APLM          | 65.978         | 1002.062        | 5) Goa (Amona)                 | -1.570         | -24.795          |
| 2) JSWEL            | 22.458         | 392.096         | <b>Total</b>                   | <b>202.895</b> | <b>3974.997</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 38.576         | 739.912          |
| 4) RPL(AMT)         | 23.433         | 457.245         | b) Mumbai Drawl                | 41.921         | 813.471          |
| 5) SWPGPL           | 10.741         | 186.462         | c) MSEDCL Bilateral *          | 87.711         | 1801.747         |
| 6) Other IPP        | 9.677          | 208.080         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 38.576         | 739.823          |
| C) 1) TPCL Thermal  | 14.737         | 220.203         | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 8.154          | 86.901          | Standby                        | 0.000          | 0.089            |
| 3) TPCL Gas         | 0.000          | 44.972          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 11.538         | 191.765         | 1) MSEDCL                      | 529.053        | 9455.481         |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 76.350         | 1357.312         |
| 1) Thermal          | 329.910        | 5779.104        | 3) Other Discoms               | 10.265         | 196.543          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>615.668</b> | <b>11009.336</b> |
| 2) Hydro (A2+C2)    | 42.089         | 480.261         |                                |                |                  |
| 3) Gas (A3+B7+C3)   | 2.740          | 150.381         |                                |                |                  |
| 4) Wind             | 21.334         | 325.526         |                                |                |                  |
| 6) SOLAR            | 16.700         | 299.067         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>412.773</b> | <b>7034.339</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 8 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 7062                      | 7164                  | 7147                      | 6822                      |
| MSPGCL Hydro               | 776                       | 656                   | 1680                      | 1834                      |
| MSPGCL Gas                 | 111                       | 114                   | 114                       | 116                       |
| MSPGCL Total Generation    | 7950                      | 7934                  | 8942                      | 8772                      |
| Central Sector Receipt     | 10150                     | 9909                  | 7897                      | 7953                      |
| WIND                       | 541                       | 637                   | 1083                      | 708                       |
| CPP / IPP Thermal          | 4378                      | 6023                  | 6241                      | 4322                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2248                      | 1396                  | 0                         | 633                       |
| Exchange with Mumbai       | -2410                     | -2286                 | -1701                     | -1433                     |
| <b>MSEDCL DEMAND MET</b>   | <b>22384</b>              | <b>23153</b>          | <b>21993</b>              | <b>20516</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 22384                     | 23153                 | 21993                     | 20516                     |
| TPCL GENERATION            | 752                       | 999                   | 1089                      | 838                       |
| AEML GENERATION            | 496                       | 500                   | 479                       | 372                       |
| <b>MUMBAI DEMAND</b>       | <b>3658</b>               | <b>3785</b>           | <b>3269</b>               | <b>2643</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>473</b>                | <b>460</b>            | <b>468</b>                | <b>439</b>                |
| STATE DEMAND MET           | 26514                     | 27398                 | 25730                     | 23598                     |
| <b>STATE DEMAND</b>        | <b>26514</b>              | <b>27398</b>          | <b>25730</b>              | <b>23598</b>              |
| Frequency (Hz)             | 49.93                     | 50.01                 | 50.02                     | 50.03                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.27 Hz at 18:47 Hrs | 49.78 Hz at 11:50 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 19/May/2023

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.41         | 82.00         | 195      | 165      |
| Unit 8             | 13.98        | 203.13        | 602      | 530      |
| Unit 9             | 13.34        | 237.44        | 592      | 515      |
| Unit 10            | 12.62        | 160.91        | 550      | 495      |
| <b>Total</b>       | <b>44.36</b> | <b>683.48</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.54         | 63.86         | 160      | 130      |
| Unit 4             | 9.35         | 147.58        | 410      | 345      |
| Unit 5             | 9.80         | 194.67        | 435      | 310      |
| <b>Total</b>       | <b>22.68</b> | <b>406.11</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 1.13         | 80.89         | 172      | 0        |
| Unit 7             | 4.51         | 73.43         | 245      | 140      |
| Unit 8             | 4.62         | 89.48         | 237      | 152      |
| <b>Total</b>       | <b>10.26</b> | <b>243.81</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.60         | 69.22         | 165      | 125      |
| Unit 4             | 3.63         | 58.64         | 158      | 120      |
| Unit 5             | 9.31         | 144.08        | 415      | 290      |
| Unit 6             | 9.29         | 173.55        | 410      | 290      |
| Unit 7             | 9.86         | 174.66        | 441      | 304      |
| Unit 8             | 11.31        | 173.81        | 499      | 366      |
| Unit 9             | 11.34        | 205.78        | 500      | 368      |
| <b>Total</b>       | <b>58.33</b> | <b>999.73</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.65         | 90.10         | 227      | 146      |
| Unit 4             | 4.99         | 94.04         | 240      | 156      |
| <b>Total</b>       | <b>9.64</b>  | <b>184.14</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.41         | 57.34         | 130      | 60       |
| Unit 2             | 2.95         | 57.74         | 145      | 0        |
| Unit 3             | 4.25         | 75.23         | 185      | 140      |
| Unit 4             | 1.02         | 77.41         | 192      | 0        |
| Unit 5             | 7.51         | 187.50        | 455      | 0        |
| <b>Total</b>       | <b>18.15</b> | <b>455.21</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.98         | 23.79         | 177      | 125      |
| Unit 4             | 3.95         | 76.51         | 177      | 125      |
| Unit 5             | 0.00         | 48.42         | 0        | 0        |
| <b>Total</b>       | <b>7.93</b>  | <b>148.72</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 2.74         | 105.41        | 117      | 111      |
| <b>Total</b>       | <b>2.74</b>  | <b>105.41</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.10         | 0.36          | 35       | 0        |
| <b>Total</b>       | <b>0.10</b>  | <b>0.36</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 6.24         | 82.32         | 530      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 17.69         | 177.48         | 1015     | 122      |
| Stage 3         | 5.76          | 57.36          | 320      | 68       |
| <b>Total</b>    | <b>29.70</b>  | <b>317.15</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.64          | 13.07          | 27       | 27       |
| VTRNA           | 1.16          | 19.32          | 60       | 0        |
| TILLARI         | 0.00          | 0.23           | 0        | 0        |
| BHIRA T.R.      | 0.47          | 4.93           | 80       | 0        |
| SMLHY_PTN       | 1.87          | 38.30          | 80       | 74       |
| GHATGHAR        | 0.00          | 0.00           | 0        | 0        |
| <b>Total</b>    | <b>4.14</b>   | <b>75.85</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 21.33         | 325.53         | 0        | 0        |
| <b>Total</b>    | <b>21.33</b>  | <b>325.53</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 65.98         | 1002.06        | 0        | 0        |
| JSWEL(Mus)      | 22.46         | 392.10         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 23.43         | 457.24         | 0        | 0        |
| SWPGPL-Mus      | 10.74         | 186.46         | 0        | 0        |
| Dhariwal        | 0.00          | 16.14          | 0        | 0        |
| IEPL            | 5.69          | 96.07          | 270      | 152      |
| Other(Mus)      | 3.99          | 95.86          | 0        | 0        |
| <b>Total</b>    | <b>132.29</b> | <b>2245.94</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 16.70         | 299.07         | 0        | 0        |
| <b>Total</b>    | <b>16.70</b>  | <b>299.07</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.40          | 143.44         | 423      | 314      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 0.00          | 25.96          | 0        | 0        |
| Trombay 7B      | 0.00          | 19.02          | 0        | 0        |
| TATA Hydro      | 8.15          | 86.90          | 442      | 218      |
| Trombay 8       | 5.34          | 76.77          | 237      | 171      |
| <b>Total</b>    | <b>22.89</b>  | <b>352.08</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 11.54         | 191.76         | 502      | 314      |
| <b>Total</b>    | <b>11.54</b>  | <b>191.76</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 171.35      | 3121.19       | MSPGCL Total        | 208.02      | 3619.96       |
|                |             |         | MSPGCL Thml+Gas | 174.09      | 3226.60       | Koyna 1,2 & 4 Total | 23.94       | 259.79        |
|                |             |         | MSPGCL Hydro    | 33.94       | 393.36        | State Total         | 412.77      | 7034.34       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 19/May/2023

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 7517        | 1940  | 115  | 9572   | 903   | 5754      | 0    | 0     | 8134        | 7686        | -1565                | 21967                  | 0                | 278                         | 21967                         | 3140             | 383                       | 25490           | 49.99         |
| 2                  | 7483        | 1950  | 116  | 9548   | 1022  | 6102      | 0    | 0     | 7455        | 7310        | -1397                | 22238                  | 0                | 295                         | 22238                         | 2932             | 347                       | 25518           | 49.95         |
| 3                  | 7549        | 1948  | 114  | 9612   | 1122  | 5975      | 0    | 0     | 6952        | 6783        | -1244                | 21911                  | 0                | 204                         | 21911                         | 2740             | 337                       | 24988           | 50.02         |
| 4                  | 7528        | 1946  | 115  | 9588   | 1141  | 5419      | 0    | 0     | 6926        | 7256        | -1211                | 21870                  | 0                | 97                          | 21870                         | 2612             | 323                       | 24806           | 50.01         |
| 5                  | 7614        | 1924  | 116  | 9654   | 1169  | 5644      | 0    | 0     | 6938        | 7044        | -1118                | 22047                  | 0                | 80                          | 22047                         | 2540             | 347                       | 24934           | 50.02         |
| 6                  | 7525        | 1774  | 117  | 9416   | 1173  | 6031      | 0    | 0     | 6977        | 6937        | -1133                | 22046                  | 0                | 45                          | 22046                         | 2532             | 378                       | 24956           | 50.01         |
| 7                  | 7246        | 1726  | 115  | 9086   | 1034  | 5536      | 0    | 171   | 7354        | 7537        | -1305                | 21642                  | 0                | 45                          | 21642                         | 2504             | 418                       | 24564           | 50.05         |
| 8                  | 6822        | 1834  | 116  | 8772   | 708   | 4322      | 0    | 633   | 8581        | 7953        | -1433                | 20516                  | 0                | 87                          | 20516                         | 2643             | 439                       | 23598           | 50.03         |
| 9                  | 6103        | 1898  | 114  | 8114   | 631   | 4004      | 0    | 1203  | 9013        | 8598        | -1416                | 20664                  | 0                | 144                         | 20664                         | 2952             | 470                       | 24086           | 50.01         |
| 10                 | 6435        | 1468  | 113  | 8016   | 652   | 4202      | 0    | 1735  | 9299        | 9380        | -1919                | 21598                  | 0                | 117                         | 21598                         | 3291             | 468                       | 25356           | 50.02         |
| 11                 | 7246        | 684   | 113  | 8044   | 632   | 4544      | 0    | 2051  | 9764        | 9570        | -2317                | 22062                  | 0                | 23                          | 22062                         | 3539             | 461                       | 26062           | 49.96         |
| 12                 | 7062        | 776   | 111  | 7950   | 541   | 4378      | 0    | 2248  | 10237       | 10150       | -2410                | 22384                  | 0                | 5                           | 22384                         | 3658             | 473                       | 26514           | 49.93         |
| 13                 | 7101        | 746   | 113  | 7960   | 610   | 4784      | 0    | 2209  | 10136       | 9887        | -2328                | 22670                  | 0                | 1                           | 22670                         | 3676             | 452                       | 26798           | 49.97         |
| 14                 | 7002        | 706   | 112  | 7820   | 565   | 4789      | 0    | 1993  | 10113       | 10014       | -2262                | 22472                  | 0                | 0                           | 22472                         | 3577             | 448                       | 26497           | 50.01         |
| 15                 | 7039        | 762   | 113  | 7914   | 616   | 5423      | 0    | 1708  | 10234       | 10178       | -2365                | 23016                  | 0                | 50                          | 23016                         | 3697             | 458                       | 27172           | 49.95         |
| 16                 | 7164        | 656   | 114  | 7934   | 637   | 6023      | 0    | 1396  | 9978        | 9909        | -2286                | 23153                  | 0                | 32                          | 23153                         | 3785             | 460                       | 27398           | 50.01         |
| 17                 | 7225        | 924   | 115  | 8264   | 718   | 6061      | 0    | 909   | 9319        | 9166        | -2167                | 22488                  | 0                | 1                           | 22488                         | 3718             | 462                       | 26668           | 50.04         |
| 18                 | 7226        | 902   | 114  | 8242   | 783   | 5977      | 0    | 400   | 8951        | 9018        | -1981                | 21967                  | 0                | 5                           | 21967                         | 3540             | 472                       | 25980           | 50.02         |
| 19                 | 7204        | 1090  | 113  | 8408   | 923   | 5889      | 0    | 44    | 8729        | 8702        | -1922                | 21571                  | 0                | 1                           | 21571                         | 3325             | 473                       | 25368           | 50.14         |
| 20                 | 7147        | 1680  | 114  | 8942   | 1083  | 6241      | 0    | 0     | 8098        | 7897        | -1701                | 21993                  | 0                | 0                           | 21993                         | 3269             | 468                       | 25730           | 50.02         |
| 21                 | 7227        | 1492  | 115  | 8834   | 1237  | 6267      | 0    | 0     | 7882        | 7694        | -1619                | 21961                  | 0                | 0                           | 21961                         | 3196             | 453                       | 25610           | 49.95         |
| 22                 | 7204        | 1310  | 114  | 8628   | 1169  | 6295      | 0    | 0     | 7684        | 7651        | -1574                | 21730                  | 0                | 0                           | 21730                         | 3139             | 440                       | 25308           | 49.95         |
| 23                 | 6879        | 1774  | 114  | 8766   | 1187  | 6295      | 0    | 0     | 7997        | 8347        | -1600                | 22577                  | 63               | 0                           | 22640                         | 3150             | 418                       | 26208           | 50.01         |
| 24                 | 6800        | 2022  | 114  | 8936   | 1078  | 6332      | 0    | 0     | 8067        | 8228        | -1648                | 22509                  | 523              | 0                           | 23032                         | 3195             | 417                       | 26644           | 50.02         |
| MUs                | 171.35      | 33.93 | 2.74 | 208.02 | 21.33 | 132.29    | 0.00 | 16.70 | 204.82      | 202.90      | -41.92               | 529.05                 | 0.59             | 1.51                        | 529.64                        | 76.35            | 10.26                     | 616.25          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

1)DLS done at 220kv Alephatastn for load management of 220kv Babheleshwer-Alephata line & due to overloading of 400kv PG line.2)ELR done due to overloading of 220kv BBLR-1 & 2 line. 3)ELR done due to BBLR-Alephata line overloaded. 4)ERL done due 132kv A'nagar(sonewadi)-MIDC Nagar line overloaded.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 19/May/2023**

**Position as on 6.30 Hrs of 20/May/2023**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                | Uran Unit 7             | 108      | 18/05/2023   | 18:14        |            | Continued. | Gas shortage                                                                                                                                            |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 01/04/2024    |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 01/05/2024    |
| MSPGCL                | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |            | Continued. | Stator Earth Fault                                                                                                                                      | 31/07/2023    |
| MSPGCL                | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 30/05/2023    |
| MSPGCL                | Uran Unit 5             | 108      | 12/11/2022   | 13:23        |            | Continued. | Material replacement work.                                                                                                                              | 01/03/2024    |
| MSPGCL                | Ghatghar Unit-2         | 125      | 08/02/2023   | 07:02        |            | Continued. | Stator Earth Fault                                                                                                                                      | 01/06/2023    |
| MSPGCL                | Uran Unit 6             | 108      | 10/05/2023   | 02:00        |            | Continued. | Zero Schedule.                                                                                                                                          |               |
| MSPGCL                | Nasik Unit 5            | 210      | 13/05/2023   | 22:53        | 20/05/2023 | 22:25      | Unit-05 subjected to Case IV Phase III Tolling immediately from 22:53 Hrs dt.13.05.2023                                                                 |               |
| IPP                   | RPL(AMT) U-2            | 270      | 16/05/2023   | 23:00        |            | Continued. | Ash Evacuation Problem.                                                                                                                                 | 22/05/2023    |
| TPC-G                 | Trombay 7A              | 120      | 18/05/2023   | 00:15        | 20/05/2023 | 19:12      | Gas shortage                                                                                                                                            |               |
| TPC-G                 | Trombay 7B              | 60       | 18/05/2023   | 00:15        |            | Continued. | Gas shortage                                                                                                                                            |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 19/05/2023   | 05:56        | 20/05/2023 | 15:04      | Boiler Tube Leakage                                                                                                                                     | 22/05/2023    |
| MSPGCL                | Parli Unit 6            | 250      | 19/05/2023   | 07:40        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 22/05/2023    |
| MSPGCL                | Khaparkheda Unit 2      | 210      | 19/05/2023   | 21:48        | 20/05/2023 | 00:49      | PA Fan problem                                                                                                                                          | 20/05/2023    |
| MSPGCL                | Khaparkheda Unit 5      | 500      | 19/05/2023   | 22:20        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 24/05/2023    |
| MSPGCL                | Nasik Unit 3            | 210      | 20/05/2023   | 08:45        | 20/05/2023 | Continued. | Boiler Tube Leakage                                                                                                                                     | 23/05/2023    |
| MSPGCL                | Koyna Unit 10           | 80       | 20/05/2023   | 17:45        |            | Continued. | Gen. motorize cooling water valve problem                                                                                                               |               |
| MSPGCL                | Koyna STG-IV Unit-2     | 250      | 20/05/2023   | 19:35        | 20/05/2023 | 22:00      | Synchronisation problem                                                                                                                                 |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/May/2023**

**Statement-VII**

Position as on 6.30 Hrs of 20/May/2023

| Name of Line                                                     | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                 |
|------------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV TIEBAY Outages/Trippings</b>                           |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| TIE BAY - 702 OF BUS REACTOR AND 765/400kV 1500MVA ICT @ AKOLA 2 | IntraState                | 19/05/2023   | 11:05        | 19/05/2023 | 15:00      | PO          | DGA Test of Current Transformer                                                                                                                                                                                                  |
| <b>765 KV MAINBAY Outages/Trippings</b>                          |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| MAIN BAY (703) BUS REACTOR @ AKOLA 2                             | IntraState                | 19/05/2023   | 15:35        | 19/05/2023 | 18:56      | PO          | DGA Test of Current Transformer                                                                                                                                                                                                  |
| <b>765 KV ICT Outages/Trippings</b>                              |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| 765/400KV 500MVA SPARE ICT UNIT @ EKTUNI                         | IntraState                | 19/05/2023   | 11:03        | 19/05/2023 | 18:55      | PO          | Diagnostic Testing & Routine Maintenance                                                                                                                                                                                         |
| <b>500 KV LINE Outages/Trippings</b>                             |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| CHANDRAPUR - PADGHE HVDC POLE 2                                  | IntraState                | 20/05/2023   | 02:32        | 20/05/2023 | 03:59      | EO          | emergency shutdown of HVDC Pole-2 Base filter Z21-Z1/Z2 for attending Hotspots at various locations in all the three phase,respective images are also attached                                                                   |
| CHANDRAPUR - PADGHE HVDC POLE 1                                  | IntraState                | 20/05/2023   | 04:24        | 20/05/2023 | 05:38      | EO          | Emergency shutdown of HVDC Pole-1 BASE FILTER Z11-Z1/Z2 for attending Hotspots at various locations in all the three phase,respective images are also attached                                                                   |
| <b>400 KV TIEBAY Outages/Trippings</b>                           |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| 400KV TIE BAY (419) STATION T/F 3 @ RPL (AMT)-NANDGAONPETH       | InterState                | 16/05/2023   | 06:21        | 19/05/2023 | 13:42      | PO          | ST-3 Tie bay following work to be carried out:-<br>1. total 3 nos. bay CT testing work.<br>2. ST-3 tie bay relay testing work<br>3.ST-3 tie breaker testing work(DCRM , CRM and timing testing)<br>4.ST-3 Tie bay isolator       |
| <b>400 KV MAINBAY Outages/Trippings</b>                          |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| 400KV MAIN BAY (419) STATION TF 3 @ RPL (AMT)-NANDGAONPETH       | InterState                | 16/05/2023   | 06:21        | 19/05/2023 | 13:42      | PO          | ST-3 (419bay) following work to be carried out<br>1. all three poles circuit breakers maintenance and testing work(DCRM,timing and CRM testing)<br>2. 3 nos. Bay CT tan testing work<br>3. 419 Bay protection relay testing work |
| MAIN BAY (405) OF KHADKA CKT - 1 @ DEEPNAGAR                     | IntraState                | 18/05/2023   | 17:16        |            |            | PO          | For servicing & overhauling of 400kV AREVA make KDK CKT-1 Main C.B. Mechanism                                                                                                                                                    |
| <b>400 KV LINE Outages/Trippings</b>                             |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| TALANDGE - KOLHAPUR (PG) CKT - 2                                 | InterState                | 20/03/2023   | 07:49        |            |            | PO          | For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1                                                                            |
| PUNE(GIS) - TALEGAON(PG) CKT - 4                                 | InterState                | 18/05/2023   | 19:09        | 19/05/2023 | 09:06      | T           | Tripped on distance protection                                                                                                                                                                                                   |
| PUNE(GIS) - TALEGAON(PG) CKT - 3                                 | InterState                | 18/05/2023   | 19:09        | 19/05/2023 | 08:48      | T           | Tripped on distance protection                                                                                                                                                                                                   |
| 400 KV AKOLA - AURANGABAD(PG) CKT -2                             | InterState                | 19/05/2023   | 13:29        | 19/05/2023 | 15:18      | PO          | For taking out LR. & Line will be taken without LR at Akola (MSETCL) end.                                                                                                                                                        |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/May/2023**

**Statement-VII**

Position as on 6.30 Hrs of 20/May/2023

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                             |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| DHULE - SSNNL CKT - 2                   | InterState                | 20/05/2023   | 09:17        | 20/05/2023 | 16:07      | PO          | For replacement of PID Suspecious string, Cold line washing & Missing Hardware replacement work.400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode during Outage period.      |
| 400 KV AKOLA - AURANGABAD(PG) CKT -2    | InterState                | 20/05/2023   | 13:38        | 20/05/2023 | 14:26      | PO          | For taking LR at Akola (MSETCL) end into service along with the line.                                                                                                                        |
| DHULE - SSNNL CKT - 2                   | InterState                | 20/05/2023   | 22:21        |            | Continued. | T           | TRIPPED ON OVER VOLTAGE                                                                                                                                                                      |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1     | IntraState                | 03/04/2023   | 11:30        |            | Continued. | HT          | H/T TO CONTROL LINE LOADING OF PUNE PG                                                                                                                                                       |
| LONIKAND I - KOYNA STAGE-IV             | IntraState                | 15/05/2023   | 08:58        | 19/05/2023 | 20:14      | PO          | 400kV CB O/H work by shifting on TBC                                                                                                                                                         |
| DEEPNAGAR - THAPTI TANDA                | IntraState                | 19/05/2023   | 09:32        | 19/05/2023 | 18:38      | PO          | Disc insulator replacement work and other annual maintenance work                                                                                                                            |
| TBC @ NEW KOYNA                         | IntraState                | 19/05/2023   | 10:50        | 19/05/2023 | 18:10      | PO          | Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance                                                                                                      |
| DEEPNAGAR - THAPTI TANDA                | IntraState                | 20/05/2023   | 10:29        | 20/05/2023 | 18:56      | PO          | Disc insulator replacement work and other annual maintenance work                                                                                                                            |
| PADGHE - NAGOTHANE CKT - 2              | IntraState                | 20/05/2023   | 12:17        | 20/05/2023 | 15:21      | EO          | For cold washing work                                                                                                                                                                        |
| CHANDRAPUR-PARLI CKT-3                  | IntraState                | 20/05/2023   | 14:28        | 20/05/2023 | 17:50      | EO          | For replacing broken clamp of 400kV CVT of 400kV Girwali-Chandrapur ckt 3 at 400kV Girwali.                                                                                                  |
| <b>400 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                              |
| STATION TF No 3 @ CHANDRAPUR GCR        | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                               |
| STATION TRANSFORMER - 3 @ NANDGAON PETH | IntraState                | 16/05/2023   | 06:21        | 19/05/2023 | 13:42      | PO          | ST-3 transformer oil leakage arresting, maintenance , diagnostic testing, Metering CT and CVT testing and ST-3 transformer protection relay testing work.<br>ST-3 transformer painting work. |
| 400/220/33 KV 500 MVA ICT - 3 @ DHULE   | IntraState                | 18/05/2023   | 09:47        | 19/05/2023 | 19:03      | PO          | RRS scheme work and pre-monsoon activity                                                                                                                                                     |
| 400/220/33 KV 315 MVA ICT - 1 @ PARLI   | IntraState                | 19/05/2023   | 09:44        | 19/05/2023 | 17:14      | PO          | Premonsoon maintenance & testing work.                                                                                                                                                       |
| 400/220 KV 500 MVA ICT @ ALKUD          | IntraState                | 19/05/2023   | 19:26        | 19/05/2023 | 23:31      | PO          | For Pre-monsoon maintenance & diagnostic testing work (Tan Delta measurement of bushings)                                                                                                    |
| 400/220 KV 500 MVA ICT @ ALKUD          | IntraState                | 20/05/2023   | 18:59        |            |            | EO          | To attend hot spot at 204-89D Isolator                                                                                                                                                       |
| <b>220 KV MAINBAY Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                                                                                              |
| BUS COUPLER @ KARAD - 1                 | IntraState                | 19/05/2023   | 13:43        | 19/05/2023 | 18:17      | EO          | For attending hotspot at 29 A R ph Conductor Jumps from Isolator to CB side by replacing conductor jumps Temp-135 degree                                                                     |
| BUS COUPLER @ DHARAVI                   | IntraState                | 20/05/2023   | 01:37        | 20/05/2023 | 02:26      | PO          | Breaker testing                                                                                                                                                                              |
| <b>220 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                              |
| EKLAHARE (OCR) - NAVASARI CKT - 1       | IntraState                | 10/02/2023   | 09:45        |            |            | PO          | Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)                                                                                               |
| EKLAHARE (OCR) - PADGHE                 | IntraState                | 05/03/2023   | 08:55        |            |            | HT          | For load management                                                                                                                                                                          |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/May/2023**

**Statement-VII**

Position as on 6.30 Hrs of 20/May/2023

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                        |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------|
| KARAD - DASGAON                           | IntraState                | 16/05/2023   | 10:40        |            |            | PO          | For erection & stringing of In line narrow base multi circuit tower (Loc No.145) of new 220kV Karad-Koyana line.        |
| 220 KV ANJANGAON (VIHIGAON) - AKOLA CKT I | IntraState                | 19/05/2023   | 08:18        | 19/05/2023 | 12:55      | PO          | Replacement of flashover disc.                                                                                          |
| WANI-WARORA 1                             | IntraState                | 19/05/2023   | 09:34        | 19/05/2023 | 13:35      | PO          | Replacement of damage/bolted clamp jumper of ct, cc , la wave trap.                                                     |
| PUSAD-GHATODI                             | IntraState                | 19/05/2023   | 09:40        | 19/05/2023 | 15:15      | PO          | For alignment of bus-ii isolator maintenance work.                                                                      |
| COLOURCHEM - TEMGHAR                      | IntraState                | 19/05/2023   | 10:01        | 19/05/2023 | 12:49      | T           | Distance Protection                                                                                                     |
| 220 KV PHULAMBRI - BHOKARDHAN             | IntraState                | 19/05/2023   | 10:35        | 19/05/2023 | 13:24      | PO          | String Replacement At Loc-No-190.                                                                                       |
| PARGAON( KATHAPUR)-LONIKAND               | IntraState                | 19/05/2023   | 10:45        | 19/05/2023 | 11:52      | T           | Tripped on LTS                                                                                                          |
| LONAND-BOTHE                              | IntraState                | 19/05/2023   | 11:11        | 19/05/2023 | 17:59      | PO          | Quarterly Maintenance Work & Annual relay testing Work                                                                  |
| ALEPHATA-PARGAON(KATHAPUR)                | IntraState                | 19/05/2023   | 11:52        | 19/05/2023 | 20:08      | HT          | HT for Load Management                                                                                                  |
| SATANA - GANGAPUR                         | IntraState                | 19/05/2023   | 12:15        | 19/05/2023 | 13:35      | EO          | for removal of wrapped plastic paper between Y B ph at Loc no 47                                                        |
| SAWANGI-PHULAMBRI CKT                     | IntraState                | 19/05/2023   | 14:10        | 19/05/2023 | 18:03      | PO          | String Replacement At Loc-No-12 R-PH.                                                                                   |
| KARAD - WATHAR                            | IntraState                | 19/05/2023   | 16:04        | 19/05/2023 | 22:45      | EO          | Auto reclosure Relay testing work.                                                                                      |
| SHIVAJINAGAR-MALEGAON                     | IntraState                | 19/05/2023   | 16:48        | 19/05/2023 | 22:20      | EO          | Emergency Outage For replacement of Y Ph. CT due to oil leakage from Dead Tank and high tan D values.                   |
| EKLAHARE (GCR) - AIROLI KNOW PARK         | IntraState                | 19/05/2023   | 17:20        | 20/05/2023 | 02:53      | EO          | Hot spot attending at Loc. No. 389B, 322/1, 322/2, 322/3, 315, 348, 341, 329 & 328                                      |
| HINJEWADI 2 - PEGASUS                     | IntraState                | 19/05/2023   | 23:48        | 20/05/2023 | 01:11      | EO          | 1) Patch work on damaged outer sheaths of cable at Y,B Ph between JB location 2 & 3 -220 kV Pegasus Hinjewadi2 Line     |
| PALGHAR - PANCHALI TSS                    | IntraState                | 20/05/2023   | 02:25        | 20/05/2023 | 06:32      | PO          | Replacement of old rusted disc insulator with porcelain long Insulator at Loc No.03,04,08,10,12,13,15,16.               |
| PARGAON( KATHAPUR)-LONIKAND               | IntraState                | 20/05/2023   | 07:43        | 20/05/2023 | 09:39      | T           | TRIPPED ONLY AT KATHAPUR END DUE TO OVER LOADING OF 220KV AALEPHATA-BBLR                                                |
| TROMBAY - CARNAC - 7                      | IntraState                | 20/05/2023   | 07:50        | 20/05/2023 | 16:58      | PO          | CVT AND LA TESTING                                                                                                      |
| PANDHARPUR - KHANAPUR                     | IntraState                | 20/05/2023   | 08:29        | 20/05/2023 | 13:13      | PO          | Cold line washing of insulator strings                                                                                  |
| NEW KOYNA - NIWALI                        | IntraState                | 20/05/2023   | 09:08        | 20/05/2023 | 18:08      | PO          | 1)Cold washing of Line insulator strings.<br>2)R-ph LA replacement at 220kV Niwali S/s                                  |
| OSMANABAD - SOLAPUR (BALE)                | IntraState                | 20/05/2023   | 10:23        | 20/05/2023 | 16:19      | PO          | DI Replacement At 79 R-Phase.                                                                                           |
| OSMANABAD - SOLAPUR (BALE)                | IntraState                | 20/05/2023   | 10:23        | 20/05/2023 | 16:19      | PO          | 1) DI replacement at 79 R phase<br>2) Fixing of Suspension clamp hanger pin missing Nut at loc. No. 79 R,80Y,74 Y phase |
| 220 KV PARLI -U-8 - PARBHANI CKT          | IntraState                | 20/05/2023   | 10:25        | 20/05/2023 | 15:10      | PO          | Lash over Disc Replacement Work.                                                                                        |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/May/2023**

**Statement-VII**

Position as on 6.30 Hrs of 20/May/2023

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                           |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| GIS BHANDUP - BORIVALI                    | IntraState                | 20/05/2023   | 13:17        | 20/05/2023 | 14:06      | EO          | 1) Work of CB overhauling of GIS BHANDUP Bay at BORIVALI was proposed from 20.05.2023 after shifting the line on TBC.<br>2) However, there is closing issue of Aux. Isolator at Borivali S/stn and the line cannot be shifted on TBC for Today's work and also it is necessary to attend the issue, so that the line can be shifted on TBC in emergency situation.<br>3) Therefore outage is required attending mechanical closing issue of Aux. Isolator. |
| GIS BHANDUP - BORIVALI                    | IntraState                | 20/05/2023   | 14:06        | 20/05/2023 | 14:06      | PO          | "1) For Annual Relay Testing Work at 220KV Bhandup GIS S/stn.<br>2) CB Pole & Mechanism overhauling at 220KV Borivali s/stn"                                                                                                                                                                                                                                                                                                                               |
| KALWA - PANCHANAND                        | IntraState                | 20/05/2023   | 17:20        |            | Continued. | PO          | String of conductor on newly erected 3 nos. of Tower between Loc no. 676 to 680 and de-stringing of said line from ERS towers.                                                                                                                                                                                                                                                                                                                             |
| INFOSYS - PEGASUS                         | IntraState                | 20/05/2023   | 18:24        |            | Continued. | EO          | 1) Providing new joint to damaged cable at Rph between JB location 2 & 3 of 220 kV Pegasus- Infosys line.                                                                                                                                                                                                                                                                                                                                                  |
| AURANGABAD (WALUJ)-BHENDA                 | IntraState                | 20/05/2023   | 18:24        |            |            | EO          | Removing of the plastic sheet found stick on the B phase oif loc no 78 . at the time of rain these plastic sheet will come in contact with the live line and earth thus tripping of the line .                                                                                                                                                                                                                                                             |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                                                                                                                                                                                                                                                                           |
| 220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE | IntraState                | 10/11/2022   | 10:35        |            |            | EO          | For attending to abnormal Noise from ICT                                                                                                                                                                                                                                                                                                                                                                                                                   |
| 220/100 KV 200 MVA ICT 3 @ PADGHE         | IntraState                | 19/05/2023   | 09:52        | 19/05/2023 | 12:40      | EO          | to replacement of 100 kV Bus section iso-4 gear box.                                                                                                                                                                                                                                                                                                                                                                                                       |
| 220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)    | IntraState                | 19/05/2023   | 10:20        | 19/05/2023 | 11:39      | PO          | Outage is required for Nitrogen fire fighting maintenance work                                                                                                                                                                                                                                                                                                                                                                                             |
| 220/132KV 100MVA PTR 2 @ KHAREPATAN       | IntraState                | 20/05/2023   | 09:02        | 20/05/2023 | 14:04      | PO          | For Winding Resistance Measurement & LV CT tan delta measurement.                                                                                                                                                                                                                                                                                                                                                                                          |
| 220/100 KV 200 MVA ICT 3 @ KALWA          | IntraState                | 20/05/2023   | 09:17        | 20/05/2023 | 15:28      | EO          | For attending Hot Spot at<br>1) 100LV Line side isolator Rph Jaw CT side.<br>2) 220KV Bus side Isolator Rph Jaw stub bus side .                                                                                                                                                                                                                                                                                                                            |
| 220/33 KV 25 MVA PTR @ RAYMOND            | IntraState                | 20/05/2023   | 09:50        | 20/05/2023 | 15:58      | PO          | diagnostic testing of power transformer and allied equipments<br>IR testing of EHV equipments                                                                                                                                                                                                                                                                                                                                                              |
| 220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR     | IntraState                | 20/05/2023   | 10:05        | 20/05/2023 | 17:18      | PO          | Premonsoon maintenance work.                                                                                                                                                                                                                                                                                                                                                                                                                               |
| 220/33KV 50MVA PTR 2@ PETH                | IntraState                | 20/05/2023   | 13:02        | 20/05/2023 | 16:05      | PO          | Premonson maintenance work                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| <b>132 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
| RISOD-YELDARI                             | IntraState                | 20/04/2023   | 17:57        |            |            | HT          | TO CONTROL LOADING ON RISOD - MALEGAON CKT                                                                                                                                                                                                                                                                                                                                                                                                                 |
| SOLAPUR 2(BALE)-NALDURG                   | IntraState                | 20/05/2023   | 16:24        | 20/05/2023 | 20:24      | PO          | fixing of bird diverters                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| <b>110 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                            |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/May/2023**

**Statement-VII**

**Position as on 6.30 Hrs of 20/May/2023**

| Name of Line            | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                      |
|-------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-------------------------------------------------------------------------------------------------------|
| SALSETTE POWAI          | IntraState                   | 27/03/2023      | 11:04           |            |               | PO             | Replacement of tower number 77 & 78 for TDS project work.                                             |
| BHIRA (T) - KHOPOLI 2   | IntraState                   | 19/05/2023      | 05:46           | 19/05/2023 | 13:37         | PO             | Project Work - Augmentation of OPGW communication link from 6 Core to 48 Core of Bhira Karanjade Link |
| WAGHIVALI - CHEMBUR     | IntraState                   | 20/05/2023      | 06:22           | 20/05/2023 | 07:22         | PO             | BIRD NEST REMOVAL                                                                                     |
| KALYAN KALWA SALSETTE 2 | IntraState                   | 20/05/2023      | 15:43           | 20/05/2023 | 19:17         | PO             | For diverting kks2 to Kalwa Kalyan ROW to facilitated tower erection at loc 31,35,36                  |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage