

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Jun/2017 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	122.543	2730.594	1) Gujrat	-2.738	-48.506
2) Hydro	3.193	99.642	2) Madhya Pradesh	11.233	195.861
3) Gas	9.659	180.658	3) Chattisgarh	6.830	127.280
Total MSPGCL	135.395	3010.894	4) Maharashtra Net	107.601	1919.136
B) 1) APML	60.769	905.717	5) Goa (Amona)	-0.308	-7.590
2) JSWEL	16.956	299.507	Total	122.618	2186.181
3) VIPL	5.933	115.279	a) Mumbai Schedule	29.213	524.626
4) RPL(AMT)	0.000	115.123	b) Mumbai Drawl	36.810	627.160
5) WPCL	4.786	70.972	c) MSEDCL Bilateral *	16.819	353.454
6) PGPL	0.000	0.000	Include PX	-0.946	24.593
7) Other IPP	2.678	60.682	d) Mumbai Bilateral *	29.213	524.498
C) 1) TPCL Thermal	15.065	266.870	Include PX	11.239	143.964
2) TPCL Hydro	3.870	72.607	Include Standby	0.000	0.128
3) TPCL Gas	4.480	84.089	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	9.441	187.912	1) MSEDCL	350.361	6566.771
D) STATE			2) Mumbai Discoms	69.666	1238.638
1) Thermal	238.171	4752.656	TOTAL STATE	420.027	7805.409
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	7.063	172.249			
3) Gas (A3+B6+C3)	14.139	264.747			
4) Wind	35.915	402.119			
6) SOLAR	2.121	27.457			
TOTAL STATE	297.409	5619.228			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5516	4937	5100	4886
MSPGCL Hydro	153	128	226	64
MSPGCL Gas	401	394	401	421
MSPGCL Total Generation	6070	5459	5727	5371
Central Sector Receipt	5839	5930	5172	4381
WIND	984	1876	1852	1487
CPP / IPP Thermal	3850	4040	3750	3175
CPP / IPP Gas	0	0	0	0
SOLAR	319	168	0	0
Exchange with Mumbai	-1693	-1763	-1538	-1150
MSEDCL DEMAND MET	15369	15710	14963	13264
Load Shedding	0	0	0	0
MSEDCL DEMAND	15369	15710	14963	13264
TPCL GENERATION	1236	1251	1102	708
R-INFRA GENERATION	468	389	389	390
MUMBAI DEMAND	3397	3403	3029	2248
STATE DEMAND MET	18766	19113	17992	15512
STATE DEMAND	18766	19113	17992	15512
Frequency (Hz)	50.00	50.01	50.03	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.23 Hz at 18.55 Hrs	49.88 Hz at 14.04 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 19/Jun/2017

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	3.44	56.67	153	135
Unit 8	7.25	120.69	320	300
Unit 9	8.08	174.35	412	263
Unit 10	7.51	163.14	320	290
Total	26.28	514.85		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	48.66	0	0
Unit 4	8.99	173.86	440	350
Unit 5	9.04	154.22	450	360
Total	18.02	376.74		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	65.93	0	0
Unit 7	0.00	59.86	0	0
Unit 8	0.00	15.86	0	0
Total	0.00	141.65		
Chandrapur				
Unit 3	0.00	19.72	0	0
Unit 4	0.00	69.04	0	0
Unit 5	9.28	170.22	415	365
Unit 6	9.74	179.17	448	360
Unit 7	9.90	173.64	457	356
Unit 8	0.00	148.00	0	0
Unit 9	10.20	177.77	480	349
Total	39.13	937.54		
Paras				
Unit 3	5.09	91.60	250	186
Unit 4	4.94	90.55	236	186
Total	10.03	182.15		
Khaparkheda				
Unit 1	3.54	63.18	165	135
Unit 2	0.00	49.37	0	0
Unit 3	3.56	60.61	162	135
Unit 4	3.33	60.10	168	107
Unit 5	10.18	185.02	500	390
Total	20.61	418.28		
Nasik				
Unit 3	4.18	9.88	195	160
Unit 4	4.28	79.82	203	161
Unit 5	0.00	69.70	0	0
Total	8.46	159.39		
Uran				
All Units	9.66	180.66	421	382
Total	9.66	180.66		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.06	0.98	23	0
Total	0.06	0.98		
Koyna				
Stage 1-2	1.32	42.53	170	35
Stage 4	0.00	5.69	0	0
Stage 3	0.13	12.22	80	0
Total	1.45	60.44		
Hydro				
KDPH	0.24	4.44	10	10
VTRNA	0.99	16.94	61	0
TILLARI	0.00	0.38	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.21	4.49	77	0
RNGR+BHTSA	0.25	3.18	11	10
BHANDARDRA	0.00	1.36	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.06	0.42	3	2
GHATGHAR	0.00	8.00	0	0
Total	1.74	39.20		
Wind				
Total	35.92	402.12	0	0
Total	35.92	402.12		
CPP				
APML(Mus)	60.77	905.72	0	0
JSWEL(Mus)	16.96	299.51	0	0
VIPL(Mus)	5.93	115.28	0	0
RPLAMT(Mus)	0.00	115.12	0	0
WPCL(Mus)	4.79	70.97	0	0
Other(Mus)	2.68	60.68	0	0
Total	91.12	1567.28		
SOLAR				
Total	2.12	27.46	0	0
Total	2.12	27.46		
Tata				
Trombay 5	9.80	169.09	487	299
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.90	54.40	122	119
Trombay 7B	1.58	29.68	67	65
Trombay 8	5.26	97.78	247	200
TATA Hydro	3.87	72.61	433	0
Total	23.42	423.57		
R-INFRA				
DTPS U-1&2	9.44	187.91	468	388
Total	9.44	187.91		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	122.54	2730.59	MSPGCL Total	135.40	3010.89
			MSPGCL Thml+Gas	132.20	2911.25	Koyna 1,2 & 4 Total	1.32	48.22
			MSPGCL Hydro	3.19	99.64	State Total	297.41	5619.23

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Jun/2017

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5277	74	411	5762	1407	3946	0	0	4739	4440	-1662	13893	0	13893	2765	16658	50.01
2	4977	69	411	5457	1461	3689	0	0	4593	4291	-1402	13496	0	13496	2498	15994	50.00
3	4853	64	413	5330	1571	3446	0	0	4372	4436	-1262	13521	0	13521	2358	15879	50.00
4	4886	64	421	5371	1487	3175	0	0	4291	4381	-1150	13264	0	13264	2248	15512	50.01
5	4924	79	412	5415	1297	3081	0	0	4332	4779	-1115	13457	0	13457	2213	15670	49.99
6	5085	64	412	5561	1224	3380	0	0	4661	5223	-1175	14213	0	14213	2272	16485	50.01
7	5318	84	412	5814	1137	3731	0	14	4788	4764	-1192	14268	0	14268	2290	16558	50.03
8	5320	82	410	5812	1116	3896	0	59	4765	5196	-1321	14758	0	14758	2451	17209	50.03
9	5225	124	408	5757	1159	3863	0	132	5038	5227	-1479	14659	0	14659	2700	17359	50.02
10	5163	206	401	5770	1136	3783	0	209	5311	5206	-1782	14322	0	14322	3141	17463	50.00
11	5407	153	397	5957	956	3803	0	244	5454	5348	-1720	14588	0	14588	3276	17864	50.02
12	5516	153	401	6070	984	3850	0	319	5643	5839	-1693	15369	0	15369	3397	18766	50.00
13	5321	133	393	5847	801	3869	0	266	5641	5734	-1658	14859	0	14859	3393	18252	49.99
14	5310	143	382	5835	1235	4047	0	255	5546	5687	-1664	15395	0	15395	3350	18745	50.00
15	5280	118	385	5783	1454	4224	0	246	5638	5379	-1707	15379	0	15379	3398	18777	49.97
16	4937	128	394	5459	1876	4040	0	168	5824	5930	-1763	15710	0	15710	3403	19113	50.01
17	4951	173	394	5518	2186	3859	0	130	5338	5424	-1770	15347	0	15347	3355	18702	50.02
18	4862	127	389	5378	2267	3771	0	66	5203	4860	-1719	14623	0	14623	3265	17888	50.04
19	4818	150	405	5373	2081	3513	0	13	4765	4784	-1576	14188	0	14188	3046	17234	50.11
20	5100	226	401	5727	1852	3750	0	0	4575	5172	-1538	14963	0	14963	3029	17992	50.03
21	5008	252	401	5661	1762	3937	0	0	4818	5181	-1554	14987	0	14987	2969	17956	50.00
22	5000	147	391	5538	1807	4130	0	0	4865	5068	-1600	14943	0	14943	2937	17880	50.01
23	5001	207	406	5614	1856	4168	0	0	4803	5264	-1665	15237	0	15237	2960	18197	50.00
24	5004	173	409	5586	1803	4173	0	0	4952	5005	-1643	14924	0	14924	2952	17876	50.09
MUs	122.54	3.19	9.66	135.40	35.91	91.12	0.00	2.12	119.95	122.62	-36.81	350.36	0.00	350.36	69.67	420.03	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 19/Jun/2017

Position as on 6.30 Hrs of 20/Jun/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown.	
MSPGCL	Chandrapur Unit 3	210	05/06/2017	23.24		Continued.	AOH.	
MSPGCL	Khaparkhedda Unit 2	210	14/06/2017	23.16		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
CENT.SECTOR	TARAPUR 4	540	23/04/2017	19:55		Continued.	Annual Maintenance	
IPP	RPL(AMT) U-1	270	24/05/2017	03.27		Continued.	Flame Failure	
IPP	JSW (J) U2	300	31/05/2017	23.58		Continued.	NO SCHEDULE.	
IPP	Dhariwal	300	01/06/2017	00.01		Continued.	NO SCHEDULE.	
CENT.SECTOR	Tarapur 1	160	04/06/2017	19.09		Continued.	3 months outage for refuelling.	
IPP	RPL(AMT) U-3	270	05/06/2017	14.31		Continued.	swaping with unit-5.	
IPP	RPL(AMT) U-4	270	09/06/2017	00.20		Continued.	Zero Schedule by MSEDCL	
IPP	RPL(AMT) U-5	270	09/06/2017	01.39		Continued.	Zero Schedule by MSEDCL	
IPP	RPL(AMT) U-2	270	09/06/2017	04.24		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Parli Unit 7	250	13/06/2017	00.04		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 3	210	13/06/2017	06.01		Continued.	Zero Schedule By MSEDCL	
IPP	VIPL U-1	300	13/06/2017	08.30		Continued.	GT WORK	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Jun/2017

Position as on 6.30 Hrs of 20/Jun/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 6	250	14/06/2017	00.02		Continued.	Zero schedule by MSEDCL.	
IPP	Adani U-1	660	15/06/2017	17.27	19/06/2017	11.24	IP Turbine Peripheral Leakage	
MSPGCL	Chandrapur Unit 4	210	16/06/2017	20.31	20/06/2017	05.56	Boiler Tube Leakage	
MSPGCL	Parli Unit 8	250	17/06/2017	00.08		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Nasik Unit 5	210	17/06/2017	15.35		Continued.	Zero schedule by MSEDCL	
MSPGCL	Chandrapur Unit-8	500	18/06/2017	02.15	20/06/2017	19.12	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	20/06/2017	02.53	20/06/2017	05.04	Furnace Pressure High	
MSPGCL	Koradi Unit 10	660	20/06/2017	23.55		Continued.	UAT.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Jun/2017

Statement-VII

Position as on 6.30 Hrs of 20/Jun/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	14/06/2017	19.04	20/06/2017	06.18	HT	Over Voltage
Talegaon PG - Aurangabad - II	InterState	19/06/2017	14.23	19/06/2017	17.25	PO	Isolator Maint.work
Koradi Bhilai	InterState	19/06/2017	22.10	20/06/2017	00.28	EO	sparking on 29A b-ph isolator scissor.
Dhule Sar'Sarovar I	InterState	20/06/2017	19.30		Continued.	HT	Over Voltage
Ektuni-Bableswhar ckt II	IntraState	06/06/2017	20.53		Continued.	HT	to control load on padghe-bableswhar.
karad -kolhapur-II	IntraState	17/06/2017	18.13	19/06/2017	09.35	HT	Over Voltage
Karad-Jaigad - I	IntraState	17/06/2017	18.54	19/06/2017	09.41	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	18/06/2017	18.01	19/06/2017	08.00	HT	Over Voltage
Chandrapur-II - Nanded ckt I	IntraState	19/06/2017	07.42	19/06/2017	16.59	PO	Line Maintenance work
Koradi-Khaperkheda I	IntraState	19/06/2017	12.29	19/06/2017	19.48	PO	Testing work(RFC 18.00Hrs)
Girwali-Solapur (Lamboti)	IntraState	19/06/2017	17.44	19/06/2017	19.54	PO	To take Reactor in service
karad -kolhapur-I	IntraState	19/06/2017	18.05		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	19/06/2017	21.24	20/06/2017	06.25	HT	Over Voltage
Karad - Jaigad - II	IntraState	19/06/2017	21.26		Continued.	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	20/06/2017	05.54	20/06/2017	09.19	EO	To attend Hot Spot
Chandrapur - Parli	IntraState	20/06/2017	14.00	20/06/2017	20.51	PO	CT Clamp Replacement,Alignment & Maintenance of Isolator Work
Bhusawal-Aurangabad	IntraState	20/06/2017	18.17		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT I @Akola	IntraState	19/06/2017	07.53		Continued.	PO	ICT Tertiary IPS Tube Coating work
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	19/06/2017	16.55	19/06/2017	19.12	PO	Spacers Tightening work
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	NO SCHEDULE.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Walchandnagar-Bhigwan	IntraState	04/06/2017	17.29		Continued.	T	Distance Protection
Kharghar-Borivali ckt II	IntraState	07/06/2017	12.23		Continued.	T	Distance Protection
New Koyna - Pedambe	IntraState	14/06/2017	09.33		Continued.	T	Distance Protection
Pophali - Pedambe II	IntraState	17/06/2017	17.00		Continued.	PO	CT REPLACEMENT WORK
Satana-Gangapur	IntraState	18/06/2017	18.02	19/06/2017	12.07	T	Distance Protection
Badnera - Nandgaonpeth	IntraState	19/06/2017	09.48	19/06/2017	14.19	PO	Routine Maintenance Work
Talandge-Mudshingi Ckt-I	IntraState	19/06/2017	10.03	19/06/2017	15.34	PO	Bus Outage at Mudshingi
Abhijeet-Wardha-Ii	IntraState	19/06/2017	10.36	19/06/2017	17.09	PO	diagnostic testing work.
Bhaveghar - Kolshet	IntraState	19/06/2017	10.42	19/06/2017	21.05	PO	Routine Maintenance Work
Talandge(400)- Mudshingi 2 Line	IntraState	19/06/2017	10.52	19/06/2017	18.55	PO	Bus Outage at Mudshingi
Miraj - Mhaishal	IntraState	19/06/2017	10.55	19/06/2017	13.20	PO	Y Phase CT Oil Leakage
Nanded-Ghatodi	IntraState	19/06/2017	12.02	19/06/2017	14.36	PO	replacement of flashed disk.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Jun/2017

Statement-VII

Position as on 6.30 Hrs of 20/Jun/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Main Bus-III @ Mudshingi	IntraState	19/06/2017	12.45	19/06/2017	18.45	PO	Routine Maintenance Work
Miraj - Ichalkaranji II	IntraState	19/06/2017	13.50	19/06/2017	19.01	PO	Routine Maintenance Work
Nadgaonpeth-Amravati	IntraState	20/06/2017	09.44	20/06/2017	14.44	PO	Diagnostic Testing Work.
Malharpeth - Karad(400kv)	IntraState	20/06/2017	10.04		Continued.	PO	Breaker Replacement Work.
Nashik-Airoli Knowledge Park	IntraState	20/06/2017	11.33	20/06/2017	12.02	T	Distance Protection
Ghatghar - Bapgaon	IntraState	20/06/2017	11.35	20/06/2017	16.15	T	Distance Protection
Bapgaon - Kalwa	IntraState	20/06/2017	11.35	20/06/2017	13.27	T	Distance Protection
Butibori-Butibori Rly Tss	IntraState	20/06/2017	12.05	20/06/2017	13.21	PO	Replacement of Faulty ABT Meter.
Butibori-Indorama	IntraState	20/06/2017	15.44	20/06/2017	16.33	T	Backup Protection
220 KV ICT Outages/Trippings							
220/110KV, 200MVA T/F-III at Mudshingi	InterState	19/06/2017	15.48	19/06/2017	19.04	PO	Bus Outage at Mudshingi
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 kv 100MVA ICT-I @ Shivajinagar	IntraState	19/06/2017	10.13	19/06/2017	12.04	PO	maintenance work.
220/100 Kv 200 MVA ICT I @Kolshet	IntraState	19/06/2017	10.49	19/06/2017	20.55	PO	Routine Maintenance Work
220/132KV 100MVA ICT-II@Shivajinagar	IntraState	19/06/2017	13.58	19/06/2017	15.58	PO	Routine Maintenance Work
220/132Kv 200MVA ICT-II @ Mudshingi	IntraState	19/06/2017	15.44	19/06/2017	19.00	PO	Bus Outage at Mudshingi
220/132 kv 200 MVA ICT- I @ Nanded	IntraState	20/06/2017	10.12	20/06/2017	12.14	PO	Oil Top up Work.
220/132 Kv 200 Mva Bbl Ict 2 @Waghala Nanded	IntraState	20/06/2017	12.21	20/06/2017	14.08	PO	Oil Top up Work.
220/132 kv 200 MVA ICT-III @ Nanded	IntraState	20/06/2017	14.33	20/06/2017	15.56	PO	Oil Top up Work.
132 KV LINE Outages/Trippings							
132KV Main bus-1@Deepnagar	IntraState	20/06/2017	15.15	20/06/2017	15.21	T	While Testing.
Deepnagar- Nimbhora	IntraState	20/06/2017	15.15	20/06/2017	15.27	T	132KV Main Bus-I Tripped Hence Connected Ckt Tripped.
Khadka-Deepnagar Ckt-1	IntraState	20/06/2017	15.15	20/06/2017	15.22	T	132KV Main Bus-I Tripped Hence Connected Ckt Tripped.
Deepnagar (Gcr) - Supreme	IntraState	20/06/2017	15.15	20/06/2017	15.31	T	132KV Main Bus-I Tripped Hence Connected Ckt Tripped.
Deepnagar(Gcr) -New Midc Jalgaon	IntraState	20/06/2017	15.15	20/06/2017	15.27	T	132KV Main Bus-I Tripped Hence Connected Ckt Tripped.
Deepnagar- Yawal	IntraState	20/06/2017	15.15	20/06/2017	15.27	T	132KV Main Bus-I Tripped Hence Connected Ckt Tripped.
Deepnagar- Muktainagar	IntraState	20/06/2017	15.15	20/06/2017	15.30	T	132KV Main Bus-I Tripped Hence Connected Ckt Tripped.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage