

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Jun/2019 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	149.432	2964.770	1) Gujrat	-5.501	-49.188
2) Hydro	6.130	73.076	2) Madhya Pradesh	6.668	123.052
3) Gas	6.488	116.261	3) Chattisgarh	3.930	64.340
Total MSPGCL	162.050	3154.107	4) Maharashtra	117.013	2133.632
B) 1) APLM	70.604	1351.022	5) Goa (Amona)	-0.616	-7.480
2) JSWEL	25.804	452.723	Total	121.494	2264.356
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.729	567.354
4) RPL(AMT)	5.726	334.584	b) Mumbai Drawl	31.533	694.972
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	10.742	182.333
6) Other IPP	7.188	132.410	Include PX	-4.563	-102.638
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.729	567.354
C) 1) TPCL Thermal	14.316	249.685	Include PX	9.410	235.309
2) TPCL Hydro	5.266	68.322	Standby	0.000	0.000
3) TPCL Gas	4.219	80.483	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.167	182.095	1) MSEDCL	408.271	7773.157
D) STATE			2) Mumbai Discoms	65.502	1275.559
1) Thermal	283.237	5667.289	TOTAL STATE	473.773	9048.716
(A1+C1+C4+(B1-B6))					
2) Hydro	11.396	141.398			
(A2+C2)					
3) Gas	10.707	196.744			
(A3+B7+C3)					
4) Wind	41.740	660.968			
6) SOLAR	5.198	117.959			
TOTAL STATE	352.278	6784.358			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6314	6407	6301	5901
MSPGCL Hydro	219	332	280	35
MSPGCL Gas	264	251	256	286
MSPGCL Total Generation	6797	6990	6837	6222
Central Sector Receipt	5489	5241	5376	4270
WIND	1689	1776	1848	1705
CPP / IPP Thermal	4731	4696	4312	4630
CPP / IPP Gas	0	0	0	0
SOLAR	594	610	0	0
Exchange with Mumbai	-1767	-1628	-1126	-1003
MSEDCL DEMAND MET	17533	17685	17247	15824
Load Shedding	0	0	0	0
MSEDCL DEMAND	17533	17685	17247	15824
TPCL GENERATION	1100	1147	1263	645
AEML GENERATION	374	438	500	374
MUMBAI DEMAND	3241	3213	2889	2022
STATE DEMAND MET	20774	20898	20136	17846
STATE DEMAND	20774	20898	20136	17846
Frequency (Hz)	49.98	49.97	49.96	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.19 Hz at 18.04 Hrs	49.79 Hz at 09.15 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 19/Jun/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.12	65.30	170	1
Unit 7	3.31	48.74	162	124
Unit 8	8.08	163.38	400	290
Unit 9	7.45	181.68	350	281
Unit 10	8.74	180.41	430	300
Total	30.70	639.51		
Bhusawal				
Unit 3	0.00	12.44	0	0
Unit 4	11.12	185.91	505	355
Unit 5	10.54	163.08	500	350
Total	21.66	361.43		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	11.77	0	0
Total	0.00	11.77		
Chandrapur				
Unit 3	4.36	81.39	190	163
Unit 4	3.97	63.66	181	148
Unit 5	9.56	178.21	423	365
Unit 6	10.24	187.20	460	365
Unit 7	0.00	145.71	0	0
Unit 8	11.24	205.59	500	385
Unit 9	11.33	200.21	495	390
Total	50.70	1061.97		
Paras				
Unit 3	6.00	107.34	260	213
Unit 4	6.05	104.54	255	215
Total	12.05	211.87		
Khaparkheda				
Unit 1	2.30	57.84	130	75
Unit 2	2.26	52.97	115	80
Unit 3	3.05	67.07	165	0
Unit 4	3.56	67.36	160	138
Unit 5	10.59	204.73	450	410
Total	21.76	449.96		
Nasik				
Unit 3	4.09	77.28	193	70
Unit 4	4.50	76.44	206	163
Unit 5	3.97	74.53	180	156
Total	12.55	228.26		
Uran				
All Units	6.49	116.26	297	250
Total	6.49	116.26		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.01	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.01		
Koyna				
Stage 1-2	2.50	27.55	365	30
Stage 4	0.00	0.34	0	0
Stage 3	1.10	7.29	80	0
Total	3.60	35.19		
Hydro				
KDPH	0.13	5.79	9	0
VTRNA	0.75	13.14	61	0
TILLARI	0.00	0.97	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.42	3.70	40	0
RNGR+BHTSA	0.00	1.71	0	0
BHANDARDRA	0.00	1.07	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.00	1.95	0	0
GHATGHAR	1.23	9.57	125	0
Total	2.53	37.89		
Wind				
Total	41.74	660.97	0	0
Total	41.74	660.97		
CPP				
APML(Mus)	70.60	1351.02	0	0
JSWEL(Mus)	25.80	452.72	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	5.73	334.58	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	7.19	132.41	0	0
Total	109.32	2270.74		
SOLAR				
Total	5.20	117.96	0	0
Total	5.20	117.96		
Tata				
Trombay 5	9.26	156.47	475	303
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.67	51.02	116	70
Trombay 7B	1.55	29.46	67	52
Trombay 8	5.05	93.21	231	198
TATA Hydro	5.27	68.32	410	104
Total	23.80	398.49		
AEML				
DTPS U-1&2	10.17	182.10	500	372
Total	10.17	182.10		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	149.43	2964.77	MSPGCL Total	162.05	3154.11
			MSPGCL Thml+Gas	155.92	3081.03	Koyna 1,2 & 4 Total	2.50	27.89
			MSPGCL Hydro	6.13	73.08	State Total	352.28	6784.36

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Jun/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6194	35	286	6515	1568	4881	0	0	4916	4910	-1202	16672	0	16672	2425	19097	49.98
2	5950	30	287	6267	1732	4819	0	0	4745	4658	-1056	16420	0	16420	2244	18664	50.01
3	5765	40	297	6102	1712	4615	0	0	4652	4865	-1034	16260	0	16260	2109	18369	49.96
4	5901	35	286	6222	1705	4630	0	0	4532	4270	-1003	15824	0	15824	2022	17846	50.02
5	6014	50	286	6350	1719	4558	0	0	4499	4481	-980	16128	0	16128	1978	18106	49.99
6	6384	160	287	6831	1416	4744	0	0	4867	4752	-1023	16720	0	16720	2050	18770	49.92
7	6470	165	286	6921	1389	4821	0	50	5282	5409	-1060	17530	0	17530	2122	19652	50.00
8	6481	182	288	6951	1675	4787	0	205	4852	4875	-1209	17284	0	17284	2277	19561	50.04
9	6023	174	261	6458	2069	4666	0	383	4765	4892	-1399	17069	0	17069	2576	19645	49.96
10	5879	316	270	6465	1976	4557	0	490	4941	5123	-1580	17031	0	17031	2885	19916	49.97
11	6144	249	269	6662	1891	4685	0	616	5094	5215	-1707	17362	0	17362	3113	20475	50.02
12	6314	219	264	6797	1689	4731	0	594	5387	5489	-1767	17533	0	17533	3241	20774	49.98
13	6316	154	254	6724	1843	4737	0	644	5506	5187	-1742	17393	0	17393	3217	20610	50.01
14	6354	190	262	6806	1758	4625	0	580	5123	5154	-1668	17255	0	17255	3152	20407	49.96
15	6407	332	251	6990	1776	4696	0	610	5388	5241	-1628	17685	0	17685	3213	20898	49.97
16	6443	342	250	7035	1656	4564	0	458	5494	5418	-1511	17620	0	17620	3261	20881	49.95
17	6393	314	262	6969	1696	4256	0	388	5400	5746	-1433	17622	0	17622	3221	20843	49.97
18	6334	372	254	6960	1993	4244	0	156	4918	5259	-1371	17241	0	17241	3134	20375	50.01
19	6307	542	267	7116	1817	4214	0	24	4185	4485	-1256	16400	0	16400	3004	19404	50.01
20	6337	649	268	7254	1926	4237	0	0	4157	4916	-1198	17135	0	17135	2968	20103	49.99
21	6301	280	256	6837	1848	4312	0	0	4386	5376	-1126	17247	0	17247	2889	20136	49.96
22	6344	402	269	7015	1761	4355	0	0	4329	4831	-1110	16852	0	16852	2809	19661	50.00
23	6167	454	268	6889	1619	4360	0	0	4802	5423	-1179	17112	0	17112	2798	19910	49.93
24	6210	444	260	6914	1506	4228	0	0	5379	5519	-1291	16876	0	16876	2793	19669	49.99
MUs	149.43	6.13	6.49	162.05	41.74	109.32	0.00	5.20	117.60	121.49	-31.53	408.27	0.00	408.27	65.50	473.77	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Jun/2019

Position as on 6.30 Hrs of 20/Jun/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	20/05/2019	16.01		Continued.	Gas shortage	
MSPGCL	Parli Unit 8	250	04/06/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 3	210	04/06/2019	20.15		Continued.	Zero Schedule	
IPP	RPL(AMT) U-5	270	11/06/2019	17.01		Continued.	Zero Schedule	
IPP	RPL(AMT) U-4	270	13/06/2019	17.00	20/06/2019	03.29	Zero Schedule.	
IPP	RPL(AMT) U-1	270	14/06/2019	00.00	20/06/2019	10.48	Zero Schedule	
IPP	RPL(AMT) U-2	270	14/06/2019	00.00	20/06/2019	05.03	Zero Schedule.	
MSPGCL	Koyna Unit 5	80	17/06/2019	08.20		Continued.	needle stuck up problem.	
MSPGCL	Koyna Unit 6	80	17/06/2019	08.40		Continued.	needle stuck up problem.	
MSPGCL	Chandrapur Unit 7	500	18/06/2019	15.41		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 3	210	18/06/2019	21.29	19/06/2019	02:43	Flame Failure	
MSPGCL	Koradi Unit 6	210	19/06/2019	00.02	19/06/2019	01.46	Loss of fuel	
IPP	Adani U-4	660	19/06/2019	16.09		Continued.	MS Drain Bonnet Leakage.	
MSPGCL	Nasik Unit 3	210	19/06/2019	22.20	19/06/2019	23.15	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 20/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Ektuni-Akola II Ckt 2	IntraState	19/06/2019	14.37	19/06/2019	18.44	PO	Broken Jumper Replacement Work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	15/06/2019	17.35	19/06/2019	01.49	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	19/06/2019	01.00	19/06/2019	14.31	T	Distance Protection
Dhule(MS)- Dhule(BDTCL) -II	InterState	19/06/2019	10.08	19/06/2019	20.13	PO	Routine Maintenance Work
Akola Aurangabad(PG) II	InterState	19/06/2019	11.50	19/06/2019	12.56	T	Bus-1 Operated Due To DC Leakage.
Dhule Sar'Sarovar II	InterState	19/06/2019	18.16	20/06/2019	10.29	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	20/06/2019	19.22		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	18/06/2019	18.34	19/06/2019	06.26	HT	Over Voltage
Koradi-Bhusawal	IntraState	19/06/2019	06.53	19/06/2019	20.20	PO	Line Maintenance work
Chandrapur-Warora-II 425 Bay	IntraState	19/06/2019	08.51	19/06/2019	15.13	PO	Diagnostic Testing.
Karad - Lonikand 1	IntraState	19/06/2019	09.14	19/06/2019	18.29	EO	Attending Hot Spot
Solapur - Parli(PG) I	IntraState	19/06/2019	10.21	19/06/2019	18.42	PO	Work At Lamboti.
Girwali-Solapur (Lamboti)	IntraState	19/06/2019	10.21	19/06/2019	18.42	PO	Disc Insulator Replacement Work
Deepnagar - Aurangabad	IntraState	19/06/2019	11.50	19/06/2019	13.00	PO	Bus-1 Operated Due To DC Leakage.
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	19/06/2019	11.50	19/06/2019	13.17	T	Bus-1 Operated Due To DC Leakage
N.Koyna-Karad -Ckt I	IntraState	19/06/2019	12.14	19/06/2019	16.49	PO	Chemical Washing.
Kala Kudus Ckt-I	IntraState	19/06/2019	14.07	19/06/2019	21.16	PO	Disc Insulator Replacement Work.
Kala Kudus Ckt-II	IntraState	19/06/2019	14.18	19/06/2019	21.28	PO	Disc Insulator Replacement Work.
Padghe - Nagothane - II	IntraState	19/06/2019	14.23	19/06/2019	17.03	HT	Padgha Ckt 2 Which Was On TBC is H/T As Dabhol Ckt 1 Tobe Taken On TBC Attend Hot Spot.
Khadka-Aurangabad (Waluj)	IntraState	19/06/2019	20.41	20/06/2019	06.41	HT	Over Voltage
Padghe - Kalwa-II	IntraState	20/06/2019	06.50	20/06/2019	10.23	EO	Attend Y-Ph IPS Tube Hole.
Koradi-Bhusawal	IntraState	20/06/2019	10.29	20/06/2019	18.41	PO	Replacement of Faulty Insulator String.
Khadka-Aurangabad (Waluj)	IntraState	20/06/2019	18.53		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.
400/220/33 Kv 315 MVA ICT-II @Aurangabad (Waluj)	IntraState	19/06/2019	11.50	19/06/2019	14.03	T	Bus-1, Operated Due To DC Leakage.
400/220/33 Kv 315 MVA ICT-I @Aurangabad (Waluj)	IntraState	19/06/2019	11.50	19/06/2019	14.00	T	Bus-1, Operated Due To DC Leakage.
500 MVA ICT I @ Kudus	IntraState	19/06/2019	14.57	19/06/2019	19.33	PO	33KV Replacement Work.
400/220kv 315MVA ICT 2 @ Chandrapur GCR	IntraState	20/06/2019	13.39	20/06/2019	19.59	EO	Attending Hot Spot
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
EKLAHARE (OCR) Nasik - Navsari I	InterState	19/06/2019	06.42	19/06/2019	07.02	T	Distance Protection
EKLAHARE (OCR) Nasik - Navsari I	InterState	20/06/2019	11.23	20/06/2019	15.52	PO	Insulator String Replacement.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 19/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 20/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Trombay Carnac 5	IntraState	16/06/2019	13.24	19/06/2019	16.00	HT	For Safety Purpose.
satara MIDC- Malharpath	IntraState	19/06/2019	06.35	19/06/2019	14.38	T	Distance Protection, Z1, B-E, IA-2422 AMP.
TPC Borivali Aarey Line 1	IntraState	19/06/2019	09.24	19/06/2019	17.39	PO	Mono Pole Work.
Akola-Paras Ckt No-li	IntraState	19/06/2019	09.35	19/06/2019	16.45	PO	New Tower Erection work And Stringing Work At Railway Crossing.
Akola-Paras Ckt No-I	IntraState	19/06/2019	09.35	19/06/2019	16.43	PO	New Tower Erection Work And Stringing Work At Railway Crossing.
Apta - Hoc	IntraState	19/06/2019	12.00	19/06/2019	20.30	PO	Testing Work
Satara (MIDC)-Ajinkyatara	IntraState	19/06/2019	12.37	19/06/2019	14.55	PO	Attend Fault On Malharpath Line.(Safety Purpose)
Paras-Chikhali Ckt No-I	IntraState	19/06/2019	17.15	19/06/2019	19.25	EO	Nut Bolt Tightening Work.
Mahad - Pedambe	IntraState	20/06/2019	09.00		Continued.	PO	Erection Stringing of Inline Tower of Proposed Kalambani Traction Substation.
Adlabs - Pedambe	IntraState	20/06/2019	09.05		Continued.	PO	Erection Stringing of Inline Tower of Proposed Kalambani Traction Substation.
Ambazari-Amravati	IntraState	20/06/2019	09.18	20/06/2019	16.10	PO	Line Maintenance work
Parli New Tps - Beed Ckt 1	IntraState	20/06/2019	09.40	20/06/2019	13.36	PO	CRM Timing of Breaker.
JEJURI (400 Kv) - GIS KONDHWA	IntraState	20/06/2019	09.45	20/06/2019	15.07	PO	Replacement of Pilot Insulator String At LOC No.1 to 4.
Washala - Ghatghar	IntraState	20/06/2019	09.50	20/06/2019	18.28	PO	Insulator Replacement Work
Ghatghar - Jindal	IntraState	20/06/2019	10.26	20/06/2019	18.47	PO	Insulator Replacement Work
Chinchwad-Hinjewadi I	IntraState	20/06/2019	10.32	20/06/2019	15.13	HT	Load Management Outage On 220KV Bhosari-Lonikand 2 Line.
Mumewadi -Halkarni ckt-I	IntraState	20/06/2019	10.45	20/06/2019	13.10	PO	Tan Delta Testing And Diagnostic Testing Work.
Badnera Tss-I	IntraState	20/06/2019	11.10	20/06/2019	16.53	PO	Replacement of Distance Relay.
Bhigwan-Baramat lagro	IntraState	20/06/2019	11.10	20/06/2019	13.11	PO	Attend CT Leakage.
Lonikand2 - Bhosari1	IntraState	20/06/2019	11.11	20/06/2019	15.06	PO	Half yearly maintenance work
Balapur-Akola I	IntraState	20/06/2019	11.48		Continued.	PO	New Tower Erection Work And Stringing Work At Railway Crossing.
Balapur-Akola li	IntraState	20/06/2019	11.49		Continued.	PO	New Tower Erection Work And Stringing Work At Railway Crossing.
Chandrapur GCR - Warora - I	IntraState	20/06/2019	13.17	20/06/2019	20.19	HT	Outage On 315MVA Ict 2 At Chandrapur GCR.
Chandrapur GCR - Wani	IntraState	20/06/2019	13.18	20/06/2019	20.27	HT	Outage On 315MVA Ict 2 At Chandrapur GCR.
Nerul-Trombay	IntraState	20/06/2019	13.25	20/06/2019	14.15	EO	Tree Cutting.
Padgha - Temghar I	IntraState	20/06/2019	13.27	20/06/2019	15.39	T	Distance Protection, Z1, R-Ph To E/F, 6.713KA, 10.5KM From Padghe (Crow Fault At loc.no.52)
Parli New Tps - Beed Ckt 2	IntraState	20/06/2019	13.38	20/06/2019	16.43	PO	CRM Timing of Breaker.
Mumewadi -Halkarni ckt-II	IntraState	20/06/2019	13.50	20/06/2019	16.46	PO	Tan Delta Testing And Diagnostic Testing Work.
Trombay - Kalwa	IntraState	20/06/2019	21.04	20/06/2019	23.46	EO	Red Hot Attending Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage