

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 19/Jun/2024 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 143.420        | 2874.093        | 1) Gujrat                      | 3.271          | 2.794            |
| 2) Hydro            | 5.449          | 167.792         | 2) Madhya Pradesh              | 0.956          | 18.771           |
| 3) Gas              | 6.960          | 129.536         | 3) Chattisgarh                 | 1.530          | 39.670           |
| <b>Total MSPGCL</b> | <b>155.829</b> | <b>3171.421</b> | 4) Maharashtra                 | 167.043        | 3603.768         |
| B) 1) APLM          | 57.036         | 1058.957        | 5) Goa (Amona)                 | -1.321         | -36.153          |
| 2) JSWEL            | 18.324         | 456.634         | <b>Total</b>                   | <b>171.479</b> | <b>3628.850</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 41.484         | 827.705          |
| 4) RPL(AMT)         | 31.416         | 574.495         | b) Mumbai Drawl                | 44.149         | 875.125          |
| 5) SWPGPL           | 11.185         | 229.677         | c) MSEDCL Bilateral *          | 90.261         | 1574.168         |
| 6) Other IPP        | 13.552         | 272.019         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 41.484         | 827.652          |
| C) 1) TPCL Thermal  | 11.587         | 245.455         | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 4.587          | 103.542         | Standby                        | 0.000          | 0.053            |
| 3) TPCL Gas         | 4.124          | 77.356          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 7.284          | 158.233         | 1) MSEDCL                      | 459.005        | 9010.805         |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 71.733         | 1459.710         |
| 1) Thermal          | 293.804        | 5869.563        | 3) Other Discoms               | 11.512         | 221.142          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>542.250</b> | <b>10691.657</b> |
| 2) Hydro            | 10.036         | 271.334         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 11.084         | 206.892         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 39.373         | 418.582         |                                |                |                  |
| 6) SOLAR            | 16.472         | 296.437         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>370.769</b> | <b>7062.808</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 4965                      | 5895                  | 6523                      | 6162                      |
| MSPGCL Hydro               | 173                       | 126                   | 570                       | 244                       |
| MSPGCL Gas                 | 291                       | 283                   | 285                       | 297                       |
| MSPGCL Total Generation    | 5429                      | 6304                  | 7378                      | 6703                      |
| Central Sector Receipt     | 8346                      | 7542                  | 7392                      | 6343                      |
| WIND                       | 1728                      | 2264                  | 1919                      | 1310                      |
| CPP / IPP Thermal          | 4722                      | 4783                  | 5911                      | 5594                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2089                      | 1382                  | 0                         | 0                         |
| Exchange with Mumbai       | -2321                     | -2290                 | -1820                     | -1355                     |
| <b>MSEDCL DEMAND MET</b>   | <b>19477</b>              | <b>19483</b>          | <b>20255</b>              | <b>18200</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 19477                     | 19483                 | 20255                     | 18200                     |
| TPCL GENERATION            | 820                       | 882                   | 886                       | 845                       |
| AEML GENERATION            | 290                       | 324                   | 434                       | 155                       |
| <b>MUMBAI DEMAND</b>       | <b>3431</b>               | <b>3496</b>           | <b>3140</b>               | <b>2355</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>516</b>                | <b>502</b>            | <b>525</b>                | <b>395</b>                |
| STATE DEMAND MET           | 23424                     | 23481                 | 23920                     | 20950                     |
| <b>STATE DEMAND</b>        | <b>23424</b>              | <b>23481</b>          | <b>23920</b>              | <b>20950</b>              |
| Frequency (Hz)             | 50.03                     | 50.01                 | 50.02                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 18.02 Hrs | 49.67 Hz at 12.42 Hrs | 50.03         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 19/Jun/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.20         | 78.52         | 189      | 146      |
| Unit 8             | 13.61        | 257.91        | 612      | 388      |
| Unit 9             | 12.98        | 226.22        | 609      | 380      |
| Unit 10            | 12.34        | 241.07        | 558      | 390      |
| <b>Total</b>       | <b>43.14</b> | <b>803.72</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.27         | 27.09         | 170      | 120      |
| Unit 4             | 0.00         | 151.03        | 0        | 0        |
| Unit 5             | 9.96         | 180.92        | 500      | 290      |
| <b>Total</b>       | <b>13.22</b> | <b>359.05</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 34.93         | 0        | 0        |
| Unit 7             | 3.89         | 33.08         | 248      | 144      |
| Unit 8             | 0.00         | 38.18         | 0        | 0        |
| <b>Total</b>       | <b>3.89</b>  | <b>106.19</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.44         | 59.02         | 168      | 123      |
| Unit 4             | 3.53         | 68.42         | 165      | 130      |
| Unit 5             | 8.32         | 133.42        | 430      | 280      |
| Unit 6             | 4.42         | 110.55        | 205      | 171      |
| Unit 7             | 8.80         | 171.13        | 480      | 292      |
| Unit 8             | 9.08         | 168.67        | 440      | 280      |
| Unit 9             | 10.20        | 165.63        | 484      | 294      |
| <b>Total</b>       | <b>47.78</b> | <b>876.85</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.69         | 87.72         | 232      | 148      |
| Unit 4             | 0.00         | 7.43          | 0        | 0        |
| <b>Total</b>       | <b>4.69</b>  | <b>95.15</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.02         | 64.60         | 145      | 95       |
| Unit 2             | 3.56         | 74.75         | 186      | 116      |
| Unit 3             | 3.41         | 60.12         | 169      | 130      |
| Unit 4             | 3.87         | 76.80         | 184      | 130      |
| Unit 5             | 9.80         | 207.21        | 450      | 335      |
| <b>Total</b>       | <b>23.66</b> | <b>483.49</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 2.38         | 64.85         | 165      | 0        |
| Unit 4             | 1.38         | 20.57         | 157      | 0        |
| Unit 5             | 3.28         | 64.23         | 165      | 121      |
| <b>Total</b>       | <b>7.04</b>  | <b>149.64</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.96         | 129.54        | 297      | 281      |
| <b>Total</b>       | <b>6.96</b>  | <b>129.54</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.00         | 1.42          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>1.42</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 1.78         | 53.25         | 295      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 0.00          | 37.42          | 0        | 0        |
| Stage 3         | 0.56          | 22.58          | 160      | 0        |
| <b>Total</b>    | <b>2.35</b>   | <b>113.25</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 2.96           | 0        | 0        |
| VTRNA           | 0.81          | 13.42          | 60       | 0        |
| TILLARI         | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.34          | 1.48           | 40       | 0        |
| SMLHY_PTN       | 1.95          | 32.47          | 87       | 71       |
| GHATGHAR        | 0.00          | 4.21           | 0        | 0        |
| <b>Total</b>    | <b>3.10</b>   | <b>54.54</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 39.37         | 418.58         | 0        | 0        |
| <b>Total</b>    | <b>39.37</b>  | <b>418.58</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 57.04         | 1058.96        | 0        | 0        |
| JSWEL(Mus)      | 18.32         | 456.63         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 31.42         | 574.50         | 0        | 0        |
| SWPGPL-Mus      | 11.18         | 229.68         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.84          | 103.97         | 266      | 193      |
| Other(Mus)      | 1.76          | 68.96          | 0        | 0        |
| JPL             | 5.96          | 99.09          | 271      | 232      |
| <b>Total</b>    | <b>131.51</b> | <b>2591.78</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 16.47         | 296.44         | 0        | 0        |
| <b>Total</b>    | <b>16.47</b>  | <b>296.44</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 7.70          | 162.79         | 367      | 269      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.59          | 48.46          | 108      | 108      |
| Trombay 7B      | 1.53          | 28.89          | 64       | 63       |
| TATA Hydro      | 4.59          | 103.54         | 322      | 109      |
| Trombay 8       | 3.88          | 82.66          | 178      | 133      |
| <b>Total</b>    | <b>20.30</b>  | <b>426.35</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 7.28          | 158.23         | 458      | 155      |
| <b>Total</b>    | <b>7.28</b>   | <b>158.23</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 143.42      | 2874.09       | MSPGCL Total        | 155.83      | 3171.42       |
|                |             |         | MSPGCL Thml+Gas | 150.38      | 3003.63       | Koyna 1,2 & 4 Total | 1.78        | 90.66         |
|                |             |         | MSPGCL Hydro    | 5.45        | 167.79        | State Total         | 370.77      | 7062.81       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 19/Jun/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 6376        | 185  | 297  | 6858   | 1477  | 6437      | 0    | 0     | 7012        | 6364        | -1726                | 18982                  | 0                | 0                           | 18982                         | 2855             | 428                       | 22265           | 49.99         |
| 2                  | 6356        | 180  | 297  | 6833   | 1517  | 5927      | 0    | 0     | 6827        | 6427        | -1603                | 18685                  | 0                | 0                           | 18685                         | 2651             | 416                       | 21752           | 50.00         |
| 3                  | 6392        | 184  | 297  | 6873   | 1450  | 5693      | 0    | 0     | 6578        | 6190        | -1430                | 18380                  | 0                | 0                           | 18380                         | 2476             | 396                       | 21252           | 50.01         |
| 4                  | 6162        | 244  | 297  | 6703   | 1310  | 5594      | 0    | 0     | 6435        | 6343        | -1355                | 18200                  | 0                | 0                           | 18200                         | 2355             | 395                       | 20950           | 50.02         |
| 5                  | 6390        | 189  | 296  | 6875   | 1181  | 5910      | 0    | 0     | 6516        | 6192        | -1304                | 18458                  | 0                | 0                           | 18458                         | 2317             | 396                       | 21171           | 50.02         |
| 6                  | 6516        | 258  | 297  | 7071   | 1068  | 6407      | 0    | 0     | 6765        | 6600        | -1290                | 19447                  | 0                | 0                           | 19447                         | 2355             | 409                       | 22211           | 50.01         |
| 7                  | 6615        | 342  | 292  | 7249   | 1045  | 6426      | 0    | 196   | 6814        | 6593        | -1309                | 19745                  | 0                | 0                           | 19745                         | 2425             | 455                       | 22625           | 50.01         |
| 8                  | 6360        | 127  | 290  | 6777   | 1040  | 5879      | 0    | 682   | 7296        | 6635        | -1494                | 19045                  | 0                | 0                           | 19045                         | 2564             | 474                       | 22083           | 50.06         |
| 9                  | 5636        | 162  | 292  | 6090   | 1315  | 4967      | 0    | 1278  | 7767        | 7533        | -1873                | 18817                  | 0                | 0                           | 18817                         | 2878             | 493                       | 22188           | 50.03         |
| 10                 | 5303        | 264  | 291  | 5858   | 1430  | 4722      | 0    | 1715  | 7822        | 7978        | -2077                | 19125                  | 0                | 0                           | 19125                         | 3171             | 501                       | 22797           | 50.03         |
| 11                 | 5380        | 165  | 293  | 5838   | 1537  | 4705      | 0    | 1968  | 8185        | 7878        | -2262                | 19147                  | 0                | 0                           | 19147                         | 3353             | 517                       | 23017           | 50.00         |
| 12                 | 4965        | 173  | 291  | 5429   | 1728  | 4722      | 0    | 2089  | 8419        | 8346        | -2321                | 19477                  | 0                | 0                           | 19477                         | 3431             | 516                       | 23424           | 50.03         |
| 13                 | 4820        | 123  | 289  | 5232   | 1958  | 4668      | 0    | 2096  | 8312        | 7885        | -2280                | 19059                  | 0                | 1                           | 19059                         | 3441             | 500                       | 23000           | 50.04         |
| 14                 | 4793        | 128  | 284  | 5205   | 1873  | 4675      | 0    | 1904  | 8335        | 8133        | -2234                | 19050                  | 0                | 3                           | 19050                         | 3394             | 506                       | 22950           | 50.02         |
| 15                 | 5329        | 127  | 285  | 5741   | 2142  | 4823      | 0    | 1689  | 8226        | 7812        | -2281                | 19413                  | 0                | 4                           | 19413                         | 3521             | 513                       | 23447           | 50.03         |
| 16                 | 5895        | 126  | 283  | 6304   | 2264  | 4783      | 0    | 1382  | 8009        | 7542        | -2290                | 19483                  | 0                | 2                           | 19483                         | 3496             | 502                       | 23481           | 50.01         |
| 17                 | 5616        | 127  | 285  | 6028   | 2321  | 4803      | 0    | 909   | 7882        | 7753        | -2153                | 19138                  | 0                | 1                           | 19138                         | 3397             | 523                       | 23058           | 50.01         |
| 18                 | 5823        | 179  | 281  | 6283   | 2358  | 5157      | 0    | 478   | 7424        | 7297        | -2055                | 18984                  | 0                | 0                           | 18984                         | 3241             | 534                       | 22759           | 50.07         |
| 19                 | 6171        | 226  | 285  | 6682   | 2182  | 5476      | 0    | 86    | 7187        | 6993        | -2015                | 18861                  | 0                | 0                           | 18861                         | 3148             | 543                       | 22552           | 50.08         |
| 20                 | 6523        | 570  | 285  | 7378   | 1919  | 5911      | 0    | 0     | 7113        | 7392        | -1820                | 20255                  | 0                | 0                           | 20255                         | 3140             | 525                       | 23920           | 50.02         |
| 21                 | 6557        | 410  | 287  | 7254   | 1478  | 6100      | 0    | 0     | 7185        | 6928        | -1742                | 19495                  | 0                | 0                           | 19495                         | 3083             | 523                       | 23101           | 50.05         |
| 22                 | 6501        | 390  | 289  | 7180   | 1594  | 6012      | 0    | 0     | 7103        | 6762        | -1772                | 19273                  | 0                | 0                           | 19273                         | 3006             | 503                       | 22782           | 50.03         |
| 23                 | 6468        | 384  | 288  | 7140   | 1560  | 5748      | 0    | 0     | 7141        | 6990        | -1771                | 19191                  | 0                | 0                           | 19191                         | 3013             | 476                       | 22680           | 50.04         |
| 24                 | 6473        | 186  | 289  | 6948   | 1626  | 5968      | 0    | 0     | 7043        | 6913        | -1692                | 19294                  | 0                | 0                           | 19294                         | 3020             | 469                       | 22783           | 50.05         |
| MUs                | 143.42      | 5.45 | 6.96 | 155.83 | 39.37 | 131.51    | 0.00 | 16.47 | 177.40      | 171.48      | -44.15               | 459.00                 | 0.00             | 0.01                        | 459.00                        | 71.73            | 11.51                     | 542.25          | 50.03         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

1) To avoid overloading of 50MVA 132/33KV TF-2 due to Failure of 50MVA TF-1 at 132kv Newasa S/S.

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 19/Jun/2024

Position as on 6.30 Hrs of 20/Jun/2024

| Generating Company             | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|--------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Koyna Unit 2            | 70       | 15/06/2024   | 07:10        |            | Continued. | Govrner renovation                                                                                                                                      | 10/07/2024    |
| MSPGCL                         | Bhusawal Unit 4         | 500      | 16/06/2024   | 00:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 06/07/2024    |
| Total Capacity MSPGCL          |                         | 570      |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                          |                         |          |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                          | Bhira PSU               | 150      | 19/06/2024   | 06:05        |            | Continued. | for GT oil filtration work.                                                                                                                             | 20/06/2024    |
| Total Capacity TPC-G           |                         | 150      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE  |                         | 720      |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/08/2024    |
| MSPGCL                         | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 26/07/2024    |
| MSPGCL                         | Paras Unit 4            | 250      | 05/06/2024   | 03:59        | 20/06/2024 | 05:45      | Fire in GT                                                                                                                                              | 19/06/2024    |
| MSPGCL                         | Nasik Unit 4            | 210      | 06/06/2024   | 19:18        | 19/06/2024 | 12:30      | ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)                                                                                               |               |
| Total Capacity MSPGCL          |                         | 705      |              |              |            |            |                                                                                                                                                         |               |
| AEML                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| AEML                           | AEML Unit 1             | 250      | 14/06/2024   | 10:16        | 19/06/2024 | 04:58      | Boiler Tube Leakage                                                                                                                                     | 22/06/2024    |
| Total Capacity AEML            |                         | 250      |              |              |            |            |                                                                                                                                                         |               |
| IPP                            |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                            | JSW (J) U1              | 300      | 17/06/2024   | 07:25        |            | Continued. | Condenser tube leakage.                                                                                                                                 | 21/06/2024    |
| Total Capacity IPP             |                         | 300      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                    |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                    | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/08/2024    |
| CENT.SECTOR                    | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/09/2024    |
| Total Capacity CENT.SECTOR     |                         | 320      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE   |                         | 1575     |              |              |            |            |                                                                                                                                                         |               |
| UNIT UNDER ZERO SCHEDULE / RSD |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Parli Unit 6            | 250      | 08/06/2024   | 21:13        |            | Continued. | Zero Schedule by MSEDCL.                                                                                                                                |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 19/Jun/2024**

**Position as on 6.30 Hrs of 20/Jun/2024**

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                        | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-----------------------------------------|---------------|
| MSPGCL                                        | Parli Unit 8            | 250      | 09/06/2024   | 20:50        |           | Continued. | Zero Schedule given by MSEDCL.          |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 17/06/2024   | 21:30        |           | Continued. | Zero Schedule given by MSEDCL           |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 17/06/2024   | 21:44        |           | Continued. | Zero Schedule given by MSEDCL           |               |
| Total Capacity MSPGCL                         |                         | 716      |              |              |           |            |                                         |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 716      |              |              |           |            |                                         |               |
| UNIT OUT ON TOLLING *                         |                         |          |              |              |           |            |                                         |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                         |               |
| MSPGCL                                        | Nasik Unit 3            | 210      | 19/06/2024   | 17:30        |           | Continued. | Case IV Tolling                         |               |
| Total Capacity MSPGCL                         |                         | 210      |              |              |           |            |                                         |               |
| Total Capacity UNIT OUT ON TOLLING *          |                         | 210      |              |              |           |            |                                         |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |           |            |                                         |               |
| IPP                                           |                         |          |              |              |           |            |                                         |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                    |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                    |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019) |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)  |               |
| Total Capacity IPP                            |                         | 988      |              |              |           |            |                                         |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |           |            |                                         |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Jun/2024**

**Statement-VII**

Position as on 6.30 Hrs of 20/Jun/2024

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV MAINBAY Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                                                                                                 |
| BUS COUPLER @ KHADKA                     | IntraState                | 19/06/2024   | 11:52        | 19/06/2024 | 14:40      | EO          | THE 400KV BUS COUPLER MAIN BUS 1 B-PHASE ISOLATOR RED HOT OBSERVED ON HANGER ROD CLAMP AND TO ATTEND THIS BY HOT LINE UNIT JALGAON                                                              |
| <b>400 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                 |
| KORADI 2-WARDHA (PG)                     | InterState                | 19/06/2024   | 11:05        | 19/06/2024 | 20:27      | PO          | Diagnostic Testing of Line CVT                                                                                                                                                                  |
| BUS REACTOR (50MVAR) @ PARLI             | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.                                                                                                                             |
| CHANDRAPUR 2 - WARORA CKT-2              | IntraState                | 22/04/2024   | 17:27        |            |            | T           | Tripped on distance protection.                                                                                                                                                                 |
| CHANDRAPUR 2 - WARORA CKT-1              | IntraState                | 22/04/2024   | 17:27        |            |            | T           | Tripped on distance protection.                                                                                                                                                                 |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1      | IntraState                | 14/05/2024   | 12:30        |            |            | HT          | HT for load Management                                                                                                                                                                          |
| MAIN BUS - 1 @ TALANDGE                  | IntraState                | 17/06/2024   | 20:36        |            |            | PO          | Insulator cleaning work. 400kV PG Isolator alignment and maintenance work.                                                                                                                      |
| NAGOTHANE - DABHOL CKT - 2               | IntraState                | 18/06/2024   | 03:15        |            |            | T           | Tripped on distance protection                                                                                                                                                                  |
| DHULE- - BABLESHWAR CKT - 2              | IntraState                | 19/06/2024   | 08:47        | 19/06/2024 | 11:00      | T           | Tripped on overvoltage stage 1 protection                                                                                                                                                       |
| DEEPNAGAR - THAPTI TANDA                 | IntraState                | 19/06/2024   | 15:52        | 19/06/2024 | 17:43      | EO          | VERIFICATION OF CB MECHANISM AND DIRECT TRIPPING                                                                                                                                                |
| <b>400 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                 |
| STATION TF No 3 @ CHANDRAPUR GCR         | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                  |
| 400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS | IntraState                | 10/02/2024   | 17:40        |            |            | HT          | H/T For LV only.                                                                                                                                                                                |
| 400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS | IntraState                | 22/05/2024   | 17:41        |            |            | HT          | HT for Load management                                                                                                                                                                          |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA      | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                         |
| 400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS | IntraState                | 13/06/2024   | 10:11        |            |            | PO          | For work in vicinity for erection of scaffolding for installation of LA&#65533;s on 220KV Bays at KVTL Vikhroli (These Bays used for feeding 220/110kV, 250MVA, ICT-1 & ICT-2 of TPC Vikhroli). |
| 400/220KV SPARE ICT @ JEJURI             | IntraState                | 20/06/2024   | 08:44        |            |            | PO          | For RRS Trials work                                                                                                                                                                             |
| 400/220/33 KV 500 MVA ICT - 3 @ JEJURI   | IntraState                | 20/06/2024   | 09:38        |            |            | PO          | For RRS Trials work                                                                                                                                                                             |
| <b>220 KV MAINBAY Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                                                                                                 |
| 220KV YAWATMAL- WARDHA(DEOLI) PG CKT 1   | InterState                | 19/06/2024   | 09:56        | 19/06/2024 | 15:22      | PO          | Maintenance work                                                                                                                                                                                |
| 220KV BUS SECTION BAY @ PEDAMBE          | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                    |
| BUS COUPLER @ NEW KOYNA                  | IntraState                | 18/06/2024   | 15:40        |            |            | PO          | Replacement of R , Y , B phase stub bus (Jack Bus ) Conductor of 220 KV Pedhambe Bay & ICT-II bay above A bus .                                                                                 |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Jun/2024**

**Statement-VII**

Position as on 6.30 Hrs of 20/Jun/2024

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                             |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 220 KV MAIN BUS - 1 @ NEW KOYNA      | IntraState                | 18/06/2024   | 15:40        |            |            | PO          | Replacement of R ,Y ,B phase stub bus (Jack Bus ) Conductor of 220 KV Pedhambe Bay & ICT-II Bay above A bus .<br>By Transferring flowing bay to B bus with the help of TBC .<br>1) 220 KV side 315 MVA ICT3 (Not In OMS )<br>2) 220 KV Lote<br>3) 220 KV side 25 MVA T/F 2<br>4) 220 KV side 315 MVA ICT2 (not In OMS)<br>5) 220 KV Pedhambe |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                              |
| BALE - SOLAPUR (PG)                  | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                             |
| 220 kV-Wardha(PG)-Yawatmal Ckt-1     | InterState                | 19/06/2024   | 09:56        | 19/06/2024 | 15:22      | PO          | MAINTENANCE WORK                                                                                                                                                                                                                                                                                                                             |
| MAIN BUS - 1 @ GORAI                 | IntraState                | 28/05/2024   | 17:59        |            |            | T           | Bus Fault                                                                                                                                                                                                                                                                                                                                    |
| NTT - KALWA                          | IntraState                | 05/06/2024   | 00:20        |            |            | PO          | For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.                                                                                                                       |
| EKLAHARE (OCR) - PADGHE              | IntraState                | 10/06/2024   | 08:42        |            |            | HT          | H/T for load management                                                                                                                                                                                                                                                                                                                      |
| TOPWORTH - KHANDESHWAR               | IntraState                | 15/06/2024   | 14:24        |            |            | PO          | Making LILO of 220kV Khandeshwar - Topwarth line & 220kV Khandeshwar Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel                                                                                                                                                                                                 |
| PANVEL TSS - KHANDESHWAR             | IntraState                | 15/06/2024   | 14:30        |            |            | PO          | Making LILO of 220kV Khandeahwar Topwarth line & 220kV Khandeshwar - Panvel TSS line and commissioing of 220/33kV Timber Market GIS, Panvel                                                                                                                                                                                                  |
| KARAD - OGALEWADI CKT 1              | IntraState                | 17/06/2024   | 09:24        |            |            | PO          | For Distance Relay Retrofitting and Relay Panel rewiring work.                                                                                                                                                                                                                                                                               |
| BARAMATI - KURKUMBH                  | IntraState                | 18/06/2024   | 10:55        | 19/06/2024 | 04:50      | PO          | Replacement of Distance relay, diagnostic testing of bay equipments.                                                                                                                                                                                                                                                                         |
| NEW KOYNA - PEDAMBE                  | IntraState                | 19/06/2024   | 06:45        | 19/06/2024 | 14:16      | PO          | Replacement of R ,Y ,B phase stub bus (Jack Bus ) Conductor of 220 KV Pedhambe Bay                                                                                                                                                                                                                                                           |
| OSMANABAD - SOLAPUR (BALE)           | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                |
| WANI-WARORA 1                        | IntraState                | 19/06/2024   | 10:38        | 19/06/2024 | 20:00      | PO          | FOR DISTANCE RELAY TESTING WORK                                                                                                                                                                                                                                                                                                              |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Jun/2024**

**Statement-VII**

Position as on 6.30 Hrs of 20/Jun/2024

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------|
| MALINAGAR - TEMBHURNI                     | IntraState                | 19/06/2024   | 11:32        | 19/06/2024 | 14:04      | PO          | Outage is required for Quarterly Maintenance                                                                    |
| MAIN BUS - 2 @ MALINAGAR                  | IntraState                | 19/06/2024   | 11:32        | 19/06/2024 | 13:50      | PO          | Outage is required for Quarterly Maintenance                                                                    |
| TROMBAY (M) - CHEMBUR CKT-1               | IntraState                | 19/06/2024   | 15:15        | 19/06/2024 | 18:41      | PO          | For bay integration in RTU Panel by PAC unit Kalwa                                                              |
| AUXILARY BUS @ VAIRAG                     | IntraState                | 19/06/2024   | 16:23        | 19/06/2024 | 19:55      | PO          | Outage is required for Quarterly Maintenance                                                                    |
| LAMBOTI - VAIRAG                          | IntraState                | 19/06/2024   | 16:23        | 19/06/2024 | 19:55      | PO          | Outage is required for Quarterly Maintenance                                                                    |
| MAIN BUS @ VAIRAG                         | IntraState                | 19/06/2024   | 16:23        | 19/06/2024 | 19:55      | PO          | Outage is required for Quarterly Maintenance                                                                    |
| URAN - APTA 3                             | IntraState                | 19/06/2024   | 18:57        | 20/06/2024 | 01:06      | T           | Distance Protection                                                                                             |
| PEDAMBE-KALAMBANI(TSS)                    | IntraState                | 19/06/2024   | 19:45        | 20/06/2024 | 04:18      | HT          | hotspot observed at B phase main bus isolator to breaker                                                        |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                 |
| 220/33kV 125 MVA TF 2 @ GORAI             | IntraState                | 28/05/2024   | 17:59        |            |            | T           | Bus Fault                                                                                                       |
| 220/110kV 250MVA ICT-2 @ VIKHROLI(GIS)    | IntraState                | 18/06/2024   | 00:47        |            |            | PO          | for LA replacement                                                                                              |
| 220/132 KV 200 MVA ICT 1 @ KAULEWADA      | IntraState                | 19/06/2024   | 07:48        | 19/06/2024 | 10:46      | PO          | FOR PREMANSOON MAINT. WORK.                                                                                     |
| 220/132 KV 100 MVA ICT 1 @ BUTIBORI       | IntraState                | 19/06/2024   | 11:05        | 19/06/2024 | 15:06      | PO          | PREMONSOON MAINTENANCE AND IR VALUE OF B PH HV LA                                                               |
| 220/132 KV 200MVA ICT 2 @ JALNA           | IntraState                | 19/06/2024   | 13:22        | 19/06/2024 | 16:46      | T           | REF PROTECTION OPTED                                                                                            |
| 200 MVA 220/132 KV ICT - III @ CHALISGAON | IntraState                | 19/06/2024   | 22:37        | 19/06/2024 | 19:05      | EO          | HEAVY OIL LEAKAGE OBSERVED AT R PH DIVERter SWITCH ( LV SIDE)                                                   |
| <b>132 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                 |
| MANSAR-PENCH                              | InterState                | 19/06/2024   | 09:30        | 19/06/2024 | 18:27      | PO          | For routine maintenance work                                                                                    |
| 132KV RENAPUR- TWENTY ONE SUGAR AT LATUR  | IntraState                | 26/05/2024   | 16:19        |            |            | T           | TOWER COLLAPSED AT LOC.11.                                                                                      |
| <b>110 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                 |
| KHOPOLI - BHOKARPADA                      | IntraState                | 19/06/2024   | 07:54        | 19/06/2024 | 09:44      | PO          | Bird nest removal at loc. 267 A Phase ,263A & B ,263A B & C ,261C phase ,260 C ,259Aph & replacement of old TBR |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage