

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Jul/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	112.883	2535.279	1) Gujrat	3.159	29.596
2) Hydro	7.074	131.900	2) Madhya Pradesh	-0.778	103.757
3) Gas	0.210	1.153	3) Chattisgarh	1.260	44.610
Total MSPGCL	120.167	2668.332	4) Maharashtra	161.179	3097.365
B) 1) APML	42.992	1122.094	5) Goa (Amona)	-1.105	-20.020
2) JSWEL	20.322	374.705	Total	163.715	3255.308
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.700	677.311
4) RPL(AMT)	24.157	440.465	b) Mumbai Drawl	36.340	739.484
5) SWPGPL	9.784	169.609	c) MSEDCL Bilateral *	90.936	1738.719
6) Other IPP	6.374	122.359	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.700	676.460
C) 1) TPCL Thermal	10.492	146.089	Include PX	0.000	0.000
2) TPCL Hydro	4.461	90.206	Standby	0.000	0.851
3) TPCL Gas	2.558	65.636	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.677	169.403	1) MSEDCL	406.433	8233.007
D) STATE			2) Mumbai Discoms	62.528	1210.820
1) Thermal	235.681	5080.003	3) Other Discoms	9.362	186.450
(A1+C1+C4+(B1-B6))			TOTAL STATE	478.323	9630.277
2) Hydro	11.535	222.106			
(A2+C2)					
3) Gas	2.768	66.789			
(A3+B7+C3)					
4) Wind	58.473	814.189			
6) SOLAR	6.151	191.880			
TOTAL STATE	314.608	6374.967			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4962	4651	4878	4874
MSPGCL Hydro	230	312	541	214
MSPGCL Gas	0	0	19	0
MSPGCL Total Generation	5192	4963	5438	5088
Central Sector Receipt	8230	7082	6571	5453
WIND	2203	2805	2680	2096
CPP / IPP Thermal	4522	4388	5188	4131
CPP / IPP Gas	0	0	0	0
SOLAR	554	341	0	0
Exchange with Mumbai	-1982	-1846	-1231	-1093
MSEDCL DEMAND MET	18291	17332	18234	15362
Load Shedding	0	0	0	0
MSEDCL DEMAND	18291	17332	18234	15362
TPCL GENERATION	644	702	1108	558
AEML GENERATION	400	307	473	320
MUMBAI DEMAND	3026	2855	2812	1971
OTHER DISCOM DEMAND	428	401	412	313
STATE DEMAND MET	21745	20588	21458	17646
STATE DEMAND	21745	20588	21458	17646
Frequency (Hz)	50.01	50.03	49.97	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 13.03 Hrs	49.76 Hz at 14.10 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 19/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.70	68.55	150	0
Unit 8	0.00	186.88	0	0
Unit 9	11.13	229.04	548	388
Unit 10	0.00	111.14	0	0
Total	13.84	595.61		
Bhusawal				
Unit 3	3.00	54.68	140	100
Unit 4	9.24	183.96	450	290
Unit 5	9.70	191.95	465	280
Total	21.94	430.59		
Parli				
Unit 6	3.65	32.95	231	110
Unit 7	4.01	25.80	238	144
Unit 8	3.60	13.91	175	143
Total	11.26	72.66		
Chandrapur				
Unit 3	0.66	53.12	114	0
Unit 4	0.00	51.71	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.65	144.95	277	185
Unit 7	5.96	147.86	273	225
Unit 8	8.76	187.30	406	290
Unit 9	9.63	198.54	446	347
Total	30.66	783.49		
Paras				
Unit 3	4.54	74.35	218	153
Unit 4	3.90	83.60	190	127
Total	8.44	157.95		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	2.49	49.77	113	94
Unit 3	3.99	73.06	182	129
Unit 4	4.24	67.86	200	126
Unit 5	10.52	170.74	475	280
Total	21.25	361.43		
Nasik				
Unit 3	3.95	56.38	179	126
Unit 4	1.54	64.84	160	0
Unit 5	0.00	12.33	0	0
Total	5.49	133.55		
Uran				
All Units	0.21	1.15	166	0
Total	0.21	1.15		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.38	1.32	25	0
Total	0.38	1.32		
Koyna				
Stage 1-2	0.88	38.92	45	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	6.91	0	0
Stage 3	2.21	18.59	160	0
Total	3.09	64.42		
Hydro				
KDPH	0.00	0.14	0	0
VTRNA	0.00	0.64	0	0
TILLARI	0.00	1.16	0	0
BHIRA T.R.	0.46	8.21	80	0
SMLHY_PTN	2.78	51.50	121	104
GHATGHAR	0.36	4.51	125	0
Total	3.60	66.16		
Wind				
Total	58.47	814.19	0	0
Total	58.47	814.19		
CPP				
APML(Mus)	42.99	1122.09	0	0
JSWEL(Mus)	20.32	374.70	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.16	440.46	0	0
SWPGPL-Mus	9.78	169.61	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.13	97.91	267	175
Other(Mus)	1.24	24.45	0	0
Total	103.63	2229.23		
SOLAR				
Total	6.15	191.88	0	0
Total	6.15	191.88		
Tata				
Trombay 5	7.06	73.77	444	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.48	40.00	108	39
Trombay 7B	1.08	25.63	64	36
TATA Hydro	4.46	90.21	388	72
Trombay 8	3.43	72.32	214	127
Total	17.51	301.93		
AEML				
DTPS U-1&2	8.68	169.40	497	292
Total	8.68	169.40		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	112.88	2535.28	MSPGCL Total	120.17	2668.33
			MSPGCL Thml+Gas	113.09	2536.43	Koyna 1,2 & 4 Total	0.88	45.83
			MSPGCL Hydro	7.07	131.90	State Total	314.61	6374.97

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	4943	175	0	5118	1946	3991	0	0	6233	6189	-1238	15632	0	0	15632	2295	374	18301	49.99
2	5002	177	0	5179	2047	4096	0	0	5918	5703	-1138	15546	0	0	15546	2138	341	18025	50.00
3	4937	174	0	5111	2075	3953	0	0	5771	5698	-1117	15394	0	0	15394	2030	326	17750	49.98
4	4874	214	0	5088	2096	4131	0	0	5541	5453	-1093	15362	0	0	15362	1971	313	17646	50.03
5	4791	255	0	5046	2185	4192	0	0	5955	5838	-1084	15855	0	0	15855	1965	322	18142	50.03
6	4519	252	0	4771	2449	3948	0	0	7146	7046	-1208	16644	0	0	16644	2075	362	19081	50.02
7	4807	323	0	5130	2422	4113	0	57	7762	7595	-1334	17596	0	0	17596	2248	387	20231	49.98
8	4840	412	0	5252	2239	3894	0	227	8102	8240	-1577	17871	0	0	17871	2452	404	20727	49.97
9	5013	351	0	5364	2318	4358	0	354	8002	7930	-1770	18127	0	0	18127	2777	427	21331	49.95
10	4962	230	0	5192	2203	4522	0	554	7921	8230	-1982	18291	0	0	18291	3026	428	21745	50.01
11	4782	172	0	4954	2205	4754	0	715	8017	7958	-2059	18112	0	7	18112	3186	415	21713	50.04
12	4518	238	0	4756	2459	4285	0	774	8492	7868	-2205	17535	0	18	17535	3189	402	21126	50.01
13	4149	286	0	4435	2396	3922	0	746	8130	8074	-2184	16975	0	0	16975	3122	414	20511	50.01
14	3858	239	0	4097	2546	3708	0	806	7952	7898	-2065	16585	0	0	16585	2995	405	19985	49.99
15	4177	250	0	4427	2482	3776	0	771	7638	7547	-1900	16712	0	0	16712	2855	391	19958	49.91
16	4677	284	0	4961	2637	4076	0	517	7157	7393	-1898	17286	0	0	17286	2862	400	20548	49.98
17	4651	312	0	4963	2805	4388	0	341	7028	7082	-1846	17332	0	0	17332	2855	401	20588	50.03
18	4660	312	0	4972	2719	4364	0	234	7110	7127	-1783	17240	0	0	17240	2823	393	20456	50.01
19	4710	425	0	5135	2756	4456	0	55	7039	7285	-1577	17691	0	0	17691	2798	419	20908	49.99
20	4878	541	19	5438	2680	5188	0	0	6392	6571	-1231	18234	0	0	18234	2812	412	21458	49.97
21	4813	505	166	5484	2796	5251	0	0	6022	5666	-1073	17708	0	0	17708	2720	416	20844	50.02
22	4747	423	25	5195	2598	5101	0	0	5590	5352	-1092	16731	0	0	16731	2553	423	19707	50.03
23	4806	301	0	5107	2700	4859	0	0	5267	5025	-1016	16279	0	0	16279	2440	396	19115	50.02
24	4769	223	0	4992	2714	4303	0	0	5233	4947	-870	15694	0	0	15694	2341	392	18427	50.04
MUs	112.88	7.07	0.21	120.17	58.47	103.63	0.00	6.15	165.42	163.72	-36.34	406.43	0.00	0.03	406.43	62.53	9.36	478.32	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)220kV GCR-BBLR-1 & 2 line load reached above 765Amp each circuit & ELR carried out.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Jul/2023

Position as on 6.30 Hrs of 20/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	
IPP	Adani U-1	660	16/07/2023	00:00		Continued.	Annual Overhaul	07/08/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/07/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	25/07/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	25/07/2023
MSPGCL	Nasik Unit 5	210	04/07/2023	18:00	20/07/2023	06:04	Generator Swapping : nashik Unit-3 sync 16:35 Hrs and tolling agreement with IEPL	
MSPGCL	Koradi Unit 8	660	16/07/2023	10:25		Continued.	Boiler Tube Leakage	20/07/2023
MSPGCL	Uran Unit 6	108	17/07/2023	21:15	19/07/2023	19:33	No Schedule	
MSPGCL	Chandrapur Unit 3	210	18/07/2023	19:45	19/07/2023	14:35	WET COAL	
MSPGCL	Uran Unit 7	108	18/07/2023	21:12	19/07/2023	19:50	No Schedule.	
MSPGCL	Chandrapur Unit 4	210	18/07/2023	23:49		Continued.	Air heater problem	21/07/2023
MSPGCL	Koradi Unit 6	210	19/07/2023	03:19	19/07/2023	07:20	Flame Failure	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Jul/2023

Position as on 6.30 Hrs of 20/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Nasik Unit 4	210	19/07/2023	10:50		Continued.	ID Fan Problem	21/07/2023
MSPGCL	Uran Unit 6	108	19/07/2023	21:11		Continued.	No schedule	
MSPGCL	Uran Unit 7	108	19/07/2023	21:27		Continued.	No schedule	
MSPGCL	Parli Unit 8	250	20/07/2023	00:02		Continued.	Drum level high.	20/07/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 20/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20			PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
TIE BAY - 417 OF IEPL @ KORADI-2	IntraState	19/07/2023	10:43	19/07/2023	15:24	PO	Diagnostic testing of Circuit Breaker & current Transformer & Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR	IntraState	06/07/2023	08:38			PO	1. Maintenance and alignment work of Bus-1, Bus-2 Aus. Bus And HCB Isolator. 2. Maintenance of CB, CT and Synch CVT.
SPARE LINE-2 BAY (404) @ TAPTITANDA	IntraState	17/07/2023	12:09	19/07/2023	16:27	PO	Circuit breaker mechanism overhauling work by M/s CGL service Engineer.
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	13/07/2023	08:03			HT	H/T Due to load management.
KHADKA-AURANGABAD (WALUJ)	IntraState	18/07/2023	22:55	19/07/2023	09:08	HT	H/T For controlling overvoltages.
AKOLA-NANDGAONPETH (RPL-AMT)	IntraState	19/07/2023	10:25	19/07/2023	16:21	PO	Routine Maintenance & testing Work
KHADKA-AURANGABAD (WALUJ)	IntraState	19/07/2023	23:23	20/07/2023	07:08	HT	H/T FOR O/V
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	IntraState	16/07/2023	10:00			PO	ABB Circuit Breaker Pole & Mechanism overhauling;HV CB DCRM/timing
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	17/07/2023	13:04			PO	1.Replacement of HV CB under LES Scheme. 2.ICT will be in service through TBC.
400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	IntraState	19/07/2023	10:05	19/07/2023	18:42	T	Tripped on NDR
400/220/20 KV 500MVA ICT - 1 @ KALWA	IntraState	19/07/2023	21:59	20/07/2023	01:52	T	TRIPPED ON PRV
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	20/07/2023	01:57	20/07/2023	05:03	HT	Sparking observed on Neutral CT of 400/220KV ,600MVA ICT-2
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 20/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DONDAICHA- SHAHADA CKT I	IntraState	01/07/2023	09:53	19/07/2023	17:10	PO	The work of second circuit stringing of 220kv Dondaicha - Shahada line.
DAHANU - VERSOVA	IntraState	10/07/2023	10:24			PO	Shifting of Lines on Newly constructed Towers for NHSRCL Project Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
BOISAR - VERSOVA	IntraState	10/07/2023	10:27			PO	Shifting of Lines on Newly constructed Towers for NHSRCL Project. Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
PADGHE - TEMGHAR - 1	IntraState	18/07/2023	19:57	19/07/2023	13:14	T	TRIPPED ON DISTANCE PROTECTION
PADGHE - WADA	IntraState	19/07/2023	03:17	19/07/2023	04:50	T	Tripped due to trial taken on 220kV Padghe-Temghar ckt1
PADGHE - JINDAL	IntraState	19/07/2023	03:17	19/07/2023	04:53	T	Tripped due to trial taken on 220kV Padghe-Temghar ckt1
PADGHE - KAMBA 2	IntraState	19/07/2023	03:17	19/07/2023	04:51	T	Tripped due to trial taken on 220kV Padghe-Temghar ckt1
PALGHAR - NALASOPARA	IntraState	19/07/2023	05:20	19/07/2023	08:40	PO	For replacement of rusted old Disc insulator string at location no. 79,94,95,97,98 & 99.
220KV HINGOLI -KURUNDA CKT	IntraState	19/07/2023	05:31	19/07/2023	07:27	T	Distance Protection
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 2	IntraState	19/07/2023	11:13	19/07/2023	15:30	PO	Outage is required for Quarterly Maintenance
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	19/07/2023	11:25	19/07/2023	13:55	PO	Diagnostic testing. Work.
AURANGABAD (WALUJ)-DEOGAON RANGARI	IntraState	19/07/2023	12:08	19/07/2023	18:37	PO	Diagnostic testing & Routine maintenance work.
GHATGHAR - BAPGAON	IntraState	19/07/2023	13:15	19/07/2023	16:03	PO	For Tree cutting work between loc no 201A & 201B
BOMBAY DYEING - SAHARA	IntraState	20/07/2023	06:14			T	TRIPPED ON DISTANCE PROTECTION
KARAD - VITA CKT- 1	IntraState	20/07/2023	08:24			PO	1.Jump Replacement Work at Loc no.01 2.String Replacement work at Loc No.61
TALANDGE - SAWANTWADI	IntraState	20/07/2023	09:18			PO	Sawantwadi end relay testing work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	15/07/2023	12:45			EO	Attending the SF6 Gas leakage . Present SF6 gas pressure is 5.7
220/33 KV 50 MVA PTR 1 @ VIRAJ	IntraState	19/07/2023	08:24	19/07/2023	15:01	T	LA Blast
220 KV BUSBAR Outages/Trippings							
AUXILIARY BUS @ PHALTAN MIDC-220 KV	IntraState	16/07/2023	10:02			PO	For Gantry replacement from AH type to AF type
132 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 20/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage