

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Sep/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	129.597	2388.593	1) Gujrat	11.035	202.688
2) Hydro	6.326	153.193	2) Madhya Pradesh	4.108	140.980
3) Gas	4.268	114.005	3) Chattisgarh	4.750	86.540
Total MSPGCL	140.191	2655.791	4) Maharashtra	107.839	2578.564
B) 1) APMIL	51.923	758.834	5) Goa (Amona)	-1.079	-6.389
2) JSWEL	17.935	337.218	Total	126.653	3002.383
3) VIPL	0.000	0.000	a) Mumbai Schedule	19.402	493.149
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	23.726	540.006
5) WPCL	2.584	49.281	c) MSEDCL Bilateral *	22.830	573.896
6) Other IPP	7.096	143.014	Include PX	-2.899	101.034
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	19.402	493.149
C) 1) TPCL Thermal	7.543	155.195	Include PX	13.088	346.712
2) TPCL Hydro	4.547	79.153	Standby	0.000	0.000
3) TPCL Gas	3.286	75.741	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.178	101.226	1) MSEDCL	334.527	6708.103
D) STATE			2) Mumbai Discoms	48.280	951.320
1) Thermal	225.856	3933.361	TOTAL STATE	382.807	7659.423
(A1+C1+C4+(B1-B6))					
2) Hydro	10.873	232.346			
(A2+C2)					
3) Gas	7.554	189.746			
(A3+B7+C3)					
4) Wind	7.327	198.095			
6) SOLAR	4.544	103.493			
TOTAL STATE	256.154	4657.041			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5644	5197	5680	5044
MSPGCL Hydro	323	201	939	70
MSPGCL Gas	128	126	128	279
MSPGCL Total Generation	6095	5524	6747	5393
Central Sector Receipt	6421	6202	5210	4386
WIND	244	176	330	358
CPP / IPP Thermal	3421	3124	3686	3041
CPP / IPP Gas	0	0	0	0
SOLAR	525	702	9	0
Exchange with Mumbai	-1369	-1361	-828	-838
MSEDCL DEMAND MET	15337	14367	15154	12340
Load Shedding	0	0	0	0
MSEDCL DEMAND	15337	14367	15154	12340
TPCL GENERATION	564	633	902	487
AEML GENERATION	372	370	480	371
MUMBAI DEMAND	2305	2364	2210	1696
STATE DEMAND MET	17642	16731	17364	14036
STATE DEMAND	17642	16731	17364	14036
Frequency (Hz)	49.99	49.91	49.78	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.12 Hz at 05.03 Hrs	49.65 Hz at 18.26 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 19/Sep/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.27	213.80	521	304
Unit 9	11.22	211.01	522	400
Unit 10	9.44	174.45	428	360
Total	30.92	599.26		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.24	162.54	490	360
Unit 5	8.97	183.22	435	355
Total	18.20	345.77		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	19.70	0	0
Unit 7	0.00	30.40	0	0
Unit 8	0.00	64.10	0	0
Total	0.00	114.20		
Chandrapur				
Unit 3	3.76	73.99	165	116
Unit 4	3.52	46.27	155	134
Unit 5	9.15	178.08	425	360
Unit 6	9.16	40.26	415	350
Unit 7	0.00	0.00	0	0
Unit 8	10.06	194.17	465	360
Unit 9	10.00	188.23	465	360
Total	45.65	721.00		
Paras				
Unit 3	5.11	81.11	258	165
Unit 4	5.24	76.56	250	190
Total	10.35	157.68		
Khaparkheda				
Unit 1	3.57	62.90	165	120
Unit 2	2.82	58.70	180	75
Unit 3	3.95	71.11	180	150
Unit 4	3.91	71.95	180	140
Unit 5	10.22	186.02	500	365
Total	24.47	450.68		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	4.27	114.00	280	126
Total	4.27	114.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.18	23.05	53	3

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.18	23.05		
Koyna				
Stage 1-2	2.64	51.12	405	40
Stage 4	0.22	40.94	185	0
Stage 3	0.93	22.30	160	0
Total	3.79	114.37		
Hydro				
KDPH	0.00	0.50	0	0
VTRNA	0.00	1.93	0	0
TILLARI	0.63	5.96	58	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.41	6.65	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.00	2.64	0	0
ELDARY	0.52	9.74	22	21
SMLHY_PTN	0.20	7.60	9	8
GHATGHAR	0.77	3.81	250	0
Total	2.54	38.82		
Wind				
Total	7.33	198.10	0	0
Total	7.33	198.10		
CPP				
APML(Mus)	51.92	758.83	0	0
JSWEL(Mus)	17.94	337.22	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.58	49.28	0	0
Other(Mus)	7.10	143.01	0	0
Total	79.54	1288.35		
SOLAR				
Total	4.54	103.49	0	0
Total	4.54	103.49		
Tata				
Trombay 5	7.54	155.20	400	299
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.00	47.53	117	50
Trombay 7B	1.28	28.21	66	39
Trombay 8	0.00	0.00	0	0
TATA Hydro	4.55	79.15	454	2
Total	15.38	310.09		
AEML				
DTPS U-1&2	9.18	101.23	499	369
Total	9.18	101.23		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	129.60	2388.59	MSPGCL Total	140.19	2655.79
			MSPGCL Thml+Gas	133.86	2502.60	Koyna 1,2 & 4 Total	2.86	92.07
			MSPGCL Hydro	6.33	153.19	State Total	256.15	4657.04

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Sep/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5130	75	279	5484	472	3101	0	0	4646	4435	-985	12507	0	12507	1854	14361	49.98
2	5074	80	280	5434	319	3105	0	0	4726	4653	-912	12599	0	12599	1767	14366	49.98
3	5044	70	279	5393	358	3041	0	0	4459	4386	-838	12340	0	12340	1696	14036	49.96
4	5097	99	279	5475	344	3063	0	0	4610	4431	-765	12548	0	12548	1622	14170	49.97
5	5122	75	260	5457	313	3050	0	0	4732	4703	-751	12772	0	12772	1605	14377	49.95
6	5242	80	229	5551	274	3087	0	0	5275	5376	-791	13497	0	13497	1628	15125	49.93
7	5494	421	130	6045	263	3154	0	15	5327	5273	-745	14005	0	14005	1661	15666	49.99
8	5658	669	140	6467	248	3519	0	143	5489	5719	-725	15371	0	15371	1729	17100	49.99
9	5702	417	129	6248	173	3681	0	299	6103	6282	-1027	15656	0	15656	1889	17545	50.02
10	5658	451	129	6238	199	3611	0	422	6467	6210	-1275	15405	0	15405	2147	17552	50.02
11	5644	323	128	6095	244	3421	0	525	6658	6421	-1369	15337	0	15337	2305	17642	49.99
12	5463	177	138	5778	178	3174	0	619	6674	6540	-1398	14891	0	14891	2355	17246	49.92
13	5197	201	126	5524	176	3124	0	702	6580	6202	-1361	14367	0	14367	2364	16731	49.91
14	5141	159	128	5428	162	3105	0	621	6013	6119	-1263	14172	0	14172	2283	16455	49.99
15	5420	121	138	5679	173	3130	0	603	6047	5835	-1232	14188	0	14188	2257	16445	49.98
16	5496	125	128	5749	189	3167	0	374	6120	5874	-1111	14242	0	14242	2203	16444	50.00
17	5364	372	128	5864	254	3180	0	166	6017	5922	-1110	14276	0	14276	2168	16444	49.94
18	5654	291	138	6083	364	3502	0	46	5813	5321	-1138	14178	0	14178	2150	16328	49.91
19	5680	939	128	6747	330	3686	0	9	5481	5210	-828	15154	0	15154	2210	17364	49.78
20	5700	703	149	6552	306	3764	0	0	5289	4838	-775	14685	0	14685	2242	16927	49.96
21	5757	170	149	6076	528	3708	0	0	4745	4345	-896	13761	0	13761	2130	15891	49.99
22	5470	151	169	5790	475	3580	0	0	4366	4308	-768	13385	0	13385	2050	15435	49.96
23	5322	86	219	5627	494	3387	0	0	4561	4047	-823	12732	0	12732	2004	14736	49.94
24	5068	71	268	5407	491	3198	0	0	4592	4204	-840	12460	0	12460	1961	14421	49.94
MUs	129.60	6.33	4.27	140.19	7.33	79.54	0.00	4.54	130.79	126.65	-23.73	334.53	0.00	334.53	48.28	382.81	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Sep/2020

Position as on 6.30 Hrs of 20/Sep/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.(Converted zero schedule from 25.03.2020)	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	06/08/2020	03.33		Continued.	Sparkling in generator R phase winding.	
CPP	SWPGL U-3	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
CPP	SWPGL U-4	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Ghatghar Unit-1	125	27/08/2020	05.25		Continued.	Runner band Drainage valve Leakage	
IPP	Adani U-2	660	01/09/2020	19.41		Continued.	Air pre-heater PA Bellow leakage.	
IPP	JSW (J) U3	300	09/09/2020	10.56		Continued.	CW Duct leakage	
MSPGCL	Parli Unit 6	250	11/09/2020	23.55		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	14/09/2020	00.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	14/09/2020	20.45		Continued.	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Sep/2020

Position as on 6.30 Hrs of 20/Sep/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	19/09/2020	06.02	19/09/2020	19.07	Gas shortage	
MSPGCL	Koyna STG- IV Unit - 1	250	20/09/2020	12.00		Continued.	CT Maintenance Work.	
MSPGCL	Bhusawal Unit 4	500	20/09/2020	20.14		Continued.	Zero Schedule by MSEDCL.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Sep/2020

Statement-VII

Position as on 6.30 Hrs of 20/Sep/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa I	InterState	12/09/2020	01.05		Continued.	HT	Over Voltage
Padgha Tarapur I	InterState	20/09/2020	03.40	20/09/2020	08.42	T	DT received at Padghe.
Akola II - RPL(Rattanindia) Ckt I	IntraState	13/09/2020	17.56		Continued.	HT	Over Voltage
Dhule- Bableshwar - I	IntraState	16/09/2020	23.30		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	18/09/2020	17.57	19/09/2020	07.52	HT	Over Voltage
Padghe - Kalwa- I	IntraState	18/09/2020	21.29	19/09/2020	09.05	HT	Over Voltage
Padghe - Nagothane - I	IntraState	18/09/2020	21.47		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	19/09/2020	00.22	19/09/2020	08.42	T	Over Voltage
New Koyna - Koyna Stage IV-II	IntraState	19/09/2020	11.02	19/09/2020	17.12	PO	Diagnostic testing & Relay Testing work.
Khadka-Aurangabad (Waluj)	IntraState	19/09/2020	17.32		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	19/09/2020	21.01	20/09/2020	09.16	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	19/09/2020	23.33	20/09/2020	09.21	HT	Over Voltage
karad -kolhapur-II	IntraState	20/09/2020	02.12		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	20/09/2020	19.34		Continued.	HT	Over Voltage (CVT Problem).
Padghe - Kalwa- I	IntraState	20/09/2020	21.42		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/132 Kv 200 Mva Ict 1 @Khadka	IntraState	20/09/2020	08.17	20/09/2020	16.17	PO	CB Maintenance Work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.
Lonikand1 (400 Kv)-Theur I	IntraState	14/08/2020	10.38		Continued.	PO	Replacement of Existing 0.4 DEER Conductor, hardware & Insulator to HTLS Conductor.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Karad(400kv) -Nigade	IntraState	17/09/2020	09.38		Continued.	PO	Construction work
Uran - Jnpt	IntraState	18/09/2020	13.07		Continued.	PO	Removal of existing E/W and string of OPGW wire
Khadka-Bhadli-1	IntraState	18/09/2020	15.55	19/09/2020	01.48	T	Over Current E/F R Phase
Ghatghar - Jindal	IntraState	18/09/2020	18.06	19/09/2020	23.42	T	Distance Protection
Khadka-Bhadli-2	IntraState	19/09/2020	00.25	19/09/2020	01.05	T	Removal of broken e/w betw loc 17-21.
Nerul-Trombay	IntraState	19/09/2020	06.26	19/09/2020	19.26	PO	Pile foundation work by MMRDA.
Lonikand1 (400 Kv)-Theur II	IntraState	19/09/2020	07.16	19/09/2020	19.03	PO	Replacement of Existing 0.4 ACSR Conductor, hardware & Insulator by HTLS Conductor.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Sep/2020

Statement-VII

Position as on 6.30 Hrs of 20/Sep/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Eklahara(Gcr)(Nasik)- Bableshtar 2	IntraState	19/09/2020	08.30	19/09/2020	10.15	EO	Relay Testing(MICOM P442) After Online Replacement of Faulty Distance relay(ABB Rel 511).
220kv Halkarni- Tillary	IntraState	19/09/2020	09.25	19/09/2020	18.02	PO	Insulator Cleaning work.
satara MIDC- Malharpath	IntraState	19/09/2020	09.51	19/09/2020	16.50	PO	Replacement of Long Rod Polymer insulator strings near Vankuswade SS from Loc. No. 49 to 53 Vankuswade LILO portion.
Pophali - New Koyana	IntraState	19/09/2020	10.28	19/09/2020	14.33	PO	Attending Redhot of W.T. jumper at 220kV Pophali SS & Tree cutting work between Loc. 11-12-13.
Kamba - Kolshet	IntraState	19/09/2020	11.03	19/09/2020	17.27	PO	Safety Purpose for Jumper nut-bolt tightening and insulator replacement at loc no.130.
Jejuri-Phursungi ckt-2	IntraState	20/09/2020	02.02	20/09/2020	02.42	T	Distance Protection
Nerul-Trombay	IntraState	20/09/2020	06.32	20/09/2020	18.36	PO	Pile Foundation Work BY MMRDA.
Vankuswade - Kdph	IntraState	20/09/2020	09.05	20/09/2020	16.30	PO	Replacement of Long Rod Polymer Insulator String Near Vankuswade Ss From LOC.No.48.
Dhule-Chalisagaon	IntraState	20/09/2020	09.23	20/09/2020	20.39	PO	Jumpers Removed At LOC.NO. 97. For Line Reorientation.
Vasai Kamba	IntraState	20/09/2020	10.00	20/09/2020	15.45	PO	Insulator replacement work.
Dhule - Malegaon	IntraState	20/09/2020	10.23	20/09/2020	20.39	PO	Jumpers Removed At LOC.NO. 97. For Line Reorientation.
Butibori-Khaperkheda	IntraState	20/09/2020	13.50	20/09/2020	18.50	T	Distance Protection
Nanded-Parbhani	IntraState	20/09/2020	14.37	20/09/2020	15.02	T	Distance Protection
Phursungi-Serum	IntraState	20/09/2020	15.37	20/09/2020	22.56	T	LA CC bust.
Jejuri-Phursungi ckt-1	IntraState	20/09/2020	15.42	20/09/2020	16.18	T	over load (Due to tripping of 220KV JEJURI- SERUM tap Line.
JEJURI (400 Kv) - GIS KONDHWA	IntraState	20/09/2020	15.49	20/09/2020	16.08	T	over load (Due to tripping of 220KV JEJURI- SERUM tap Line.
220 KV ICT Outages/Trippings							
220/132 Kv 100mva lct 2 @South Solapur (Kumbhari)	IntraState	19/09/2020	16.25	19/09/2020	18.32	PO	CTR Fire protection work.
220/22kV 50MVA T/F-III @ Nalasopara	IntraState	20/09/2020	15.55	20/09/2020	16.55	EO	Commissioning Of Master trip relay on LV Panel.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage