

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Oct/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	119.947	2248.887	1) Gujrat	7.832	193.625
2) Hydro	11.982	161.146	2) Madhya Pradesh	4.198	122.576
3) Gas	2.194	42.136	3) Chattisgarh	5.350	102.840
Total MSPGCL	134.123	2452.169	4) Maharashtra	161.108	3051.564
B) 1) APLM	65.256	1006.537	5) Goa (Amona)	-1.275	-24.576
2) JSWEL	14.301	294.966	Total	177.213	3446.029
3) VIPL	0.000	0.000	a) Mumbai Schedule	37.808	637.303
4) RPL(AMT)	25.453	443.217	b) Mumbai Drawl	40.973	698.580
5) SWPGPL	7.497	138.482	c) MSEDCL Bilateral *	65.235	1265.281
6) Other IPP	9.664	146.604	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	37.808	637.291
C) 1) TPCL Thermal	11.468	194.195	Include PX	0.000	0.000
2) TPCL Hydro	4.596	76.735	Standby	0.000	0.012
3) TPCL Gas	2.568	47.168	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.029	178.975	1) MSEDCL	395.933	7438.724
D) STATE			2) Mumbai Discoms	68.634	1195.630
1) Thermal	262.615	4651.863	3) Other Discoms	9.414	175.022
(A1+C1+C4+(B1-B6))			TOTAL STATE	473.981	8809.376
2) Hydro	16.578	237.881			
(A2+C2)					
3) Gas	4.762	89.304			
(A3+B7+C3)					
4) Wind	2.220	203.938			
6) SOLAR	10.593	180.384			
TOTAL STATE	296.768	5363.370			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	4835	5240	5278	4887
MSPGCL Hydro	268	866	1889	224
MSPGCL Gas	91	88	88	95
MSPGCL Total Generation	5194	6194	7255	5206
Central Sector Receipt	8096	6803	7457	6369
WIND	55	89	99	119
CPP / IPP Thermal	4783	5862	5919	4735
CPP / IPP Gas	0	0	0	0
SOLAR	1175	77	3	0
Exchange with Mumbai	-1769	-1723	-1634	-1457
MSEDCL DEMAND MET	17088	16870	18666	14654
Load Shedding	0	0	0	0
MSEDCL DEMAND	17088	16870	18666	14654
TPCL GENERATION	920	1058	1120	586
AEML GENERATION	464	481	491	293
MUMBAI DEMAND	3153	3262	3245	2336
OTHER DISCOM DEMAND	446	433	433	318
STATE DEMAND MET	20687	20564	22344	17308
STATE DEMAND	20687	20564	22344	17308
Frequency (Hz)	50.00	49.92	49.96	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 13:01 Hrs	49.75 Hz at 18:12 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 19/Oct/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.44	35.09	165	120
Unit 7	0.00	0.00	0	0
Unit 8	10.85	143.12	488	403
Unit 9	0.00	59.24	0	0
Unit 10	9.69	183.90	425	384
Total	23.98	421.34		
Bhusawal				
Unit 3	0.00	32.53	0	0
Unit 4	8.80	150.62	420	285
Unit 5	0.00	145.12	0	0
Total	8.80	328.27		
Parli				
Unit 6	4.18	77.28	240	144
Unit 7	4.18	65.21	220	144
Unit 8	3.86	52.14	187	140
Total	12.21	194.64		
Chandrapur				
Unit 3	0.00	49.32	0	0
Unit 4	3.29	52.71	164	122
Unit 5	7.08	128.39	325	275
Unit 6	7.01	137.84	330	263
Unit 7	7.24	135.36	333	265
Unit 8	9.49	65.29	464	285
Unit 9	8.95	161.41	432	288
Total	43.07	730.32		
Paras				
Unit 3	4.48	78.37	206	157
Unit 4	0.00	0.00	0	0
Total	4.48	78.37		
Khaparkheda				
Unit 1	2.88	53.50	135	90
Unit 2	3.12	53.79	145	115
Unit 3	3.46	64.65	160	124
Unit 4	3.17	60.61	155	112
Unit 5	9.25	151.65	480	280
Total	21.88	384.20		
Nasik				
Unit 3	0.00	25.32	0	0
Unit 4	2.73	58.49	133	95
Unit 5	2.80	27.93	129	96
Total	5.53	111.75		
Uran				
All Units	2.19	42.14	95	87
Total	2.19	42.14		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.59	11.28	27	23
Total	0.59	11.28		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.22	40.46	530	35
Stage 4	3.15	35.71	798	0
Stage 3	1.33	18.52	240	0
Total	7.69	94.68		
Hydro				
KDPH	0.27	5.96	18	0
VTRNA	0.62	2.45	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.30	5.18	77	0
SMLHY_PTN	2.20	37.70	106	85
GHATGHAR	0.30	3.90	125	0
Total	3.70	55.18		
Wind				
Total	2.22	203.94	0	0
Total	2.22	203.94		
CPP				
APML(Mus)	65.26	1006.54	0	0
JSWEL(Mus)	14.30	294.97	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.45	443.22	0	0
SWPGPL-Mus	7.50	138.48	0	0
Other(Mus)	9.66	146.60	0	0
Total	122.17	2029.81		
SOLAR				
Total	10.59	180.38	0	0
Total	10.59	180.38		
Tata				
Trombay 5	7.84	123.73	466	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.44	26.51	106	36
Trombay 7B	1.13	20.66	64	33
TATA Hydro	4.60	76.74	429	20
Trombay 8	3.62	70.47	219	129
Total	18.63	318.10		
AEMIL				
DTPS U-1&2	9.03	178.98	499	291
Total	9.03	178.98		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	119.95	2248.89	MSPGCL Total	134.12	2452.17
			MSPGCL Thml+Gas	122.14	2291.02	Koyna 1,2 & 4 Total	6.36	76.16
			MSPGCL Hydro	11.98	161.15	State Total	296.77	5363.37

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 19/Oct/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4984	400	94	5478	140	4703	0	0	6462	6304	-1511	14776	0	14776	2552	338	17666	49.91
2	4887	224	95	5206	119	4735	0	0	6372	6369	-1457	14654	0	14654	2336	318	17308	49.97
3	5025	220	95	5340	120	4721	0	0	6316	6277	-1256	14911	0	14911	2187	291	17389	49.98
4	5024	186	95	5305	92	4781	0	0	6251	6426	-1153	15168	0	15168	2086	283	17537	49.98
5	5181	304	95	5580	64	5052	0	0	6218	6544	-1238	15702	0	15702	2060	300	18062	49.97
6	5300	259	95	5654	78	5522	0	0	6460	6948	-1265	16602	0	16602	2151	335	19088	49.98
7	5424	670	95	6189	58	5489	0	37	7197	7220	-1382	17236	0	17236	2287	376	19898	49.98
8	5350	426	95	5871	46	5535	0	313	8002	8152	-1584	17919	0	17919	2476	414	20809	50.01
9	5120	236	93	5449	51	5354	0	791	8182	7794	-1832	17171	0	17171	2804	436	20411	50.02
10	4835	268	91	5194	55	4783	0	1175	7814	8096	-1769	17088	0	17088	3153	446	20687	50.00
11	4584	266	90	4940	56	4592	0	1356	8088	8251	-1998	16764	0	16764	3380	434	20577	49.99
12	4370	327	89	4786	28	4264	0	1465	8158	8374	-2068	16420	0	16420	3442	428	20291	49.99
13	4601	277	88	4966	37	4374	0	1467	7841	7881	-2040	16251	0	16251	3394	435	20079	49.99
14	4460	233	87	4780	48	4235	0	1434	8273	8089	-2288	15876	0	15876	3262	423	19560	50.04
15	4568	225	87	4880	69	4388	0	1161	8430	8463	-2368	16177	0	16177	3306	416	19899	50.03
16	4840	207	87	5134	78	4727	0	897	8341	8164	-2325	16265	0	16265	3345	410	20020	50.03
17	5149	207	88	5444	125	5298	0	417	8037	7822	-2003	16665	0	16665	3313	438	20416	50.01
18	5240	866	88	6194	89	5862	0	77	7176	6803	-1723	16870	0	16870	3262	433	20564	49.92
19	5278	1889	88	7255	99	5919	0	3	6782	7457	-1634	18666	0	18666	3245	433	22344	49.96
20	5284	1813	90	7187	137	5895	0	0	6937	7189	-1377	18590	0	18590	3160	441	22191	50.03
21	5310	1017	91	6418	102	5585	0	0	7340	7493	-1629	17555	0	17555	3014	415	20983	50.01
22	5184	732	92	6008	141	5551	0	0	7047	7132	-1712	16710	0	16710	2876	410	19996	50.03
23	5117	474	93	5684	191	5583	0	0	6967	7043	-1698	16409	0	16409	2799	394	19602	50.00
24	4832	256	93	5181	197	5223	0	0	6979	6922	-1663	15492	0	15492	2744	368	18604	50.01
MUs	119.95	11.98	2.19	134.12	2.22	122.17	0.00	10.59	175.67	177.21	-40.97	395.93	0.00	395.93	68.63	9.41	473.98	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Oct/2022

Position as on 6.30 Hrs of 20/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	22/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	22/10/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High	20/10/2022
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	28/10/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	28/10/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-4	135	16/10/2022	14:55		Continued.	Lube oil Pressure Low due to AOP tripping	19/10/2022
MSPGCL	Chandrapur Unit 3	210	17/10/2022	07:28		Continued.	Boiler Tube Leakage	20/10/2022
MSPGCL	Bhusawal Unit 5	500	18/10/2022	10:00		Continued.	Boiler Tube Leakage	20/10/2022
MSPGCL	Koradi Unit 9	660	18/10/2022	17:15		Continued.	Boiler Tube Leakage	20/10/2022
MSPGCL	Koyna STG-IV Unit-1	250	19/10/2022	18:00	19/10/2022	19:50	GENERATOR BREAK PADS WORN OUT	19/10/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 20/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	19/10/2022	01:34	19/10/2022	05:55	EO	Emergency shutdown of HVDC Pole 1 - Base Filter Z11-Z1 & Z11-Z2 for attending the red hot observed at connecting jumper of capacitor bushing
400 KV TIEBAY Outages/Trippings							
TIE BREAKER (411) OF KORADI CKT 1 AND STATION TF-2 @ NANDGAONPETH	InterState	13/10/2022	11:42			EO	SF6 Gas Replenishment in Tie breaker (411) due to low SF6 Gas Alarm is coming intermittently and Density Monitor level is showing near alarm value.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	IntraState	19/10/2022	11:08	19/10/2022	14:46	PO	Routine maintenance & testing work
MAIN BAY (412) OF EKTUNI CKT - 2 @ TAPTITANDA	IntraState	19/10/2022	12:24	19/10/2022	14:30	PO	CB Diagnostic Testing
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	19/10/2022	10:28	19/10/2022	17:21	EO	While PID testing carried out, at loc no. 238 R PH String flashover observed, so please give permission for emergency outage on 400 KV Dhule-SSNNL-2 line. Load will manage on 400KV Dhule-SSNNL-1 line. 400 KV Dhule-SSNNL-1 line AR need to be shifted on Non-Auto mode.
KARAD - LONIKAND I	IntraState	10/10/2022	09:28			PO	1. Errection of 315A & 316 in line tower. 2. Loc no. 315 to 315A S/C stringing. 3. Loc no. 315A to 33(D/C LILO tower) stringing. 4. Loc No. 316 to 33(D/C LILO tower) stringing. 5. Dismantling of existing in line tower at loc no 316.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	11/10/2022	08:52	19/10/2022	06:28	HT	H/T FOR LOAD MANAGEMENT
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	18/10/2022	12:14			EO	The SF 6 Gas pressure of Y - phase & B-Phase live EMVT's of 400 KV Line Circuit -1 (NTPP-1) is not adequate and gone below the required pressure setting 5.5 KG/square CM The Outage required SF 6 Gas filling and maintenance of these EMVT's on top priority.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	18/10/2022	13:49	19/10/2022	16:53	HT	H/T TO CONTROL LINE LOADING OF PUNE-PUNE GIS
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	19/10/2022	14:42	19/10/2022	23:08	HT	H/T TO CONTROL LINE LOADING
400 KV ICT Outages/Trippings							
400/220/33 KV 315MVA ICT - 1 @ CHAKAN	IntraState	18/10/2022	23:45	19/10/2022	02:31	EO	For topping up oil in conservator tank of R phase unit.
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	19/10/2022	10:50	19/10/2022	18:26	PO	Diagnostic Testing Of Line CTs,Tie CTs & Tie CB DCRM
400/220 KV 167 MVA ICT @ PARLI	IntraState	19/10/2022	10:56	19/10/2022	17:37	PO	(1) Backup relay & Breaker testing work. (2) Bay maintenance work.
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	19/10/2022	12:21	19/10/2022	17:40	PO	1. Diagnostic Testing Work 2. Routine Maintenance Work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 20/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	IntraState	19/10/2022	23:50	20/10/2022	04:34	EO	1) Bph LV CT Hotspot attending work. 2) Rph HV Bushing hotspot attending work
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	19/10/2022	06:35	19/10/2022	09:37	EO	To attend hot-spot (Red hot) observed on 220 KV PG - Nalasopara line at Loc. 137 in Y phase.
EKLAHARE (OCR) - PADGHE	IntraState	08/10/2022	22:52			HT	For load management
BORIVALI - TARAPUR	IntraState	18/10/2022	09:21			PO	Conductor replacement work under Scheme from Loc No.19-28 (Yph & Bph).
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	19/10/2022	07:21	19/10/2022	22:12	HT	H/T FOR LOAD CONTROL
BIDRI - SAWANTWADI	IntraState	19/10/2022	09:02	19/10/2022	15:47	PO	Insulator Cleaning
GOREGAON - VERSOVA CKT - 1	IntraState	19/10/2022	09:03	19/10/2022	19:25	PO	Replacement of in-service polymer insulators with high creepage polymer insulators (VAB 1 to VAB). Also attending to hotspot is 4 locations.
BUS @ BARSHI	IntraState	19/10/2022	09:23	19/10/2022	13:07	PO	Outage is required for Quarterly Maintenance
NERLE- POPHALI	IntraState	19/10/2022	09:39	19/10/2022	18:15	PO	For replacement of flashover polymer string at loc no. 73A, 74A both are Y-ph.
MHAISHAL- JATH	IntraState	19/10/2022	10:10	19/10/2022	13:02	PO	Jump Nut Bolt fixing work at Loc No.212 R Y B Ph
LAMBOTI - KARKAMB	IntraState	19/10/2022	10:35	19/10/2022	14:50	PO	Outage is required for Quarterly Maintenance
TILLARI - AMONA LINE	IntraState	19/10/2022	11:03	19/10/2022	16:35	PO	Annual maintenance work
BAPGAON - KALWA	IntraState	19/10/2022	11:25	19/10/2022	14:30	EO	Shifting of 220KV Bapgaon-Kalwa line on TBC Bay for own 245Kv CB Y Phase top palm nut-bolt hotspot attending work.
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 2	IntraState	19/10/2022	11:54	19/10/2022	14:22	PO	Outage is required for Quarterly Maintenance
ACCIL - APTA	IntraState	19/10/2022	12:37	19/10/2022	18:35	PO	Attending hot spot at Loc No. 537, 568, 542 & Apta S/Sn Gantry
MHAISHAL - SHEDYAL	IntraState	19/10/2022	13:17	19/10/2022	15:30	PO	Jump Nut Bolt fixing work at Loc no.212 R Y B Ph
LAMBOTI - SOLAPUR 2(BALE) CKT- 2	IntraState	19/10/2022	14:59	19/10/2022	17:26	PO	Outage is required for Quarterly Maintenance
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	20/10/2022	02:03			T	Tripped on Dist. Protection, Ph-Ph fault
BAPGAON - KALWA	IntraState	20/10/2022	04:53			EO	To attend Hot spot at Loc No. 390.
WALCHANDNAGAR-LONI DEOKAR	IntraState	20/10/2022	06:12	20/10/2022	07:06	T	Tripped on dist. protection at Walchandnagar end only
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/100 KV 200 MVA ICT 2 @ KOLSHET	IntraState	19/10/2022	10:08	19/10/2022	15:41	PO	1) Diagnostic testing work i.e CT TAN DELTA, BUSHING TAN DELTA, CB TIMMING & CRM, 2) Arresting of Oil leakage. 3) Testing work 4) Bay maintenance &RMW 5) Equipment Painting.
220/132kv 100MVA ICT - 2 @ KALWAN	IntraState	19/10/2022	10:35	19/10/2022	15:41	PO	For ICT-2 220kV Auxiliary Isolator HV/LV Line Isolator alignment work by Agency.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 20/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 3 @ LONIKAND	IntraState	19/10/2022	11:10	19/10/2022	16:33	PO	Transformer OLTC overhauling work to be carried out.
220/22 KV 50 MVA PTR 3 @ MAHAD	IntraState	19/10/2022	11:12	19/10/2022	17:24	PO	22 Kv LV LA (R-Y-B) replacement work & diagnostic testing work.
220/132 KV 200MVA ICT NO 2 @ THEUR	IntraState	19/10/2022	11:44	19/10/2022	17:37	PO	Half yearly maintenance and diagnostic testing work.
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ URAN	IntraState	19/10/2022	10:05	19/10/2022	18:16	PO	For MAIN BUS insulator string replacement work.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage