

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Oct/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.517	2917.033	1) Gujrat	3.504	185.222
2) Hydro	19.099	341.188	2) Madhya Pradesh	9.070	121.662
3) Gas	6.805	112.470	3) Chattisgarh	6.200	82.640
Total MSPGCL	166.421	3370.691	4) Maharashtra	259.399	3791.506
B) 1) APMIL	74.161	1206.188	5) Goa (Amona)	-1.913	-30.437
2) JSWEL	28.304	488.845	Total	276.260	4150.593
3) VIPL	0.000	0.000	a) Mumbai Schedule	41.123	684.196
4) RPL(AMT)	25.160	498.093	b) Mumbai Drawl	44.969	764.068
5) SWPGPL	6.349	146.989	c) MSEDCL Bilateral *	137.714	1808.734
6) Other IPP	5.702	98.769	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	41.072	683.049
C) 1) TPCL Thermal	13.730	261.789	Include PX	0.000	0.000
2) TPCL Hydro	4.609	92.347	Standby	0.051	1.147
3) TPCL Gas	1.121	41.503	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.074	189.870	1) MSEDCL	543.020	9443.586
D) STATE			2) Mumbai Discoms	75.503	1349.577
1) Thermal	304.997	5807.576	3) Other Discoms	10.468	196.046
(A1+C1+C4+(B1-B6))			TOTAL STATE	628.991	10989.209
2) Hydro (A2+C2)	23.708	433.535			
3) Gas (A3+B7+C3)	7.926	153.973			
4) Wind	2.949	148.879			
6) SOLAR	13.151	294.653			
TOTAL STATE	352.731	6838.616			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 14 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5756	5854	6061	5684
MSPGCL Hydro	902	273	2077	134
MSPGCL Gas	279	273	281	288
MSPGCL Total Generation	6937	6400	8419	6106
Central Sector Receipt	12722	13475	10574	11174
WIND	79	93	161	85
CPP / IPP Thermal	5611	5219	5771	6076
CPP / IPP Gas	0	0	0	0
SOLAR	1847	1704	6	0
Exchange with Mumbai	-2557	-2372	-1852	-1557
MSEDCL DEMAND MET	24175	24058	22593	21539
Load Shedding	0	0	0	0
MSEDCL DEMAND	24175	24058	22593	21539
TPCL GENERATION	592	681	1161	540
AEML GENERATION	393	474	470	491
MUMBAI DEMAND	3542	3527	3483	2588
OTHER DISCOM DEMAND	464	461	486	345
STATE DEMAND MET	28181	28046	26562	24472
STATE DEMAND	28181	28046	26562	24472
Frequency (Hz)	50.00	50.05	49.89	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 13.01 Hrs	49.72 Hz at 18.23 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 19/Oct/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.42	75.88	190	175
Unit 8	0.00	209.26	0	0
Unit 9	15.23	247.36	660	572
Unit 10	0.00	197.17	0	0
Total	19.65	729.66		
Bhusawal				
Unit 3	2.57	55.82	120	90
Unit 4	9.56	156.46	455	360
Unit 5	9.48	165.06	475	350
Total	21.62	377.34		
Parli				
Unit 6	5.51	92.21	243	185
Unit 7	4.22	78.38	248	0
Unit 8	4.48	75.84	224	147
Total	14.20	246.43		
Chandrapur				
Unit 3	2.55	46.21	140	81
Unit 4	2.99	52.19	151	0
Unit 5	0.00	34.06	0	0
Unit 6	8.44	118.54	366	330
Unit 7	7.08	129.51	333	260
Unit 8	10.54	196.77	470	405
Unit 9	10.42	199.36	472	379
Total	42.01	776.64		
Paras				
Unit 3	5.34	93.60	240	207
Unit 4	5.31	96.86	241	171
Total	10.65	190.46		
Khaparkheda				
Unit 1	3.98	68.76	180	145
Unit 2	2.25	42.55	132	63
Unit 3	4.22	61.52	184	166
Unit 4	3.97	65.48	180	134
Unit 5	10.96	202.86	470	439
Total	25.39	441.18		
Nasik				
Unit 3	0.00	37.94	0	0
Unit 4	3.81	60.46	170	148
Unit 5	3.20	56.92	142	126
Total	7.01	155.31		
Uran				
All Units	6.80	112.47	291	273
Total	6.80	112.47		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.40	15.74	47	0
Total	0.40	15.74		
Koyna				
Stage 1-2	4.28	74.14	530	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	8.52	142.23	1002	0
Stage 3	2.65	47.28	240	0
Total	15.45	263.65		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.65	0	0
TILLARI	0.51	2.79	60	0
BHIRA T.R.	0.30	6.12	77	0
SMLHY_PTN	2.22	47.73	95	88
GHATGHAR	0.22	4.52	108	0
Total	3.25	61.80		
Wind				
Total	2.95	148.88	0	0
Total	2.95	148.88		
CPP				
APML(Mus)	74.16	1206.19	0	0
JSWEL(Mus)	28.30	488.84	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.16	498.09	0	0
SWPGPL-Mus	6.35	146.99	0	0
Dhariwal	0.00	0.00	0	0
IEPL	3.69	61.14	267	0
Other(Mus)	0.46	6.60	0	0
JPL	1.55	31.03	123	0
Total	139.68	2438.88		
SOLAR				
Total	13.15	294.65	0	0
Total	13.15	294.65		
Tata				
Trombay 5	9.09	174.05	454	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.79	23.39	106	0
Trombay 7B	0.33	18.11	42	0
TATA Hydro	4.61	92.35	432	57
Trombay 8	4.64	87.74	217	143
Total	19.46	395.64		
AEML				
DTPS U-1&2	11.07	189.87	501	363
Total	11.07	189.87		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.52	2917.03	MSPGCL Total	166.42	3370.69
			MSPGCL Thml+Gas	147.32	3029.50	Koyna 1,2 & 4 Total	12.80	216.37
			MSPGCL Hydro	19.10	341.19	State Total	352.73	6838.62

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Oct/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5813	425	288	6526	93	6066	0	0	10777	10942	-1656	21577	0	25	21577	3054	394	25025	49.95
2	5762	185	290	6237	120	6078	0	0	11248	11056	-1614	21505	0	17	21505	2795	372	24672	50.00
3	5684	134	288	6106	85	6076	0	0	11213	11174	-1557	21539	0	16	21539	2588	345	24472	49.99
4	5591	134	290	6015	87	6024	0	0	11487	11521	-1484	21824	0	1	21824	2458	339	24621	50.00
5	5633	134	288	6055	91	6062	0	0	11828	11697	-1346	22210	0	4	22210	2413	349	24972	49.99
6	5740	137	290	6167	141	6089	0	0	11987	12038	-1072	22980	0	26	22980	2460	383	25823	49.98
7	5817	961	291	7069	147	6087	0	48	11209	11224	-1094	23067	0	49	23067	2548	414	26029	49.95
8	5773	1264	290	7327	171	6053	0	406	11040	11020	-1431	23115	0	13	23115	2675	431	26221	50.02
9	5796	664	289	6749	114	6013	0	936	11423	11688	-1908	23135	0	46	23135	2967	457	26559	49.98
10	5763	590	286	6639	87	5814	0	1437	12302	12442	-2344	23601	0	200	23601	3295	474	27370	49.95
11	5756	902	279	6937	79	5611	0	1847	12738	12722	-2557	24175	0	182	24175	3542	464	28181	50.00
12	5772	465	276	6513	61	5448	0	1975	13219	12829	-2436	23923	0	174	23923	3612	467	28002	50.02
13	5845	221	273	6339	71	5268	0	1860	13395	13140	-2408	23812	0	123	23812	3605	458	27875	50.05
14	5854	273	273	6400	93	5219	0	1704	13272	13475	-2372	24058	0	45	24058	3527	461	28046	50.05
15	5840	328	274	6442	86	5519	0	1464	13615	13381	-2491	23937	0	180	23937	3641	464	28042	49.98
16	5823	718	275	6816	110	5678	0	909	13467	13134	-2411	23762	0	133	23762	3721	474	27957	49.97
17	5859	1736	274	7869	125	5689	0	464	11839	11478	-2176	22981	0	65	22981	3656	468	27105	49.89
18	5921	1979	275	8175	164	5763	0	95	10563	10323	-1864	22182	0	0	22182	3519	474	26175	49.87
19	6061	2077	281	8419	161	5771	0	6	10399	10574	-1852	22593	0	0	22593	3483	486	26562	49.89
20	6087	1423	285	7795	168	5863	0	0	11023	10996	-1793	22552	0	0	22552	3394	477	26423	50.04
21	6045	1111	287	7443	131	5797	0	0	10719	9854	-1827	20921	0	0	20921	3252	477	24650	50.05
22	6041	1096	284	7421	138	5644	0	0	10186	9813	-1785	20766	0	0	20766	3114	465	24345	50.04
23	6122	1050	289	7461	183	5959	0	0	9866	9556	-1627	21080	0	0	21080	3085	452	24617	49.98
24	6119	1091	290	7500	243	6085	0	0	10249	10184	-1864	21726	0	0	21726	3099	422	25247	49.97
MUs	140.52	19.10	6.80	166.42	2.95	139.68	0.00	13.15	279.06	276.26	-44.97	543.02	0.00	1.30	543.02	75.50	10.47	628.99	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR carried out due to 132kv sangamner-BBLR line over load.
Lonand-jejuri line overloading.

2)FLS done due to 220kv

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 19/Oct/2023

Position as on 6.30 Hrs of 20/Oct/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
IPP	SWPGPL U-4	135	29/09/2023	00:03		Continued.	Turbine Bearing no.4 temperature high	20/10/2023
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	10/10/2023	23:56		Continued.	Electrostatic precipitator problem	26/10/2023
MSPGCL	Chandrapur Unit 5	500	11/10/2023	08:12		Continued.	Turbine Vibration High.	27/10/2023
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	20/11/2023
MSPGCL	Koradi Unit-10	660	14/10/2023	22:19		Continued.	Boiler Tube Leakage	20/10/2023
MSPGCL	Koradi Unit 8	660	16/10/2023	10:40		Continued.	Boiler Tube Leakage	21/10/2023
MSPGCL	Nasik Unit 3	210	17/10/2023	21:16		Continued.	Heavy Hunting in CVSM	20/10/2023
MSPGCL	Parli Unit 7	250	18/10/2023	20:45	19/10/2023	04:17	Station T/F Fail	
MSPGCL	Chandrapur Unit 4	210	18/10/2023	21:34	19/10/2023	02:54	Excitation system problem	19/10/2023
TPC-G	Trombay 7B	60	19/10/2023	02:07	19/10/2023	17:15	Gas shortage	
TPC-G	Trombay 7A	120	19/10/2023	02:25	19/10/2023	13:06	Gas shortage	
IPP	JPL Unit 1	150	19/10/2023	10:08	19/10/2023	16:55	bFP tripped	
IPP	IEPL Unit 1	270	19/10/2023	10:17	19/10/2023	19:38	PA Fan problem	
MSPGCL	Ghatghar Unit-2	125	19/10/2023	16:25	19/10/2023	18:25	GM LINK FAULT	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 19/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 20/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2	IntraState	19/10/2023	11:53	19/10/2023	19:10	PO	Annual Bay Maintenance
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT-2 @ EKTUNI	IntraState	18/10/2023	22:48	19/10/2023	03:26	EO	To attend the hotspot on Neutral Bushing Jumper Conductor (Jumper conductor between Neutral Bushing and IPS Tube connecting Neutral CT) of R-ph Unit of 1500MVA ICT-2 (Temp=136 deg.C).
765/400kV 1500MVA ICT-2 @ EKTUNI	IntraState	18/10/2023	23:10	19/10/2023	03:26	EO	TO ATTEND THE HOTSPOT ON NEUTRAL BUSHING JUMPER CONDUCTOR (JUMPER CONDUCTOR BETWEEN NEUTRAL BUSHING AND IPS TUBE CONNECTING NEUTRAL CT) OF R-PH UNIT OF 1500MVA ICT-2 (TEMP=136 DEG.C).
765/400kV 1500MVA ICT-2 @ EKTUNI	IntraState	18/10/2023	23:10	19/10/2023	03:26	EO	TO ATTEND THE HOTSPOT ON NEUTRAL BUSHING JUMPER CONDUCTOR (JUMPER CONDUCTOR BETWEEN NEUTRAL BUSHING AND IPS TUBE CONNECTING NEUTRAL CT) OF R-PH UNIT OF 1500MVA ICT-2 (TEMP=136 DEG.C).
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
220 KV BUS COUPLER	IntraState	19/10/2023	09:36	19/10/2023	12:17	PO	Routine maintenance work.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
LONIKAND I - TALEGAON (PGCIL)	InterState	19/10/2023	19:59	20/10/2023	02:39	T	Tripped on distance protection
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\Delta Y \Delta$ phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/10/2023	08:04			HT	H/T for load management.
BABHALESHWAR - PADGHE CKT - 2	IntraState	16/10/2023	07:21	19/10/2023	13:10	PO	CB pole overhauling work
220 KV DEEPNAGAR (400 KV) - VIRODA CKT	IntraState	19/10/2023	17:55	19/10/2023	21:09	PO	For attending red hot spot.
NEW KOYNA-KARAD CKT - 2	IntraState	20/10/2023	09:16			PO	Diagnostic testing & Relay testing work , Routine maint. Work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220kV SPARE ICT @ JEJURI	IntraState	19/10/2023	10:46	19/10/2023	17:19	PO	For WRM kit demo
400/220/33 KV 500 MVA ICT - 2 @ NANDED	IntraState	19/10/2023	11:52	19/10/2023	17:14	PO	Tan-d of CT's, Bay Maintenance (Oil leakage attending works)
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	19/10/2023	12:10	19/10/2023	21:26	PO	IV (220 kV) Circuit Breaker Overhauling work.
220 KV TBC Outages/Trippings							
TBC @ Vile - bhagad-220 KV	IntraState	20/10/2023	09:45			PO	Diagnostic testing work.
220 KV LINE Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 19/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 20/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - PADGHE	IntraState	06/10/2023	07:37			HT	Kept Handtripped from padghe end for load managment
HALKARNI-OLAM AGRO (HEMRUS) LINE	IntraState	19/10/2023	09:44	19/10/2023	20:35	PO	SF6 Circuit breaker erecting & commissioning works at Olam end
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	19/10/2023	10:10	19/10/2023	12:02	PO	Outage is required for CT tan delta & maintenance work
WPCL-WARORA 1	IntraState	19/10/2023	11:09	19/10/2023	17:34	PO	For protecting relay testing work.
BHIGWAN - WALCHAND NAGAR	IntraState	19/10/2023	12:00	19/10/2023	19:02	PO	Replacement of disc insulator strings of R,Y and B Phase at loc no-78 and cold line cleaning and washing of R, Y & B phase disc insulator string from loc no-50 to 90.
WALCHANDNAGAR-LONI DEOKAR	IntraState	19/10/2023	12:07	19/10/2023	19:07	PO	Loc. no-78 is of M/C type tower. top circuit is 220 kV Bhigwan Walchandnagar and below that 220 kV Walchandnagar Loni deokar line. to carry work of Top circuit it should be essential to keep the lower circuit off state.
DAHANU - GHODBUNDER CKT - 1	IntraState	20/10/2023	06:15			PO	OPGW laying work for NHRCL Project work.
LONIKAND 2 - BHOSARI	IntraState	20/10/2023	09:40			PO	Lonikand-II Bay CB mechanism Overhauling work by M/S Siemens
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 200 MVA ICT 1 @ BORIVALI	IntraState	12/10/2023	10:19			PO	For replacement of various EHV equipments under LE Scheme. The old EHV equipments are to be replaced under LE Scheme whose details are as given below - 1. 220 kV Circuit Breaker - 1 No. 2. 220 kV Lightning Arrestors - 3 Nos. 3. 100 kV Potential Transformers - 6 Nos. 4. 100 kV Isolators - 9 Nos. Also the Anti Corrosive Painting of ICT-1 will be carried out in this outage.
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	19/10/2023	10:39	19/10/2023	18:55	PO	1) Preventive Maintenance of CTR Make NIFPS & Testing & Checking the Healthiness by M/s CTR 2) Bay Routine Maintenance Work 3) Inspection of oil leakage from ICT
100 MVA 220/132 KV ICT 2	IntraState	19/10/2023	12:25	19/10/2023	13:48	PO	To measure HV side Y-Ph bushing tan delta tp check its progress.
220/33kV 50MVA TF-1 @ KOPARGAON	IntraState	19/10/2023	16:00	19/10/2023	19:00	PO	To attend & check LV BKR TC -1 faulty alarm and bay maintenance work.
220/110 kV 200 MVA ICT 2 @ MUDSHINGI	IntraState	20/10/2023	10:11			PO	Quarterly maintenance work
220 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Oct/2023

Statement-VII

Position as on 6.30 Hrs of 20/Oct/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
220 kV Hybrid Switchgear	IntraState	19/10/2023	12:28	19/10/2023	13:31	PO	SF6 gas refilling/top up in Y-ph pole CB of 245kV Hybrid GIS Bus Sectionalizer bay by M/s CGL team.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
NERAL - AMBERNATH	IntraState	20/10/2023	06:46	20/10/2023	08:25	PO	TREE TRIMMING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage