

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Nov/2019 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	126.319	2056.252	1) Gujrat	4.092	57.221
2) Hydro	12.143	158.141	2) Madhya Pradesh	12.076	159.485
3) Gas	10.293	159.913	3) Chattisgarh	6.720	124.920
Total MSPGCL	148.755	2374.306	4) Maharashtra	115.201	2135.757
B) 1) APMIL	74.023	1329.639	5) Goa (Amona)	-0.682	-9.394
2) JSWEL	18.255	371.248	Total	137.407	2467.989
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.166	485.216
4) RPL(AMT)	0.000	49.977	b) Mumbai Drawl	28.004	543.120
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	25.879	471.894
6) Other IPP	8.711	150.758	Include PX	-1.361	-5.313
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.166	485.216
C) 1) TPCL Thermal	14.311	255.378	Include PX	6.324	164.144
2) TPCL Hydro	4.479	73.510	Standby	0.000	0.000
3) TPCL Gas	4.359	80.193	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.429	188.400	1) MSEDCL	371.170	6446.891
D) STATE			2) Mumbai Discoms	61.582	1140.596
1) Thermal	252.048	4401.652	TOTAL STATE	432.752	7587.487
(A1+C1+C4+(B1-B6))					
2) Hydro	16.622	231.651			
(A2+C2)					
3) Gas	14.652	240.106			
(A3+B7+C3)					
4) Wind	6.475	142.036			
6) SOLAR	5.548	104.058			
TOTAL STATE	295.345	5119.503			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5379	5614	5454	4788
MSPGCL Hydro	411	142	1325	66
MSPGCL Gas	410	406	423	438
MSPGCL Total Generation	6200	6162	7202	5292
Central Sector Receipt	6936	6874	6030	4446
WIND	196	157	268	459
CPP / IPP Thermal	4404	4343	4435	3748
CPP / IPP Gas	0	0	0	0
SOLAR	874	874	0	0
Exchange with Mumbai	-1423	-1483	-1272	-821
MSEDCL DEMAND MET	17187	16927	16663	13124
Load Shedding	0	0	0	0
MSEDCL DEMAND	17187	16927	16663	13124
TPCL GENERATION	1150	1047	1223	674
AEML GENERATION	497	497	499	375
MUMBAI DEMAND	3070	3027	2994	1870
STATE DEMAND MET	20257	19954	19657	14994
STATE DEMAND	20257	19954	19657	14994
Frequency (Hz)	50.01	49.99	50.04	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 17.03 Hrs	49.71 Hz at 07.15 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 19/Nov/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.07	209.71	535	460
Unit 9	0.00	190.34	0	0
Unit 10	11.73	185.32	520	460
Total	23.80	585.37		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.16	177.48	500	350
Unit 5	10.22	179.48	500	350
Total	20.38	356.96		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.26	38.31	250	190
Unit 7	5.27	38.03	249	166
Unit 8	4.86	38.83	215	190
Total	15.39	115.17		
Chandrapur				
Unit 3	3.78	62.08	190	125
Unit 4	2.75	3.48	150	94
Unit 5	8.74	137.26	385	330
Unit 6	9.98	151.88	465	360
Unit 7	0.00	0.00	0	0
Unit 8	9.94	188.12	485	360
Unit 9	9.18	174.68	460	320
Total	44.39	717.50		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	4.24	20.50	200	158
Unit 4	3.89	26.71	195	0
Unit 5	10.10	161.13	500	356
Total	18.22	208.34		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.14	68.01	191	152
Unit 5	0.00	4.91	0	0
Total	4.14	72.92		
Uran				
All Units	10.29	159.91	458	403
Total	10.29	159.91		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.20	5.57	53	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.20	5.57		
Koyna				
Stage 1-2	4.10	53.64	430	35
Stage 4	5.04	53.14	957	0
Stage 3	2.17	23.81	240	0
Total	11.31	130.60		
Hydro				
KDPH	0.00	1.01	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	1.61	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.26	5.35	80	0
RNGR+BHTSA	0.40	5.45	17	16
BHANDARDRA	0.00	0.19	0	0
ELDARY	0.00	4.71	0	0
SMLHY_PTN	0.00	3.87	0	0
GHATGHAR	0.18	5.36	125	0
Total	0.83	27.54		
Wind				
Total	6.48	142.04	0	0
Total	6.48	142.04		
CPP				
APML(Mus)	74.02	1329.64	0	0
JSWEL(Mus)	18.26	371.25	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	49.98	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.71	150.76	0	0
Total	100.99	1901.62		
SOLAR				
Total	5.55	104.06	0	0
Total	5.55	104.06		
Tata				
Trombay 5	9.61	164.95	483	294
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	50.82	117	114
Trombay 7B	1.58	29.37	67	65
Trombay 8	4.70	90.42	199	193
TATA Hydro	4.48	73.51	411	0
Total	23.15	409.08		
AEML				
DTPS U-1&2	10.43	188.40	502	372
Total	10.43	188.40		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	126.32	2056.25	MSPGCL Total	148.76	2374.31
			MSPGCL Thml+Gas	136.61	2216.16	Koyna 1,2 & 4 Total	9.14	106.78
			MSPGCL Hydro	12.14	158.14	State Total	295.34	5119.50

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Nov/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4779	51	434	5264	510	3737	0	0	4951	4744	-1165	13090	0	13090	2269	15359	50.00
2	4791	51	437	5279	478	3694	0	0	4684	4632	-1016	13067	0	13067	2087	15154	50.00
3	4796	56	458	5310	461	3725	0	0	4365	4607	-886	13217	0	13217	1966	15183	49.99
4	4788	66	438	5292	459	3748	0	0	4292	4446	-821	13124	0	13124	1870	14994	50.00
5	4813	116	439	5368	431	3777	0	0	4686	4908	-799	13685	0	13685	1853	15538	49.99
6	5261	214	448	5923	380	4248	0	0	5249	5324	-875	15000	0	15000	1922	16922	49.96
7	5554	1287	447	7288	352	4329	0	8	5352	5409	-821	16565	0	16565	2062	18627	49.92
8	5677	1559	440	7676	344	4374	0	135	5419	5464	-801	17192	0	17192	2206	19398	49.93
9	5706	792	446	6944	263	4384	0	386	5656	5725	-924	16778	0	16778	2477	19255	50.01
10	5655	289	432	6376	244	4388	0	624	6012	6090	-1182	16540	0	16540	2775	19314	49.99
11	5441	376	425	6242	187	4387	0	816	6575	6625	-1411	16846	0	16846	2993	19839	50.01
12	5379	411	410	6200	196	4404	0	874	6875	6936	-1423	17187	0	17187	3070	20257	50.01
13	5614	142	406	6162	157	4343	0	874	6731	6874	-1483	16927	0	16927	3027	19954	49.99
14	5673	172	414	6259	122	4325	0	727	6649	6840	-1547	16726	0	16726	2935	19661	50.01
15	5682	514	403	6599	77	4320	0	541	6757	6717	-1474	16780	0	16780	3001	19781	49.96
16	5702	754	403	6859	66	4325	0	351	6550	6517	-1290	16828	0	16828	3038	19866	49.92
17	5460	1331	426	7217	83	4333	0	189	6035	5998	-1249	16571	0	16571	3018	19589	49.95
18	5385	1316	412	7113	146	4409	0	23	5776	5839	-1214	16316	0	16316	2974	19290	50.01
19	5454	1325	423	7202	268	4435	0	0	5905	6030	-1272	16663	0	16663	2994	19657	50.04
20	5474	443	426	6343	276	4354	0	0	5946	5991	-1172	15792	0	15792	2861	18653	50.03
21	4858	277	420	5555	261	4345	0	0	5631	5804	-1307	14658	0	14658	2707	17365	50.01
22	4800	247	442	5489	257	4391	0	0	5342	5494	-1284	14347	0	14347	2575	16922	50.02
23	4809	172	430	5411	212	4351	0	0	5404	5306	-1313	13966	0	13966	2500	16466	50.00
24	4768	182	434	5384	245	3863	0	0	5278	5087	-1275	13304	0	13304	2402	15706	49.96
MUs	126.32	12.14	10.29	148.76	6.48	100.99	0.00	5.55	136.12	137.41	-28.00	371.17	0.00	371.17	61.58	432.75	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Nov/2019

Position as on 6.30 Hrs of 20/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
MSPGCL	Nasik Unit 4	210	20/11/2019	04.15		Continued.	ID Fan Problem(Converted for Zero Schedule from 05.00hrs DT. 21-11-2019 and Continued for Annual Overhaul From 01.12.2019	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	02/11/2019	10.35	20/11/2019	01.46	Boiler Tube Leakage(Converted to Zero Schedule from 19.05Hrs DT.03-11-2019)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Nov/2019

Position as on 6.30 Hrs of 20/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	06/11/2019	19.23		Continued.	Turbine Vibration	
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	JSW (J) U3	300	10/11/2019	18.16		Continued.	Zero schedule.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 9	660	17/11/2019	19.00		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	19/11/2019	16.47	19/11/2019	18.07	Generator Protection operated	
MSPGCL	Khaparkheda Unit 3	210	20/11/2019	07.41		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 19/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 20/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Tirora ckt-II	IntraState	20/11/2019	09.22	20/11/2019	17.12	PO	Replacement of Line 2 Reactor.
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	20/11/2019	18.09		Continued.	PO	Annual Maintenance & Diagnostic Testing Work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	18/11/2019	20.38		Continued.	HT	Over Voltage
Dhule(MS)- Dhule(BDTCL) -I	InterState	19/11/2019	10.03	20/11/2019	09.31	PO	Routine Maintenance work(RFC at 20.05Hrs)
Dhule(MS)- Dhule(BDTCL) -II	InterState	20/11/2019	10.10	20/11/2019	17.05	PO	Routine Maintenance Work
Jaigad-Karad Ckt-II	IntraState	15/11/2019	23.48	19/11/2019	09.10	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	18/11/2019	22.00	19/11/2019	09.00	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	19/11/2019	06.01	20/11/2019	09.52	PO	Replacement of CVT In R-Phase, CB DCRM, Timing, Mechanism Timing.
Khadka-Aurangabad (Waluj)	IntraState	19/11/2019	20.27	20/11/2019	08.25	HT	Over Voltage
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	20/11/2019	09.41	20/11/2019	12.43	PO	Replacement Work At AMEL End.
Bhusawal-Aurangabad	IntraState	20/11/2019	19.52		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220 kv 500 MVA ICT III @ Jejuri	IntraState	19/11/2019	07.42	19/11/2019	23.19	PO	Single ro twin conductor conversion work
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	20/11/2019	10.50	20/11/2019	13.54	PO	CB & CT Diagnostic Testing Work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Trombay - Mulund	IntraState	16/11/2019	19.59		Continued.	PO	Piling work At LOC 5 Completed.
Karad(400kv) -Nigade	IntraState	18/11/2019	09.58	19/11/2019	17.33	PO	Routine Maintenance Work
Koradi-Khaperkheda	IntraState	18/11/2019	11.12		Continued.	HT	Over Voltage
Nagothane-Wadkhal-I	IntraState	19/11/2019	08.33	19/11/2019	19.19	PO	Replacement of Conductor
Koradi-Ambazari-I	IntraState	19/11/2019	08.48	19/11/2019	17.36	PO	Disc Replacement work
Miraj-Ichalkaranji I	IntraState	19/11/2019	08.58	19/11/2019	16.55	PO	Stringing of 220KV Miraj Tilwani Ckt-II
Mahad-Kandalgaon	IntraState	19/11/2019	09.00	19/11/2019	20.30	PO	Flashover Insulator string replacement
Pedambe-Pophali	IntraState	19/11/2019	09.35	19/11/2019	10.50	EO	To attend CT Oil Leakage
Satara (MIDC)-Ajinkyatara	IntraState	19/11/2019	10.07	19/11/2019	14.32	PO	Tan Delta Measurment of CTs
Hinganghat - Bhugaon	IntraState	19/11/2019	10.27	19/11/2019	17.14	PO	Routine Maintenance Work
Aurangabad PG (Chitepimpalgaon)-Shedra I	IntraState	19/11/2019	10.59	19/11/2019	16.54	PO	Line Maintenance work
Pusad - Hingoli	IntraState	19/11/2019	11.42	19/11/2019	14.32	PO	Pilot Insulator String at Tap line
Paras-Chikhali Ckt No-I	IntraState	19/11/2019	11.45	19/11/2019	11.57	HT	To Facilitate outage of Akola ICT
Paras-Chikhali Ckt No-II	IntraState	19/11/2019	11.46	19/11/2019	11.58	HT	To Facilitate outage of Akola ICT
Raymond - Washala	IntraState	19/11/2019	14.07	19/11/2019	17.28	EO	To attend Hot Spot

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 20/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
satara MIDC- Malharpeth	IntraState	19/11/2019	14.43	19/11/2019	17.01	PO	Quarterly Maintenance Work
Waluj - Chitegaon li	IntraState	19/11/2019	20.39	20/11/2019	04.39	T	Backup Protection
Trombay MSETCL Tie 1	IntraState	19/11/2019	21.32	20/11/2019	06.58	PO	Strengthening of RCC Beam alongwith Bus Section-III at Trombay
Nagothane-Wadkhal II	IntraState	20/11/2019	08.18	20/11/2019	19.20	PO	Replacement of Conductor.
Khaparkheda-Ambazari-li	IntraState	20/11/2019	09.09	20/11/2019	13.55	PO	SSN To DSN Conversion Work.
Kandalgaon - Koyna (Pophali)	IntraState	20/11/2019	09.10	20/11/2019	18.37	PO	Tree Cutting and Jumper Nut Bolt Tightening.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	20/11/2019	09.18	20/11/2019	18.54	PO	Overhauling of CB.
Peth- Mudshingi -I	IntraState	20/11/2019	10.08	20/11/2019	18.50	PO	Stringing of Earthwire.
TBC @ Parli-II	IntraState	20/11/2019	10.20	20/11/2019	13.00	PO	CR CRM and Timing Measurement.
AKOLA ANJANGAON (VIHIGAON) CKT-II	IntraState	20/11/2019	10.57	20/11/2019	19.15	PO	Diagnostic Testing Work, Timing of IP and PL.
Jamde-Dondaicha 1	IntraState	20/11/2019	11.06	20/11/2019	14.16	PO	Annual Diagnostic and Maintenance Work.
Osmanabad - Barshi	IntraState	20/11/2019	12.00	20/11/2019	15.53	PO	Replacement of Flashover Suspension String.
Miraj - Mhaishal	IntraState	20/11/2019	12.15	20/11/2019	16.40	PO	Testing Work
Jamde-Dondaicha 2	IntraState	20/11/2019	16.18	20/11/2019	16.29	PO	Annual Diagnostic and Maintenance Work.
Valve-Jamde	IntraState	20/11/2019	16.38	20/11/2019	18.02	PO	Diagnostic Testing Work.
Trombay MSETCL Tie 1	IntraState	20/11/2019	21.28		Continued.	PO	Construction Work.
220 KV ICT Outages/Trippings							
220/100 Kv 100 Mva Emco Ict 1 @Tambati	IntraState	19/11/2019	08.50	19/11/2019	18.04	PO	Routine Maintenance Work
220/100 Kv 200 Mva Vijai Ict 3 @Padghe	IntraState	20/11/2019	10.08	20/11/2019	18.58	PO	Diagnostic Testing.