

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 20/Jan/2024 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 167.185        | 3248.535        | 1) Gujrat                      | -3.699         | -91.168          |
| 2) Hydro            | 9.258          | 188.062         | 2) Madhya Pradesh              | 2.428          | 64.744           |
| 3) Gas              | 7.256          | 134.285         | 3) Chattisgarh                 | 4.350          | 113.110          |
| <b>Total MSPGCL</b> | <b>183.699</b> | <b>3570.882</b> | 4) Maharashtra                 | 166.847        | 3538.784         |
| B) 1) APLM          | 53.537         | 1096.044        | 5) Goa (Amona)                 | -1.338         | -32.254          |
| 2) JSWEL            | 26.150         | 486.667         | <b>Total</b>                   | <b>168.588</b> | <b>3593.216</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 21.282         | 607.407          |
| 4) RPL(AMT)         | 31.610         | 516.513         | b) Mumbai Drawl                | 25.097         | 685.003          |
| 5) SWPGPL           | 11.927         | 240.735         | c) MSEDCL Bilateral *          | 71.616         | 1340.354         |
| 6) Other IPP        | 45.584         | 853.217         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 21.282         | 606.955          |
| C) 1) TPCL Thermal  | 13.606         | 250.192         | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 2.436          | 81.782          | Standby                        | 0.000          | 0.452            |
| 3) TPCL Gas         | 3.054          | 52.661          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 9.617          | 97.830          | 1) MSEDCL                      | 508.052        | 9929.184         |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 53.810         | 1167.455         |
| 1) Thermal          | 359.216        | 6789.733        | 3) Other Discoms               | 10.277         | 204.674          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>572.139</b> | <b>11301.313</b> |
| 2) Hydro            | 11.694         | 269.844         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 10.310         | 186.946         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 8.946          | 196.413         |                                |                |                  |
| 6) SOLAR            | 13.385         | 265.174         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>403.551</b> | <b>7708.110</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 7414                      | 6650                  | 7367                      | 6843                      |
| MSPGCL Hydro               | 949                       | 222                   | 369                       | 167                       |
| MSPGCL Gas                 | 304                       | 292                   | 296                       | 309                       |
| MSPGCL Total Generation    | 8667                      | 7164                  | 8032                      | 7319                      |
| Central Sector Receipt     | 8390                      | 7842                  | 6888                      | 6111                      |
| WIND                       | 293                       | 467                   | 489                       | 210                       |
| CPP / IPP Thermal          | 7401                      | 7290                  | 7506                      | 6398                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 1768                      | 2079                  | 1                         | 0                         |
| Exchange with Mumbai       | -1373                     | -1480                 | -992                      | -918                      |
| <b>MSEDCL DEMAND MET</b>   | <b>24705</b>              | <b>22921</b>          | <b>21429</b>              | <b>18772</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 24705                     | 22921                 | 21429                     | 18772                     |
| TPCL GENERATION            | 934                       | 833                   | 1107                      | 490                       |
| AEML GENERATION            | 389                       | 374                   | 500                       | 310                       |
| <b>MUMBAI DEMAND</b>       | <b>2696</b>               | <b>2687</b>           | <b>2599</b>               | <b>1718</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>441</b>                | <b>441</b>            | <b>495</b>                | <b>348</b>                |
| STATE DEMAND MET           | 27842                     | 26049                 | 24523                     | 20838                     |
| <b>STATE DEMAND</b>        | <b>27842</b>              | <b>26049</b>          | <b>24523</b>              | <b>20838</b>              |
| Frequency (Hz)             | 50.05                     | 50.01                 | 50.01                     | 49.97                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.26 Hz at 06.02 Hrs | 49.79 Hz at 08.18 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 20/Jan/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.30         | 85.98         | 185      | 170      |
| Unit 8             | 15.05        | 225.49        | 638      | 616      |
| Unit 9             | 13.69        | 255.82        | 615      | 540      |
| Unit 10            | 13.61        | 276.71        | 594      | 545      |
| <b>Total</b>       | <b>46.64</b> | <b>844.00</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 38.06         | 0        | 0        |
| Unit 4             | 10.36        | 193.68        | 500      | 295      |
| Unit 5             | 9.40         | 185.80        | 500      | 285      |
| <b>Total</b>       | <b>19.76</b> | <b>417.54</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.78         | 87.34         | 248      | 145      |
| Unit 7             | 4.31         | 83.93         | 223      | 97       |
| Unit 8             | 4.61         | 66.48         | 250      | 144      |
| <b>Total</b>       | <b>13.70</b> | <b>237.74</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.35         | 66.04         | 150      | 121      |
| Unit 4             | 0.00         | 47.55         | 0        | 0        |
| Unit 5             | 8.75         | 169.77        | 445      | 285      |
| Unit 6             | 7.39         | 148.33        | 360      | 275      |
| Unit 7             | 7.37         | 100.49        | 339      | 275      |
| Unit 8             | 9.66         | 176.20        | 423      | 300      |
| Unit 9             | 10.91        | 199.30        | 483      | 319      |
| <b>Total</b>       | <b>47.43</b> | <b>907.68</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.20         | 108.06        | 231      | 179      |
| Unit 4             | 5.30         | 113.35        | 229      | 179      |
| <b>Total</b>       | <b>10.50</b> | <b>221.41</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.82         | 70.12         | 180      | 140      |
| Unit 2             | 0.00         | 27.92         | 0        | 0        |
| Unit 3             | 3.67         | 76.57         | 168      | 130      |
| Unit 4             | 4.57         | 84.92         | 195      | 167      |
| Unit 5             | 10.09        | 204.78        | 470      | 355      |
| <b>Total</b>       | <b>22.16</b> | <b>464.32</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 24.60         | 0        | 0        |
| Unit 4             | 3.66         | 65.71         | 184      | 122      |
| Unit 5             | 3.34         | 65.54         | 161      | 118      |
| <b>Total</b>       | <b>7.00</b>  | <b>155.84</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.26         | 134.28        | 312      | 289      |
| <b>Total</b>       | <b>7.26</b>  | <b>134.28</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.72         | 6.27          | 50       | 0        |
| <b>Total</b>       | <b>0.72</b>  | <b>6.27</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 2.38         | 45.22         | 455      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 1.49          | 42.10          | 500      | 0        |
| Stage 3         | 0.81          | 19.30          | 240      | 0        |
| <b>Total</b>    | <b>4.68</b>   | <b>106.62</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.86          | 12.69          | 36       | 36       |
| VTRNA           | 0.20          | 1.48           | 61       | 0        |
| TILLARI         | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 2.28          | 44.08          | 101      | 91       |
| GHATGHAR        | 0.52          | 16.93          | 125      | 0        |
| <b>Total</b>    | <b>3.86</b>   | <b>75.17</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 8.95          | 196.41         | 0        | 0        |
| <b>Total</b>    | <b>8.95</b>   | <b>196.41</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 53.54         | 1096.04        | 0        | 0        |
| JSWEL(Mus)      | 26.15         | 486.67         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 31.61         | 516.51         | 0        | 0        |
| SWPGPL-Mus      | 11.93         | 240.74         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.95          | 98.20          | 268      | 172      |
| Other(Mus)      | 39.64         | 730.87         | 0        | 0        |
| JPL             | 0.00          | 24.15          | 0        | 0        |
| <b>Total</b>    | <b>168.81</b> | <b>3193.18</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 13.38         | 265.17         | 0        | 0        |
| <b>Total</b>    | <b>13.38</b>  | <b>265.17</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.08          | 159.21         | 471      | 261      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.83          | 31.67          | 108      | 39       |
| Trombay 7B      | 1.23          | 20.99          | 65       | 35       |
| TATA Hydro      | 2.44          | 81.78          | 284      | 21       |
| Trombay 8       | 4.52          | 90.98          | 232      | 132      |
| <b>Total</b>    | <b>19.10</b>  | <b>384.64</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 9.62          | 97.83          | 500      | 300      |
| <b>Total</b>    | <b>9.62</b>   | <b>97.83</b>   |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 167.18      | 3248.54       | MSPGCL Total        | 183.70      | 3570.88       |
|                |             |         | MSPGCL Thml+Gas | 174.44      | 3382.82       | Koyna 1,2 & 4 Total | 3.87        | 87.32         |
|                |             |         | MSPGCL Hydro    | 9.26        | 188.06        | State Total         | 403.55      | 7708.11       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 20/Jan/2024

| TIME SR. NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | Load Shedding |                          | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|------|------|--------|------|-----------|------|-------|----------|----------|----------------|------------------|---------------|--------------------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY   | GAS  |        |      | THM       | GAS  |       |          |          |                |                  | Planned       | *Transmission Constraint |                      |               |                     |              |            |
| 1            | 6683        | 172  | 308  | 7163   | 198  | 6365      | 0    | 0     | 6264     | 6435     | -1037          | 18738            | 0             | 0                        | 18738                | 1848          | 386                 | 20972        | 49.93      |
| 2            | 6664        | 167  | 309  | 7140   | 224  | 6404      | 0    | 0     | 6135     | 6424     | -951           | 18881            | 0             | 0                        | 18881                | 1761          | 360                 | 21002        | 49.96      |
| 3            | 6843        | 167  | 309  | 7319   | 210  | 6398      | 0    | 0     | 6053     | 6111     | -918           | 18772            | 0             | 0                        | 18772                | 1718          | 348                 | 20838        | 49.97      |
| 4            | 6583        | 167  | 309  | 7059   | 264  | 6376      | 0    | 0     | 6362     | 6549     | -885           | 19029            | 0             | 0                        | 19029                | 1684          | 334                 | 21047        | 49.99      |
| 5            | 6895        | 167  | 310  | 7372   | 222  | 6413      | 0    | 0     | 6370     | 6680     | -896           | 19435            | 0             | 0                        | 19435                | 1697          | 356                 | 21488        | 49.99      |
| 6            | 7027        | 175  | 312  | 7514   | 213  | 6550      | 0    | 0     | 7274     | 7367     | -934           | 20334            | 0             | 0                        | 20334                | 1744          | 376                 | 22454        | 50.01      |
| 7            | 7303        | 397  | 311  | 8011   | 258  | 6846      | 0    | 0     | 7202     | 7390     | -727           | 21389            | 0             | 0                        | 21389                | 1858          | 389                 | 23636        | 50.02      |
| 8            | 7302        | 999  | 311  | 8612   | 261  | 6996      | 0    | 112   | 7308     | 7775     | -728           | 22607            | 0             | 0                        | 22607                | 1999          | 421                 | 25027        | 49.99      |
| 9            | 7302        | 1163 | 312  | 8777   | 209  | 7144      | 0    | 621   | 7651     | 7842     | -935           | 23213            | 0             | 0                        | 23213                | 2259          | 445                 | 25917        | 49.96      |
| 10           | 7299        | 1505 | 306  | 9110   | 187  | 7261      | 0    | 1225  | 7926     | 8378     | -1202          | 24511            | 0             | 7                        | 24511                | 2519          | 448                 | 27478        | 50.03      |
| 11           | 7414        | 949  | 304  | 8667   | 293  | 7401      | 0    | 1768  | 8413     | 8390     | -1373          | 24705            | 0             | 11                       | 24705                | 2696          | 441                 | 27842        | 50.05      |
| 12           | 7248        | 240  | 298  | 7786   | 374  | 7532      | 0    | 2075  | 8313     | 8243     | -1470          | 24087            | 0             | 8                        | 24087                | 2740          | 453                 | 27280        | 50.05      |
| 13           | 6650        | 222  | 292  | 7164   | 467  | 7290      | 0    | 2079  | 7697     | 7842     | -1480          | 22921            | 0             | 9                        | 22921                | 2687          | 441                 | 26049        | 50.01      |
| 14           | 6025        | 218  | 289  | 6532   | 547  | 6854      | 0    | 1914  | 7853     | 8240     | -1445          | 22211            | 0             | 9                        | 22211                | 2542          | 431                 | 25184        | 50.00      |
| 15           | 6573        | 219  | 291  | 7083   | 636  | 7005      | 0    | 1585  | 7486     | 7822     | -1412          | 22279            | 0             | 7                        | 22279                | 2534          | 440                 | 25253        | 50.00      |
| 16           | 7193        | 219  | 293  | 7705   | 568  | 7442      | 0    | 1201  | 7315     | 7151     | -1313          | 22274            | 0             | 0                        | 22274                | 2547          | 480                 | 25301        | 49.99      |
| 17           | 7324        | 221  | 294  | 7839   | 530  | 7508      | 0    | 644   | 7044     | 6790     | -1097          | 21722            | 0             | 0                        | 21722                | 2557          | 492                 | 24771        | 50.02      |
| 18           | 7346        | 266  | 294  | 7906   | 574  | 7524      | 0    | 160   | 6653     | 6280     | -988           | 20962            | 0             | 0                        | 20962                | 2557          | 494                 | 24013        | 50.02      |
| 19           | 7367        | 369  | 296  | 8032   | 489  | 7506      | 0    | 1     | 6824     | 6888     | -992           | 21429            | 0             | 0                        | 21429                | 2599          | 495                 | 24523        | 50.01      |
| 20           | 7370        | 492  | 297  | 8159   | 599  | 7488      | 0    | 0     | 6638     | 6571     | -888           | 21461            | 0             | 0                        | 21461                | 2547          | 468                 | 24476        | 50.01      |
| 21           | 7294        | 247  | 300  | 7841   | 395  | 7482      | 0    | 0     | 5791     | 5496     | -878           | 19867            | 0             | 0                        | 19867                | 2418          | 469                 | 22754        | 50.02      |
| 22           | 6784        | 181  | 300  | 7265   | 328  | 7301      | 0    | 0     | 6063     | 6262     | -1148          | 19552            | 0             | 0                        | 19552                | 2247          | 456                 | 22255        | 50.01      |
| 23           | 6416        | 168  | 304  | 6888   | 441  | 6916      | 0    | 0     | 6460     | 6014     | -881           | 18943            | 0             | 0                        | 18943                | 2094          | 435                 | 21472        | 49.97      |
| 24           | 6280        | 168  | 307  | 6755   | 459  | 6806      | 0    | 0     | 6340     | 5648     | -519           | 18731            | 0             | 0                        | 18731                | 1958          | 418                 | 21107        | 50.01      |
| MUs          | 167.18      | 9.26 | 7.26 | 183.70 | 8.95 | 168.81    | 0.00 | 13.39 | 167.43   | 168.59   | -25.10         | 508.05           | 0.00          | 0.05                     | 508.05               | 53.81         | 10.28               | 572.14       | 50.00      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

1)ELR Carried out due to 50 MVA 220/33 kV TF 1 & 2 are parallel & HV Overload :-134 Amp / 44.05 MW (Each).

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 20/Jan/2024**

Position as on 6.30 Hrs of 21/Jan/2024

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                             | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                              |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                              |               |
| MSPGCL                        | Uran Unit 5             | 108      | 12/11/2022   | 13:23        |            | Continued. | Major overhaul.                                              | 15/02/2024    |
| MSPGCL                        | Koyna Unit 11           | 80       | 10/07/2023   | 09:40        |            | Continued. | Capital Overhaul                                             | 29/02/2024    |
| MSPGCL                        | Koyna STG-IV Unit-3     | 250      | 24/11/2023   | 08:00        |            | Continued. | Capital Overhauling                                          | 24/01/2024    |
| MSPGCL                        | Khaparkheda Unit 2      | 210      | 10/01/2024   | 23:30        |            | Continued. | Annual Overhaul                                              | 06/02/2024    |
| MSPGCL                        | Koyna Unit 3            | 70       | 15/01/2024   | 08:45        | 21/01/2024 | 18:20      | Generator Excitation system new panel commissioning activity | 22/01/2024    |
| Total Capacity MSPGCL         |                         | 718      |              |              |            |            |                                                              |               |
| TPC-G                         |                         |          |              |              |            |            |                                                              |               |
| TPC-G                         | Trombay 8               | 250      | 21/01/2024   | 21:28        |            | Continued. | Annual Overhaul                                              | 21/02/2024    |
| Total Capacity TPC-G          |                         | 250      |              |              |            |            |                                                              |               |
| IPP                           |                         |          |              |              |            |            |                                                              |               |
| IPP                           | Adani U-3               | 660      | 31/12/2023   | 23:59        |            | Continued. | COH activities                                               | 05/02/2024    |
| Total Capacity IPP            |                         | 660      |              |              |            |            |                                                              |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                              |               |
| CENT.SECTOR                   | Tarapur 3               | 540      | 11/01/2024   | 21:45        |            | Continued. | Annual Overhaul                                              | 29/02/2024    |
| Total Capacity CENT.SECTOR    |                         | 540      |              |              |            |            |                                                              |               |
| Total Capacity PLANNED OUTAGE |                         | 2168     |              |              |            |            |                                                              |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                              |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                              |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                           | 31/08/2024    |
| MSPGCL                        | Bhusawal Unit 3         | 210      | 11/01/2024   | 23:56        |            | Continued. | work Seal liner outage                                       | 23/01/2024    |
| MSPGCL                        | Uran Unit 6             | 108      | 16/01/2024   | 20:29        |            | Continued. | For open cycle No schedule from MSEDCL.                      |               |
| MSPGCL                        | Chandrapur Unit 4       | 210      | 18/01/2024   | 08:32        |            | Continued. | Boiler Tube Leakage                                          | 26/01/2024    |
| MSPGCL                        | Ghatghar Unit-1         | 125      | 18/01/2024   | 16:00        |            | Continued. | G/M link fault                                               | 23/01/2024    |
| MSPGCL                        | Nasik Unit 3            | 210      | 18/01/2024   | 16:56        |            | Continued. | Tolling                                                      |               |
| MSPGCL                        | Chandrapur Unit 5       | 500      | 21/01/2024   | 08:04        | 21/01/2024 | 16:50      | Generator Differential Protection Operated                   |               |
| Total Capacity MSPGCL         |                         | 1483     |              |              |            |            |                                                              |               |
| IPP                           |                         |          |              |              |            |            |                                                              |               |
| IPP                           | JPL Unit 1              | 150      | 13/01/2024   | 01:00        |            | Continued. | Due to low net sale realisation.                             | 29/01/2024    |
| IPP                           | Adani U-2               | 660      | 16/01/2024   | 10:32        | 20/01/2024 | 06:53      | APH-A HOT PA bellow leakage                                  | 20/01/2024    |
| IPP                           | SWPGPL U-1              | 135      | 20/01/2024   | 21:51        | 21/01/2024 | 05:53      | ID Fan Vibration.                                            |               |
| Total Capacity IPP            |                         | 945      |              |              |            |            |                                                              |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                              |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 20/Jan/2024**

**Position as on 6.30 Hrs of 21/Jan/2024**

| Generating Company                         | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|--------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| CENT.SECTOR                                | Tarapur 1               | 160      | 08/01/2020   | 10:37        |           | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 01/04/2024    |
| CENT.SECTOR                                | Tarapur 2               | 160      | 13/07/2020   | 04:38        |           | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 01/05/2024    |
| Total Capacity CENT.SECTOR                 |                         | 320      |              |              |           |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE               |                         | 2748     |              |              |           |            |                                                                                                                                                         |               |
| FORCED OUTAGE DUE TO NO PPA                |                         |          |              |              |           |            |                                                                                                                                                         |               |
| IPP                                        |                         |          |              |              |           |            |                                                                                                                                                         |               |
| IPP                                        | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| IPP                                        | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                                        | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                                        | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| Total Capacity IPP                         |                         | 988      |              |              |           |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA |                         | 988      |              |              |           |            |                                                                                                                                                         |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 20/Jan/2024**

**Statement-VII**

Position as on 6.30 Hrs of 21/Jan/2024

| Name of Line                                                     | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
|------------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Trippings</b>                             |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| KORADI III - AKOLA II Ckt - 1                                    | IntraState                | 21/01/2024   | 11:40        | 21/01/2024 | 19:59      | PO          | Annual maintenance of line.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| <b>400 KV TIEBAY Outages/Trippings</b>                           |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| TIE BAY (405) OF SWICHING SS CKT - 2 & NANDED - 1 @ CHANDRAPUR 2 | IntraState                | 16/01/2024   | 11:43        |            |            | PO          | replacement of non pir breker with pir breaker                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |
| <b>400 KV MAINBAY Outages/Trippings</b>                          |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| MAIN BAY - 418 OF IEPL @ KORADI-2                                | IntraState                | 29/09/2023   | 10:42        |            |            | PO          | 1)Diagnostic testing of Circuit breaker 418-Q52.<br>2) Routine Maintenance work of Bay 418.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| <b>400 KV LINE Outages/Trippings</b>                             |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| 400KV-PARLI NEW-PARLI-M-2                                        | InterState                | 20/12/2023   | 12:11        |            |            | HT          | For ongoing project of "Upgradation of 400kV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS&#65533;                                                                                                                                                                                                                                                                                                                                                                                                         |
| BUS REACTOR (50MVAR) @ PARLI                                     | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2                              | IntraState                | 26/11/2023   | 19:17        |            |            | HT          | HT Load Management                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
| PADGHE - KALWA CKT - 2                                           | IntraState                | 30/12/2023   | 22:01        | 21/01/2024 | 04:50      | PO          | During the outage on Dtd: 30.12.2023 temporary tapping arrangement on 400kV Kalwa-Padgha Ckt.2 line will be done by making a bunching arrangement from loc no 3 to loc 132 of 400Kv Padgha-Kharghar (dead line) line at Padgha substation premises. By this bunching arrangement, line will be diverted from loc no.132 to loc.No .09. Due to this tapping of 400Kv Kalwa-Padgha Ckt.2-line section b/w loc no 3 to Kalwa Substation (loc1135) will become dead. And this dead Ckt. will be free for completion of the balance HTLS conversion work i.e between Loc no. 61-62 to 1012 (approximately 2.7 km). |
| KHARGHAR - VIKHROLI GIS CKT - 1                                  | IntraState                | 30/12/2023   | 22:43        |            |            | HT          | Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| KHARGHAR - VIKHROLI GIS CKT - 2                                  | IntraState                | 30/12/2023   | 22:44        |            |            | HT          | Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| CHANDRAPUR GCR - CHANDRAPUR HVDC - 2                             | IntraState                | 16/01/2024   | 13:00        |            |            | PO          | 1. Pole Overhauling of Bhel make CB of 400KV HVDC CKT-2 bay.<br>2. Diagnostic testing of Circuit breaker.<br>3. 400KV HVDC CKT-2 will be in service via TBC-2.                                                                                                                                                                                                                                                                                                                                                                                                                                                |
| WARORA - IEPL                                                    | IntraState                | 20/01/2024   | 08:00        | 20/01/2024 | 18:35      | PO          | LINE MAINT. WORKS                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |
| LONIKAND 2 - KARJAT CKT - 1                                      | IntraState                | 20/01/2024   | 08:50        | 20/01/2024 | 20:58      | PO          | Cold washing of Insulator Strings                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |
| KHADKA - BABLESHWAR                                              | IntraState                | 20/01/2024   | 12:33        | 20/01/2024 | 19:39      | PO          | Routine Line maintenance work;CVT tan D testing work                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 20/Jan/2024**

**Statement-VII**

Position as on 6.30 Hrs of 21/Jan/2024

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| PADGHE - KALWA CKT - 1                   | IntraState                | 20/01/2024   | 23:07        | 21/01/2024 | 04:31      | PO          | Normalization of 400kV Kalwa-Padgha-1 by removing the bunching with Ckt-2 between Loc no. 3-4 and re-jumpering at Loc no.4.                                                                                                                                                                                                                                                                                                                                                                                                   |
| KHARGHAR - TALEGAON (PG)                 | IntraState                | 21/01/2024   | 04:50        | 21/01/2024 | 07:58      | PO          | Removing of jumpirng at loc no-9 of Dead 400kV Padghe-Kharghar Line and restoration of 400kV Kharghar-Talegaon(PG) Line.<br><br>Removing of bunching between 400kV Kalwa-Padgha-2 and dead Padghe-Kharghar Line and restoring the 400kV Kalwa-Padgha-2 line                                                                                                                                                                                                                                                                   |
| PADGHE - KALWA CKT - 2                   | IntraState                | 21/01/2024   | 04:50        | 21/01/2024 | 10:50      | PO          | Removing of jumpirng at loc no-9 of Dead 400kV Padghe-Kharghar Line and restoration of 400kV Kharghar-Talegaon(PG) Line.<br><br>Removing of bunching between 400kV Kalwa-Padgha-2 and dead Padghe-Kharghar Line and restoring the 400kV Kalwa-Padgha-2 line                                                                                                                                                                                                                                                                   |
| KHADKA-AURANGABAD (WALUJ)                | IntraState                | 21/01/2024   | 20:27        |            | Continued. | HT          | Line Hand tripped for voltage management.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| BABHALESHWAR - PADGHE CKT - 2            | IntraState                | 21/01/2024   | 22:46        |            | Continued. | PO          | Shifting of 400 KV Babhaleshwar-Padghe Ckt-2 on 400 KV Talegaon-Padghe (Dead Ckt).<br>Outage No. 1 on Ckt-2 this temporarily arrangement for 14 days<br>1. Bunching and ERS Stringing between Loc 33 & 108.<br>2. Bunching between Loc 57 and 132.<br>3.Removing of Jumpers at Loc 33 and 57.<br>4. Removing of jumper at Loc 106.<br>5. Transferring of 400KV BBLR-PDG Ckt-2 on 400KV Talegaon-PDG Ckt.<br>6.Charging of 400KV BBLR-PDG Ckt-2 on 400KV Talegaon-PDG CKT. 7 Above temporarily arrangement will be for 14 days |
| <b>400 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| STATION TF No 3 @ CHANDRAPUR GCR         | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                                                                                                                                                                                                                                                                                                                |
| 400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS | IntraState                | 30/12/2023   | 23:20        |            |            | T           | Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)                                                                                                                                                                                                                                                                                                                                                                                  |
| 400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS | IntraState                | 30/12/2023   | 23:21        |            |            | HT          | Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)                                                                                                                                                                                                                                                                                                                                                                                  |
| 400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS | IntraState                | 30/12/2023   | 23:22        |            |            | HT          | Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)                                                                                                                                                                                                                                                                                                                                                                                  |
| 400KV/21KV GT - 3 @ TIRORA               | IntraState                | 01/01/2024   | 10:45        |            |            | PO          | Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.                                                                                                                                                                                                                                                                                                                                                                                                                              |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 20/Jan/2024**

**Statement-VII**

Position as on 6.30 Hrs of 21/Jan/2024

| Name of Line                                       | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                             |
|----------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS | IntraState                | 16/01/2024   | 12:03        |            |            | PO          | In view of the continuous H2 gas rising trend of Station Transformer 8A, forced outage needed for degassing/filtration of transformer oil from Dt. 16.01.2024 to Dt. 17.01.2024 tentatively. |
| STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS | IntraState                | 16/01/2024   | 12:03        |            |            | PO          | In view of the continuous H2 gas rising trend of Station Transformer 8A, forced outage needed for degassing/filtration of transformer oil from Dt. 16.01.2024 to Dt. 17.01.2024 tentatively. |
| 400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR        | IntraState                | 19/01/2024   | 17:08        | 20/01/2024 | 00:12      | PO          | Rapid Restoration Scheme work; LV LBB relay, LV CT tan D, Bushing tan D, DFRA; Quarterly bay maintenance work                                                                                |
| 400/11.5KV STATION TRANSFORMER - 1 @ TIRORA        | IntraState                | 19/01/2024   | 22:19        | 20/01/2024 | 20:14      | T           | Tripped                                                                                                                                                                                      |
| 400/220/33 KV 600 MVA ICT - 4 @ PADGHE             | IntraState                | 20/01/2024   | 01:20        | 20/01/2024 | 05:27      | PO          | 1) Topping of oil in yph due to low oil level<br>2) Attending Hot spot on Bph IV & HV Bushing                                                                                                |
| <b>400 KV BR Outages/Trippings</b>                 |                           |              |              |            |            |             |                                                                                                                                                                                              |
| 400KV 125MVAR BUS REACTOR @ KARAD                  | IntraState                | 06/01/2024   | 11:55        |            |            | PO          | Existing 125 MVAR Reactor CB Have mechanical problem and need to replace                                                                                                                     |
| <b>220 KV MAINBAY Outages/Trippings</b>            |                           |              |              |            |            |             |                                                                                                                                                                                              |
| 220 KV BUS                                         | IntraState                | 20/01/2024   | 11:28        | 20/01/2024 | 21:20      | PO          | For replacement of Y phase main bus conductor for one bus section.                                                                                                                           |
| <b>220 KV LINE Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                                                                              |
| PANCHALI TSS - BOISAR (PG)                         | InterState                | 21/01/2024   | 12:36        | 21/01/2024 | 19:55      | PO          | Outage required for Hot spot attending work at loc No.DP Between Loc No.12-13                                                                                                                |
| BAPGAON - KALWA                                    | IntraState                | 31/12/2023   | 18:05        |            |            | T           | Distance Protection                                                                                                                                                                          |
| BUS SECTION BREAKER-3 @ TROMBAY                    | IntraState                | 17/01/2024   | 06:42        | 20/01/2024 | 04:21      | PO          | Breaker replacement                                                                                                                                                                          |
| CHEMBUR (AEML) - NERUL (M)                         | IntraState                | 18/01/2024   | 23:29        |            |            | PO          | LILo removal by Bunching at Tower No 720 .Post this Line shall be configured as MSETCL NERUL-MSETCL TROMBAY Line. LILo arrangement shall be normalized on 09.02.2024 after debunching        |
| TROMBAY (M) - CHEMBUR CKT - 3                      | IntraState                | 18/01/2024   | 23:36        |            |            |             | LILo removal by Bunching at Tower No 720 . Post this Line shall be configured as MSETCL NERUL-MSETCL TROMBAY Line. LILo arrangement shall be normalized on 09.02.2024 after debunching       |
| MAIN BUS - 2 @ CHEMBUR                             | IntraState                | 19/01/2024   | 10:17        | 21/01/2024 | 20:54      | PO          | Installation of Adapter Chamber for Bus-2 at Chembur for Bus Extension under MERC approved Project                                                                                           |
| BUTIBORI 3- VIPL CKT II                            | IntraState                | 19/01/2024   | 11:16        |            |            | HT          | Diagnostic testing work.                                                                                                                                                                     |
| KARAD - OGALEWADI CKT 2                            | IntraState                | 19/01/2024   | 14:26        | 20/01/2024 | 18:22      | PO          | CB Mechanism Overhauling Work                                                                                                                                                                |
| CHALISGAON - SAYNE                                 | IntraState                | 19/01/2024   | 20:35        | 20/01/2024 | 01:01      | PO          | For replacement of existing R-ph CT by new CT                                                                                                                                                |
| GHODBUNDER - GORAI                                 | IntraState                | 20/01/2024   | 00:24        | 20/01/2024 | 07:06      | PO          | Erection of I-grider from pier location P154-P155.                                                                                                                                           |
| APTA - TAMBATI                                     | IntraState                | 20/01/2024   | 06:13        | 20/01/2024 | 11:27      | PO          | Twin jumpering work at all cut point locations.                                                                                                                                              |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 20/Jan/2024**

**Statement-VII**

Position as on 6.30 Hrs of 21/Jan/2024

| Name of Line                                       | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                        |
|----------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| LONAND - KANDALGAON (SONA ALLOY TAP)               | IntraState                | 20/01/2024   | 08:44        | 20/01/2024 | 19:08      | PO          | Damaged Conductor Replacement Work                                                                                                                                                                                                                                      |
| VERSOVA - GHODBUNDER                               | IntraState                | 20/01/2024   | 08:57        | 20/01/2024 | 18:53      | PO          | METRO 9 PROJECT WORK.                                                                                                                                                                                                                                                   |
| COLOURCHEM - TEMGHAR                               | IntraState                | 20/01/2024   | 09:15        | 20/01/2024 | 17:22      |             | Replacement of existing back up relay back with Distance Relay (M2) as per the scheme of 220kV Padgha-Temghar-Kalwa Gateway.                                                                                                                                            |
| COLOURCHEM - TEMGHAR                               | IntraState                | 20/01/2024   | 09:15        | 20/01/2024 | 17:22      | PO          | Annual diagnostics & Bay maintenance work.                                                                                                                                                                                                                              |
| KARAD -NIGADE                                      | IntraState                | 20/01/2024   | 10:22        | 20/01/2024 | 12:38      | PO          | CB timing and CRM testing                                                                                                                                                                                                                                               |
| NIGADE- PETH LINE                                  | IntraState                | 20/01/2024   | 13:13        | 20/01/2024 | 14:50      | PO          | CB timing and CRM testing work of CB                                                                                                                                                                                                                                    |
| APTA - TAMBATI                                     | IntraState                | 21/01/2024   | 05:53        | 21/01/2024 | 11:01      | PO          | Twin jumpering work at all cut point locations.                                                                                                                                                                                                                         |
| 132 KV DONDAICHA (220 KV) - DONDAICHA (132 KV) CKT | IntraState                | 21/01/2024   | 10:46        | 21/01/2024 | 13:40      | PO          | Diagnostic testing work.                                                                                                                                                                                                                                                |
| TROMBAY - VIKHROLI (GIS) CKT - 1                   | IntraState                | 21/01/2024   | 11:23        | 21/01/2024 | 21:03      | PO          | FOR FORMATION OF THREE TERMINAL LINE                                                                                                                                                                                                                                    |
| TROMBAY - CARNAC - 7                               | IntraState                | 21/01/2024   | 11:33        | 21/01/2024 | 21:03      | PO          | FOR FORMATION OF THREE TERMINAL LINE                                                                                                                                                                                                                                    |
| KANDALGAON - KOYNA (POPHALI)                       | IntraState                | 21/01/2024   | 11:40        | 21/01/2024 | 19:20      | PO          | Replacement of Faulty Insulator At Loc No.320 & Other Line Maintenance work                                                                                                                                                                                             |
| TROMBAY DHARAVI - 6                                | IntraState                | 21/01/2024   | 11:40        | 21/01/2024 | 19:38      | PO          | FOR WORK IN VICINITY OF THREE TERMINAL LINE FORMATION                                                                                                                                                                                                                   |
| PALGHAR - NALASOPARA                               | IntraState                | 21/01/2024   | 11:41        | 21/01/2024 | 19:15      | PO          | Stringing work between Loc no. 127-130 in r/o shifting/ height raising of the 220kv Boisar-Nalasopara (Dead Line) & Palghar -Nalasopara line for maintaining electrical clearance for construction of Railwa flover for Virar- Suray line in Palghar & Saphale for PWD. |
| BOISAR II - BOISAR (PG) CKT - 2                    | IntraState                | 21/01/2024   | 11:59        | 21/01/2024 | 21:09      | PO          | For Bay maintenance & equipment testing.                                                                                                                                                                                                                                |
| PALGHAR - PANCHALI TSS                             | IntraState                | 21/01/2024   | 12:05        | 21/01/2024 | 19:48      | PO          | Outage is required for safety purpose for Hot Spot attending work on 132kV Boisar-Palghar CKT at Loc No.21(R-Ph Palghar Side Temp- 74°C).                                                                                                                               |
| <b>220 KV ICT Outages/Trippings</b>                |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                         |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE          | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                                                                                        |
| 220/33KV 25MVA PTR 1 @ HALKARNI                    | IntraState                | 16/01/2024   | 11:43        |            |            | PO          | For Replacement TF Oil of 25 MVA CGL TRF-I .                                                                                                                                                                                                                            |
| 220/33KV 50MVA BBL T/F @ OGLEWADI                  | IntraState                | 18/01/2024   | 10:31        |            |            | PO          | HV CB Mechanism Overhauling Work                                                                                                                                                                                                                                        |
| 220/33KV 125 MVA TF 1 @ CHEMBUR                    | IntraState                | 19/01/2024   | 09:44        |            |            | PO          | Installation of Adapter Chamber for Bus-2 and Bus-1 at Chembur for Bus Extension                                                                                                                                                                                        |
| 220/132 KV 200 MVA ICT 4                           | IntraState                | 20/01/2024   | 11:52        | 20/01/2024 | 14:25      | PO          | For replacement of 200MVA ict 4 ctr nitrogen fire extinguisher system nitrogen cylinder due o low pressure.                                                                                                                                                             |
| 220 / 110 / 33kv 250MVA ICT 10 @ DHARAVI           | IntraState                | 21/01/2024   | 08:28        | 21/01/2024 | 18:41      | PO          | R/M AND TESTING                                                                                                                                                                                                                                                         |
| 220/132 KV 100MVA ICT 2 @ BARAMATI                 | IntraState                | 21/01/2024   | 10:02        | 21/01/2024 | 18:02      | PO          | ICT Painting work                                                                                                                                                                                                                                                       |
| <b>220 KV BUSBAR Outages/Trippings</b>             |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                         |
| BUS SECTION-1 @ TROMBAY (TATA)-220 KV              | IntraState                | 19/01/2024   | 23:30        | 20/01/2024 | 00:30      | PO          | for test charging activity of Bus section 3 breaker                                                                                                                                                                                                                     |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 20/Jan/2024**

**Statement-VII**

Position as on 6.30 Hrs of 21/Jan/2024

| Name of Line                           | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                        |
|----------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-----------------------------------------------------------------------------------------|
| <b>110 KV LINE Outages/Trippings</b>   |                              |                 |                 |            |               |                |                                                                                         |
| SALSETTE POWAI                         | IntraState                   | 27/03/2023      | 11:04           |            |               | PO             | Replacement of tower number 77 & 78 for TDS project work.                               |
| BHIVPURI - AMBERNATH CKT - 1           | IntraState                   | 21/01/2024      | 06:25           | 21/01/2024 | 13:50         | PO             | Derrick erection in vicinity of line at Bhivpuri                                        |
| AMBERNATH - KALYAN CKT - 2             | IntraState                   | 21/01/2024      | 23:50           |            | Continued.    | PO             | FOR R/M                                                                                 |
| <b>110 KV BUSBAR Outages/Trippings</b> |                              |                 |                 |            |               |                |                                                                                         |
| ZONE 1 (BUS SECTION 1+2+3) @ BHIVPURI  | IntraState                   | 20/01/2024      | 01:14           | 20/01/2024 | 03:43         | PO             | For removing Bus between breaker to MBS GOD & LS GOD to CT OF BHIVPURI - AMBERNATH LINE |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage