

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 20/Jun/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.521	3241.922	1) Gujrat	-3.329	-112.741
2) Hydro	10.767	248.664	2) Madhya Pradesh	5.529	90.076
3) Gas	3.245	85.477	3) Chattisgarh	3.060	49.840
Total MSPGCL	150.533	3576.063	4) Maharashtra	167.121	3390.365
B) 1) APLM	59.808	1409.296	5) Goa (Amona)	-1.239	-19.133
2) JSWEL	14.633	340.650	Total	171.142	3398.407
3) VIPL	0.000	0.000	a) Mumbai Schedule	37.013	679.620
4) RPL(AMT)	24.036	503.010	b) Mumbai Drawl	39.833	746.169
5) SWPGPL	9.359	171.145	c) MSEDCL Bilateral *	98.632	1466.911
6) Other IPP	11.610	275.701	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	37.013	679.411
C) 1) TPCL Thermal	11.840	298.553	Include PX	0.000	0.000
2) TPCL Hydro	2.224	89.494	Standby	0.000	0.209
3) TPCL Gas	0.000	29.093	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.633	213.649	1) MSEDCL	445.997	9469.468
D) STATE			2) Mumbai Discoms	62.530	1376.959
1) Thermal	276.440	6453.926	3) Other Discoms	9.212	187.528
(A1+C1+C4+(B1-B6))			TOTAL STATE	517.739	11033.955
2) Hydro	12.991	338.158			
(A2+C2)					
3) Gas	3.245	114.570			
(A3+B7+C3)					
4) Wind	44.846	540.550			
6) SOLAR	9.075	188.343			
TOTAL STATE	346.597	7635.547			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5467	5431	5718	6005
MSPGCL Hydro	630	341	636	297
MSPGCL Gas	132	133	131	140
MSPGCL Total Generation	6229	5905	6485	6442
Central Sector Receipt	8368	8177	6542	6203
WIND	1912	1657	2252	1208
CPP / IPP Thermal	4744	5141	5060	5222
CPP / IPP Gas	0	0	0	0
SOLAR	1120	1242	0	0
Exchange with Mumbai	-2050	-2044	-1677	-1222
MSEDCL DEMAND MET	19894	19647	18244	17567
Load Shedding	0	0	0	0
MSEDCL DEMAND	19894	19647	18244	17567
TPCL GENERATION	707	650	716	481
AEML GENERATION	394	413	392	331
MUMBAI DEMAND	3151	3107	2785	2034
OTHER DISCOM DEMAND	429	431	418	286
STATE DEMAND MET	23474	23185	21447	19887
STATE DEMAND	23474	23185	21447	19887
Frequency (Hz)	49.98	50.08	49.98	50.05

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 08.48 Hrs	49.75 Hz at 10.54 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 20/Jun/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.52	83.46	180	95
Unit 7	0.00	0.00	0	0
Unit 8	12.12	247.48	555	420
Unit 9	10.19	228.08	455	390
Unit 10	7.17	232.22	532	0
Total	33.00	791.23		
Bhusawal				
Unit 3	2.93	65.70	140	105
Unit 4	10.32	205.36	465	350
Unit 5	9.31	186.00	460	315
Total	22.56	457.05		
Parli				
Unit 6	0.00	87.03	0	0
Unit 7	4.56	87.32	227	140
Unit 8	3.15	62.60	136	126
Total	7.71	236.95		
Chandrapur				
Unit 3	3.12	58.98	137	115
Unit 4	0.00	51.00	0	0
Unit 5	8.38	168.29	380	300
Unit 6	0.00	160.48	0	0
Unit 7	0.00	113.41	0	0
Unit 8	11.27	215.70	480	453
Unit 9	10.89	164.85	467	440
Total	33.65	932.70		
Paras				
Unit 3	4.43	97.16	202	148
Unit 4	4.60	92.75	209	153
Total	9.02	189.91		
Khaparkheda				
Unit 1	3.20	64.08	145	115
Unit 2	2.50	68.07	130	65
Unit 3	4.18	82.82	183	146
Unit 4	0.00	13.16	0	0
Unit 5	10.58	215.42	469	360
Total	20.47	443.55		
Nasik				
Unit 3	3.41	75.60	163	120
Unit 4	3.39	60.57	163	120
Unit 5	3.30	54.35	154	111
Total	10.10	190.52		
Uran				
All Units	3.24	85.48	149	122
Total	3.24	85.48		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	4.69	9	0
Total	0.03	4.69		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.02	57.77	510	40
Stage 4	0.20	44.01	122	0
Stage 3	1.05	24.95	160	0
Total	4.27	126.73		
Hydro				
KDPH	0.46	8.80	19	19
VTRNA	0.08	0.08	60	0
TILLARI	0.49	4.66	58	0
BHIRA T.R.	0.08	5.02	40	0
SMLHY_PTN	5.36	96.55	238	210
GHATGHAR	0.00	2.13	0	0
Total	6.47	117.24		
Wind				
Total	44.85	540.55	0	0
Total	44.85	540.55		
CPP				
APML(Mus)	59.81	1409.30	0	0
JSWEL(Mus)	14.63	340.65	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.04	503.01	0	0
SWPGPL-Mus	9.36	171.14	0	0
Other(Mus)	11.61	275.70	0	0
Total	119.45	2699.80		
SOLAR				
Total	9.08	188.34	0	0
Total	9.08	188.34		
Tata				
Trombay 5	7.66	193.86	421	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	17.72	0	0
Trombay 7B	0.00	11.38	0	0
TATA Hydro	2.22	89.49	213	7
Trombay 8	4.18	104.69	220	132
Total	14.06	417.14		
AEML				
DTPS U-1&2	8.63	213.65	443	287
Total	8.63	213.65		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.52	3241.92	MSPGCL Total	150.53	3576.06
			MSPGCL Thml+Gas	139.77	3327.40	Koyna 1,2 & 4 Total	3.22	101.78
			MSPGCL Hydro	10.77	248.66	State Total	346.60	7635.55

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 20/Jun/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5998	293	141	6432	1749	5090	0	0	6415	6485	-1515	17901	0	17901	2409	340	20650	50.04
2	5913	583	140	6636	1521	4684	0	0	6694	6787	-1417	17888	0	17888	2245	323	20456	49.95
3	6029	537	140	6706	1337	5287	0	0	6106	6040	-1267	17814	0	17814	2118	289	20221	49.98
4	6005	297	140	6442	1208	5222	0	0	6713	6203	-1222	17567	0	17567	2034	286	19887	50.05
5	5988	293	140	6421	1298	5220	0	0	6885	6548	-1185	17989	0	17989	2003	313	20305	49.98
6	5928	285	149	6362	1227	5512	0	0	7296	7269	-1271	18773	0	18773	2079	326	21178	49.94
7	6025	416	140	6581	1298	5641	0	89	7476	7316	-1353	19205	0	19205	2175	367	21747	49.95
8	6099	361	140	6600	1620	5535	0	406	7335	6940	-1467	19229	0	19229	2317	405	21951	49.99
9	5809	370	141	6320	2137	4740	0	640	7535	7391	-1684	19131	0	19131	2608	413	22152	50.10
10	5411	411	137	5959	2141	4413	0	916	7843	8209	-1785	19436	0	19436	2911	417	22764	50.02
11	5136	650	134	5920	2023	4407	0	999	8220	8232	-1989	19162	0	19162	3084	430	22676	49.93
12	5467	630	132	6229	1912	4744	0	1120	8299	8368	-2050	19894	0	19894	3151	429	23474	49.98
13	5431	341	133	5905	1657	5141	0	1242	8553	8177	-2044	19647	0	19647	3107	431	23185	50.08
14	5279	331	132	5742	1965	4530	0	1118	8959	8607	-2164	19392	0	19392	2922	406	22720	50.04
15	5376	332	133	5841	2291	4477	0	948	8583	8311	-1884	19584	0	19584	2919	400	22903	49.96
16	5340	339	132	5811	2582	4464	0	775	8303	7551	-1912	18847	0	18847	2902	424	22173	49.94
17	5056	442	131	5629	2713	4315	0	522	7266	7234	-1867	18127	0	18127	2892	419	21438	49.98
18	5155	957	130	6242	2688	4299	0	253	6610	6767	-1880	17945	0	17945	2843	424	21212	49.92
19	5616	576	131	6323	2678	4669	0	47	6470	6491	-1853	17924	0	17924	2801	431	21156	49.99
20	5718	636	131	6485	2252	5060	0	0	6369	6542	-1677	18244	0	18244	2785	418	21447	49.98
21	5980	422	122	6524	1900	5484	0	0	6463	6360	-1684	18175	0	18175	2674	409	21258	49.98
22	5918	534	131	6583	1562	5569	0	0	6154	6347	-1681	18019	0	18019	2571	361	20951	50.03
23	5949	385	133	6467	1643	5533	0	0	6306	6512	-1524	18259	0	18259	2518	372	21149	50.05
24	5895	346	132	6373	1444	5410	0	0	6945	6455	-1458	17847	0	17847	2462	377	20686	50.03
MUs	136.52	10.77	3.25	150.53	44.85	119.45	0.00	9.08	173.80	171.14	-39.83	446.00	0.00	446.00	62.53	9.21	517.74	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 20/Jun/2022

Position as on 6.30 Hrs of 21/Jun/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkhedha Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna STG-IV Unit-2	250	13/06/2022	00:00		Continued.	Commissioning and installation of New TSLG governor	30/06/2022
IPP	RPL(AMT) U-5	270	15/06/2022	00:00		Continued.	Annual Overhaul	25/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 5	108	11/06/2022	14:29		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	13/06/2022	00:25		Continued.	Gas shortage	
MSPGCL	Uran Unit 6	108	13/06/2022	00:25		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Turbine Gland steam temperature not maintained	22/06/2022
MSPGCL	Chandrapur Unit 4	210	18/06/2022	00:05		Continued.	Ash handling problem.	20/06/2022
TPC-G	Trombay 7B	60	18/06/2022	03:55		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	18/06/2022	04:12		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 6	500	18/06/2022	12:53		Continued.	Boiler Tube Leakage	21/06/2022
MSPGCL	Parli Unit 6	250	18/06/2022	18:37		Continued.	Boiler Tube Leakage	21/06/2022
MSPGCL	Koradi Unit-10	660	20/06/2022	12:00	20/06/2022	17:29	BOILER UNSTABLE CONDITION.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 21/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	20/06/2022	09:46	20/06/2022	19:48	PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
WARORA - WARDHA (PG)	InterState	20/06/2022	10:10			PO	1. Tower Erection of loc. No. 01 under 400 kV Wardha-Warora line. 2. Connecting 400kV Warora (MSETCL) to 400kV Warora (PGCIL)
AURANGABAD(MS) - AURANGABAD(PG) CKT -1	InterState	20/06/2022	12:30	20/06/2022	19:19	PO	Routine maintenance work & to attend Hot Spot on Yph line CT (developing Hot Spot)
DHULE - SSNNL CKT - 2	InterState	21/06/2022	01:51			HT	HT for Overvoltage
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/06/2022	16:32			HT	Load management
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	18/06/2022	19:17	20/06/2022	06:55	T	Distance Protection
TBC @ NEW KOYNA	IntraState	20/06/2022	09:26	20/06/2022	18:50	PO	Routine maint. Work
WARORA - IEPL	IntraState	20/06/2022	09:58			PO	1. De-stringing and Connecting 400kV IEPL-Warora through new towers. 2. Connecting Horizontal Jumper and covert 400kV IEPL Ckt to 400kV IEPL-PGCIL Deoli Ckt (Temporary Arrangemet for next 10 Days)
LONIKAND I - KOYNA STAGE-IV	IntraState	20/06/2022	16:44	20/06/2022	19:11	EO	To attend the hotspot of 29 B PGI at B- PH. Load will be shifted on 400kV TBC.
NEW KOYNA-KARAD CKT - 2	IntraState	21/06/2022	04:36			T	Distance Protection
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	06/06/2022	12:33			PO	For CB replacement work. ICT will be in service through TBC.
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	IntraState	19/06/2022	19:15	20/06/2022	02:56	EO	"For attending 220kV side Y phase Stub Bus Hot spot attending work. "
500 MVA 400/220 KV ICT - I @ CHANDRAPUR 2	IntraState	20/06/2022	09:11	20/06/2022	14:45	PO	For premonsoon activities and allied bay maintenance work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 20/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 21/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	20/06/2022	15:28	20/06/2022	17:54	EO	To attend the N2 gas leakage problem and low N2 gas alarm of CTR make N2 injection fire protection and extinguisher system of B-ph Unit of ICT-2On dt. - 20/06/2022 @ 07:00 Hrs. low N2 gas alarm is appeared on control panel of CTR make NIFPS of B-ph unit of ICT-2 bank. Upon inspection it is observed that, the pressure of N2 gas in cylinder very low i.e 80KG/Cm2 and N2 gas leakage problem is observed from stem valve assembly. The window indication appeared on control panel is attached h/w outage proposal. Therefore, it is very necessary to attend the same on top priority.
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	21/06/2022	09:48			PO	Premonsoon Maintenance Work
220 KV MAINBAY Outages/Trippings							
.220 KV BUS-1 PT BAY @ KARAD I-220 KV	IntraState	20/06/2022	10:11	20/06/2022	11:52	PO	Testing of PT
.220 KV BUS-2 PT BAY @ KARAD I-220 KV	IntraState	20/06/2022	12:08	20/06/2022	13:59	PO	Testing of PT
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
PADGHE - TEMGHAR - 2	IntraState	15/06/2022	00:11			PO	Bunching of 220KV Padgha-Temghar -1 & 2 line at Loc no. 80 and jumper removing at Loc. no.80 & 81 for diversion of 220KV Padgha-Temghar 2 line bay to 220KV Padgha-Temghar-1 line bay at Padgha S/s by availing simultaneous outages on 220KV Padgha-Temghar -1 & 2 line.
BOISAR - VERSOVA	IntraState	15/06/2022	06:51			PO	Bunching on Tower no BTL 16, to facilitate Modification / relocation of existing tower no BTL 13 to BTL 15 for NHSRCL projectNote: Post bunching of line, the configuration of line will change as below:1.220 kV Dahanu - Virar and 220 kV Viraj - Versova. 2.MSETCL Boisar will be disconnected from the AEML Versova and MSETCL Viraj for a period of 10 days (i.e.from 15/06/2022 to 24/06/2022). 3.Normalization of bunching shall be carried out on 25/06/2022
BOISAR II - VIRAJ	IntraState	15/06/2022	07:06			PO	Bunching on Tower no BTL 16, to facilitate Modification / relocation of existing tower no BTL 13 to BTL 15 for NHSRCL projectNote: Post bunching of line, the configuration of line will change as below:1.220 kV Dahanu - Virar and 220 kV Viraj - Versova. 2.MSETCL Boisar will be disconnected from the AEML Versova and MSETCL Viraj for a period of 10 days (i.e.from 15/06/2022 to 24/06/2022). 3.Normalization of bunching shall be carried out on 25/06/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 20/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 21/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BHIRA - KARANJADE 8	IntraState	20/06/2022	00:41	20/06/2022	05:45	PO	ATTENDING HOT SPOT ON LINE GOD AT BHIRA
VITTAL SUGAR CO GEN (VSSK) - KARKAMBH	IntraState	20/06/2022	10:05	20/06/2022	15:56	PO	Outage is required for 1) For changing / replacement of faulty string at loc no. 126, 128, 130, 133.
URAN - ONGC URAN	IntraState	20/06/2022	10:06	20/06/2022	19:02	EO	Attending Trip Circuit Supervision Problem by Testing Division Panvel.
NAGOTHANE - IPCL	IntraState	20/06/2022	10:36	20/06/2022	13:16	PO	For emergency tree cutting work
ADLABS - PEDAMBE	IntraState	20/06/2022	12:15	20/06/2022	19:02	PO	Outage tree cutting work and other line maintenance work.
MUDSHINGI - CHIKODI	IntraState	20/06/2022	13:50	20/06/2022	15:10	T	TRIPPED ON DIST. PROTECTION
IPCL - SPCL	IntraState	20/06/2022	14:50	20/06/2022	16:16	PO	For emergency tree cutting work
CHALISGAON - BABHALESHWAR	IntraState	20/06/2022	16:22	20/06/2022	19:46	T	TRIPPED ON DIST. PROTECTION
MALINAGAR - TEMBHURNI	IntraState	21/06/2022	10:20			PO	Outage is required 1) For changing / replacement of faulty string at loc no. 119, 121, 127, 130, 131. 2) Disc Cleaning work from loc no. 70 to 82.
MHAISAL - ALKUD	IntraState	21/06/2022	10:28			PO	Quarterly maintenance and diagnostic testing work
MAHAD - KANDALGAON	IntraState	21/06/2022	11:38			PO	Outage tree cutting at various locations and other line maintenance work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132-110 KV 100MVA ICT 1	IntraState	21/06/2022	10:01			PO	OLTC overhauling work
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shifting these lines on new Multicircuit Towers between Darave to Vashi.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 21/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De- Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage