

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 20/Sep/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	104.172	2261.207	1) Gujrat	9.346	183.003
2) Hydro	9.756	246.888	2) Madhya Pradesh	5.246	59.677
3) Gas	1.921	55.001	3) Chattisgarh	4.560	70.430
Total MSPGCL	115.849	2563.096	4) Maharashtra	148.294	3021.814
B) 1) APML	60.172	1272.571	5) Goa (Amona)	-1.286	-23.795
2) JSWEL	17.722	364.745	Total	166.160	3311.129
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.427	656.417
4) RPL(AMT)	17.639	326.290	b) Mumbai Drawl	34.856	722.420
5) SWPGPL	4.054	87.812	c) MSEDCL Bilateral *	67.782	1096.684
6) Other IPP	5.660	113.420	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.411	656.227
C) 1) TPCL Thermal	10.185	229.771	Include PX	0.000	0.000
2) TPCL Hydro	7.482	107.726	Standby	0.016	0.190
3) TPCL Gas	0.000	13.433	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.546	183.208	1) MSEDCL	377.806	7736.032
D) STATE			2) Mumbai Discoms	60.069	1256.559
1) Thermal	227.150	4839.024	3) Other Discoms	9.328	180.244
(A1+C1+C4+(B1-B6))			TOTAL STATE	447.203	9172.835
2) Hydro (A2+C2)	17.238	354.614			
3) Gas (A3+B7+C3)	1.921	68.434			
4) Wind	26.898	428.085			
6) SOLAR	7.836	171.548			
TOTAL STATE	281.043	5861.705			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4677	3884	4936	3914
MSPGCL Hydro	291	291	1267	181
MSPGCL Gas	87	15	92	90
MSPGCL Total Generation	5055	4190	6295	4185
Central Sector Receipt	8620	7973	6597	5127
WIND	873	895	1200	1511
CPP / IPP Thermal	4237	4218	5463	4006
CPP / IPP Gas	0	0	0	0
SOLAR	781	1065	0	0
Exchange with Mumbai	-1953	-2153	-1361	-927
MSEDCL DEMAND MET	17174	15762	17763	13592
Load Shedding	0	0	0	0
MSEDCL DEMAND	17174	15762	17763	13592
TPCL GENERATION	615	592	1039	647
AEML GENERATION	299	291	444	284
MUMBAI DEMAND	2867	3036	2844	1858
OTHER DISCOM DEMAND	439	426	431	310
STATE DEMAND MET	20480	19224	21038	15760
STATE DEMAND	20480	19224	21038	15760
Frequency (Hz)	50.01	49.99	50.03	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 13.01 Hrs	49.84 Hz at 14.28 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 20/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.89	199.54	468	369
Unit 9	0.00	0.00	0	0
Unit 10	10.26	202.39	491	375
Total	20.16	441.29		
Bhusawal				
Unit 3	2.90	42.22	140	110
Unit 4	9.04	164.04	470	285
Unit 5	0.00	37.41	0	0
Total	11.94	243.67		
Parli				
Unit 6	4.10	85.55	203	148
Unit 7	3.89	68.05	198	133
Unit 8	3.56	73.78	160	136
Total	11.54	227.38		
Chandrapur				
Unit 3	3.20	57.04	155	120
Unit 4	3.09	59.66	145	118
Unit 5	6.50	103.24	325	215
Unit 6	6.32	107.04	330	163
Unit 7	1.26	108.91	273	0
Unit 8	0.00	49.00	0	0
Unit 9	8.50	189.28	432	288
Total	28.86	674.17		
Paras				
Unit 3	4.75	86.66	228	146
Unit 4	4.23	86.14	211	148
Total	8.98	172.79		
Khaparkheda				
Unit 1	2.86	52.50	135	105
Unit 2	0.00	38.82	0	0
Unit 3	3.38	66.94	174	127
Unit 4	3.14	58.34	163	118
Unit 5	7.92	162.55	465	270
Total	17.31	379.14		
Nasik				
Unit 3	0.00	32.57	0	0
Unit 4	2.78	33.65	129	100
Unit 5	2.61	56.54	126	0
Total	5.39	122.76		
Uran				
All Units	1.92	55.00	92	0
Total	1.92	55.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.55	11.66	24	22
Total	0.55	11.66		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.92	46.41	425	35
Stage 4	1.57	39.39	481	0
Stage 3	1.16	22.78	160	0
Total	4.64	108.58		
Hydro				
KDPH	0.43	3.96	18	18
VTRNA	0.75	15.28	61	0
TILLARI	0.46	9.64	58	0
BHIRA T.R.	0.16	8.30	80	0
SMLHY_PTN	2.56	84.83	117	97
GHATGHAR	0.20	4.63	125	0
Total	4.56	126.64		
Wind				
Total	26.90	428.08	0	0
Total	26.90	428.08		
CPP				
APML(Mus)	60.17	1272.57	0	0
JSWEL(Mus)	17.72	364.74	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	17.64	326.29	0	0
SWPGPL-Mus	4.05	87.81	0	0
Other(Mus)	5.66	113.42	0	0
Total	105.25	2164.84		
SOLAR				
Total	7.84	171.55	0	0
Total	7.84	171.55		
Tata				
Trombay 5	6.92	154.74	420	262
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	8.68	0	0
Trombay 7B	0.00	4.76	0	0
TATA Hydro	7.48	107.73	439	176
Trombay 8	3.27	75.03	180	131
Total	17.67	350.93		
AEML				
DTPS U-1&2	7.55	183.21	444	284
Total	7.55	183.21		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	104.17	2261.21	MSPGCL Total	115.85	2563.10
			MSPGCL Thml+Gas	106.09	2316.21	Koyna 1,2 & 4 Total	3.48	85.80
			MSPGCL Hydro	9.76	246.89	State Total	281.04	5861.70

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 20/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	3922	179	90	4191	1340	4170	0	0	6074	6022	-1016	14346	0	14346	2105	361	16812	50.02
2	3880	181	89	4150	1442	4130	0	0	5970	5747	-926	14212	0	14212	1964	331	16507	50.02
3	3914	181	90	4185	1511	4006	0	0	5747	5127	-927	13592	0	13592	1858	310	15760	50.02
4	3875	182	90	4147	1415	4045	0	0	5777	5513	-908	13917	0	13917	1786	295	15998	50.00
5	3867	269	89	4225	1245	4108	0	0	6112	6094	-879	14479	0	14479	1786	314	16579	49.98
6	4176	664	89	4929	1173	4034	0	0	6313	6377	-870	15308	0	15308	1916	335	17559	50.02
7	4800	728	89	5617	1132	4760	0	25	6698	6711	-1030	16854	0	16854	2095	361	19310	49.98
8	4909	378	88	5375	1032	4782	0	213	7637	7547	-1245	17314	0	17314	2300	390	20004	49.99
9	4764	345	88	5197	876	4627	0	513	8042	8121	-1612	17312	0	17312	2583	410	20305	49.99
10	4677	291	87	5055	873	4237	0	781	8599	8620	-1953	17174	0	17174	2867	439	20480	50.01
11	4467	299	28	4794	886	4261	0	863	8660	8536	-2136	16779	0	16779	3066	425	20270	50.03
12	4214	299	0	4513	850	4280	0	1030	8469	8267	-2188	16329	0	16329	3126	423	19878	50.01
13	3884	291	15	4190	895	4218	0	1065	8142	7973	-2153	15762	0	15762	3036	426	19224	49.99
14	3841	295	85	4221	901	3897	0	1090	7753	7914	-1982	15621	0	15621	2858	420	18899	50.03
15	3975	431	87	4493	1015	3748	0	956	7792	7672	-1946	15509	0	15509	2840	429	18778	49.96
16	3991	297	87	4375	1274	4058	0	706	7765	6899	-1645	15247	0	15247	2875	420	18542	50.03
17	3973	318	91	4382	1303	3916	0	441	7559	7585	-1653	15550	0	15550	2832	424	18806	49.99
18	4466	387	91	4944	1166	4407	0	149	7273	7240	-1694	15790	0	15790	2792	422	19004	49.97
19	4690	1254	91	6035	1253	5046	0	4	6899	6715	-1554	17077	0	17077	2829	422	20328	49.95
20	4936	1267	92	6295	1200	5463	0	0	6374	6597	-1361	17763	0	17763	2844	431	21038	50.03
21	4965	411	91	5467	1131	5224	0	0	6698	6514	-1444	16475	0	16475	2675	417	19567	50.04
22	4970	344	91	5405	1031	4959	0	0	6473	6170	-1352	15830	0	15830	2505	383	18718	50.02
23	4740	269	92	5101	1072	4494	0	0	6533	6286	-1255	15317	0	15317	2334	381	18032	50.02
24	4276	196	91	4563	882	4377	0	0	6265	5913	-1127	14246	0	14246	2197	362	16805	50.01
MUs	104.17	9.76	1.92	115.85	26.90	105.25	0.00	7.84	169.62	166.16	-34.86	377.81	0.00	377.81	60.07	9.33	447.20	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 20/Sep/2022

Position as on 6.30 Hrs of 21/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53	21/09/2022	14:48	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	
IPP	SWPGPL U-2	135	14/09/2022	04:12	20/09/2022	08:13	Vibration high ID fan	25/09/2022
TPC-G	Trombay 7A	120	14/09/2022	05:36		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	14/09/2022	05:50		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	14/09/2022	21:39		Continued.	ID Fan Problem	25/09/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 20/Sep/2022

Position as on 6.30 Hrs of 21/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 7	500	16/09/2022	10:09	20/09/2022	18:25	Boiler Tube Leakage	20/09/2022
MSPGCL	Khaparkheda Unit 2	210	17/09/2022	13:00		Continued.	wet coal	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59		Continued.	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	29/09/2022
MSPGCL	Bhusawal Unit 5	500	19/09/2022	22:30		Continued.	Boiler Tube Leakage	24/09/2022
MSPGCL	Nasik Unit 5	210	20/09/2022	23:00	21/09/2022	03:13	Flame Failure	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 20/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 21/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	13/09/2022	21:00		Continued.	T	Reason awaited
TIE BAY - 405 OF SOLAPUR PG @ ALKUD	IntraState	20/09/2022	11:47	20/09/2022	21:51	PO	QM Work
417 TIE BAY OF ICT 1	IntraState	21/09/2022	12:23	21/09/2022	14:51	PO	CB diagnostic and CT diagnostic Testing
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BUS - 2 @ ALKUD	IntraState	20/09/2022	11:48	20/09/2022	20:26	PO	QM Work
MAIN BAY (416) OF 500MVA ICT - 1 @ TAPTITANDA	IntraState	20/09/2022	11:52	20/09/2022	15:16	PO	CB diagnostic and CT diagnostic Testing
MAIN BAY - 404 OF SOLAPUR PG @ ALKUD	IntraState	20/09/2022	12:10	20/09/2022	21:50	PO	QM Work
400 KV LINE Outages/Trippings							
SOLAPUR PG - ALKUD	InterState	20/09/2022	12:10	20/09/2022	21:50	PO	QM Work
KORADI 2-WARDHA (PG)	InterState	21/09/2022	08:55		Continued.	PO	Diversion of 400 kv Koradi-Wardha Line through 6 nos of Newly constructed tower of POWERGRID. Configuration of 400 kv Koradi Bays at Wardha shall remain the same. MSETCL 400 kv IEPL-Warora Line shall be in non- A/R Mode for safety precautions
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38		Continued.	T	Y Phase Ground Fault
KHADKA-AURANGABAD (WALUJ)	IntraState	15/09/2022	21:37	20/09/2022	06:53	HT	To control OV
KARAD - LONIKAND I	IntraState	17/09/2022	08:47	20/09/2022	08:42	HT	For load Management
KORADI-NANDGAONPETH (RPL)	IntraState	20/09/2022	06:42	20/09/2022	19:46	PO	various line maintenace works of missing and loose bolts and nuts refixing on jumpers and hardwares
KARAD - LONIKAND I	IntraState	20/09/2022	14:34	21/09/2022	08:47	HT	To control line loading in Mumbai system
CHANDRAPUR GCR - CHANDRAPUR HVDC - 2	IntraState	20/09/2022	15:27	20/09/2022	21:58	EO	1. To attend the work of replacement of damaged scissor assembly and 2. Hanger rod assembly by hot line technique.
KHADKA-AURANGABAD (WALUJ)	IntraState	21/09/2022	00:31	21/09/2022	08:24	HT	For controlling Over Voltage
AKOLA - KHADKA (BHUSAWAL)	IntraState	21/09/2022	08:58	21/09/2022	08:58	PO	For attending SF6 gas leakage problem from R Pole by OEM
KHADKA-AURANGABAD (WALUJ)	IntraState	21/09/2022	21:52		Continued.	HT	For Voltage control
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 1 @ DHULE	IntraState	20/09/2022	10:29	20/09/2022	14:05	PO	Routine Maint & testing work
400/220/33 KV 500 MVA ICT - 3 @ DHULE	IntraState	21/09/2022	09:56	21/09/2022	21:47	PO	Routine Maint & testing work
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	21/09/2022	10:53	21/09/2022	17:35	PO	Post Monsoon Maintenance Work
220 KV MAINBAY Outages/Trippings							
BUS SETION - 2 @ KANDALGAON	IntraState	20/09/2022	07:48	21/09/2022	14:42	PO	For Replacing Single Bus to Twin Bus of 220 KV Bus section No. 02 & 220 KV HyBrid Pass No. 01 Overhauling Work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 21/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS @ KARKAMB	IntraState	21/09/2022	10:25	21/09/2022	17:25	PO	Outage is required for Testing of 220 kV Busbar protection relay, tan delta of 220 kV PT & Quarterly maintenance of 220 KV Bus
220 KV LINE Outages/Trippings							
BOISAR - VERSOVA	IntraState	15/09/2022	10:39	21/09/2022	15:41	PO	Bunching of lines at location no.SS 82 to facilitate the following project work:NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223.DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	15/09/2022	11:00	21/09/2022	16:23	PO	Bunching of lines at location no.SS 82 to facilitate the following project work:NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223.DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - PADGHE	IntraState	19/09/2022	08:40		Continued.	HT	H/T TO CONTROL LINE LOADING OF BBLR
KALMESHWAR-PANDHURNA	IntraState	20/09/2022	07:16	20/09/2022	11:56	T	TRIPPED ON DISTANCE PROTECTION.
KARAD - VITA CKT- 2	IntraState	20/09/2022	09:17	20/09/2022	17:44	PO	1.String Replacement work at Loc no.44B 2.Nut bolt tightening & fixing repaired sleeve at Loc no.23B & 34B
BABLESHWAR-BABLESHWAR(400KV)-I	IntraState	20/09/2022	10:18	20/09/2022	15:52	PO	CT Tan D
NEW KOYNA - PEDAMBE	IntraState	20/09/2022	11:56	20/09/2022	12:26	T	Back-up Protection
PEDHAMBE ONI LINE	IntraState	20/09/2022	11:56	20/09/2022	13:06	T	Distance Protection
KALWA - MULUND 1	IntraState	20/09/2022	12:09	20/09/2022	18:50	EO	To attend hot spot at Loc. No. 5, 6 & 7 by re-pressing dead end h/w & jumper cone.
RANJANGAON - U TECH SUGAR CKT	IntraState	20/09/2022	14:00	20/09/2022	19:52	PO	For Isolator maintenance work & Half yearly maintenance work.
BOISAR - VERSOVA	IntraState	21/09/2022	08:30	21/09/2022	15:41	EO	Debunching of lines at location no.SS 82
DAHANU - VERSOVA	IntraState	21/09/2022	08:30	21/09/2022	16:23	EO	Deunching of lines at location no.SS 82
BIDRI - SAWANTWADI	IntraState	21/09/2022	09:23	21/09/2022	17:23		For CB timing & CRM testing
PARANDA-BARSHI	IntraState	21/09/2022	09:26	21/09/2022	12:57	PO	Outage is required for Quarterly Maintenance
HAMIDWADA - MUMEWADI	IntraState	21/09/2022	10:15	21/09/2022	13:29	PO	For TAN DELTA Testing of CT,Relay Testing & Bay equip.Maintenance Work.
KALMESHWAR-PANDHURNA	IntraState	21/09/2022	10:29	21/09/2022	23:06	PO	Diagnostic testing work and routine maintence work
BELEWADI - MUMEWADI LINE	IntraState	21/09/2022	14:32	21/09/2022	18:04	PO	For TAN DELTA Testing of CT,Relay Testing & Bay equip.Maintenance Work.
KHARGHAR - NERUL	IntraState	21/09/2022	15:05	21/09/2022	19:28	EO	For hot spot attending at Loc. No. 2B, 3B, 4B & 5B.
JEJURI - BARAMATI	IntraState	21/09/2022	15:48	21/09/2022	18:38	EO	B Phase String Insulator Flashover Found at location no-18 CP .
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 21/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33KV 25MVA TF NO.2 @ SAYNE	IntraState	15/09/2022	15:40		Continued.	PO	Work of Replacement of 220/33kv 25 MVA TF2 by 220/33kv 50MVA BHEL TF
220/33KV 50MVA PTR 2 @ MUMEWADI	IntraState	20/09/2022	10:10	20/09/2022	15:15	PO	For Diagnostic testing work of T/F,Relay testing & its HV/LV side equipmemnts and Maintenance Work
220/33kv 125 MVA TF 2 @ BORIVALI (AEML)	IntraState	20/09/2022	10:31	20/09/2022	18:50	PO	Disconnection of 33kv Cables from TR-2 to Sw. No. 10
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	21/09/2022	09:40	21/09/2022	16:51	PO	Relay testing work
220/132-110KV 200MVA ICT 2 @ MIRAJ	IntraState	21/09/2022	10:00		Continued.	PO	OLTC Overhauling work
220/33 KV 125MVA TF-3 @ BORIVALI (AEML)	IntraState	21/09/2022	10:23		Continued.	PO	33kv Cable connection at TR-3 end and Sw. No. 10 & Stability test.
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	IntraState	21/09/2022	11:30	21/09/2022	12:57	PO	Outage is required for Diagnostic testing work
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage