

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 20/Nov/2019 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	124.802	2181.054	1) Gujrat	4.259	61.480
2) Hydro	16.532	174.673	2) Madhya Pradesh	10.651	170.136
3) Gas	10.301	170.214	3) Chattisgarh	6.520	131.440
Total MSPGCL	151.635	2525.941	4) Maharashtra	113.880	2249.637
B) 1) APLM	73.863	1403.502	5) Goa (Amona)	-0.572	-9.966
2) JSWEL	19.287	390.535	Total	134.738	2602.727
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.358	511.575
4) RPL(AMT)	0.000	49.977	b) Mumbai Drawl	27.567	570.687
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	26.402	498.297
6) Other IPP	8.145	158.903	Include PX	-0.446	-5.759
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.358	511.575
C) 1) TPCL Thermal	14.516	269.894	Include PX	6.117	170.261
2) TPCL Hydro	4.452	77.962	Standby	0.000	0.000
3) TPCL Gas	4.366	84.559	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.769	199.169	1) MSEDCL	372.863	6819.754
D) STATE			2) Mumbai Discoms	61.670	1202.266
1) Thermal	251.382	4653.034	TOTAL STATE	434.533	8022.020
(A1+C1+C4+(B1-B6))					
2) Hydro	20.984	252.635			
(A2+C2)					
3) Gas	14.667	254.773			
(A3+B7+C3)					
4) Wind	7.429	149.465			
6) SOLAR	5.333	109.391			
TOTAL STATE	299.795	5419.298			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5513	5401	5425	4859
MSPGCL Hydro	539	1257	1497	82
MSPGCL Gas	410	415	424	446
MSPGCL Total Generation	6462	7073	7346	5387
Central Sector Receipt	6642	6117	5760	4472
WIND	247	175	235	457
CPP / IPP Thermal	4386	4358	4402	3748
CPP / IPP Gas	0	0	0	0
SOLAR	814	365	0	0
Exchange with Mumbai	-1456	-1301	-1236	-792
MSEDCL DEMAND MET	17095	16787	16507	13272
Load Shedding	0	0	0	0
MSEDCL DEMAND	17095	16787	16507	13272
TPCL GENERATION	1140	1242	1267	675
AEML GENERATION	499	498	499	375
MUMBAI DEMAND	3095	3041	3002	1842
STATE DEMAND MET	20190	19828	19509	15114
STATE DEMAND	20190	19828	19509	15114
Frequency (Hz)	50.02	49.98	50.01	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.23 Hz at 12.01 Hrs	49.73 Hz at 07.26 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation, Maximum, Minimum for 20/Nov/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.92	221.63	550	460
Unit 9	0.00	190.34	0	0
Unit 10	12.16	197.49	555	450
Total	24.09	609.46		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.38	186.86	430	350
Unit 5	9.48	188.95	460	350
Total	18.86	375.81		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.32	43.62	250	191
Unit 7	5.49	43.52	248	191
Unit 8	5.39	44.22	249	187
Total	16.19	131.36		
Chandrapur				
Unit 3	3.64	65.72	169	117
Unit 4	2.99	6.48	150	106
Unit 5	8.85	146.11	380	342
Unit 6	10.01	161.89	475	360
Unit 7	0.00	0.00	0	0
Unit 8	10.51	198.63	500	360
Unit 9	9.79	184.47	470	360
Total	45.79	763.28		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkhedda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	1.25	21.75	183	0
Unit 4	4.24	30.95	195	160
Unit 5	10.14	171.27	475	360
Total	15.63	223.97		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.63	68.64	162	0
Unit 5	3.62	8.53	193	0
Total	4.25	77.17		
Uran				
All Units	10.30	170.21	459	403
Total	10.30	170.21		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	5.60	20	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.03	5.60		
Koyna				
Stage 1-2	5.32	58.97	500	35
Stage 4	7.17	60.31	969	0
Stage 3	2.57	26.38	236	0
Total	15.06	145.66		
Hydro				
KDPH	0.00	1.01	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	1.61	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.27	5.62	80	0
RNGR+BHTSA	0.40	5.84	17	16
BHANDARDRA	0.00	0.19	0	0
ELDARY	0.37	5.08	22	11
SMLHY_PTN	0.07	3.94	3	2
GHATGHAR	0.37	5.72	125	0
Total	1.47	29.01		
Wind				
Total	7.43	149.46	0	0
Total	7.43	149.46		
CPP				
APML(Mus)	73.86	1403.50	0	0
JSWEL(Mus)	19.29	390.54	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	49.98	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.14	158.90	0	0
Total	101.30	2002.92		
SOLAR				
Total	5.33	109.39	0	0
Total	5.33	109.39		
Tata				
Trombay 5	9.85	174.80	483	296
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	53.60	117	115
Trombay 7B	1.58	30.96	67	65
Trombay 8	4.67	95.09	196	194
TATA Hydro	4.45	77.96	411	0
Total	23.33	432.42		
AEML				
DTPS U-1&2	10.77	199.17	502	369
Total	10.77	199.17		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	124.80	2181.05	MSPGCL Total	151.64	2525.94
			MSPGCL Thml+Gas	135.10	2351.27	Koyna 1,2 & 4 Total	12.49	119.28
			MSPGCL Hydro	16.53	174.67	State Total	299.80	5419.30

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 20/Nov/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4775	132	445	5352	344	3727	0	0	5261	5129	-1162	13390	0	13390	2222	15612	49.94
2	4782	77	436	5295	384	3732	0	0	5021	5045	-981	13475	0	13475	2042	15517	49.99
3	4819	77	448	5344	397	3702	0	0	4764	4697	-863	13277	0	13277	1925	15202	49.99
4	4859	82	446	5387	457	3748	0	0	4707	4472	-792	13272	0	13272	1842	15114	49.98
5	4825	227	435	5487	427	3826	0	0	4816	4917	-770	13887	0	13887	1816	15703	49.96
6	5434	353	440	6227	319	4283	0	0	5100	5248	-815	15262	0	15262	1911	17173	49.98
7	5688	1204	459	7351	388	4440	0	7	5278	5245	-742	16689	0	16689	2065	18754	49.95
8	5583	1697	439	7719	348	4430	0	132	5346	5480	-817	17292	0	17292	2210	19502	49.90
9	5425	1474	435	7334	277	4410	0	372	5544	5723	-968	17148	0	17148	2490	19638	50.00
10	5377	957	440	6774	292	4426	0	612	5847	5897	-1104	16897	0	16897	2789	19686	49.98
11	5461	445	424	6330	306	4406	0	784	6304	6449	-1273	17002	0	17002	2999	20001	50.02
12	5513	539	410	6462	247	4386	0	814	6573	6642	-1456	17095	0	17095	3095	20190	50.02
13	5443	670	405	6518	194	4369	0	799	6425	6331	-1508	16703	0	16703	3059	19762	50.01
14	5419	418	413	6250	179	4363	0	720	6321	6426	-1431	16507	0	16507	2967	19474	50.00
15	5425	814	403	6642	143	4352	0	532	6428	6524	-1429	16764	0	16764	3030	19794	50.01
16	5401	1257	415	7073	175	4358	0	365	6252	6117	-1301	16787	0	16787	3041	19828	49.98
17	5423	1455	408	7286	181	4352	0	177	5758	5762	-1254	16504	0	16504	3018	19522	49.99
18	5482	1181	421	7084	172	4402	0	19	5569	5620	-1201	16096	0	16096	2970	19066	50.00
19	5425	1497	424	7346	235	4402	0	0	5709	5760	-1236	16507	0	16507	3002	19509	50.01
20	5312	953	434	6699	286	4367	0	0	5726	5672	-1137	15887	0	15887	2887	18774	50.02
21	4931	378	428	5737	371	4354	0	0	5511	5620	-1324	14758	0	14758	2734	17492	50.00
22	4729	475	421	5625	439	4358	0	0	5257	5312	-1347	14387	0	14387	2588	16975	50.02
23	4656	101	440	5197	439	4188	0	0	5309	5296	-1335	13785	0	13785	2516	16301	50.02
24	4615	69	432	5116	429	3914	0	0	5328	5354	-1321	13492	0	13492	2452	15944	50.01
MUs	124.80	16.53	10.30	151.63	7.43	101.30	0.00	5.33	134.15	134.74	-27.57	372.86	0.00	372.86	61.67	434.53	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 20/Nov/2019

Position as on 6.30 Hrs of 21/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage. Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
MSPGCL	Nasik Unit 4	210	20/11/2019	04.15		Continued.	ID Fan Problem(Converted for Zero Schedule from 05.00hrs DT. 21-11-2019 and Continued for Annual Overhaul From 01.12.2019	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	02/11/2019	10.35	20/11/2019	01.46	Boiler Tube Leakage(Converted to Zero Schedule from 19.05Hrs DT.03-11-2019)	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 20/Nov/2019

Position as on 6.30 Hrs of 21/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	06/11/2019	19.23		Continued.	Turbine Vibration	
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	JSW (J) U3	300	10/11/2019	18.16		Continued.	Zero schedule.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 9	660	17/11/2019	19.00	21/11/2019	04.22	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 3	210	20/11/2019	07.41	21/11/2019	15.08	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	21/11/2019	06.18	21/11/2019	07.46	Boiler feed Pump.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 21/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Tirora ckt-II	IntraState	20/11/2019	09.22	20/11/2019	17.12	PO	Replacement of Line 2 Reactor.
765 KV ICT Outages/Trippings							
765/400kv 1500MVA ICT-I@Koradi-III	IntraState	21/11/2019	12.57	21/11/2019	19.14	PO	Maintenance Work.
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	20/11/2019	18.09		Continued.	PO	Annual Maintenance & Diagnostic Testing Work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	18/11/2019	20.38		Continued.	HT	Over Voltage
Dhule(MS)- Dhule(BDTCL) -I	InterState	19/11/2019	10.03	20/11/2019	09.31	PO	Routine Maintenance work(RFC at 20.05Hrs)
Dhule(MS)- Dhule(BDTCL) -II	InterState	20/11/2019	10.10	20/11/2019	17.05	PO	Routine Maintenance Work
Akola II - RPL(Rattanindia) Ckt I	IntraState	19/11/2019	06.01	20/11/2019	09.52	PO	Replacement of CVT In R-Phase, CB DCRM, Timing, Mechanism Timing.
Khadka-Aurangabad (Waluj)	IntraState	19/11/2019	20.27	20/11/2019	08.25	HT	Over Voltage
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	20/11/2019	09.41	20/11/2019	12.43	PO	Replacement Work At AMEL End.
Bhusawal-Aurangabad	IntraState	20/11/2019	19.52	21/11/2019	06.56	HT	Over Voltage
Khadka- Deepnagar Ckt 1	IntraState	21/11/2019	07.09	21/11/2019	17.10	PO	String Replacement.
Warora -IEPL	IntraState	21/11/2019	09.53	21/11/2019	18.47	PO	Maintenance/Testing Work.
Jejuri- Koynastage-IV	IntraState	21/11/2019	10.05	21/11/2019	19.29	PO	Insulator String Replacement.
Khadka-Aurangabad (Waluj)	IntraState	21/11/2019	19.58		Continued.	HT	Over Voltage
Chandrapur II - Chandrapur ckt I	IntraState	21/11/2019	22.32		Continued.	EO	Drilling & Cutting of Panel For Cable.
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	20/11/2019	10.50	20/11/2019	13.54	PO	CB & CT Diagnostic Testing Work.
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	21/11/2019	10.13	21/11/2019	14.57	PO	Diagnostic Teasting.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Trombay - Mulund	IntraState	16/11/2019	19.59		Continued.	PO	Piling work At LOC 5 Completed.
Koradi-Khaperkheda	IntraState	18/11/2019	11.12	21/11/2019	21.11	HT	Over Voltage
Waluj - Chitegaon li	IntraState	19/11/2019	20.39	20/11/2019	04.39	T	Backup Protection
Trombay MSETCL Tie 1	IntraState	19/11/2019	21.32	20/11/2019	06.58	PO	Strengthening of RCC Beam alongwith Bus Section-III at Trombay
Nagothane-Wadkhal II	IntraState	20/11/2019	08.18	20/11/2019	19.20	PO	Replacement of Conductor.
Khaparkheda-Ambazari-li	IntraState	20/11/2019	09.09	20/11/2019	13.55	PO	SSN To DSN Conversion Work.
Kandalgaon - Koyna (Pophali)	IntraState	20/11/2019	09.10	20/11/2019	18.37	PO	Tree Cutting and Jumper Nut Bolt Tightening.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	20/11/2019	09.18	20/11/2019	18.54	PO	Overhauling of CB.
Peth- Mudshingi -I	IntraState	20/11/2019	10.08	20/11/2019	18.50	PO	Stringing of Earthwire.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 21/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TBC @ Parli-II	IntraState	20/11/2019	10.20	20/11/2019	13.00	PO	CR CRM and Timing Measurement.
AKOLA ANJANGAON (VIHIGAON) CKT-II	IntraState	20/11/2019	10.57	20/11/2019	19.15	PO	Diagnostic Testing Work, Timing of IP and PI.
Jamde-Dondaicha 1	IntraState	20/11/2019	11.06	20/11/2019	14.16	PO	Annual Diagnostic and Maintenance Work.
Osmanabad - Barshi	IntraState	20/11/2019	12.00	20/11/2019	15.53	PO	Replacement of Flashover Suspension String.
Miraj - Mhaishal	IntraState	20/11/2019	12.15	20/11/2019	16.40	PO	Testing Work
Jamde-Dondaicha 2	IntraState	20/11/2019	16.18	20/11/2019	16.29	PO	Annual Diagnostic and Maintenance Work.
Valve-Jamde	IntraState	20/11/2019	16.38	20/11/2019	18.02	PO	Diagnostic Testing Work.
Trombay MSETCL Tie 1	IntraState	20/11/2019	21.28	21/11/2019	06.38	PO	Construction Work.
Nagothane-Wadkhal II	IntraState	21/11/2019	08.04	21/11/2019	18.35	PO	Replacement Of Dead end Jumps
Deepnagar Bambhori	IntraState	21/11/2019	09.18	21/11/2019	17.30	PO	Faulty Disc Replacement.
Eklahare (Ocr)Nasik - Padghe 2	IntraState	21/11/2019	09.32	21/11/2019	18.57	PO	Insulator Replacement.
Karad-Nerle	IntraState	21/11/2019	09.40	21/11/2019	16.50	PO	CB overhauling/Maintenance.
Malegaon-Sayne	IntraState	21/11/2019	10.14	21/11/2019	13.41	EO	Attending Hot Spot
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	21/11/2019	10.23	21/11/2019	17.52	PO	CB overhauling/Maintenance.
Peth- Mudshingi -I	IntraState	21/11/2019	10.26	21/11/2019	17.48	PO	Earthwire Work.
Wani-Warora	IntraState	21/11/2019	11.15	21/11/2019	17.05	PO	Replacement Of B-Phase LA.
Adlabs - Pedambe	IntraState	21/11/2019	11.30	21/11/2019	19.20	EO	Tree cutting/HOT Spot.
220 KV ICT Outages/Trippings							
220/100 Kv 200 Mva Vijai Ict 3 @Padghe	IntraState	20/11/2019	10.08	20/11/2019	18.58	PO	Diagnostic Testing.
220/100 Kv 200 Mva Vijai Ict 3 @Padghe	IntraState	21/11/2019	10.03	21/11/2019	20.29	PO	Diagnositc Testing.
220/100 Kv 100 MVA ICT II @Kandalgaon	IntraState	21/11/2019	11.28	21/11/2019	18.00	PO	Maintenance/Testing Work.
220/132 KV 200MVA Vijai ICT-2 @Theur	IntraState	21/11/2019	13.26	21/11/2019	17.55	PO	Relay Replacement.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage