

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 20/Nov/2020 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	137.648	2582.799	1) Gujrat	0.213	16.806
2) Hydro	10.227	128.592	2) Madhya Pradesh	5.186	108.319
3) Gas	3.285	128.647	3) Chattisgarh	8.280	140.210
Total MSPGCL	151.160	2840.038	4) Maharashtra	145.820	2559.265
B) 1) APML	57.564	1226.249	5) Goa (Amona)	-1.571	-25.496
2) JSWEL	18.114	354.373	Total	157.928	2799.104
3) VIPL	0.000	0.000	a) Mumbai Schedule	21.337	414.933
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	22.442	461.209
5) WPCL	7.926	146.151	c) MSEDCL Bilateral *	31.726	576.924
6) Other IPP	16.366	283.657	Include PX	1.836	11.639
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	21.337	414.933
C) 1) TPCL Thermal	14.616	278.424	Include PX	13.154	251.685
2) TPCL Hydro	2.844	57.730	Standby	0.000	0.000
3) TPCL Gas	3.661	86.306	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.774	158.352	1) MSEDCL	398.173	7566.861
D) STATE			2) Mumbai Discoms	53.337	1042.020
1) Thermal	262.008	5030.005	TOTAL STATE	451.510	8608.881
(A1+C1+C4+(B1-B6))					
2) Hydro	13.071	186.322			
(A2+C2)					
3) Gas	6.946	214.953			
(A3+B7+C3)					
4) Wind	5.637	248.579			
6) SOLAR	5.920	129.919			
TOTAL STATE	293.582	5809.778			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5836	5795	5889	5574
MSPGCL Hydro	877	781	136	60
MSPGCL Gas	130	130	130	140
MSPGCL Total Generation	6843	6706	6155	5774
Central Sector Receipt	7875	7682	6040	5399
WIND	76	85	170	505
CPP / IPP Thermal	4400	4387	4455	4007
CPP / IPP Gas	0	0	0	0
SOLAR	824	816	0	0
Exchange with Mumbai	-1204	-1217	-834	-894
MSEDCL DEMAND MET	18814	18459	15986	14791
Load Shedding	0	0	0	0
MSEDCL DEMAND	18814	18459	15986	14791
TPCL GENERATION	964	948	1191	602
AEML GENERATION	500	500	498	282
MUMBAI DEMAND	2668	2665	2523	1778
STATE DEMAND MET	21482	21124	18509	16569
STATE DEMAND	21482	21124	18509	16569
Frequency (Hz)	49.98	49.99	50.02	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 13.03 Hrs	49.77 Hz at 01.18 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 20/Nov/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.76	221.65	549	390
Unit 9	11.84	187.42	525	400
Unit 10	0.00	71.95	0	0
Total	23.60	481.03		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.64	185.46	500	280
Unit 5	9.52	165.60	495	280
Total	19.16	351.06		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	8.84	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.41	96.22	250	195
Total	5.41	105.06		
Chandrapur				
Unit 3	4.13	76.20	177	170
Unit 4	3.82	72.41	160	157
Unit 5	10.32	180.45	440	390
Unit 6	9.66	182.00	420	380
Unit 7	0.00	0.00	0	0
Unit 8	11.24	180.19	475	460
Unit 9	11.23	218.70	477	455
Total	50.40	909.94		
Paras				
Unit 3	5.23	91.69	234	194
Unit 4	5.40	96.66	243	188
Total	10.63	188.35		
Khaparkheda				
Unit 1	3.69	70.83	160	135
Unit 2	3.84	76.44	170	140
Unit 3	0.00	60.50	0	0
Unit 4	4.08	79.27	187	140
Unit 5	10.56	161.61	460	425
Total	22.17	448.65		
Nasik				
Unit 3	3.04	32.26	138	108
Unit 4	3.24	66.45	152	127
Unit 5	0.00	0.00	0	0
Total	6.28	98.70		
Uran				
All Units	3.28	128.65	185	120
Total	3.28	128.65		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	2.65	27	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.04	2.65		
Koyna				
Stage 1-2	2.94	58.14	530	25
Stage 4	3.79	22.31	500	0
Stage 3	1.58	18.58	160	0
Total	8.31	99.02		
Hydro				
KDPH	0.00	2.05	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.11	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.18	3.28	40	0
RNGR+BHTSA	0.35	6.88	15	14
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.93	0	0
SMLHY_PTN	0.14	1.02	6	5
GHATGHAR	1.25	15.30	250	0
Total	1.92	29.57		
Wind				
Total	5.64	248.58	0	0
Total	5.64	248.58		
CPP				
APML(Mus)	57.56	1226.25	0	0
JSWEL(Mus)	18.11	354.37	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	7.93	146.15	0	0
Other(Mus)	16.37	283.66	0	0
Total	99.97	2010.43		
SOLAR				
Total	5.92	129.92	0	0
Total	5.92	129.92		
Tata				
Trombay 5	9.79	187.07	464	280
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.24	54.98	118	73
Trombay 7B	1.42	31.32	67	53
Trombay 8	4.82	91.36	231	136
TATA Hydro	2.84	57.73	395	2
Total	21.12	422.46		
AEML				
DTPS U-1&2	9.77	158.35	501	282
Total	9.77	158.35		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	137.65	2582.80	MSPGCL Total	151.16	2840.04
			MSPGCL Thml+Gas	140.93	2711.45	Koyna 1,2 & 4 Total	6.73	80.44
			MSPGCL Hydro	10.23	128.59	State Total	293.58	5809.78

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 20/Nov/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5414	75	185	5674	705	4019	0	0	5865	5780	-1113	15065	0	15065	2007	17072	49.96
2	5543	215	140	5898	579	4016	0	0	5778	5641	-990	15144	0	15144	1884	17028	49.93
3	5574	60	140	5774	505	4007	0	0	5778	5399	-894	14791	0	14791	1778	16569	49.97
4	5269	70	140	5479	397	3987	0	0	5842	5839	-829	14873	0	14873	1713	16586	49.96
5	5593	80	140	5813	351	4009	0	0	5913	5845	-799	15219	0	15219	1685	16904	49.98
6	5888	75	130	6093	261	4519	0	0	6139	6168	-856	16185	0	16185	1742	17927	49.98
7	5990	564	150	6704	200	4561	0	8	6442	6161	-728	16906	0	16906	1786	18692	50.01
8	5929	1211	140	7280	99	4344	0	151	6391	6490	-568	17796	0	17796	1899	19695	50.02
9	5953	1041	130	7124	65	4466	0	392	6736	6710	-789	17968	0	17968	2116	20084	50.00
10	5971	623	150	6744	90	4524	0	675	7189	7076	-1044	18065	0	18065	2377	20442	50.01
11	5872	768	120	6760	120	4395	0	799	7581	7948	-1171	18851	0	18851	2590	21441	50.03
12	5836	877	130	6843	76	4400	0	824	7752	7875	-1204	18814	0	18814	2668	21482	49.98
13	5795	781	130	6706	85	4387	0	816	7920	7682	-1217	18459	0	18459	2665	21124	49.99
14	5792	351	140	6283	55	4363	0	767	7968	8026	-1113	18381	0	18381	2571	20952	50.04
15	5820	411	120	6351	38	4336	0	740	7909	7879	-1139	18205	0	18205	2591	20796	49.99
16	5865	900	130	6895	37	4372	0	490	7665	7553	-1068	18279	0	18279	2580	20859	50.01
17	5884	933	130	6947	50	4368	0	222	7016	6674	-896	17365	0	17365	2523	19888	49.98
18	5895	571	130	6596	61	4449	0	36	6298	6167	-758	16551	0	16551	2473	19024	49.99
19	5889	136	130	6155	170	4455	0	0	6190	6040	-834	15986	0	15986	2523	18509	50.02
20	5863	80	140	6083	186	4236	0	0	6310	5879	-761	15623	0	15623	2476	18099	50.04
21	5450	75	140	5665	284	3569	0	0	6286	6430	-817	15131	0	15131	2323	17454	49.99
22	5365	175	130	5670	382	3439	0	0	6163	6475	-890	15076	0	15076	2203	17279	50.01
23	5478	80	140	5698	407	3369	0	0	6150	6176	-901	14749	0	14749	2112	16861	50.00
24	5720	75	130	5925	434	3380	0	0	6200	6015	-1063	14691	0	14691	2052	16743	50.01
MUs	137.65	10.23	3.29	151.16	5.64	99.97	0.00	5.92	159.48	157.93	-22.44	398.17	0.00	398.17	53.34	451.51	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 20/Nov/2020

Position as on 6.30 Hrs of 21/Nov/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koradi Unit 10	660	09/11/2020	01.28		Continued.	Air heater problem(Converted in to Annual Overhaul.From	
MSPGCL	Khaparkhedha Unit 3	210	19/11/2020	23.55		Continued.	ANNUAL OVERHAUL	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	29/09/2020	01.58		Continued.	Tripped On Generator Protection.	
MSPGCL	Parli Unit 7	250	22/10/2020	20.00		Continued.	Zero Schedule By MSEDCL	
IPP	JSW (J) U2	300	01/11/2020	04.44		Continued.	No Schedule	
MSPGCL	Parli Unit 6	250	02/11/2020	23.28		Continued.	Excess DM water consumption.	
MSPGCL	Uran Unit 5	108	20/11/2020	00.28		Continued.	Filter Replacement work	
IPP	Adani U-2	660	20/11/2020	06.23		Continued.	ID Fan Problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 21/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	19/10/2020	23.01		Continued.	PO	Abnormal sound from main tank of smoothing reactor at Chandrapur end
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	17/11/2020	17.33	21/11/2020	09.46	HT	Over Voltage
Akola Wardha li	InterState	20/11/2020	09.11	20/11/2020	19.28	PO	Replacement of Porcelain Insulator with polymer Insulators
Akola Wardha I	InterState	21/11/2020	06.53	21/11/2020	18.45	PO	Replacement of porcelain insulators with polymer insulators.
Dhule Sar'Sarovar I	InterState	21/11/2020	10.18		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Bhusawal-Aurangabad	IntraState	19/11/2020	18.19	20/11/2020	09.27	T	Over Voltage
Dhule - Bableshwar - II	IntraState	19/11/2020	20.03	20/11/2020	09.28	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	20/11/2020	09.26	20/11/2020	15.37	PO	Diagnostic testing and Bay Maint.work
Khadka-Aurangabad (Waluj)	IntraState	20/11/2020	18.20	21/11/2020	09.14	HT	Over Voltage
Dhule - Bableshwar - II	IntraState	20/11/2020	20.02	21/11/2020	09.23	HT	Over Voltage
New Koyna - Dabhol-I	IntraState	21/11/2020	09.50	21/11/2020	19.40	PO	Cold washing & Faulty string replacement work.
Koradi-Khaperkhedha li	IntraState	21/11/2020	11.09	21/11/2020	19.35	PO	Relay testing work.
Parly(MS)- Nanded ckt II	IntraState	21/11/2020	11.14	21/11/2020	21.27	PO	To attend broken conductor strand at loc 33.
Khadka-Aurangabad (Waluj)	IntraState	21/11/2020	17.43		Continued.	HT	Over Voltage
Dhule - Bableshwar - II	IntraState	21/11/2020	18.17		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220/33 Kv 315 MVA ICT II @Chandrapur GCR	IntraState	18/11/2020	19.25		Continued.	PO	Bursting Of HV Side R-Phase Bushing.
400/220/33 Kv 315 Mva ICT I @ Akola (M)	IntraState	20/11/2020	09.36		Continued.	PO	Tan Delta of Bushing
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Tillari Amona	InterState	02/11/2020	14.30		Continued.	PO	220 kv Amona Bay old CB Replacement (civil,Erection & Commissioning,testing)Work at 220 kv Tillari Switch yard.
EKLAHARE (OCR) Nasik - Navsari I	InterState	14/11/2020	17.19		Continued.	HT	Outage at Navsari end.
Kharghar-Borivali ckt II	IntraState	11/08/2020	01.45		Continued.	T	Special Repair Cable work.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
ANANDNAGAR - PALAVA	IntraState	13/11/2020	09.50	20/11/2020	12.17	PO	For Removing damaged E/W

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 21/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kalwa - Colourchem	IntraState	20/11/2020	08.24	20/11/2020	15.22	PO	Testing Work
Pedhambe - Oni	IntraState	20/11/2020	08.40	20/11/2020	18.05	PO	Cold washing of Insulator strings
Padghe - Wada	IntraState	20/11/2020	09.01	20/11/2020	18.18	PO	Tan Delta Measurment of CTs
Malegaon-Sayne	IntraState	20/11/2020	09.22	20/11/2020	17.40	PO	Diagnostic testing and Bay Maint.work
Nanded - Parli Ext. Ckt I	IntraState	20/11/2020	09.38	20/11/2020	19.26	PO	CT Replacement work
Malegaon-Satana	IntraState	20/11/2020	09.40	20/11/2020	10.50	PO	Diagnostic testing and Bay Maint.work
Jambhul - Anandnagar	IntraState	20/11/2020	09.53	20/11/2020	11.47	PO	For Removing damaged E/W
Eklahara(Ocr)(Nasik)-Raymond (Padagha-I)	IntraState	20/11/2020	10.48	20/11/2020	16.27	PO	Daignostic testing and Bay Maint.work
Kalmeshwar-Kalmeshwar Rly Tss 1	IntraState	20/11/2020	11.00	20/11/2020	15.09	PO	Tan Delta Measurment of CTs
MALEGAON - KALWAN CKT-1	IntraState	20/11/2020	11.13	20/11/2020	12.44	PO	Daignostic testing and Bay maint.work
Uran - Hoc 1	IntraState	20/11/2020	11.26	20/11/2020	18.00	PO	Replacement of B Phase CT
Nerul-Trombay	IntraState	20/11/2020	13.04	20/11/2020	17.11	PO	Diagnostic testing and Routine Maint.work
Loteparshuram- Dasturi Line	IntraState	20/11/2020	13.43	20/11/2020	19.24	T	Distance Protection
Dhule - Malegaon	IntraState	20/11/2020	14.10	20/11/2020	16.23	PO	Diagnostic testing and Bay Maint.work
Chalishaon-Malegaon	IntraState	20/11/2020	14.10	20/11/2020	16.23	PO	Routine Maintenance Work
Nanded - Parli Ext. Ckt II	IntraState	20/11/2020	14.22	20/11/2020	16.14	T	Trip CKT Faulty
Jejuri (400 Kv)- Baramati li	IntraState	20/11/2020	15.08	20/11/2020	17.24	PO	Replacement of Flashover Suspension String
Kalmeshwar-Kalmeshwar Rly Tss 2	IntraState	20/11/2020	15.21	20/11/2020	18.42	PO	Tan Delta Measurment of CTs
Shivajinagar - Malegaon	IntraState	20/11/2020	17.50	20/11/2020	19.27	PO	Diagnostic testing and Bay Maint.work
Karad - Vita Ckt- I	IntraState	20/11/2020	19.03	21/11/2020	18.07	T	Distance Protection
Salsette - Sahara	IntraState	21/11/2020	06.43	21/11/2020	08.30	PO	Project work.
Adlabs - Pedambe	IntraState	21/11/2020	07.55	21/11/2020	19.35	PO	Dismantling of existing inline tower.
Boisar Versova Line	IntraState	21/11/2020	08.39	21/11/2020	16.54	HT	H/T for Load Management.
Kalwa-TIFIL	IntraState	21/11/2020	08.57	21/11/2020	18.37	PO	Safety outage to pull down cable termination of 220KV Kharghar-Borivali-2 line B phase.
Kharghar-Borivali ckt I	IntraState	21/11/2020	09.06	21/11/2020	17.45	PO	Safety outage to pull down cable termination of 220KV Kharghar-Borivali-2 line B phase.
Mahad - Pedambe	IntraState	21/11/2020	09.20	21/11/2020	21.40	PO	For 220KV Kalambani TSS with LILO on pedhambe-Mahad ckt. is ready for test charging. Taking SCADA trials of Kalambani TSS from Mahad S/s & Dismantling of existing inline tower.
Boisar(M) - Ghodbunder	IntraState	21/11/2020	09.27	21/11/2020	16.09	HT	H/T for Load Management.
Talandage(400kv) - Five Star Midc	IntraState	21/11/2020	09.59	21/11/2020	12.12	PO	CB Timing.
Talandge(400)- Mudshingi 2 Line	IntraState	21/11/2020	10.25	21/11/2020	14.41	PO	Line signature analysis of line by tourus kit.
Lonikand1 (400 Kv)-Theur I	IntraState	21/11/2020	10.38	21/11/2020	19.10	PO	Dismantelling of 29C isolator & CT along with support S/ture, Erection of CTs & 29C isolator along with GI support Structure.
Kolshet-Roma	IntraState	21/11/2020	10.44	21/11/2020	14.42	PO	Diagnostic work.
Nashik-Padgha	IntraState	21/11/2020	13.10	21/11/2020	17.29	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 Mva ICT III @Kalwa	IntraState	19/11/2020	09.36	20/11/2020	12.05	PO	Painting work
220/33kV 100 MVA Transformer 2 @Ghodbunder R/S	IntraState	20/11/2020	08.58	21/11/2020	23.30	PO	Isolation of 33KV cables

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 21/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 Kv 200 MVA ICT-III @Phursungi	IntraState	20/11/2020	09.00	20/11/2020	15.46	PO	Half yearly maintenance work
220/132 KV 200MVA Vijai ICT-2 @Theur	IntraState	20/11/2020	09.02	20/11/2020	17.44	PO	Half yearly maintenance work
220/33kv 125 MVA T/F-I @ Goregaon	IntraState	20/11/2020	09.43	20/11/2020	17.19	PO	Annual Maintenance Work
220/132 kV 200 Mva ICT-II @Boisar -li	IntraState	20/11/2020	11.26	20/11/2020	19.23	PO	Tan Delta Measurment of CTs
220/132 Kv 200 Mva Ict - 2 @Harangul	IntraState	20/11/2020	17.03	20/11/2020	19.02	PO	Testing Work
220/132-110kv 100mva Imp Ptr 2 @Wathar	IntraState	21/11/2020	10.02	21/11/2020	13.42	PO	Diagnostic testing work, 1)C & Tan delta testing of LV CT, 2)IR testing of ICT.LV CT.
220/132-110kv 100mva Imp Ptr 1 @Wathar	IntraState	21/11/2020	14.46	21/11/2020	16.30	PO	Diagnostic testing of LV CT, C & Tan delta test & IR value measurement.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage