

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 20/Nov/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	163.129	3340.149	1) Gujrat	3.624	65.160
2) Hydro	6.699	145.066	2) Madhya Pradesh	3.109	87.167
3) Gas	6.884	114.300	3) Chattisgarh	7.500	156.000
Total MSPGCL	176.712	3599.515	4) Maharashtra	211.622	4062.937
B) 1) APMIL	38.539	918.752	5) Goa (Amona)	-1.949	-30.700
2) JSWEL	24.240	484.075	Total	223.906	4340.564
3) VIPL	0.000	0.000	a) Mumbai Schedule	37.895	766.078
4) RPL(AMT)	25.460	486.855	b) Mumbai Drawl	43.010	824.515
5) SWPGPL	11.739	213.214	c) MSEDCL Bilateral *	104.637	1917.811
6) Other IPP	31.501	488.982	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	37.895	766.061
C) 1) TPCL Thermal	10.885	232.651	Include PX	0.000	0.000
2) TPCL Hydro	3.313	51.325	Standby	0.000	0.017
3) TPCL Gas	2.349	45.791	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.536	152.988	1) MSEDCL	501.328	9940.207
D) STATE			2) Mumbai Discoms	66.095	1307.250
1) Thermal	312.029	6317.666	3) Other Discoms	10.413	207.934
(A1+C1+C4+(B1-B6))			TOTAL STATE	577.836	11455.391
2) Hydro (A2+C2)	10.012	196.391			
3) Gas (A3+B7+C3)	9.233	160.091			
4) Wind	9.112	179.293			
6) SOLAR	13.542	261.406			
TOTAL STATE	353.928	7114.847			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6698	6976	7058	6298
MSPGCL Hydro	182	179	1280	136
MSPGCL Gas	280	272	285	292
MSPGCL Total Generation	7160	7427	8623	6726
Central Sector Receipt	11571	10993	9050	7590
WIND	480	205	259	481
CPP / IPP Thermal	5268	5424	6039	4920
CPP / IPP Gas	0	0	0	0
SOLAR	1756	1623	9	0
Exchange with Mumbai	-2184	-2216	-1601	-1587
MSEDCL DEMAND MET	23579	23021	21882	17742
Load Shedding	0	0	0	0
MSEDCL DEMAND	23579	23021	21882	17742
TPCL GENERATION	688	652	1246	564
AEML GENERATION	326	362	353	173
MUMBAI DEMAND	3198	3230	3200	2324
OTHER DISCOM DEMAND	471	435	497	388
STATE DEMAND MET	27249	26686	25579	20454
STATE DEMAND	27249	26686	25579	20454
Frequency (Hz)	49.98	50.00	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 16:03 Hrs	49.83 Hz at 12:18 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 20/Nov/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.24	81.22	185	170
Unit 8	14.71	223.75	624	588
Unit 9	0.06	207.06	60	0
Unit 10	14.26	279.16	605	577
Total	33.28	791.19		
Bhusawal				
Unit 3	1.40	1.40	140	0
Unit 4	10.70	176.56	500	295
Unit 5	10.84	196.26	490	295
Total	22.94	374.22		
Parli				
Unit 6	4.56	93.62	249	143
Unit 7	4.70	81.64	248	148
Unit 8	4.97	101.66	250	154
Total	14.23	276.92		
Chandrapur				
Unit 3	3.19	68.17	151	107
Unit 4	3.19	71.14	153	88
Unit 5	10.01	207.06	435	360
Unit 6	8.35	162.39	375	295
Unit 7	7.06	152.92	313	267
Unit 8	10.12	216.22	440	402
Unit 9	11.18	222.00	478	440
Total	53.10	1099.90		
Paras				
Unit 3	5.45	108.78	246	212
Unit 4	5.24	108.58	239	171
Total	10.70	217.36		
Khaparkheda				
Unit 1	3.39	69.51	175	105
Unit 2	0.62	45.72	70	0
Unit 3	3.79	75.02	168	142
Unit 4	4.35	54.09	187	160
Unit 5	10.03	187.86	430	390
Total	22.18	432.20		
Nasik				
Unit 3	3.44	62.90	164	126
Unit 4	0.00	53.00	0	0
Unit 5	3.25	32.46	150	118
Total	6.70	148.36		
Uran				
All Units	6.88	114.30	295	272
Total	6.88	114.30		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	13.44	53	0
Total	0.13	13.44		
Koyna				
Stage 1-2	1.55	39.20	410	20

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.48	16.71	500	0
Stage 3	0.90	13.38	182	0
Total	3.94	69.29		
Hydro				
KDPH	0.00	6.08	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	2.54	0	0
SMLHY_PTN	2.03	50.86	96	75
GHATGHAR	0.60	2.86	125	0
Total	2.63	62.34		
Wind				
Total	9.11	179.29	0	0
Total	9.11	179.29		
CPP				
APML(Mus)	38.54	918.75	0	0
JSWEL(Mus)	24.24	484.08	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.46	486.86	0	0
SWPGPL-Mus	11.74	213.21	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.37	104.86	269	0
Other(Mus)	27.13	379.32	0	0
JPL	0.00	4.81	0	0
Total	131.48	2591.88		
SOLAR				
Total	13.54	261.41	0	0
Total	13.54	261.41		
Tata				
Trombay 5	7.24	152.46	453	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.31	26.12	108	38
Trombay 7B	1.04	19.67	65	36
TATA Hydro	3.31	51.32	406	44
Trombay 8	3.64	80.19	223	131
Total	16.55	329.77		
AEML				
DTPS U-1&2	6.54	152.99	392	164
Total	6.54	152.99		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	163.13	3340.15	MSPGCL Total	176.71	3599.52
			MSPGCL Thml+Gas	170.01	3454.45	Koyna 1,2 & 4 Total	3.03	55.91
			MSPGCL Hydro	6.70	145.07	State Total	353.93	7114.85

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 20/Nov/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6298	136	292	6726	481	4920	0	0	8204	7590	-1587	17742	0	0	17742	2324	388	20454	49.99
2	6257	135	294	6686	465	4933	0	0	7971	8161	-1438	18443	0	0	18443	2184	364	20991	49.96
3	6432	135	295	6862	431	4930	0	0	7792	7976	-1346	18528	0	0	18528	2056	326	20909	49.99
4	6584	133	295	7012	383	4963	0	0	7715	7883	-1266	18643	0	0	18643	1987	332	20962	50.01
5	6699	132	294	7125	348	5177	0	0	7949	8276	-1261	19310	0	0	19310	1974	354	21639	50.00
6	6785	137	294	7216	419	5508	0	0	8581	8681	-1315	20133	0	0	20133	2057	377	22566	50.06
7	6726	137	293	7156	513	5605	0	21	8915	8873	-1311	20448	0	4	20448	2155	409	23012	49.98
8	6886	135	292	7313	560	5733	0	257	8937	9190	-1389	21211	0	4	21211	2364	453	24028	50.04
9	6910	130	294	7334	512	5673	0	791	9713	9962	-1767	22052	0	0	22052	2669	453	25174	50.06
10	6856	129	288	7273	491	5391	0	1334	11039	11094	-2060	23057	0	30	23057	2974	466	26497	50.00
11	6698	182	280	7160	480	5268	0	1756	11636	11571	-2184	23579	0	13	23579	3198	471	27249	49.98
12	6740	269	279	7288	376	5092	0	1991	11255	11281	-2265	23290	0	1	23290	3284	473	27047	49.99
13	6962	163	279	7404	284	5383	0	2066	10813	10526	-2287	22908	0	0	22908	3276	468	26652	49.96
14	6840	189	275	7304	244	5362	0	1917	10446	10537	-2213	22704	0	1	22704	3180	446	26331	50.03
15	6976	179	272	7427	205	5424	0	1623	10946	10993	-2216	23021	0	1	23021	3230	435	26686	50.00
16	6942	201	278	7421	257	5574	0	1114	11226	11001	-2198	22703	0	0	22703	3273	466	26442	49.99
17	7033	610	279	7922	289	5944	0	536	9550	9722	-1796	22145	0	0	22145	3254	472	25871	50.00
18	7068	1136	280	8484	273	6029	0	127	8131	8527	-1590	21372	0	0	21372	3199	478	25049	49.98
19	7058	1280	285	8623	259	6039	0	9	8807	9050	-1601	21882	0	0	21882	3200	497	25579	50.03
20	7053	647	284	7984	247	6044	0	0	8984	8881	-1903	20754	0	0	20754	3071	500	24324	50.04
21	7021	157	286	7464	207	5922	0	0	8511	8431	-2026	19525	0	0	19525	2923	473	22921	49.99
22	6891	115	290	7296	282	5777	0	0	8394	8298	-2029	19159	0	0	19159	2809	465	22433	50.02
23	6794	116	293	7203	517	5445	0	0	8751	8631	-2031	19313	0	0	19313	2747	453	22512	50.00
24	6620	116	293	7029	589	5344	0	0	8748	8771	-1931	19408	0	0	19408	2705	394	22507	49.96
MUs	163.13	6.70	6.88	176.71	9.11	131.48	0.00	13.54	223.01	223.91	-43.01	501.33	0.00	0.05	501.33	66.09	10.41	577.83	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

Overloading of 220Kv BBLR-I & II.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 20/Nov/2023

Position as on 6.30 Hrs of 21/Nov/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
AEML	AEML Unit 1	250	11/11/2023	21:17	20/11/2023	05:29	For Boiler license renewal	21/11/2023
MSPGCL	Nasik Unit 4	210	19/11/2023	15:48		Continued.	Stator Earth Fault (Converted into AOH from 00:00 hrs dt.20/11/2023)	12/12/2023
MSPGCL	Koyna Unit 8	80	20/11/2023	12:05	20/11/2023	18:00	Black Start Mockdrill of Koyna HPS.	
MSPGCL	Koyna Unit 7	80	20/11/2023	12:10	20/11/2023	18:15	Black Start Mockdrill of Koyna HPS.	
MSPGCL	Koyna Unit 6	80	20/11/2023	12:20	20/11/2023	17:46	Black Start Mockdrill of Koyna HPS.	
MSPGCL	Koyna Unit 5	80	20/11/2023	12:25	20/11/2023	17:43	Black Start Mockdrill of Koyna HPS.	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	23/11/2023
MSPGCL	Bhusawal Unit 3	210	31/10/2023	23:45	20/11/2023	11:38	ID Fan Problem	20/11/2023
IPP	JPL Unit 1	150	03/11/2023	00:01		Continued.	Under shutdown condition Due to low net sales Realization cost.	23/11/2023
IPP	Adani U-1	660	12/11/2023	14:11		Continued.	Zero Schedule	
MSPGCL	Koradi Unit 9	660	16/11/2023	11:21	20/11/2023	22:49	SUSPECTED BTL	20/11/2023
IPP	Adani U-5	660	16/11/2023	23:16		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	17/11/2023	10:28	20/11/2023	13:33	ID Fan Problem	21/11/2023
IPP	IEPL Unit 1	270	20/11/2023	10:44	20/11/2023	14:39	Compressor Problem	
AEML	AEML Unit 1	250	20/11/2023	18:56		Continued.	Leakage at boiler high pressure drain valve.	21/11/2023
MSPGCL	Chandrapur Unit 4	210	21/11/2023	00:23		Continued.	HP TURBINE CONTROL VALVE PROBLEM	23/11/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 20/Nov/2023

Position as on 6.30 Hrs of 21/Nov/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 3	210	21/11/2023	03:55		Continued.	DRUM LEVEL HIGH	21/11/2023
MSPGCL	Nasik Unit 3	210	21/11/2023	10:45		Continued.	Economizer Tube Leakage.	
MSPGCL	Khaparkheda Unit 3	210	21/11/2023	11:57		Continued.	Air heater problem	
MSPGCL	Nasik Unit 5	210	21/11/2023	12:45		Continued.	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 21/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
408 TIE BAY OF EKTUNI CKT 1 AND BUS REACTOR	InterState	20/11/2023	13:04			PO	CB mechanism overhauling work by M/s CGL service engineer.
400 KV MAINBAY Outages/Trippings							
400/11.5 KV 110MVA STN T/F 6A @ DEEPNAGAR	InterState	09/11/2023	15:36			PO	For alignment work of 89L isolator of Station Transformer 6A
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 2Y2 phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
NEW KOYNA-KARAD CKT - 1	IntraState	17/11/2023	18:23	20/11/2023	11:04	HT	Ready for charging after planned outage, but kept out of service to control overvoltage.
JAIGAD - KARAD CKT - 1	IntraState	19/11/2023	21:06	20/11/2023	09:38	HT	For voltage management
KHADKA-AURANGABAD (WALUJ)	IntraState	19/11/2023	22:03	20/11/2023	07:13	HT	H/T on overvoltage
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/11/2023	09:06			HT	For managing over load on 400 kv PUNEGIS- TALEGAONPG line .
KHADKA-AURANGABAD (WALUJ)	IntraState	20/11/2023	22:54	21/11/2023	06:40	HT	HT due to Overvoltage
JAIGAD - KARAD CKT - 1	IntraState	21/11/2023	03:29	21/11/2023	09:54	HT	HT due to Overvoltage
NAGOTHANE - DABHOL CKT - 1	IntraState	21/11/2023	08:30			PO	Cold washing & Earthwire replcement
JAIGAD - KARAD CKT - 1	IntraState	21/11/2023	12:05			PO	Quarterly maintenance work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	28/10/2023	22:20			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	28/10/2023	22:27			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	28/10/2023	22:32			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
105 MVA SPARE ICT @ AKOLA	IntraState	21/11/2023	09:23			PO	DCRM, Tandelta for CT & routine maintenance work
220 KV MAINBAY Outages/Trippings							
BUS SECTION 3 @ MUDSHINGI	IntraState	20/11/2023	10:53	20/11/2023	18:25	PO	Half yearly maint. 220 kV Bus section III isolators.
BUS COUPLER @ NEW KOYNA	IntraState	20/11/2023	12:42			PO	Black Start Mockdrill of Koyna HPS.
BUS SECTION 2 @ MUDSHINGI	IntraState	20/11/2023	15:03	20/11/2023	18:17	PO	Half yearly maint. 220 kV Bus section III isolators.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 21/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV MAIN BUS - 2 @ NEW KOYNA	IntraState	20/11/2023	18:02	20/11/2023	18:02	PO	Black start mock drill and After Mock drill Bus insulator replacement work of B bus by transferring following bay. 1)220 KV side ICT 1 2) 220 KV Nivli 3) 25 MVA TF 1(After Mock drill) 4) 220 KV Pophali(After Mock drill) 5) 220 KV Bus Coupler (Kept Off)
TBC @ BABHLESHWAR	IntraState	21/11/2023	11:35			PO	CB ,DCRM and Timing CT Tan Delta
220 KV LINE Outages/Trippings							
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kv Aarey-AEML Borivali Line (which is under outage) with 220kv Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	26/10/2023	20:16	21/11/2023	13:27	HT	Charged from Navsary end only
OSMANABAD - PARLY (PG)	IntraState	16/11/2023	12:23			PO	For HTLS Reconductoring works of 400kv Parli-Parli(M) line-Ckt#2
BUS - 1 @ TROMBAY	IntraState	20/11/2023	00:45	20/11/2023	06:16	PO	For attending ICT#4 Main bus side GOD opening problem for availing outage of ICT-4 breaker for replacement.
MUDSHINGI - CHIKODI	IntraState	20/11/2023	09:31	20/11/2023	19:33	PO	Maintenance work
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA CKT 1	IntraState	20/11/2023	10:03	20/11/2023	14:25	PO	CT Tan delta, Capacitance & Routine maintenance work.
EKLAHARE (OCR) - PADGHE	IntraState	20/11/2023	10:03	20/11/2023	17:31	PO	Work of Tan delta testing of CT & CC
PETH- MUDSHINGI 1 LINE	IntraState	20/11/2023	10:44	20/11/2023	18:25	HT	For main bus section III outage at 220 kv Bus Section III. Line handtripped at Mudshingi end only.
KARAD -MUDSHINGI CKT 2-TAK	IntraState	20/11/2023	10:46	20/11/2023	18:26	HT	For main bus section III outage at 220 kv Bus Section III. Line handtripped at Mudshingi end only.
MUDSHINGI- BELEWADI LINE	IntraState	20/11/2023	10:50	20/11/2023	18:28	HT	For main bus section III outage at 220 kv Bus Section III. Line handtripped at Mudshingi end only.
WARORA - WARORA RLY TSS 2	IntraState	20/11/2023	11:20	20/11/2023	12:37	PO	Attending of SF6 Gas leakage on B-ph pole of circuit breaker
NERLE- POPHALI	IntraState	20/11/2023	12:14	20/11/2023	19:00	PO	Black Start Mockdrill of Koyna HPS.
POPHLI PEDHMBE LINE- 2	IntraState	20/11/2023	12:20	20/11/2023	17:28	PO	Black Start Mockdrill of Koyna HPS.
NEW KOYNA - POPHALI	IntraState	20/11/2023	12:20	20/11/2023	17:56	PO	Black Start Mockdrill of Koyna HPS.
EKLAHARE (OCR) - PADGHE	IntraState	20/11/2023	17:31			HT	HT for load management from Padghe end
THEUR-PHURSUNGI CKT I	IntraState	21/11/2023	09:50				Bay Diagnostic testing and half yearly maintenance work
VSNL - STT GIS CKT - 1	IntraState	21/11/2023	10:15			PO	Testing Work at both SS
GHATGHAR - BAPGAON	IntraState	21/11/2023	13:28			HT	To reduce emergency load sheddind in Nashik region. Line handtripped at Bapgaon end only.
GHATGHAR - JINDAL	IntraState	21/11/2023	13:37			HT	To reduce emergency load sheddind in Nashik region. Line handtripped at Jindal end only.
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 21/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
250 MVA ICT-4 @ TROMBAY	IntraState	18/11/2023	09:05			PO	1.Transformer complete gasket replacement (except bell tank) 2.Transformer complete oil filtration post gasket replacement 3.Cooler cabinet replacement 4.Radiator replacement at Trombay Generating Station.
220/33KV 50 MVA PTR 2 @ HALKARNI	IntraState	20/11/2023	09:30	20/11/2023	17:14	PO	for taking CRM CB Timing of 50 MVA BHEL T/F-II and 33kV Halkarni, 33kV Kanur, 33kV MIDC & 33kV Tudiye feeders , Diagnostic test, Quaterly Maintenance
220/132 KV 100 MVA ICT - II	IntraState	20/11/2023	10:35	20/11/2023	16:20	PO	Diagnostic testing work
220/100 KV 200 MVA ICT 2 @ PADGHE	IntraState	20/11/2023	11:28	20/11/2023	20:30		1. Diagnostic testing work of CT, CB, & T/F 2. Bay maintenance work 3. Attending hotspot (if any)
220/33KV 25MVA PTR 2 @ NEW KOYNA	IntraState	20/11/2023	12:41	20/11/2023	17:22	PO	Black Start Mockdrill of Koyna HPS.
220/132-110KV 100MVA PTR 2 @ WATHAR	IntraState	21/11/2023	09:54			PO	Diagonstic testing work by TCC Team
220/22 KV 50 MVA PTR 2 @ PADGHE	IntraState	21/11/2023	10:17			PO	For chargingof 22kV GIS s/s at 100/22kV s/s Padghe
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	21/11/2023	10:35			PO	Diagnostic testing of ICT 01 by Mobile testing unit, Pune
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
BUS COUPLER @ POPHALI	IntraState	20/11/2023	12:30	20/11/2023	17:40	PO	Black Start Mockdrill of Koyna HPS.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage