

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 20/Dec/2021 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	146.486	2683.504	1) Gujrat	-9.092	-136.012
2) Hydro	5.994	145.484	2) Madhya Pradesh	2.215	22.759
3) Gas	5.737	93.545	3) Chattisgarh	6.510	115.670
Total MSPGCL	158.217	2922.533	4) Maharashtra	132.920	2693.738
B) 1) APLM	61.760	1187.323	5) Goa (Amona)	-1.555	-33.841
2) JSWEL	13.394	283.056	Total	130.998	2662.314
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.365	499.133
4) RPL(AMT)	26.023	517.501	b) Mumbai Drawl	27.127	535.753
5) SWPGPL	7.662	154.600	c) MSEDCL Bilateral *	54.956	980.477
6) Other IPP	39.957	740.514	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.365	499.133
C) 1) TPCL Thermal	6.739	161.859	Include PX	0.000	1.590
2) TPCL Hydro	3.783	84.995	Standby	0.000	0.000
3) TPCL Gas	3.491	61.197	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.157	193.477	1) MSEDCL	417.643	8038.130
D) STATE			2) Mumbai Discoms	50.297	1037.278
1) Thermal	311.178	5921.834	3) Other Discoms	9.560	195.274
(A1+C1+C4+(B1-B6))			TOTAL STATE	477.500	9270.682
2) Hydro	9.777	230.479			
(A2+C2)					
3) Gas	9.228	154.742			
(A3+B7+C3)					
4) Wind	8.997	186.389			
6) SOLAR	7.322	114.927			
TOTAL STATE	346.502	6608.371			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6938	6649	6914	4736
MSPGCL Hydro	292	226	224	159
MSPGCL Gas	235	239	235	238
MSPGCL Total Generation	7465	7114	7373	5133
Central Sector Receipt	6698	6628	5163	4552
WIND	288	151	196	831
CPP / IPP Thermal	7023	6846	7091	5049
CPP / IPP Gas	0	0	0	0
SOLAR	961	1113	0	0
Exchange with Mumbai	-1438	-1601	-1050	-699
MSEDCL DEMAND MET	13511	13634	11554	9816
Load Shedding	0	0	0	0
MSEDCL DEMAND	13511	13634	11554	9816
TPCL GENERATION	667	616	970	400
AEML GENERATION	478	322	483	357
MUMBAI DEMAND	2583	2539	2503	1456
OTHER DISCOM DEMAND	394	348	380	266
STATE DEMAND MET	23580	22790	21276	16322
STATE DEMAND	23580	22790	21276	16322
Frequency (Hz)	50.01	50.03	49.93	50.12

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.35 Hz at 02:01 Hrs	49.72 Hz at 19:48 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 20/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.53	71.72	190	120
Unit 7	0.00	0.00	0	0
Unit 8	12.89	272.15	654	365
Unit 9	13.58	138.23	660	365
Unit 10	12.76	260.97	606	371
Total	42.76	743.06		
Bhusawal				
Unit 3	3.10	36.54	155	120
Unit 4	8.68	172.58	450	275
Unit 5	8.85	172.04	445	275
Total	20.64	381.16		
Parli				
Unit 6	4.17	25.51	225	152
Unit 7	3.79	9.72	212	36
Unit 8	3.99	61.50	208	151
Total	11.96	96.72		
Chandrapur				
Unit 3	3.66	39.17	170	119
Unit 4	3.46	61.54	163	121
Unit 5	8.20	98.82	385	300
Unit 6	8.68	148.53	425	267
Unit 7	7.05	156.12	368	220
Unit 8	8.41	182.71	399	270
Unit 9	8.36	184.19	392	277
Total	47.82	871.08		
Paras				
Unit 3	4.16	85.32	222	139
Unit 4	4.13	87.40	223	138
Total	8.29	172.72		
Khaparkheda				
Unit 1	0.00	24.87	0	0
Unit 2	0.00	25.46	0	0
Unit 3	0.00	27.06	0	0
Unit 4	0.00	20.47	0	0
Unit 5	8.95	191.00	435	280
Total	8.95	288.86		
Nasik				
Unit 3	3.04	31.26	174	116
Unit 4	0.00	33.17	0	0
Unit 5	3.02	65.48	163	117
Total	6.06	129.90		
Uran				
All Units	5.74	93.54	253	226
Total	5.74	93.54		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.39	2.83	33	0
Total	0.39	2.83		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.72	45.48	285	35
Stage 4	0.17	15.45	101	0
Stage 3	0.28	14.07	80	0
Total	2.17	74.99		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.06	0	0
TILLARI	0.41	6.12	58	0
BHIRA T.R.	0.12	5.13	77	0
SMLHY_PTN	3.30	59.18	193	111
GHATGHAR	0.00	0.00	0	0
Total	3.82	70.49		
Wind				
Total	9.00	186.39	0	0
Total	9.00	186.39		
CPP				
APML(Mus)	61.76	1187.32	0	0
JSWEL(Mus)	13.39	283.06	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.02	517.50	0	0
SWPGPL-Mus	7.66	154.60	0	0
Other(Mus)	39.96	740.51	0	0
Total	148.80	2882.99		
SOLAR				
Total	7.32	114.93	0	0
Total	7.32	114.93		
Tata				
Trombay 5	6.74	140.06	413	248
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.10	36.64	113	61
Trombay 7B	1.39	24.55	66	49
Trombay 8	0.00	21.80	0	0
TATA Hydro	3.78	85.00	381	0
Total	14.01	308.05		
AEMIL				
DTPS U-1&2	9.16	193.48	483	293
Total	9.16	193.48		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	146.49	2683.50	MSPGCL Total	158.22	2922.53
			MSPGCL Thml+Gas	152.22	2777.05	Koyna 1,2 & 4 Total	1.90	60.92
			MSPGCL Hydro	5.99	145.48	State Total	346.50	6608.37

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 20/Dec/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4677	163	234	5074	480	5089	0	0	4642	4976	-899	14430	0	14430	1680	290	16400	50.07
2	4802	153	249	5204	635	5114	0	0	4535	4676	-791	14548	0	14548	1588	290	16426	50.13
3	4782	159	238	5179	808	5297	0	0	4653	4413	-724	14702	0	14702	1511	271	16484	50.22
4	4736	159	238	5133	831	5049	0	0	4751	4552	-699	14600	0	14600	1456	266	16322	50.12
5	4883	169	249	5301	779	5272	0	0	4718	4912	-692	15290	0	15290	1464	282	17036	50.05
6	5379	165	240	5784	759	5617	0	0	5061	4902	-762	15992	0	15992	1553	308	17853	50.02
7	6183	159	253	6595	737	6048	0	5	5003	5136	-739	17441	0	17441	1683	341	19465	49.94
8	6747	235	246	7228	695	6632	0	96	5184	5263	-864	18691	0	18691	1867	358	20917	49.97
9	6777	274	240	7291	474	7040	0	422	5707	5513	-1118	19259	0	19259	2153	363	21775	50.03
10	6669	536	247	7452	367	6706	0	756	6282	6578	-1363	20129	0	20129	2412	367	22908	50.03
11	6938	292	235	7465	288	7023	0	961	6634	6698	-1438	20603	0	20603	2583	394	23580	50.01
12	6564	394	234	7192	205	6704	0	1086	6966	7111	-1460	20466	0	20466	2605	372	23443	50.03
13	6649	226	239	7114	151	6846	0	1113	6923	6628	-1601	19903	0	19903	2539	348	22790	50.03
14	6508	211	227	6946	113	6111	0	1048	6967	7027	-1570	19334	0	19334	2413	341	22088	50.04
15	6787	232	227	7246	81	6232	0	897	6873	7067	-1560	19596	0	19596	2429	367	22392	50.02
16	6906	218	226	7350	108	6595	0	623	6686	6355	-1482	19193	0	19193	2434	355	21983	49.96
17	6929	339	230	7498	73	7097	0	281	5870	5479	-1349	18702	0	18702	2425	377	21504	49.95
18	6960	220	239	7419	119	7078	0	34	5090	4380	-1025	17631	0	17631	2443	374	20448	49.91
19	6914	224	235	7373	196	7091	0	0	5500	5163	-1050	18393	0	18393	2503	380	21276	49.93
20	6918	263	236	7417	249	6936	0	0	5067	4927	-1207	17933	0	17933	2400	389	20722	49.86
21	6348	226	249	6823	264	6413	0	0	4909	4487	-1205	16400	0	16400	2265	382	19047	50.02
22	5904	234	238	6376	208	5744	0	0	5164	4984	-1224	15722	0	15722	2107	366	18195	50.03
23	5457	219	239	5915	207	5481	0	0	5250	5089	-1214	15141	0	15141	1958	337	17436	49.97
24	5069	524	249	5842	170	5581	0	0	4809	4683	-1091	14861	0	14861	1826	324	17011	49.99
MUs	146.49	5.99	5.74	158.22	9.00	148.80	0.00	7.32	133.24	131.00	-27.13	418.96	0.00	418.96	50.30	8.24	477.50	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 20/Dec/2021

Position as on 6.30 Hrs of 21/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 4	210	08/12/2021	21:00		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 3	210	09/12/2021	00:01		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 1	210	09/12/2021	00:56		Continued.	CHP coal feeding problem	
MSPGCL	Nasik Unit 4	210	11/12/2021	21:22		Continued.	withdrawn against case 4 to dhariwal	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 20/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 21/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Tripping							
765/400KV 1500 MVA ICT-2 @ KORADI 3	IntraState	21/12/2021	11:11	21/12/2021	19:39	PO	Annual Maintenance of 765/400KV ICT-2
500 KV TBC Outages/Tripping							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	20/12/2021	21:13	20/12/2021	00:22	EO	1. To attend the hotspot having temperature > 150 °C & between 100- 150 °C
400 KV TIEBAY Outages/Tripping							
400 KV BUS BAR PROTECTION @ CHANDRAPUR	InterState	20/12/2021	14:30	20/12/2021	21:03	EO	For the removal of isolator contact wires (of 89A & 89B) used in formation of LBB trip bus (P3 & P5) in ZIV BB scheme and activities to be carried out.
400 KV MAINBAY Outages/Tripping							
BUS COUPLER @ BABHALESHWAR	IntraState	21/12/2021	07:29	21/12/2021	09:18	T	Bus Operated due to Reactor B-ph Pole Burst
400 KV LINE Outages/Tripping							
AKOLA - KHADKA (BHUSAWAL)	IntraState	11/12/2021	09:34		Continued.	PO	for replacement of 400 KV Damage Main Bus (1&2) section of Akola & Aurangabad bay
NAGOTHANE - DABHOL CKT - 2	IntraState	19/12/2021	20:40	20/12/2021	09:34	EO	To replace Rph broken string at loc no.230
JAIGAD - KARAD CKT - 2	IntraState	19/12/2021	22:10	20/12/2021	10:23	HT	HT FOR OVERVOLTAGE
PADGHE - NAGOTHANE CKT - 1	IntraState	20/12/2021	01:26	20/12/2021	09:21	HT	H/T DUE TO OVERVOLTAGE
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadruple CB. 3) Measurement of Timing, DCRM and CRM of CB.
PADGHE - NAGOTHANE CKT - 1	IntraState	20/12/2021	09:21	21/12/2021	17:22	PO	1) For CB mechanism Overhauling work and Diagnostic Testing work. 2) A & B Bus PG Isolator maintenance work
JAIGAD - KARAD CKT - 1	IntraState	20/12/2021	23:34	21/12/2021	09:27	HT	HAND TRIPPED DUE TO OVER VOLTAGE
EKTUNI - BABHALESHWAR CKT - 1	IntraState	21/12/2021	07:29	21/12/2021	08:23	T	Bus Operated due to Reactor B-ph Pole Burst.
BABHALESHWAR - PADGHE CKT-1	IntraState	21/12/2021	07:29	21/12/2021	08:48	T	Bus Operated due to Reactor B-ph Pole Burst.
BABHALESHWAR- AURANGABAD (WALUJ)	IntraState	21/12/2021	07:29	21/12/2021	08:13	T	Bus Operated due to Reactor B-ph Pole Burst
DHULE- - BABHALESHWAR - I	IntraState	21/12/2021	07:29	21/12/2021	11:02	T	Bus operated due to Reactor B-ph pole burst
JAIGAD - KARAD CKT - 2	IntraState	21/12/2021	21:07		Continued.	HT	HT OV
400 KV ICT Outages/Tripping							
400/220 KV 315MVA ICT - 2 @ KARAD	IntraState	20/12/2021	09:30	20/12/2021	17:47	PO	In DGA rising trend of Hydrogen and Methane observed. Outage required for SFRA and other testing activities.
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	21/12/2021	07:29	21/12/2021	08:47	T	Bus Operated due to Reactor B-ph Pole Burst
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	21/12/2021	07:29	21/12/2021	08:25	T	Bus Operated due to Reactor B-ph Pole Burst
220 KV MAINBAY Outages/Tripping							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 20/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 21/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BAY(208) OF 220KV-SOLAPUR-FUTURE 1 @SOLAPUR (PG)-220 KV	InterState	20/12/2021	17:22		Continued.	PO	reorientation work along with the disconnection of 220KV Bale-Tuljapur line at Loc.NO. 37 and establishment of link between Solapur PG to 220KV Bale substation will be carried out by utilizing D/C portion of Solapur PG -Bale line and jumpering work at substation end.
220 KV LINE Outages/Tripping							
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01		Continued.	HT	air leakage in CB
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
BIDRI - SAWANTWADI	IntraState	20/12/2021	00:17	20/12/2021	09:04	HT	H/T DUE TO OVERVOLTAGE
CHALISGAON - SAYNE	IntraState	20/12/2021	04:03	20/12/2021	04:58	T	Distance Protection
TALANDAGE - FIVE STAR MIDC 1	IntraState	20/12/2021	09:07	20/12/2021	14:14	PO	Replacement of PID tested Faulty Strings
URAN - HOC 1	IntraState	20/12/2021	09:30	20/12/2021	16:01	PO	Replacement of flashover pilot disc insulator at Loc.No.25, providing missing earthwire at Loc.No.46 to 47. Repairing of damaged conductor at Loc.No.20
BUS SECTION - 1 @ BIDRI	IntraState	20/12/2021	09:45	20/12/2021	14:18	PO	QMW, IR values of PT on 19.10.2020
KARAD - NERLE	IntraState	20/12/2021	10:28	20/12/2021	18:18	PO	CT Tan delta testing, CRM, CB timing test & maintenance work
MAIN BUS - 2 @ AAREY	IntraState	20/12/2021	10:43	20/12/2021	18:25	PO	Annual maintenance of Main Bus-2 side isolators and equipments and attending alignment of 489 B Isolator of Main Bus-2 of Bay No. 04
BUS COUPLER @ AAREY	IntraState	20/12/2021	10:43	20/12/2021	17:54	PO	Annual maintenance of Main Bus-2 side isolators and equipments and attending alignment of 489 B Isolator of Main Bus-2 of Bay No. 04
TAMBATI - ADLABS	IntraState	20/12/2021	10:50	20/12/2021	17:23	PO	Diagnostic testing and R&M work at 220KV Tambati substation end
SOLAPUR(BALE) - TULJAPUR	IntraState	20/12/2021	10:54		Continued.	PO	Outage is required 1. Testing & communication work of line and bay at both substation (Bale & PGCIL) 2. Jumpering work at loc 37 on 220kV PGCIL Bale Line 3. Shifting of WT, CC & LMU (in existing Tuljapur bay) at 220kV Bale Substaion.
BAPGAON - KALWA	IntraState	20/12/2021	11:00	20/12/2021	13:30	PO	Pole overhauling work by shifting of line on TBC

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 20/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 21/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BAPGAON - KALWA	IntraState	20/12/2021	11:00	20/12/2021	13:30	PO	Shifting of 220KV Bapgaon-Kalwa line on TBC Bay for own 245Kv CB Y Ph Top & Bottom Palm Hot Spot attending work
TALANDGE - BIDRI	IntraState	20/12/2021	11:28	20/12/2021	16:13		1. replacement of PID tested faulty Strings 2.QM Work
NAGAR BELWANDI CKT 1	IntraState	20/12/2021	11:55	20/12/2021	17:22	PO	For Integration of Bay into New SCADA System
NAGAR BELWANDI CKT 2	IntraState	20/12/2021	11:55	20/12/2021	17:22	PO	For Integration of Bay into New SCADA System
TROMBAY - KALWA	IntraState	20/12/2021	12:01	20/12/2021	16:57	PO	CT Tan Delta testing & RM work
VITA WAIPHALE	IntraState	20/12/2021	13:30	20/12/2021	19:45	PO	String replacement at Loc No.100 Y Ph (Outer Waiphale Side) found faulty in PID testing
TALANDAGE - FIVE STAR MIDC 2	IntraState	20/12/2021	14:23	20/12/2021	17:53	PO	Replacement of PID tested Faulty Strings
CHALISGAON -KOPARGAON	IntraState	20/12/2021	16:30	20/12/2021	20:41	PO	Tan delta, CRM and CBT test and bay maintenance work
TALANDAGE - CHIKODI	IntraState	21/12/2021	09:44	21/12/2021	18:36	PO	1. QM Work 2. Annual diagnostic testing work
APTA - TAMBATI	IntraState	21/12/2021	11:36	21/12/2021	14:15	PO	For removing of Bunching at LILO Loc.No.1 to 2 of 220kV Apta-Tambati-Adlab line for providing of missing earthwire at Loc.No.4 to 5.
TAMBATI - ADLABS	IntraState	21/12/2021	11:40	21/12/2021	16:44	PO	Removing of bunching at LILO Loc no. 1 to 2 of 220KV APTA - Tambati - ADLAB line. Providing of missing earthwire at Loc no. LILO 4 to 5.
CHAKAN-BHOSARI 1	IntraState	21/12/2021	12:05	21/12/2021	15:12	PO	CRM measurment of CB & timing test of CB
URAN - KHARGHAR 2	IntraState	21/12/2021	12:26	21/12/2021	20:13	T	distance protection trip
KAMBA - KOLSHET	IntraState	21/12/2021	13:00	21/12/2021	14:09	PO	Replace the breaker spring charging faulty motor by new one
BHOSARI- BHOSARI 2	IntraState	21/12/2021	15:44	21/12/2021	17:46	PO	CRM measurment of CB & timing test of CB
220 KV ICT Outages/Tripping							
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/33KV 50MVA PTR 1 @ 5 STAR MIDC, KAGAL	IntraState	20/12/2021	09:07	20/12/2021	12:30	PO	For replacement of Buchholz relay of TF1
220/22-22 KV 50 MVA PTR 4 @ MULUND	IntraState	20/12/2021	09:12	20/12/2021	18:01	PO	1. Diagnostic testing work. 2. Transformer painting work
220/100 KV 200 MVA ICT 2 @ PADGHE	IntraState	20/12/2021	09:56	21/12/2021	20:00	PO	1. Replacement of Y LA (LCM Value- 324 ȳA) 2. Painting Of ICT 3. Attending hotspot 4. Retrofitting of REF relay of MTAMC remaining Work
220/33 KV 50 MVA PTR - 7 @ WATHAR	IntraState	20/12/2021	09:58	20/12/2021	14:50	PO	Attending hot spot on 33KV LV CB and Quarterly maintenance work.
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	IntraState	20/12/2021	10:32	21/12/2021	07:30	PO	For 132kv Rph LV torret CT terminal plate replacement, OLTC & PRV replacement work.
220/22-22 KV 50 MVA PTR 4 @ MULUND	IntraState	21/12/2021	09:09	21/12/2021	17:22	PO	1. Diagnostic testing work. 2. Transformer painting work
220/132kv 100MVA ICT -1 @ LONI DEOKAR	IntraState	21/12/2021	11:15	21/12/2021	15:35	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	21/12/2021	11:37	21/12/2021	16:46	HT	RM works

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 21/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	21/12/2021	11:39	21/12/2021	14:20	HT	RM Works
220/132kv 100MVA ICT -2 @ LONI DEOKAR	IntraState	21/12/2021	15:40	21/12/2021	17:22	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 2	IntraState	20/12/2021	09:01	20/12/2021	14:44	PO	ATTENDING HOTSPOT AT LOC.5,30 & 31

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage