

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 20/Dec/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.326	3006.429	1) Gujrat	-7.633	-129.342
2) Hydro	11.986	213.485	2) Madhya Pradesh	2.803	26.998
3) Gas	3.382	89.890	3) Chattisgarh	4.930	107.870
Total MSPGCL	174.694	3309.804	4) Maharashtra	179.622	3415.980
B) 1) APLM	50.604	1288.346	5) Goa (Amona)	-1.033	-25.248
2) JSWEL	13.026	255.191	Total	178.689	3396.258
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.191	583.004
4) RPL(AMT)	31.190	565.087	b) Mumbai Drawl	34.027	673.397
5) SWPGPL	9.169	165.463	c) MSEDCL Bilateral *	70.509	1485.868
6) Other IPP	44.351	880.235	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.191	582.602
C) 1) TPCL Thermal	11.907	220.353	Include PX	0.000	0.000
2) TPCL Hydro	4.579	77.859	Standby	0.000	0.402
3) TPCL Gas	1.667	30.033	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.256	198.533	1) MSEDCL	479.251	9429.288
D) STATE			2) Mumbai Discoms	62.436	1200.175
1) Thermal	329.829	6579.637	3) Other Discoms	9.452	188.142
(A1+C1+C4+(B1-B6))			TOTAL STATE	551.139	10817.605
2) Hydro	16.565	291.344			
(A2+C2)					
3) Gas	5.049	119.923			
(A3+B7+C3)					
4) Wind	7.724	214.454			
6) SOLAR	13.283	215.989			
TOTAL STATE	372.450	7421.347			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	7100	7001	6753	5931
MSPGCL Hydro	852	140	1632	79
MSPGCL Gas	136	135	138	144
MSPGCL Total Generation	8088	7276	8523	6154
Central Sector Receipt	8534	8709	6771	7103
WIND	161	195	347	374
CPP / IPP Thermal	6754	6423	6701	5490
CPP / IPP Gas	0	0	0	0
SOLAR	1721	1915	0	0
Exchange with Mumbai	-1664	-1768	-1338	-1211
MSEDCL DEMAND MET	23167	22352	20573	17613
Load Shedding	0	0	0	0
MSEDCL DEMAND	23167	22352	20573	17613
TPCL GENERATION	917	822	1127	518
AEML GENERATION	495	493	498	302
MUMBAI DEMAND	3076	3083	2963	2031
OTHER DISCOM DEMAND	427	398	431	297
STATE DEMAND MET	26670	25833	23967	19941
STATE DEMAND	26670	25833	23967	19941
Frequency (Hz)	49.74	50.19	50.06	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.5 Hz at 13.02 Hrs	49.41 Hz at 09.30 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 20/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.04	100.04	215	200
Unit 7	0.00	0.00	0	0
Unit 8	13.29	255.74	592	490
Unit 9	12.42	261.65	550	470
Unit 10	12.49	259.06	571	471
Total	43.25	876.49		
Bhusawal				
Unit 3	0.00	7.84	0	0
Unit 4	10.79	199.71	495	290
Unit 5	10.44	202.57	490	275
Total	21.24	410.12		
Parli				
Unit 6	4.62	86.42	232	148
Unit 7	4.70	88.29	248	148
Unit 8	3.60	66.52	188	133
Total	12.92	241.24		
Chandrapur				
Unit 3	3.32	66.89	160	125
Unit 4	3.09	62.54	148	120
Unit 5	7.25	126.77	330	280
Unit 6	7.65	147.30	410	285
Unit 7	0.00	0.00	0	0
Unit 8	10.34	161.48	475	304
Unit 9	10.73	203.08	481	325
Total	42.38	768.06		
Paras				
Unit 3	5.13	85.74	225	198
Unit 4	5.64	88.46	247	216
Total	10.77	174.20		
Khaparkheda				
Unit 1	2.80	55.74	130	95
Unit 2	2.94	55.58	135	100
Unit 3	3.83	68.59	180	132
Unit 4	3.24	65.38	143	127
Unit 5	9.91	166.10	450	325
Total	22.72	411.38		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.05	63.39	145	113
Unit 5	3.01	38.22	142	108
Total	6.06	124.92		
Uran				
All Units	3.38	89.89	159	133
Total	3.38	89.89		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.32	2.97	44	0
Total	0.32	2.97		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.46	65.74	535	35
Stage 4	4.13	60.25	694	0
Stage 3	1.87	27.59	240	0
Total	9.46	153.58		
Hydro				
KDPH	0.11	4.18	36	0
VTRNA	0.00	0.00	0	0
TILLARI	0.34	9.75	59	0
BHIRA T.R.	0.30	4.29	77	0
SMLHY_PTN	0.76	28.00	40	23
GHATGHAR	0.69	10.72	125	0
Total	2.21	56.94		
Wind				
Total	7.72	214.45	0	0
Total	7.72	214.45		
CPP				
APML(Mus)	50.60	1288.35	0	0
JSWEL(Mus)	13.03	255.19	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.19	565.09	0	0
SWPGPL-Mus	9.17	165.46	0	0
Other(Mus)	44.35	880.24	0	0
Total	148.34	3154.32		
SOLAR				
Total	13.28	215.99	0	0
Total	13.28	215.99		
Tata				
Trombay 5	7.90	145.27	428	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.00	16.63	101	0
Trombay 7B	0.66	13.41	51	0
TATA Hydro	4.58	77.86	374	28
Trombay 8	4.00	75.08	231	131
Total	18.15	328.24		
AEML				
DTPS U-1&2	10.26	198.53	499	301
Total	10.26	198.53		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.33	3006.43	MSPGCL Total	174.69	3309.80
			MSPGCL Thml+Gas	162.71	3096.32	Koyna 1,2 & 4 Total	7.59	125.99
			MSPGCL Hydro	11.99	213.48	State Total	372.45	7421.35

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 20/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5894	79	142	6115	480	5464	0	0	7232	7270	-1414	17548	0	17548	2329	367	20244	50.01
2	5988	89	144	6221	510	5504	0	0	7210	7063	-1317	17657	0	17657	2159	324	20140	50.02
3	5931	79	144	6154	374	5490	0	0	7099	7103	-1211	17613	0	17613	2031	297	19941	50.00
4	6110	79	143	6332	410	5456	0	0	7066	7017	-1146	17771	0	17771	1946	298	20015	50.01
5	6351	80	143	6574	410	5519	0	0	7249	7243	-1093	18327	0	18327	1936	326	20589	50.00
6	6643	80	144	6867	405	5867	0	0	7698	7748	-1182	19349	0	19349	2030	356	21735	50.00
7	6779	231	139	7149	358	6165	0	7	8213	7820	-1142	19972	0	19972	2165	385	22522	50.03
8	7005	1374	143	8522	296	6586	0	238	7231	6970	-1093	21119	0	21119	2317	400	23836	49.94
9	7077	735	142	7954	242	6788	0	851	7510	7417	-1211	21619	0	21619	2593	422	24634	49.74
10	7042	716	137	7895	208	6764	0	1376	7906	7843	-1441	22225	0	22225	2865	420	25510	49.68
11	7100	852	136	8088	161	6754	0	1721	8389	8534	-1664	23167	0	23167	3076	427	26670	49.74
12	7107	541	137	7785	212	6722	0	1902	8459	8477	-1759	22922	0	22922	3138	417	26477	49.97
13	7001	140	135	7276	195	6423	0	1915	8488	8709	-1768	22352	0	22352	3083	398	25833	50.19
14	6958	162	133	7253	157	6043	0	1800	8409	8557	-1749	21646	0	21646	2909	415	24970	50.31
15	6950	423	159	7532	158	6336	0	1591	8785	8441	-1758	21890	0	21890	2926	410	25226	50.16
16	6891	485	145	7521	148	6409	0	1185	9008	8414	-1611	21641	0	21641	3008	425	25074	49.84
17	6837	865	144	7846	148	6516	0	577	7781	7863	-1436	21074	0	21074	2987	440	24501	49.85
18	6758	1449	137	8344	244	6613	0	120	6856	6699	-1316	20261	0	20261	2943	443	23647	49.99
19	6753	1632	138	8523	347	6701	0	0	6781	6771	-1338	20573	0	20573	2963	431	23967	50.06
20	6780	950	138	7868	400	6714	0	0	6677	6589	-1270	19874	0	19874	2861	427	23162	50.06
21	6590	397	138	7125	463	6375	0	0	6544	6132	-1495	18177	0	18177	2728	423	21328	50.01
22	6416	180	138	6734	465	5805	0	0	6421	6693	-1484	17797	0	17797	2569	416	20782	50.08
23	6275	180	141	6596	459	5739	0	0	6596	6493	-1600	17280	0	17280	2479	407	20166	50.10
24	6090	188	142	6420	474	5587	0	0	6768	6823	-1529	17397	0	17397	2395	378	20170	50.02
MUs	159.33	11.99	3.38	174.69	7.72	148.34	0.00	13.28	180.38	178.69	-34.03	479.25	0.00	479.25	62.44	9.45	551.14	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 20/Dec/2022

Position as on 6.30 Hrs of 21/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	JSW (J) U2	300	10/12/2022	15:51		Continued.	NO SCHEDULE	
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/01/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	03/01/2023
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
MSPGCL	Uran Unit 6	108	14/12/2022	08:14	20/12/2022	14:02	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	18/12/2022	11:00	21/12/2022	07:08	Boiler Tube Leakage	21/12/2022
TPC-G	Trombay 7B	60	20/12/2022	05:06	20/12/2022	13:24	Gas shortage	
TPC-G	Trombay 7A	120	20/12/2022	05:26	20/12/2022	11:29	Gas shortage	
MSPGCL	Uran Unit 6	108	20/12/2022	15:10	20/12/2022	15:36	Gas shortage	
MSPGCL	Uran Unit 6	108	20/12/2022	17:00		Continued.	Gas shortage	
MSPGCL	Koyna STG-IV Unit-3	250	21/12/2022	09:53		Continued.	Generator lower guide bearing oil leakage	26/12/2022
TPC-G	Trombay 7B	60	21/12/2022	23:37		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 20/Dec/2022

Position as on 6.30 Hrs of 21/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 7A	120	21/12/2022	23:53		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 21/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	IntraState	20/12/2022	11:38	20/12/2022	17:01	PO	Diagnostic testing and allied bay maintenance work.
400 KV TBC Outages/Trippings							
TBC @ NAGOTHANE	IntraState	19/12/2022	11:20		Continued.	PO	for CB overhauling work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (412) LINE - 1 OF KORADI-2 @ KORADI 3	IntraState	20/12/2022	09:51	20/12/2022	17:29	PO	Annual Maintenance of Bay Equipment
400 KV LINE Outages/Trippings							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
LAMBOTI - SOLAPUR (PG)	InterState	21/12/2022	08:13	21/12/2022	19:55	PO	Replacement of string
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	20/12/2022	08:37	20/12/2022	18:53	PO	Pending work at Loc.No.154 related to height extension work at Span 155-156 for samdrudhhi highway Carried out by Project Division Aurangabad
LONIKAND 2 - KARJAT CKT - 2	IntraState	20/12/2022	13:59	20/12/2022	16:52	T	Distance Protection
CHANDRAPUR - KHAPERKHEDA	IntraState	21/12/2022	09:07	21/12/2022	16:05	PO	Conductor & Earthwire Hardware tightening work & Replacement of PID disc Insulator if any
CHANDRAPUR 2 - DHARIWAL CKT - 2	IntraState	21/12/2022	09:19	21/12/2022	17:01	PO	1. Bay equipment maintenance work 2. Bay equipment testing work 3. Installation of energy meters at both end
Akola II (Yelwan) - Akola I CKT - 1	IntraState	21/12/2022	10:23	21/12/2022	18:50	PO	Annual Maintenance of Line Equipment
400 KV ICT Outages/Trippings							
400/220/33 KV 315MVA ICT - 3 @ KARAD	IntraState	20/12/2022	09:35	20/12/2022	17:45	PO	For CT Tan delta of HV & LV CT.
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	20/12/2022	10:01	20/12/2022	19:25	PO	(1) HV CTs & HV backup relay testing work. (2) Bay maintenance work.
220 KV TIEBAY Outages/Trippings							
TBC @ PHURSUNGI	IntraState	20/12/2022	11:10	20/12/2022	13:04	PO	Half yearly Maintenance.
220 KV TBC Outages/Trippings							
BUS COUPLER @ VILEBHAGAD	IntraState	21/12/2022	10:40	21/12/2022	17:00	PO	1.CB CRM & Timing test 2.CT Tandelta test & other mainantenance work. 3.Realay testing work by testing team
220 KV LINE Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 20/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 21/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
POPHALI - KDPH	IntraState	10/12/2022	10:20	20/12/2022	20:15	PO	For erection & stringing of In-line Multi circuit tower (Loc No.1to7) of new 220KV Karad-Koyana line and restringing of existing 220KV D/C KDPH LILO line.
VANKUSWADE - KDPH	IntraState	10/12/2022	11:00	20/12/2022	20:00	PO	For erection & Stringing of In line multi circuit tower (Loc no.01 to 07) of new 220kv Karad-Koyana line and re stringing of existing 220kv D/C KDPH LILO line.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
EKLAHARE (OCR) - PADGHE	IntraState	19/12/2022	18:12			HT	HT for Load Management
ONGC PANVEL - TSS PANVEL	IntraState	20/12/2022	08:11	20/12/2022	18:10	PO	For stringing of 2Nos conductors from new monopole to monopole of 220kv ONGC - Panvel TSS line between loc. No 2 & 3 for Height rising work of proposed DFCCIL Railway Track . Also destriking of 3No old existing conductors.
MAIN BUS - 2 @ AAREY	IntraState	20/12/2022	08:17	20/12/2022	18:22	PO	Annual Maintenance of 220kv Main Bus 2 and Bus Side connected Isolator
VANKUSWADE - KDPH	IntraState	20/12/2022	11:10	20/12/2022	20:00	PO	For removing through jumps & reconnecting of LILO jumps at Loc No.42 for taking 220 kV KDPH line into service
CHAKAN -BRIDGESTONE	IntraState	20/12/2022	12:02	20/12/2022	18:32	PO	Annual Realay Testing Work at Bridgestone SS
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	20/12/2022	12:51	20/12/2022	20:51	HT	H/T for load Management.
MALEGAON-SATANA	IntraState	20/12/2022	13:35	20/12/2022	17:46	HT	H/T For load management
PEDHAMBE ONI LINE	IntraState	21/12/2022	08:40	21/12/2022	17:10	EO	For attending Hot spot at loc no. 201B R ph Oni side & 202B Rph Pedhambe side.
PARANDA-BARSHI	IntraState	21/12/2022	09:25	21/12/2022	14:00	PO	Outage is required for Quarterly Maintenance
URAN - APTA CKT - 1	IntraState	21/12/2022	09:43	21/12/2022	17:30	PO	R&M, Diagnostic Work & hot spot attending work, Disc String Insulator replacement
BUS SECTIONIZER @ BIDRI	IntraState	21/12/2022	10:18	21/12/2022	15:36	PO	For QMW
MALEGAON-SATANA	IntraState	21/12/2022	11:17	21/12/2022	17:02	HT	For load management
GOREGAON - VERSOVA CKT - 2	IntraState	21/12/2022	11:17	21/12/2022	15:34	EO	Checking of SF6 gas leakage in CB
AEML BORIVALI -MSETCL BORIVALI CKT -2	IntraState	21/12/2022	11:30	21/12/2022	13:04	T	Tripped at AEML end only
ALEPHATA-PARGAON(KATHAPUR)	IntraState	21/12/2022	11:38	21/12/2022	16:49	HT	For load management
KARAD - NERLE	IntraState	21/12/2022	12:30	21/12/2022	16:24	PO	For taking CT tan Delta & Quarterly Maintenance work.
AAREY - MSETCL BORIVALI CKT - 1	IntraState	21/12/2022	13:24	21/12/2022	13:40	HT	on 220 kV MSETCL Borivali-Adani Borivali 1, abnormality observed on Y Phase current. Y phase current is zero as compared to other two phases. After inspection it is observed that a chattering noise is observed in 220 kV Bus isolator at 220kv Borivali s/stn.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 20/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 21/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 100 MVA ICT 2 @ KANDALGAON	IntraState	20/12/2022	10:10	20/12/2022	17:48	PO	Diagnostic Testing & Thermosyfon filter changing work.
220/33KV 50MVA PTR 1 @ MIRAJ	IntraState	20/12/2022	10:30	20/12/2022	17:17	PO	For T/F painting work
220/132KV 100MVA ICT 2 @ SATARA MIDC	IntraState	21/12/2022	11:21	21/12/2022	15:03	PO	Diagnostic testing work
132 KV LINE Outages/Trippings							
NALDURG-WAGHDARI CKT	IntraState	21/12/2022	15:25	21/12/2022	18:30	PO	Outage is required for Quarterly Maintenance
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	21/12/2022	09:26	21/12/2022	18:43	PO	Conductor inspection by using Line Vue

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage