

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/Jan/2019 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	138.686	3001.586	1) Gujrat	2.148	46.316
2) Hydro	5.406	137.877	2) Madhya Pradesh	11.371	179.586
3) Gas	7.236	142.647	3) Chattisgarh	4.470	80.370
Total MSPGCL	151.328	3282.110	4) Maharashtra	106.863	2001.115
B) 1) APLM	62.545	1430.991	5) Goa (Amona)	-0.550	-4.862
2) JSWEL	22.153	473.226	Total	124.302	2302.525
3) VIPL	0.000	81.108	a) Mumbai Schedule	25.351	427.810
4) RPL(AMT)	0.000	23.204	b) Mumbai Drawl	28.914	506.876
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	10.093	209.595
6) Other IPP	12.566	298.265	Include PX	-1.772	-103.098
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.700	422.122
C) 1) TPCL Thermal	5.257	193.109	Include PX	10.539	104.499
2) TPCL Hydro	5.202	80.459	Standby	2.651	5.688
3) TPCL Gas	4.365	91.788	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.027	106.763	1) MSEDCL	361.581	7638.770
D) STATE			2) Mumbai Discoms	50.765	978.993
1) Thermal	248.234	5608.252	TOTAL STATE	412.346	8617.763
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	10.608	218.336			
3) Gas (A3+B7+C3)	11.601	234.435			
4) Wind	11.911	134.735			
6) SOLAR	5.690	119.482			
TOTAL STATE	288.044	6315.240			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6196	6069	5745	5333
MSPGCL Hydro	454	326	414	92
MSPGCL Gas	294	288	287	303
MSPGCL Total Generation	6944	6684	6446	5728
Central Sector Receipt	6619	5900	5834	3440
WIND	284	291	684	471
CPP / IPP Thermal	4889	4796	3644	3625
CPP / IPP Gas	0	0	0	0
SOLAR	638	860	6	0
Exchange with Mumbai	-1391	-1586	-1455	-644
MSEDCL DEMAND MET	17984	16944	15158	12620
Load Shedding	0	0	0	0
MSEDCL DEMAND	17984	16944	15158	12620
TPCL GENERATION	810	800	814	387
AEML GENERATION	447	212	195	374
MUMBAI DEMAND	2648	2598	2464	1405
STATE DEMAND MET	20632	19542	17622	14024
STATE DEMAND	20632	19542	17622	14024
Frequency (Hz)	49.99	49.98	50.00	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 18.00 Hrs	49.68 Hz at 16.29 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 21/Jan/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.53	51.88	210	165
Unit 7	0.00	63.84	0	0
Unit 8	11.12	139.94	500	406
Unit 9	11.94	186.34	574	460
Unit 10	0.00	149.01	0	0
Total	27.59	591.02		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.19	202.35	490	350
Unit 5	9.10	202.31	485	350
Total	18.30	404.66		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	56.43	0	0
Total	0.00	56.43		
Chandrapur				
Unit 3	4.26	89.13	190	163
Unit 4	4.20	83.37	185	162
Unit 5	9.26	193.36	410	360
Unit 6	9.61	204.55	460	345
Unit 7	9.49	198.19	425	343
Unit 8	10.71	220.72	490	370
Unit 9	10.69	220.20	490	365
Total	58.23	1209.52		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	5.61	113.38	257	190
Total	5.61	113.38		
Khaparkheda				
Unit 1	3.76	77.04	175	140
Unit 2	3.90	76.53	175	155
Unit 3	3.84	78.59	163	157
Unit 4	3.82	77.81	165	150
Unit 5	9.50	207.16	430	376
Total	24.83	517.14		
Nasik				
Unit 3	0.00	22.11	0	0
Unit 4	4.13	87.33	207	160
Unit 5	0.00	0.00	0	0
Total	4.13	109.44		
Uran				
All Units	7.24	142.65	316	287
Total	7.24	142.65		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.92	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.92		
Koyna				
Stage 1-2	1.48	38.54	170	40
Stage 4	0.00	8.32	0	0
Stage 3	0.17	10.80	80	0
Total	1.65	57.66		
Hydro				
KDPH	0.44	7.73	19	19
VTRNA	0.55	10.72	60	0
TILLARI	0.66	9.20	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.17	4.09	80	0
RNGR+BHTSA	0.30	6.17	13	12
BHANDARDRA	0.00	0.06	0	0
ELDARY	0.00	2.78	0	0
SMLHY_PTN	0.44	8.43	26	16
GHATGHAR	1.19	31.04	250	0
Total	3.76	80.22		
Wind				
Total	11.91	134.74	0	0
Total	11.91	134.74		
CPP				
APML(Mus)	62.54	1430.99	0	0
JSWEL(Mus)	22.15	473.23	0	0
VIPL(Mus)	0.00	81.11	0	0
RPLAMT(Mus)	0.00	23.20	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	12.57	298.26	0	0
Total	97.26	2306.79		
SOLAR				
Total	5.69	119.48	0	0
Total	5.69	119.48		
Tata				
Trombay 5	0.00	83.46	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.77	58.12	117	107
Trombay 7B	1.60	33.67	68	64
Trombay 8	5.26	109.65	236	202
TATA Hydro	5.20	80.46	425	18
Total	14.82	365.36		
AEML				
DTPS U-1&2	7.03	106.76	472	192
Total	7.03	106.76		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	138.69	3001.59	MSPGCL Total	151.33	3282.11
			MSPGCL Thml+Gas	145.92	3144.23	Koyna 1,2 & 4 Total	1.48	46.86
			MSPGCL Hydro	5.41	137.88	State Total	288.04	6315.24

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 21/Jan/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5374	92	300	5766	405	3616	0	0	3930	3917	-887	12816	0	12816	1646	14462	50.02
2	5375	86	311	5772	461	3615	0	0	3619	3532	-754	12626	0	12626	1517	14144	49.99
3	5351	92	312	5754	465	3648	0	0	3525	3416	-686	12598	0	12598	1449	14046	50.05
4	5333	92	303	5728	471	3625	0	0	3496	3440	-644	12620	0	12620	1405	14024	50.01
5	5349	86	312	5748	419	3554	0	0	3913	4062	-655	13128	0	13128	1417	14544	50.00
6	5528	86	313	5928	482	3632	0	0	4835	4976	-770	14248	0	14248	1548	15796	49.87
7	6057	180	315	6552	464	4077	0	5	5585	5448	-979	15566	0	15566	1764	17330	49.97
8	6290	234	316	6840	416	4736	0	66	5861	5823	-1087	16794	0	16794	1963	18756	50.03
9	6288	266	304	6858	259	4892	0	299	6027	6012	-1132	17188	0	17188	2230	19418	49.97
10	6243	226	309	6778	280	4892	0	558	6273	6473	-1295	17686	0	17686	2483	20170	50.00
11	6196	454	294	6944	284	4889	0	638	6346	6619	-1391	17984	0	17984	2648	20632	49.99
12	6173	486	291	6950	270	4903	0	795	6328	6238	-1551	17606	0	17606	2662	20268	50.01
13	6069	326	288	6684	291	4796	0	860	6061	5900	-1586	16944	0	16944	2598	19542	49.98
14	5964	282	288	6534	318	4561	0	804	5783	5784	-1518	16482	0	16482	2478	18960	50.01
15	5969	272	288	6530	355	4486	0	711	5707	5992	-1535	16538	0	16538	2479	19018	50.00
16	6080	278	298	6656	430	4506	0	545	5697	5554	-1483	16208	0	16208	2491	18698	49.92
17	5925	288	289	6502	524	4304	0	315	5546	5310	-1473	15482	0	15482	2471	17952	49.81
18	5834	234	292	6360	721	3842	0	88	5267	5343	-1454	14900	0	14900	2446	17346	50.01
19	5745	414	287	6446	684	3644	0	6	5549	5834	-1455	15158	0	15158	2464	17622	50.00
20	5731	342	304	6378	577	3657	0	0	5515	5520	-1421	14710	0	14710	2432	17142	50.01
21	5726	162	299	6188	716	3653	0	0	5112	5073	-1398	14232	0	14232	2285	16516	50.04
22	5461	152	310	5924	999	3356	0	0	5122	4908	-1283	13904	0	13904	2109	16012	50.05
23	5330	152	301	5784	716	3239	0	0	4727	4676	-1294	13120	0	13120	1961	15082	50.01
24	5295	124	312	5730	904	3141	0	0	4007	4452	-1183	13044	0	13044	1819	14864	50.04
MUs	138.69	5.41	7.24	151.33	11.91	97.26	0.00	5.69	123.83	124.30	-28.91	361.58	0.00	361.58	50.77	412.35	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 21/Jan/2019

Position as on 6.30 Hrs of 22/Jan/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 5	210	22/11/2018	03.50		Continued.	Boiler Tube Leakage Work Completed On 24/11/2018. Available Against Case 4 From 25/11/2018. Converted To COH From 00:00 Hrs of 05/12/2018 (Converted COH to Zero sch by MSEDCL from 29.01.2019)	
TPC-G	Trombay 5	500	11/01/2019	23.56		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-2	250	14/01/2019	09:40	22/01/2019	12:35	Routine Maintenance work.	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
MSPGCL	Koyna Unit 1	70	26/11/2018	00.00		Continued.	Oil Cooler Leakage.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	14/12/2018	16.30		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	RPL(AMT) U-2	270	27/12/2018	19.30		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/01/2019	19.30		Continued.	Zero Schedule	
IPP	Dhariwal	300	12/01/2019	10.15		Continued.	Coal Shortage	
MSPGCL	Parli Unit 8	250	12/01/2019	12.00		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Koradi Unit 10	660	15/01/2019	23.25		Continued.	Condenser Tube Cleaning	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 21/Jan/2019

Position as on 6.30 Hrs of 22/Jan/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							Work & PCR.	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
IPP	RPL(AMT) U-1	270	18/01/2019	19.30	22/01/2019	05.30	Zero Schedule.	
MSPGCL	Koradi Unit 7	210	19/01/2019	18.21		Continued.	Poor Coal Receipt	
AEML	AEML Unit 1	250	21/01/2019	11.11		Continued.	Turbine Vibration	
IPP	Adani U-2	660	21/01/2019	17.32		Continued.	Hot PA Duct Bellow Leakage.	
MSPGCL	Chandrapur Unit 9	500	22/01/2019	19.03		Continued.	Tripping of Primary Water Pumps.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dabhol Nagothane I	InterState	18/01/2019	11.52	21/01/2019	10.22	PO	String Replacement of Insulator Strings.
Dhule Sar'Sarovar II	InterState	20/01/2019	16.39	22/01/2019	10.22	HT	Over Voltage
Kolhapur(M)-Kolhapur(GIS) cktII	InterState	22/01/2019	08.31	22/01/2019	19.02	HT	As Heavy Sparking Observed At Isolator BPL.Code 2241 Issue For Work Permit At 10.33HRS.
Kolhapur(M)-Kolhapur(GIS) ckt1	InterState	22/01/2019	11.09	22/01/2019	15.41	HT	As Heavy Sparking Observed At R PH CT.Code 2253 Issue For Work Permit.
Dhule Sar'Sarovar I	InterState	22/01/2019	17.30		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	18/01/2019	17.31	21/01/2019	06.59	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	20/01/2019	22.05	21/01/2019	07.18	HT	Over Voltage
Karad-Jaigad - I	IntraState	20/01/2019	22.06	21/01/2019	09.38	HT	Over Voltage
Akola - Bhusawal	IntraState	21/01/2019	07.09	21/01/2019	18.22	PO	Replacement Of Conductor.
Deepnagar Taptitanda	IntraState	21/01/2019	07.15	21/01/2019	18.35	PO	Replacement of Dead End & Mid Span Joint.
Warora-Adani(Tiroda)1	IntraState	21/01/2019	09.18	21/01/2019	19.54	PO	Annual Maintenance Work
Jaigad-New Koyna Ckt-I	IntraState	21/01/2019	10.07	22/01/2019	09.31	PO	Insulator Replacement & Maintenance Work.
Khadka-Aurangabad (Waluj)	IntraState	21/01/2019	18.44	22/01/2019	07.11	HT	Over Voltage
Deepnagar Taptitanda	IntraState	22/01/2019	07.20	22/01/2019	20.35	PO	Replt. of Dead End & Mid Span Joint.
Warora-Tirora-Ii	IntraState	22/01/2019	08.48	22/01/2019	18.56	PO	Annual Maintenance Work
Jaigad-New Koyna Ckt-II	IntraState	22/01/2019	10.04	22/01/2019	17.44	PO	Insulator Replacement Work.
Khadka-Aurangabad (Waluj)	IntraState	22/01/2019	21.37		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220kv 315MVA ICT 2 @ Kolhapur	IntraState	21/01/2019	09.02	21/01/2019	19.35	PO	Annual Maintenance Work
400/220KV 315MVA ICT-I@bhusawal(khadka)	IntraState	22/01/2019	08.33	22/01/2019	21.22	PO	For Commissioning of CSD Relay.
400/220KV 500MVA ICT-II@Taptitanda	IntraState	22/01/2019	10.11	22/01/2019	19.49	EO	Testing & Maintenance.
400/220KV 105MVASpare ICT@Akola	IntraState	22/01/2019	12.21	22/01/2019	16.08	EO	For Removing Bird Nest At Y-PH Gantry Structure.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Mudshingi Chikodi	InterState	22/01/2019	07.00	22/01/2019	16.43	T	Distance Protection, PDR Optd, IC-9.4KA,10.8KM, Z1, B-PH, At LOC No-285 B-PH String Flashover.
Talandage - Chikodi	InterState	22/01/2019	07.02	22/01/2019	20.23	T	Distance Protection, Zone 2.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.
Nanded - Parli Ext. Ckt I	IntraState	06/12/2018	07.02	22/01/2019	08.50	HT	Waghala-Kumbhargaoon CKT O/L.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Main bus section-II @ Pedambe	IntraState	21/01/2019	07.05	21/01/2019	17.30	PO	Bus Isolator Maintenance Work.
Ghatghar - Bapgaon	IntraState	21/01/2019	10.06	21/01/2019	19.00	PO	For Earth Wire Replacement Of Ghatghar M/C Line.
Eklahare (Gcr) - Ghatghar	IntraState	21/01/2019	10.50	21/01/2019	14.40	PO	For Earth Wire Replacement Of Ghatghar M/C Line.
Kharghar - Tss Panvel	IntraState	21/01/2019	12.09	21/01/2019	17.13	PO	Height Raising Of 220KV Kandalgaon Kharghar D/C Line At Loc No.646-649 For DFCCIL.
Topworth - Kharghar	IntraState	21/01/2019	12.35	21/01/2019	17.38	PO	Height Raising Of 220KV Kandalgaon Kharghar D/C Line At Loc No.646-649 For DFCCIL.
Bhugaon-WardhaPG (Deoli)	IntraState	21/01/2019	13.09	21/01/2019	22.55	EO	Attending Hot Spot At CB & CT.
Talandge(400kv)- Ichalkaranji 2	IntraState	22/01/2019	07.02	22/01/2019	09.01	T	Distance Protection, B-PH, IC-1.07 KA.
Pusad - Hingoli	IntraState	22/01/2019	07.30	22/01/2019	18.46	HT	In View Outage On Wardha-Yavatmal CKT.
Nanded-Parbhani	IntraState	22/01/2019	07.38	22/01/2019	11.028	HT	In View Outage On 220KV Wardha-Yavatmal CKT.
Pusad-Ghatodi	IntraState	22/01/2019	07.45	22/01/2019	18.47	HT	In View Outage On 220KV Wardha-Yavatmal CKT.
Khadka-Chalisgaon-1	IntraState	22/01/2019	08.23	22/01/2019	21.46	HT	For Outage On Khadka ICT.
Karad(400kv) - Ogalewadi Ckt 2	IntraState	22/01/2019	08.39	22/01/2019	23.12	PO	Restrining of Conductor Between LOC 1 to 9 R-PH.18.57HRS Trail Taken from Kard End, Tripped Due To R PH CC Blast At Ogalewadi End.
New Koyna - Loteparshuram	IntraState	22/01/2019	09.41	22/01/2019	13.31	PO	Washing Insulator String.
Eklahare (Gcr) - Ghatghar	IntraState	22/01/2019	09.53	22/01/2019	19.08	PO	For Earth Wire Replacement of Ghatghar m/c line.
Nigade- Peth Line	IntraState	22/01/2019	10.00	22/01/2019	11.30	PO	Quarterly Maintenance Work & CT Leakages Attending Work.
Ghatghar - Bapgaon	IntraState	22/01/2019	10.25	22/01/2019	19.35	PO	For Earth Wire Replacement of Ghatghar m/c line.
Taloja II - OCIL-I	IntraState	22/01/2019	11.09	22/01/2019	11.51	EO	For Removing Bird Nest At Y-PH Gantry Structure.
Nanded - Parli Ext. Ckt I	IntraState	22/01/2019	11.23		Continued.	HT	For Nanded-Nanded Loading.
Khaparkheda-Ambazari-Ii	IntraState	22/01/2019	12.24	22/01/2019	13.22	PO	For Connecting PT Supply.
Babhaleshwar-Nagar-I	IntraState	22/01/2019	13.22	22/01/2019	17.18	PO	Flash Over Insulator Replacement.
Koradi-Ambazari-Ii	IntraState	22/01/2019	13.49	22/01/2019	14.37	PO	For Connecting PT Supply.
Koradi-Ambazari-I	IntraState	22/01/2019	14.42	22/01/2019	15.27	PO	For Connecting PT Supply.
Kharghar-Borivali ckt I	IntraState	22/01/2019	16.37	22/01/2019	20.40	T	Distance Protection, R-PH E/F.

220 KV ICT Outages/Trippings

220/132 KV 200MVA ict 1@Nasik GCR	IntraState	19/01/2019	09.52	21/01/2019	16.37	PO	Dismantling of existing main and aux Bus Isolator and commissioning of new Isolator
220/100kv 200MVA ICT @ Ogalewadi	IntraState	21/01/2019	10.33	21/01/2019	16.15	PO	Diagnostic testing work.
220/132 kv 200MVA ICT-V @ Nashik	IntraState	22/01/2019	09.05	22/01/2019	11.21	PO	Replacement of Winding Temperature Indicator Meter of Tertiary.
220/132 kv 200 MVA ICT- I @ Nanded	IntraState	22/01/2019	13.45	22/01/2019	18.08	PO	Measurment of Tan Delta of CT Diagnostic Testing Work SFRA Test of ICT.

132 KV LINE Outages/Trippings

Mansar Pench	InterState	22/01/2019	18.40		Continued.	HT	After Completion of Outage.
Pusad-Jambazar	IntraState	22/01/2019	07.45	22/01/2019	18.51	HT	In View Outage On 220KV Wardha-Yavatmal CKT.
Waghala (Nanded2) - Elichpur	IntraState	22/01/2019	07.48	22/01/2019	18.55	HT	In View Outage On 220KV Wardha-Yavatmal CKT.
Killari Tap On Ujani-Omerga	IntraState	22/01/2019	13.18	22/01/2019	16.38	T	Distance Protection Operated Zone 15.5KM B-PH.
Kanhan-Pench	IntraState	22/01/2019	18.44		Continued.	HT	After Completion of Outage.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage