

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/Jan/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	141.842	3038.298	1) Gujrat	-5.603	-138.663
2) Hydro	12.903	248.681	2) Madhya Pradesh	5.778	104.808
3) Gas	4.586	97.027	3) Chattisgarh	7.060	123.850
Total MSPGCL	159.331	3384.006	4) Maharashtra	141.841	2740.933
B) 1) APLM	67.352	1434.248	5) Goa (Amona)	-1.624	-30.180
2) JSWEL	14.138	295.589	Total	147.452	2800.748
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.990	456.525
4) RPL(AMT)	22.257	532.709	b) Mumbai Drawl	27.791	493.196
5) SWPGPL	8.122	123.823	c) MSEDCL Bilateral *	64.119	1204.071
6) Other IPP	39.722	802.173	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.990	456.402
C) 1) TPCL Thermal	11.240	216.404	Include PX	0.000	0.000
2) TPCL Hydro	4.052	82.825	Standby	0.000	0.123
3) TPCL Gas	0.000	9.340	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.783	185.665	1) MSEDCL	441.873	9002.701
D) STATE			2) Mumbai Discoms	48.866	987.429
1) Thermal	310.456	6628.909	3) Other Discoms	8.083	194.909
(A1+C1+C4+(B1-B6))			TOTAL STATE	498.822	10185.039
2) Hydro	16.955	331.506			
(A2+C2)					
3) Gas	4.586	106.367			
(A3+B7+C3)					
4) Wind	10.734	181.133			
6) SOLAR	8.639	136.377			
TOTAL STATE	351.370	7384.292			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	6531	6443	6395	5101
MSPGCL Hydro	1656	599	351	341
MSPGCL Gas	147	167	247	149
MSPGCL Total Generation	8334	7209	6993	5591
Central Sector Receipt	7268	7627	5937	5216
WIND	279	292	377	702
CPP / IPP Thermal	6940	6808	6877	5193
CPP / IPP Gas	0	0	0	0
SOLAR	1071	1248	0	0
Exchange with Mumbai	-1414	-1391	-1206	-870
MSEDCL DEMAND MET	18130	17369	14549	12663
Load Shedding	0	0	0	0
MSEDCL DEMAND	18130	17369	14549	12663
TPCL GENERATION	885	871	904	396
AEML GENERATION	246	243	245	248
MUMBAI DEMAND	2545	2505	2355	1514
OTHER DISCOM DEMAND	362	369	369	264
STATE DEMAND MET	25023	24298	21333	17346
STATE DEMAND	25023	24298	21333	17346
Frequency (Hz)	50.00	50.04	50.01	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 13.03 Hrs	49.72 Hz at 00.33 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 21/Jan/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.48	62.26	165	120
Unit 7	0.00	0.00	0	0
Unit 8	14.36	282.81	607	583
Unit 9	14.17	242.28	603	579
Unit 10	12.31	244.99	535	486
Total	44.31	832.34		
Bhusawal				
Unit 3	3.04	57.52	150	115
Unit 4	0.00	100.73	0	0
Unit 5	8.65	179.54	435	285
Total	11.70	337.78		
Parli				
Unit 6	4.22	83.06	249	141
Unit 7	4.27	82.16	248	140
Unit 8	4.03	83.69	223	143
Total	12.52	248.92		
Chandrapur				
Unit 3	0.00	49.03	0	0
Unit 4	0.00	58.23	0	0
Unit 5	7.92	161.14	370	296
Unit 6	8.37	174.84	390	284
Unit 7	8.28	110.28	400	285
Unit 8	9.25	197.03	446	5
Unit 9	10.33	195.59	472	279
Total	44.15	946.14		
Paras				
Unit 3	4.56	92.20	257	142
Unit 4	4.47	78.27	242	142
Total	9.03	170.47		
Khaparkheda				
Unit 1	3.18	54.58	155	120
Unit 2	0.00	0.00	0	0
Unit 3	0.72	64.64	138	0
Unit 4	0.00	54.04	0	0
Unit 5	9.82	205.71	480	280
Total	13.72	378.96		
Nasik				
Unit 3	3.24	62.16	180	114
Unit 4	0.00	18.28	0	0
Unit 5	3.18	43.26	178	114
Total	6.42	123.69		
Uran				
All Units	4.59	97.03	257	143
Total	4.59	97.03		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.16	5.78	30	0
Total	0.16	5.78		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.37	50.39	415	35
Stage 4	2.07	31.30	617	0
Stage 3	1.00	18.34	240	0
Total	5.44	100.02		
Hydro				
KDPH	0.43	5.97	18	18
VTRNA	0.72	11.86	60	0
TILLARI	0.52	10.96	58	0
BHIRA T.R.	0.20	4.86	40	0
SMLHY_PTN	5.59	113.72	244	212
GHATGHAR	0.00	1.29	0	0
Total	7.46	148.66		
Wind				
Total	10.73	181.13	0	0
Total	10.73	181.13		
CPP				
APML(Mus)	67.35	1434.25	0	0
JSWEL(Mus)	14.14	295.59	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	22.26	532.71	0	0
SWPGPL-Mus	8.12	123.82	0	0
Other(Mus)	39.72	802.17	0	0
Total	151.59	3188.54		
SOLAR				
Total	8.64	136.38	0	0
Total	8.64	136.38		
Tata				
Trombay 5	7.37	141.70	456	253
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	5.17	0	0
Trombay 7B	0.00	4.17	0	0
Trombay 8	3.87	74.70	225	130
TATA Hydro	4.05	82.82	346	0
Total	15.29	308.57		
AEMIL				
DTPS U-1&2	5.78	185.66	249	215
Total	5.78	185.66		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	141.84	3038.30	MSPGCL Total	159.33	3384.01
			MSPGCL Thml+Gas	146.43	3135.32	Koyna 1,2 & 4 Total	4.44	81.68
			MSPGCL Hydro	12.90	248.68	State Total	351.37	7384.29

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 21/Jan/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5117	400	149	5666	659	5122	0	0	5489	5342	-958	15551	0	15551	1602	280	17433	49.86
2	5101	341	149	5591	702	5193	0	0	5404	5216	-870	15568	0	15568	1514	264	17346	49.99
3	5111	304	159	5574	716	5366	0	0	5344	5247	-807	15842	0	15842	1449	254	17545	49.98
4	5092	301	151	5544	733	5462	0	0	5469	5062	-780	15759	0	15759	1415	262	17436	49.98
5	5371	304	151	5826	903	5501	0	0	5488	5156	-799	16303	0	16303	1429	284	18016	50.01
6	5744	304	159	6207	699	5829	0	0	5596	5527	-893	17061	0	17061	1527	308	18896	50.00
7	6105	352	149	6606	571	6650	0	5	5516	5919	-908	18521	0	18521	1637	322	20480	50.02
8	6512	696	150	7358	460	6990	0	108	5863	5919	-943	19549	0	19549	1839	343	21731	49.98
9	6595	1076	149	7820	320	6994	0	456	6159	6073	-1105	20209	0	20209	2122	349	22680	49.99
10	6562	1293	158	8013	299	6993	0	811	6853	6789	-1295	21248	0	21248	2392	362	24002	49.87
11	6531	1656	147	8334	279	6940	0	1071	7192	7268	-1414	22116	0	22116	2545	362	25023	50.00
12	6518	1258	143	7919	268	6912	0	1228	7314	7522	-1444	22048	0	22048	2572	357	24977	50.02
13	6443	599	167	7209	292	6808	0	1248	7328	7627	-1391	21424	0	21424	2505	369	24298	50.04
14	6024	496	200	6720	263	6569	0	1208	7239	7493	-1413	20487	0	20487	2334	353	23174	50.07
15	5878	502	217	6597	289	6328	0	1091	7597	7600	-1476	20075	0	20075	2341	354	22770	50.03
16	5932	417	223	6572	380	6653	0	807	7438	7305	-1452	19910	0	19910	2332	355	22597	50.02
17	5978	389	243	6610	407	6790	0	491	6615	6517	-1363	19076	0	19076	2342	376	21794	50.00
18	6100	360	235	6695	409	6759	0	115	5882	6131	-1239	18482	0	18482	2347	388	21217	50.05
19	6331	325	236	6892	369	6836	0	0	5748	6058	-1257	18512	0	18512	2395	386	21293	50.03
20	6395	351	247	6993	377	6877	0	0	5809	5937	-1206	18609	0	18609	2355	369	21333	50.01
21	6081	328	257	6666	320	6610	0	0	5555	4993	-1257	16970	0	16970	2208	362	19540	49.98
22	5704	313	248	6265	331	5938	0	0	5647	5851	-1245	16784	0	16784	2043	356	19183	49.99
23	5437	265	250	5952	320	5766	0	0	5566	5735	-1189	16238	0	16238	1881	346	18465	50.02
24	5180	273	249	5702	368	5705	0	0	5537	5165	-1087	15532	0	15532	1740	321	17593	50.04
MUs	141.84	12.90	4.59	159.33	10.73	151.59	0.00	8.64	147.65	147.45	-27.79	441.87	0.00	441.87	48.87	8.08	498.82	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 21/Jan/2022

Position as on 6.30 Hrs of 22/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 4	210	16/01/2022	23:52	22/01/2022	05:50	Extension of Boiler Steaming Validity.	
AEML	AEML Unit 2	250	20/01/2022	08:54		Continued.	Boiler Validity Renevoation	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Uran Unit 6	108	02/12/2021	07:45	21/01/2022	12:05	Gas shortage	
TPC-G	Trombay 7A	120	04/01/2022	19:40		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/01/2022	20:00		Continued.	Gas shortage	
MSPGCL	Nasik Unit 4	210	07/01/2022	22:00		Continued.	CONDENSER TUBE LEAKAGE	
IPP	JSW (J) U3	300	15/01/2022	07:46		Continued.	non availability of load schedule.	
MSPGCL	Chandrapur Unit 4	210	18/01/2022	23:47		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 3	210	19/01/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 3	210	19/01/2022	06:11	21/01/2022	17:22	Furnace Pressure High	
MSPGCL	Ghatghar Unit-2	125	19/01/2022	12:05	21/01/2022	16:25	AVR Heavy fault.	
MSPGCL	Uran Unit 5	108	20/01/2022	12:42		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	20/01/2022	21:15		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 8	500	21/01/2022	23:04		Continued.	Boiler Tube Leakage	
MSPGCL	Ghatghar Unit-2	125	21/01/2022	23:05	22/01/2022	00:52	HS FAULT	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
Main bay 704 of Koradi 3 ckt 2 @ 765 KV Tiroda	IntraState	22/01/2022	09:34		Continued.	PO	-For (704-52) CB Maintenance & for attending SF6 gas leakage
400 KV TIEBAY Outages/Trippings							
TIE BAY (423) OF STATION TF - 1 @ KORADI 2	IntraState	21/01/2022	11:18	21/01/2022	16:58	PO	1) Diagnostic testing of CB 423-Q52 at bay 423. 2) Routine Bay Maintenance work.
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	22/01/2022	09:15	22/01/2022	18:31	PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/12/2021	12:35	21/01/2022	10:35	HT	HAND TRIPPED TO CONTROL LINE LOADING OF 400KV TALEGAON-KALWA AND 400KV TALEGAON - KHARGHAR CKT
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	04/01/2022	15:46			PO	Height raising work of 400kV Waluj-Babhleshwar line at Loc No. 239 to 240 crossing to Samruddhi Highway i.e. 1. Dismantling of loc No. 239,240,241 (all DA+01) 2. Erection of new towers at loc No.239, 240,241 (All DD+9) 3. Restrtringing between Loc No. 237 to 242
KORADI-NANDGAONPETH (RPL)	IntraState	20/01/2022	10:30	21/01/2022	21:25	PO	Retrofitting of Distance Relay I & II under MTAMC Project
TBC 2 @ CHANDRAPUR	IntraState	20/01/2022	12:35			EO	It is very necessary to attend the SF6 gas leakage considering the emergency and urgency. Low gas alarm is continuously appearing in short duration, Hence the problem needs to attend. To attend the SF6 gas leakage from NRV valve of R-ph pole of 400KV BHEL make Cicuit Breaker.
BUS - 2 @ NEW KOYNA	IntraState	20/01/2022	12:35	21/01/2022	09:29	PO	Bus CVT replacement work
NAGOTHANE - DABHOL CKT - 1	IntraState	21/01/2022	09:02	21/01/2022	18:45	PO	400KV string replacement, Equipment PM & testing
AKOLA-NANDGAONPETH (RPL-AMT)	IntraState	21/01/2022	22:15	22/01/2022	02:17	EO	For attending Hotspot in 413 89 B in U clamp from Isolator to CT side
BABHALESHWAR - PADGHE CKT-1	IntraState	21/01/2022	23:29	22/01/2022	01:55	T	tripped on dist. protn
BABHALESHWAR - PADGHE CKT-1	IntraState	21/01/2022	23:29	22/01/2022	01:55	T	DISTANCE PROTECTION
JAIGAD - KARAD CKT - 2	IntraState	22/01/2022	00:11	22/01/2022	10:36	HT	H/T FOR O/V
NEW KOYNA - DABHOL CKT - 2	IntraState	22/01/2022	06:06		Continued.	T	TRIPPED ON DIST. PROTN
KHARGHAR - TALEGAON (PG)	IntraState	22/01/2022	14:37	22/01/2022	19:18	PO	For AMP Work
BABHALESHWAR - PADGHE CKT-1	IntraState	22/01/2022	21:40		Continued.	EO	Fixing of rod type bird guard at loc no. 60
JAIGAD - KARAD CKT - 1	IntraState	22/01/2022	22:21		Continued.	HT	H/T FOR O/V
400 KV ICT Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315MVA ICT - 3 @ KHADKA	IntraState	21/01/2022	08:41	21/01/2022	21:18	PO	for MTAMC Relay retrofitting work and routine bay maintenance activities including Bushing, wdg tan Delta, HV CT tan delta testing
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	IntraState	22/01/2022	20:17		Continued.	PO	For MTAMC project related work and oil leakage attending work
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	20/01/2022	09:30			PO	Annual Maintenance of 220kV Ghodbunder to Dahanu Line -1 & 2
220 KV MAINBAY Outages/Trippings							
220kV Bus bar protection @ TROMBAY (MSETCL)	IntraState	21/01/2022	14:25	21/01/2022	18:50	PO	Annual testing of Bus Bar relay by Testing Team for which Bus Bar Protection will be made Off.
220 KV LINE Outages/Trippings							
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18		Continued.	PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
PADGHE - NALASOPARA - VASAI (T)	IntraState	19/12/2021	10:06		Continued.	PO	1) 220KV Padgha Nalasopara - Vasai Tap line & Jumper will open at loc.33 ,35 and loc no.204 after that link line i.e. 220kV Nalasopara- Vasai link line will be charged at 12:00 hrs on dtd: 19.12.2021. this link line will be in service for 43 days continuous i.e 1024 hrs.
PADGHE - TEMGHAR - 2	IntraState	02/01/2022	23:25			HT	conductor replacement work
TEMGHAR - KALWA	IntraState	13/01/2022	23:10				As safety precaution for the replacement of CB pole of 220/22 kV, 50MVA PTR-2
DAHANU - GHODBUNDER CKT - 1	IntraState	20/01/2022	09:23				Modification / relocation of existing tower no LS 45 to 47 at Vangoan for NHRCL Project. 2) Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Towers. 4. Re-stringing of conductors & OPGW cable.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - GHODBUNDER CKT - 2	IntraState	20/01/2022	09:27				Modification / relocation of existing tower no LS 45 to 47 at Vangoan for NHSRCL Project.2) Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out:1. De-stringing of existing conductors & OPGW cable.2. Dismantling of existing towers.3. Erection of Towers.4. Re-stringing of conductors & OPGW cable.
TPC BORIVALI - AAREY	IntraState	20/01/2022	09:32			PO	For shifting to new GIS with cable extension with transition joint
CENTURI ENKA- BHOSARI	IntraState	21/01/2022	10:38	21/01/2022	15:55	PO	Due to high Tan delta values of CT replacement work as per LE Scheme
KANDALGAON - POSCO	IntraState	21/01/2022	12:45	21/01/2022	17:06	PO	Diagnostic Testing & Bay Maintenance Work.
PADGHA - TEMGHAR - 1	IntraState	21/01/2022	15:51	21/01/2022	18:36	PO	Outage is required for safety purpose for replacement of Existing conductor by HTLS Drake of 220KV Padgha-Temghar-2 line in between Loc. No. 3 & 4 which is above 220KV Padgha-Temghar-1 & 220KV Colourchem-Temghar line.
COLOURCHEM - TEMGHAR	IntraState	21/01/2022	16:00	21/01/2022	18:40	PO	Outage is required for safety purpose for replacement of Existing conductor by HTLS Drake of 220KV Padgha-Temghar-2 line in between Loc. No. 3 & 4 which is above 220KV Padgha-Temghar-1 & 220KV Colourchem-Temghar line.
GOREGAON - AAREY CKT - 2	IntraState	22/01/2022	03:55	22/01/2022	12:00	T	TRIPPED ON DIST.PROTN
ADLABS - PEDAMBE	IntraState	22/01/2022	06:13	22/01/2022	14:10	T	TRIPPED ON DIST. PROTN
PEDAMBE-KALAMBANI(TSS)	IntraState	22/01/2022	06:53	22/01/2022	13:55	T	TRIPPED ON DIST. PROTN
MAHAPE - RELIANCE GIS	IntraState	22/01/2022	09:02	22/01/2022	11:25	PO	For attending hotspot on B-ph Line CT clamp 100C by replacement of palm
KHADKI- CENTURY ENKA	IntraState	22/01/2022	10:22	22/01/2022	17:13	PO	CB overhauling and HYM
BOMBAY DYEING - SAHARA	IntraState	22/01/2022	11:48	22/01/2022	17:53	PO	Work :- Restraining of conductors loc 130-131 (3.46m,Bph) Loc-146-147(4.03m) YPh
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 2 @ BOISAR-II	IntraState	21/01/2022	10:30	21/01/2022	20:58	PO	Diagnostic testing works,(WRM, CT Tan Delta,CRM,IR)
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	21/01/2022	10:30	21/01/2022	18:03	PO	DIGANOSTIC TESTING AND BAY MAINTENANCE WORK
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	21/01/2022	10:31	21/01/2022	13:58	PO	Removal of HV R-ph LA. due to high leakage current.
220/33KV 25MVA TF NO.2 @ SAYNE	IntraState	21/01/2022	10:55	21/01/2022	15:55	PO	tan delta testing
220/22 KV 50 MVA PTR 2 @ ANANDNAGAR	IntraState	21/01/2022	14:08	21/01/2022	17:13	PO	Removal of HV Y-PH LA due to high leakage current.
220/33KV 50MVA TF NO.1 @ SAYNE	IntraState	21/01/2022	16:15	21/01/2022	18:05	PO	tan delta testing

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22KV 50 MVA PTR - 3 @ AKP	IntraState	22/01/2022	09:12	22/01/2022	17:35	PO	1) Diagnostic testing work , 2) 50 MVA TF Incommer -3 Y ph CT Hot Spot attending work and R&M work. 3) Bus Isolator & C Isolator maintenance by removing jumper through Hot Line team.
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	22/01/2022	09:36	22/01/2022	14:09	PO	ICT diagnostic testing, Bay maint. work
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	22/01/2022	16:05	22/01/2022	16:45	PO	MAIN TANK OIL TOP UP WORK
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	22/01/2022	16:28	22/01/2022	17:40	PO	MAIN TANK OIL TOP UP WORK
220 KV BUSBAR Outages/Trippings							
BUS - B @ PADGHE	IntraState	22/01/2022	01:05		Continued.	PO	For making Stub Bus Twin arrangement of 220Kv Padghe- Temghar-2 Line above the A Bus at Padghe end.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage