

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/Jan/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	142.981	3020.527	1) Gujrat	-5.542	-104.820
2) Hydro	15.776	281.371	2) Madhya Pradesh	3.459	60.781
3) Gas	5.633	104.977	3) Chattisgarh	5.520	116.080
Total MSPGCL	164.390	3406.875	4) Maharashtra	166.420	3692.196
B) 1) APMIL	69.953	1153.285	5) Goa (Amona)	-1.389	-31.597
2) JSWEL	21.201	411.389	Total	168.468	3732.640
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.660	472.579
4) RPL(AMT)	25.456	521.746	b) Mumbai Drawl	29.507	554.593
5) SWPGPL	9.869	177.135	c) MSEDCL Bilateral *	63.724	1486.348
6) Other IPP	48.907	974.795	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.593	471.919
C) 1) TPCL Thermal	0.000	204.766	Include PX	0.000	0.000
2) TPCL Hydro	7.097	80.087	Standby	0.067	0.660
3) TPCL Gas	2.526	49.963	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.172	190.920	1) MSEDCL	490.169	10042.902
D) STATE			2) Mumbai Discoms	49.302	1080.326
1) Thermal	328.539	6654.563	3) Other Discoms	9.733	202.839
(A1+C1+C4+(B1-B6))			TOTAL STATE	549.204	11326.067
2) Hydro (A2+C2)	22.873	361.458			
3) Gas (A3+B7+C3)	8.159	154.940			
4) Wind	8.009	155.705			
6) SOLAR	13.156	266.764			
TOTAL STATE	380.736	7593.430			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	6410	6350	6058	5076
MSPGCL Hydro	1691	597	1315	233
MSPGCL Gas	236	230	230	237
MSPGCL Total Generation	8337	7177	7603	5546
Central Sector Receipt	8146	8255	6282	7170
WIND	206	111	202	548
CPP / IPP Thermal	7866	7407	7916	6047
CPP / IPP Gas	0	0	0	0
SOLAR	1693	1984	1	0
Exchange with Mumbai	-1562	-1596	-1372	-1022
MSEDCL DEMAND MET	24233	22917	20183	17941
Load Shedding	0	0	0	0
MSEDCL DEMAND	24233	22917	20183	17941
TPCL GENERATION	493	412	577	206
AEML GENERATION	499	493	492	314
MUMBAI DEMAND	2554	2501	2441	1542
OTHER DISCOM DEMAND	453	421	449	348
STATE DEMAND MET	27240	25839	23073	19831
STATE DEMAND	27240	25839	23073	19831
Frequency (Hz)	49.99	50.02	50.00	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.33 Hz at 17:05 Hrs	49.77 Hz at 09:07 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 21/Jan/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.52	88.77	140	0
Unit 7	0.00	0.00	0	0
Unit 8	12.91	281.39	592	483
Unit 9	13.62	176.87	629	496
Unit 10	13.61	269.92	614	521
Total	40.67	816.95		
Bhusawal				
Unit 3	3.42	43.04	170	120
Unit 4	9.84	210.00	475	280
Unit 5	9.08	163.58	425	280
Total	22.36	416.61		
Parli				
Unit 6	4.74	84.86	239	150
Unit 7	0.00	13.70	0	0
Unit 8	1.60	54.20	145	0
Total	6.35	152.76		
Chandrapur				
Unit 3	3.00	70.52	165	0
Unit 4	2.95	53.09	134	110
Unit 5	7.03	133.20	304	280
Unit 6	2.26	141.99	320	0
Unit 7	0.00	0.00	0	0
Unit 8	10.30	223.47	490	282
Unit 9	10.90	227.04	500	297
Total	36.45	849.30		
Paras				
Unit 3	4.54	98.03	220	158
Unit 4	5.13	90.26	235	191
Total	9.67	188.30		
Khaparkheda				
Unit 1	2.98	57.98	135	105
Unit 2	2.65	57.95	135	93
Unit 3	3.78	72.28	180	126
Unit 4	3.64	63.57	177	130
Unit 5	7.56	207.27	490	0
Total	20.61	459.05		
Nasik				
Unit 3	3.48	18.78	172	112
Unit 4	3.41	70.79	165	117
Unit 5	0.00	47.98	0	0
Total	6.88	137.55		
Uran				
All Units	5.63	104.98	239	227
Total	5.63	104.98		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	7.75	23	0
Total	0.06	7.75		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.64	81.50	490	35
Stage 4	5.13	92.69	684	0
Stage 3	2.18	37.56	276	0
Total	10.94	211.74		
Hydro				
KDPH	0.86	5.72	36	36
VTRNA	0.39	1.20	61	0
TILLARI	0.00	4.41	0	0
BHIRA T.R.	0.38	4.46	80	0
SMLHY_PTN	2.52	32.24	111	100
GHATGHAR	0.62	13.85	125	0
Total	4.77	61.88		
Wind				
Total	8.01	155.70	0	0
Total	8.01	155.70		
CPP				
APML(Mus)	69.95	1153.28	0	0
JSWEL(Mus)	21.20	411.39	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.46	521.75	0	0
SWPGPL-Mus	9.87	177.14	0	0
Other(Mus)	48.91	974.80	0	0
Total	175.39	3238.35		
SOLAR				
Total	13.16	266.76	0	0
Total	13.16	266.76		
Tata				
Trombay 5	0.00	128.60	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.44	28.49	108	44
Trombay 7B	1.08	21.47	64	38
TATA Hydro	7.10	80.09	428	109
Trombay 8	0.00	76.16	0	0
Total	9.62	334.82		
AEML				
DTPS U-1&2	10.17	190.92	501	308
Total	10.17	190.92		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	142.98	3020.53	MSPGCL Total	164.39	3406.88
			MSPGCL Thml+Gas	148.61	3125.50	Koyna 1,2 & 4 Total	8.76	174.18
			MSPGCL Hydro	15.78	281.37	State Total	380.74	7593.43

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 21/Jan/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4966	188	236	5390	545	6151	0	0	7019	7295	-1128	17883	0	17883	1660	370	19913	50.03
2	5076	233	237	5546	548	6047	0	0	7104	7170	-1022	17941	0	17941	1542	348	19831	49.99
3	5184	172	238	5594	533	6491	0	0	7106	6752	-951	18088	0	18088	1472	331	19891	49.98
4	5207	171	237	5615	613	6452	0	0	7025	6684	-892	18168	0	18168	1419	304	19891	49.95
5	5340	177	238	5755	606	6617	0	0	7231	7025	-922	18759	0	18759	1436	322	20517	49.98
6	5903	286	238	6427	503	6955	0	0	6984	6859	-1024	19366	0	19366	1567	354	21287	50.04
7	6346	574	236	7156	533	7588	0	1	6570	6480	-1016	20352	0	20352	1716	390	22458	50.01
8	6441	1242	236	7919	554	7858	0	163	6468	6286	-1043	21316	0	21316	1886	421	23623	50.03
9	6416	1253	239	7908	378	7871	0	640	6784	6996	-1142	22229	0	22229	2140	422	24791	49.97
10	6451	1509	236	8196	287	7857	0	1256	7540	7874	-1380	23663	0	23663	2389	427	26479	49.92
11	6410	1691	236	8337	206	7866	0	1693	8067	8146	-1562	24233	0	24233	2554	453	27240	49.99
12	6402	1053	232	7687	164	7811	0	1914	8272	8346	-1602	23893	0	23893	2562	427	26882	50.01
13	6350	597	230	7177	111	7407	0	1984	8410	8255	-1596	22917	0	22917	2501	421	25839	50.02
14	6324	574	231	7129	119	7440	0	1865	8099	7737	-1445	22439	0	22439	2334	406	25179	50.06
15	6265	528	230	7023	112	7360	0	1600	8395	7913	-1374	22214	0	22214	2309	420	24943	50.00
16	6271	587	227	7085	127	7440	0	1251	8165	8064	-1356	22175	0	22175	2304	436	24915	50.00
17	6435	957	231	7623	133	7726	0	644	7277	7102	-1313	21468	0	21468	2296	447	24211	50.04
18	6334	761	233	7328	180	7876	0	144	6567	6258	-1291	20044	0	20044	2334	451	22829	50.13
19	6058	1315	230	7603	202	7916	0	1	6312	6282	-1372	20183	0	20183	2441	449	23073	50.00
20	6079	1142	234	7455	263	7918	0	0	6303	6212	-1328	20073	0	20073	2399	447	22919	50.02
21	5835	190	235	6260	288	7617	0	0	6189	6399	-1227	18887	0	18887	2239	450	21576	50.01
22	5731	223	236	6190	323	7254	0	0	6058	5888	-1159	18065	0	18065	2124	431	20620	50.05
23	5658	176	238	6072	337	7048	0	0	6237	6289	-1202	18131	0	18131	1922	413	20466	50.00
24	5499	177	239	5915	344	6820	0	0	6328	6156	-1160	17681	0	17681	1756	394	19831	49.96
MUs	142.98	15.78	5.63	164.39	8.01	175.39	0.00	13.16	170.51	168.47	-29.51	490.17	0.00	490.17	49.30	9.73	549.20	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 21/Jan/2023

Position as on 6.30 Hrs of 22/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
TPC-G	Trombay 5	500	18/01/2023	01:10		Continued.	Annual Overhaul	15/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	24/01/2023
MSPGCL	Parli Unit 8	250	14/01/2023	08:51	21/01/2023	09:34	Lube oil system problem	19/01/2023
MSPGCL	Nasik Unit 5	210	15/01/2023	21:18		Continued.	ID Fan Problem	24/01/2023
MSPGCL	Chandrapur Unit 6	500	17/01/2023	10:17	21/01/2023	15:41	Boiler Tube Leakage	20/01/2023
MSPGCL	Koradi Unit 6	210	19/01/2023	10:15	21/01/2023	19:09	Boiler Tube Leakage	23/01/2023
MSPGCL	Koyna Unit 4	70	20/01/2023	07:30	22/01/2023	17:15	Preventive Maintenance Work	24/01/2023
TPC_G	Trombay 8	250	20/01/2023	12:26	22/01/2023	23:45	Due to heavy leakage near Main steam line strainer.	22/01/2023
IPP	RPL(AMT) U-2	270	21/01/2023	00:00		Continued.	For Boiler License Renewal work.	24/01/2023
MSPGCL	Khaparkheda Unit 5	500	21/01/2023	17:47	22/01/2023	19:02	Air heater problem	24/01/2023
MSPGCL	Chandrapur Unit 3	210	21/01/2023	20:15		Continued.	Boiler Tube Leakage	24/01/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 21/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Tripping							
TIE BAY (708) of KORADI - 3 CKT - 2 & EKTUNI CKT - 2 @ AKOLA 2	IntraState	21/01/2023	09:15	21/01/2023	18:44	PO	OEM Inspection of CB
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
BABHALESHWAR - PADGHE CKT- 1	IntraState	22/01/2023	08:53	22/01/2023	19:23	PO	TO ATTEND DEFECTS IDENTIFIED IN MONKEY PATROLLING UNDER PADGHE AND JUNNER S-DN:-1. To FIX REPAIR SLEEVE AT BROKEN CONDUCTOR STRANDS.2. REPLACEMENT OF BROKEN AND FLASHOVER DISC INSULATORS STRINGS.3. CHEMICAL AND COLD WASHING OF DUST/BIRD SHIT POLLUTED INSULATOR STRING.4. FIX OF BIRD GUARD AT INSULATORS BIRD SHIT LOCATIONS.5. TIGHTENING OF NUT BOLTS OF CONDUCTOR JUMPER AND EARTHWIRE HARDWARE.6. STRINGING OF EARTHWIRE AND LOC 919-920.7. FIXING OF MISSING/DAMAGED HARDWARE.
LONIKAND 2 - KARJAT CKT - 2	IntraState	22/01/2023	11:31	22/01/2023	16:41	PO	Cold line washing of insulator strings
LONIKAND 2 - KARJAT CKT - 1	IntraState	22/01/2023	17:22	22/01/2023	18:21	HT	Tarpaulin cover removed from conductor span between location no:- 451 to 452 Y ph.
400 KV ICT Outages/Tripping							
400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	IntraState	20/01/2023	06:55	22/01/2023	18:06	PO	400kv CB mechanism Overhauling work. ICT-3 to be in service through TBC
STATION TF No 5 @ CHANDRAPUR GCR	IntraState	21/01/2023	10:14			PO	Oil Filtration work. Attending oil leakages. Testing of Transformer.
220 KV LINE Outages/Tripping							
MAIN BUS-1 @ WARDHA PG	InterState	21/01/2023	11:14	21/01/2023	13:09	T	Bus -1 fault at 220kv Wardha PG end
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kv Karad-Koyana Line and Re stringing of existing 220kv D/C KDPH LILO line.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	17/01/2023	10:16			PO	Erection and Stringing of 8nos of monopole, out of which of 6nos of In-line monopole loc.no.118, 118A,119A,122, 123, 123A.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (GCR) - GHATGHAR	IntraState	17/01/2023	10:37			PO	Erection and Stringing of 8nos of monopole, out of which of 6nos of In-line monopole loc.no.118, 118A,119A,122, 123, 123A.
TROMBAY - KALWA	IntraState	18/01/2023	13:07			EO	For attending SF6 gas leakage in main CB of 220KV Trombay Bay by shifting the 220KV Kalwa-Trombay line on TBC.
NEW KOYNA - NIWALI	IntraState	19/01/2023	10:05		Continued.	PO	Circuit Breaker overhauling work
ONGC PANVEL - TSS PANVEL	IntraState	20/01/2023	23:15	21/01/2023	10:58	HT	project related work
CHAKAN - CHINCHWAD 2	IntraState	20/01/2023	23:50	21/01/2023	02:51	PO	Removal of bunching at loc 14 (Chinchwad side) and loc 25 (Telco side) 2) Reconnection of jumpers at loc 14 & 25 on 220 kV Chinchwad-Telco line.
CHINCHWAD-2 - TELCO	IntraState	20/01/2023	23:54	21/01/2023	02:53	PO	Removal of bunching at loc 14 (Chinchwad side) and loc 25 (Telco side) 2) Reconnection of jumpers at loc 14 & 25 on 220 kV Chinchwad-Telco line.
COLOURCHEM - TEMGHAR	IntraState	21/01/2023	06:06	21/01/2023	16:47	PO	1. Line shifting on ERS in between Loc No.20 to 24 2. Stringing of 2 Nos. Of span 3.Above work is for shifting/rerouting of line for NHSRCL.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	21/01/2023	10:48	21/01/2023	12:52	EO	During outage work of replacement of R ph string flashover at loc no 86 is to be carry out, as Line was AR operated on dt 20.01.2023 at 02:18 Hrs.
WARDHA - WARDHA (PG)	IntraState	21/01/2023	11:14	21/01/2023	13:18	T	Bus -1 fault at 220kv Wardha PG end
WARDHA (PG) - BADNERA	IntraState	21/01/2023	11:14	21/01/2023	13:18	T	Bus -1 fault at 220kv Wardha PG end
BHUGAON - WARDHA (PG)	IntraState	21/01/2023	11:14	21/01/2023	13:19	T	Bus -1 fault at 220kv Wardha PG end
KANDALGAON - KOYNA (POPHALI)	IntraState	21/01/2023	12:46	21/01/2023	20:40	PO	Cold washing of insulator string work, Outage tree cutting work and other line maintenance work.
BABLESHWAR AHAMADNAGAR-II	IntraState	21/01/2023	13:35	21/01/2023	17:37	EO	Outage of Bblr-Nagar II , Time:-14 to 16, reason-Replacement of R ph flashover string at loc 89 , found in monkey patrolling. Area affected -Nil
RAYMOND - TKEC	IntraState	21/01/2023	18:50	21/01/2023	22:20	EO	Bypass hybrid pass CB due to system constraints
PEDHAMBE ONI LINE	IntraState	22/01/2023	06:00	22/01/2023	17:45	HT	For bus outage at Pedambe
TEMGHAR - KALWA	IntraState	22/01/2023	06:03	22/01/2023	15:36	PO	1) Line shifting on ERS in between Loc No.20 to 24. 2) Stringing of 2 Nos. Of span for shifting/ re-routing of the line for NHSRCL Project. 3) After above work line will be charged on ERS till 29.01.2023.
ADLABS - PEDAMBE	IntraState	22/01/2023	06:19	22/01/2023	17:35	HT	For bus outage at Pedambe

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 22/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KAMBA - KHARBAO TSS	IntraState	22/01/2023	06:28	22/01/2023	20:10	PO	1.Stringing of conductor from Loc no. 107 to Loc no. 108A. 2.Stringing of conductor from Loc no. 109 to Loc no. 110. 3.Stringing of new OPGW conductor with new junction box between 108A to 109A.
KAMBA - KHARBAO TSS	IntraState	22/01/2023	06:28	22/01/2023	20:10	PO	1) Stringing of conductor between Loc no. 107 to 108A. 2) Stringing of conductor between Loc no. 109A to 110. 3) Stringing of new OPGW conductor with new junction box between loc no.between Loc no. 108A to 109A (There may be disconnectionof Data transfer during OPGW shifting for 12 Hrs).
POPHLI PEDHMBE LINE- 2	IntraState	22/01/2023	06:50	22/01/2023	17:25	HT	For bus outage at Pedambe
NERLE - PEDAMBE	IntraState	22/01/2023	07:15	22/01/2023	17:30	HT	For bus outage at Pedambe
MAIN BUS SECTION - 2 @ PEDAMBE	IntraState	22/01/2023	07:29	22/01/2023	17:10	PO	Pophali II R Phase main bus isolator female arm damaged needs to be replaced, All bay main bus PM work.
BORIVALI - BOISAR (PG)	IntraState	22/01/2023	13:29	22/01/2023	21:30	EO	Repairing of Damage Conductor at Loc No.36, 37 Y-Ph. 44-45 &46-47 on 220kV PGCIL Borivali Line.
BORIVALI - TARAPUR	IntraState	22/01/2023	13:33	22/01/2023	21:23	EO	Hot spot attending work at Loc No.32 Tarapur Side Temp-96°C) and repairing Damage Conductor at Loc No.82-83.
220 KV DEEPNAGAR (400 KV) - CHALISGAON CKT	IntraState	22/01/2023	14:12	22/01/2023	17:33	T	CHALISGAON -DIST PRTO Z1 Y-BPH D=33.32 KMIF=4.477 KA AND5.046 KADEEPNAGAR-Z1D=85.5 KM Y-B PH
NANDED CITY - PARVATI	IntraState	22/01/2023	17:13	22/01/2023	17:45	T	TRIPPED ON DISTANCE PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 200 MVA ICT 4 @ APTA	IntraState	16/01/2023	09:26			PO	Bushing Gasket Replacement work & Schedule maintenance work.
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	21/01/2023	09:52	21/01/2023	12:18	PO	Attending hotpot and Diagonastic testing
220/132 KV 100 MVA ICT-3 @ BHENDA	IntraState	21/01/2023	10:13	21/01/2023	13:14	PO	Oil top up & quarterly maintenance work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage