

**State Load Despatch Center,Airoli (MSETCL) Statement I**  
**Daily system Report for 21/Feb/2019 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 139.998        | 2853.879        | 1) Gujrat                      | 1.226          | 38.357          |
| 2) Hydro            | 9.821          | 168.925         | 2) Madhya Pradesh              | 14.293         | 291.602         |
| 3) Gas              | 6.660          | 145.469         | 3) Chattisgarh                 | 5.440          | 128.860         |
| <b>Total MSPGCL</b> | <b>156.479</b> | <b>3168.273</b> | 4) Maharashtra                 | 103.993        | 2097.036        |
| B) 1) APMIL         | 74.089         | 1283.527        | 5) Goa (Amona)                 | -0.528         | -10.252         |
| 2) JSWEL            | 24.826         | 435.926         | <b>Total</b>                   | <b>124.424</b> | <b>2545.603</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 16.817         | 336.582         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 17.257         | 364.608         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 10.399         | 312.676         |
| 6) Other IPP        | 12.184         | 267.504         | Include PX                     | -4.498         | 0.713           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 16.817         | 335.688         |
| C) 1) TPCL Thermal  | 15.590         | 286.406         | Include PX                     | 4.800          | 103.994         |
| 2) TPCL Hydro       | 4.952          | 68.934          | Standby                        | 0.000          | 0.894           |
| 3) TPCL Gas         | 4.298          | 85.492          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 10.984         | 203.173         | 1) MSEDCL                      | 389.641        | 7669.442        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 53.081         | 1008.610        |
| 1) Thermal          | 277.671        | 5330.415        | <b>TOTAL STATE</b>             | <b>442.722</b> | <b>8678.052</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 14.773         | 237.859         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 10.958         | 230.961         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 8.730          | 202.993         |                                |                |                 |
| 6) SOLAR            | 6.166          | 130.224         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>318.298</b> | <b>6132.452</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6052                      | 6021                  | 5756                      | 5297                      |
| MSPGCL Hydro             | 1071                      | 428                   | 289                       | 242                       |
| MSPGCL Gas               | 284                       | 284                   | 300                       | 155                       |
| MSPGCL Total Generation  | 7407                      | 6733                  | 6345                      | 5694                      |
| Central Sector Receipt   | 5699                      | 5671                  | 5158                      | 5084                      |
| WIND                     | 293                       | 273                   | 410                       | 349                       |
| CPP / IPP Thermal        | 4916                      | 4904                  | 4819                      | 3770                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 886                       | 920                   | 0                         | 0                         |
| Exchange with Mumbai     | -951                      | -909                  | -824                      | -423                      |
| <b>MSEDCL DEMAND MET</b> | <b>18250</b>              | <b>17592</b>          | <b>15908</b>              | <b>14474</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 18250                     | 17592                 | 15908                     | 14474                     |
| TPCL GENERATION          | 1327                      | 1318                  | 1221                      | 668                       |
| AEML GENERATION          | 503                       | 503                   | 499                       | 374                       |
| <b>MUMBAI DEMAND</b>     | <b>2781</b>               | <b>2730</b>           | <b>2544</b>               | <b>1465</b>               |
| STATE DEMAND MET         | 21031                     | 20322                 | 18452                     | 15939                     |
| <b>STATE DEMAND</b>      | <b>21031</b>              | <b>20322</b>          | <b>18452</b>              | <b>15939</b>              |
| Frequency (Hz)           | 49.92                     | 50.02                 | 50.00                     | 49.97                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.13 Hz at 22.00 Hrs | 49.72 Hz at 00.56 Hrs | 49.96         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 21/Feb/2019

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 4.06         | 38.41          | 180      | 145      |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 9.81         | 213.73         | 431      | 370      |
| Unit 9             | 12.00        | 225.92         | 547      | 438      |
| Unit 10            | 9.32         | 214.97         | 484      | 302      |
| <b>Total</b>       | <b>35.19</b> | <b>693.03</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 10.90        | 205.90         | 500      | 350      |
| Unit 5             | 10.84        | 174.53         | 500      | 350      |
| <b>Total</b>       | <b>21.74</b> | <b>380.43</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 4.54         | 90.84          | 195      | 170      |
| Unit 4             | 4.43         | 65.68          | 190      | 163      |
| Unit 5             | 9.94         | 142.65         | 430      | 365      |
| Unit 6             | 0.00         | 167.41         | 0        | 0        |
| Unit 7             | 10.10        | 203.71         | 441      | 370      |
| Unit 8             | 8.84         | 220.49         | 500      | 0        |
| Unit 9             | 10.39        | 219.38         | 470      | 360      |
| <b>Total</b>       | <b>48.24</b> | <b>1110.17</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 5.28         | 80.82          | 228      | 188      |
| <b>Total</b>       | <b>5.28</b>  | <b>80.82</b>   |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.70         | 75.46          | 165      | 130      |
| Unit 2             | 3.68         | 76.96          | 160      | 145      |
| Unit 3             | 3.54         | 70.21          | 167      | 88       |
| Unit 4             | 3.82         | 78.88          | 165      | 155      |
| Unit 5             | 10.50        | 201.55         | 490      | 385      |
| <b>Total</b>       | <b>25.24</b> | <b>503.07</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 30.01          | 0        | 0        |
| Unit 5             | 4.32         | 56.34          | 198      | 160      |
| <b>Total</b>       | <b>4.32</b>  | <b>86.36</b>   |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 6.66         | 145.47         | 311      | 155      |
| <b>Total</b>       | <b>6.66</b>  | <b>145.47</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.09         | 0.44           | 33       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.09</b>   | <b>0.44</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 2.84          | 48.50          | 310      | 40       |
| Stage 4         | 2.04          | 24.07          | 842      | 0        |
| Stage 3         | 0.66          | 15.84          | 160      | 0        |
| <b>Total</b>    | <b>5.54</b>   | <b>88.41</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.89          | 7.86           | 37       | 37       |
| VTRNA           | 0.22          | 13.56          | 61       | 0        |
| TILLARI         | 0.44          | 5.06           | 61       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.26          | 3.35           | 80       | 0        |
| RNGR+BHTSA      | 0.28          | 6.38           | 12       | 11       |
| BHANDARDRA      | 0.50          | 2.38           | 44       | 11       |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.14          | 10.64          | 6        | 5        |
| GHATGHAR        | 1.54          | 31.28          | 250      | 0        |
| <b>Total</b>    | <b>4.28</b>   | <b>80.51</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 8.73          | 202.99         | 0        | 0        |
| <b>Total</b>    | <b>8.73</b>   | <b>202.99</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 74.09         | 1283.53        | 0        | 0        |
| JSWEL(Mus)      | 24.83         | 435.93         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 0.00          | 0.00           | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 12.18         | 267.50         | 0        | 0        |
| <b>Total</b>    | <b>111.10</b> | <b>1986.96</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 6.17          | 130.22         | 0        | 0        |
| <b>Total</b>    | <b>6.17</b>   | <b>130.22</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 10.29         | 177.36         | 484      | 307      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.72          | 53.50          | 117      | 88       |
| Trombay 7B      | 1.58          | 31.99          | 67       | 58       |
| Trombay 8       | 5.30          | 109.05         | 233      | 201      |
| TATA Hydro      | 4.95          | 68.93          | 431      | 0        |
| <b>Total</b>    | <b>24.84</b>  | <b>440.83</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 10.98         | 203.17         | 504      | 374      |
| <b>Total</b>    | <b>10.98</b>  | <b>203.17</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 140.00      | 2853.88       | MSPGCL Total        | 156.48      | 3168.27       |
|                |             |         | MSPGCL Thml+Gas | 146.66      | 2999.35       | Koyna 1,2 & 4 Total | 4.88        | 72.57         |
|                |             |         | MSPGCL Hydro    | 9.82        | 168.92        | State Total         | 318.30      | 6132.45       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 21/Feb/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5720        | 177  | 307  | 6204   | 467  | 4088      | 0    | 0     | 4705        | 4905        | -601                 | 15063                 | 0                    | 15063                     | 1717             | 16780           | 49.83         |
| 2                  | 5632        | 127  | 300  | 6059   | 392  | 3970      | 0    | 0     | 4837        | 4593        | -483                 | 14531                 | 0                    | 14531                     | 1583             | 16114           | 49.86         |
| 3                  | 5294        | 112  | 242  | 5648   | 337  | 3852      | 0    | 0     | 5090        | 5067        | -447                 | 14457                 | 0                    | 14457                     | 1507             | 15964           | 49.93         |
| 4                  | 5297        | 242  | 155  | 5694   | 349  | 3770      | 0    | 0     | 4798        | 5084        | -423                 | 14474                 | 0                    | 14474                     | 1465             | 15939           | 49.97         |
| 5                  | 5466        | 221  | 175  | 5862   | 305  | 3991      | 0    | 0     | 4853        | 5017        | -449                 | 14726                 | 0                    | 14726                     | 1478             | 16204           | 49.97         |
| 6                  | 5984        | 345  | 214  | 6543   | 213  | 4301      | 0    | 0     | 5030        | 5267        | -490                 | 15834                 | 0                    | 15834                     | 1614             | 17448           | 49.98         |
| 7                  | 6192        | 634  | 299  | 7125   | 249  | 4765      | 0    | 2     | 5282        | 5316        | -473                 | 16984                 | 0                    | 16984                     | 1838             | 18822           | 50.00         |
| 8                  | 6101        | 1408 | 311  | 7820   | 283  | 4913      | 0    | 77    | 5412        | 5499        | -564                 | 18028                 | 0                    | 18028                     | 2048             | 20076           | 50.02         |
| 9                  | 6122        | 970  | 309  | 7401   | 237  | 4919      | 0    | 328   | 5512        | 5550        | -736                 | 17699                 | 0                    | 17699                     | 2325             | 20024           | 50.01         |
| 10                 | 6109        | 777  | 295  | 7181   | 196  | 4940      | 0    | 566   | 5646        | 5529        | -883                 | 17529                 | 0                    | 17529                     | 2587             | 20116           | 49.91         |
| 11                 | 6079        | 755  | 289  | 7123   | 273  | 4897      | 0    | 767   | 5637        | 5829        | -967                 | 17922                 | 0                    | 17922                     | 2753             | 20675           | 50.00         |
| 12                 | 6052        | 1071 | 284  | 7407   | 293  | 4916      | 0    | 886   | 5605        | 5699        | -951                 | 18250                 | 0                    | 18250                     | 2781             | 21031           | 49.92         |
| 13                 | 6021        | 428  | 284  | 6733   | 273  | 4904      | 0    | 920   | 5644        | 5671        | -909                 | 17592                 | 0                    | 17592                     | 2730             | 20322           | 50.02         |
| 14                 | 5999        | 258  | 284  | 6541   | 237  | 4881      | 0    | 852   | 5617        | 5649        | -940                 | 17220                 | 0                    | 17220                     | 2588             | 19808           | 50.03         |
| 15                 | 6034        | 161  | 284  | 6479   | 247  | 4889      | 0    | 752   | 5580        | 5615        | -880                 | 17102                 | 0                    | 17102                     | 2591             | 19693           | 50.01         |
| 16                 | 6049        | 201  | 284  | 6534   | 246  | 4899      | 0    | 556   | 5435        | 5386        | -800                 | 16821                 | 0                    | 16821                     | 2604             | 19425           | 49.90         |
| 17                 | 6058        | 142  | 284  | 6484   | 353  | 4897      | 0    | 347   | 5297        | 5253        | -823                 | 16511                 | 0                    | 16511                     | 2602             | 19113           | 49.93         |
| 18                 | 6059        | 291  | 288  | 6638   | 353  | 4831      | 0    | 112   | 4837        | 4779        | -911                 | 15802                 | 0                    | 15802                     | 2556             | 18358           | 49.96         |
| 19                 | 5963        | 193  | 289  | 6445   | 391  | 4817      | 0    | 1     | 5050        | 4758        | -849                 | 15563                 | 0                    | 15563                     | 2537             | 18100           | 49.96         |
| 20                 | 5756        | 289  | 300  | 6345   | 410  | 4819      | 0    | 0     | 5127        | 5158        | -824                 | 15908                 | 0                    | 15908                     | 2544             | 18452           | 50.00         |
| 21                 | 5607        | 508  | 293  | 6408   | 524  | 4852      | 0    | 0     | 4536        | 4627        | -705                 | 15706                 | 0                    | 15706                     | 2417             | 18123           | 49.99         |
| 22                 | 5598        | 223  | 292  | 6113   | 667  | 4923      | 0    | 0     | 4608        | 4237        | -660                 | 15280                 | 0                    | 15280                     | 2247             | 17527           | 49.99         |
| 23                 | 5505        | 124  | 304  | 5933   | 688  | 4746      | 0    | 0     | 4907        | 4933        | -754                 | 15546                 | 0                    | 15546                     | 2071             | 17617           | 49.96         |
| 24                 | 5301        | 164  | 294  | 5759   | 747  | 4319      | 0    | 0     | 4985        | 5003        | -735                 | 15093                 | 0                    | 15093                     | 1898             | 16991           | 49.93         |
| MUs                | 140.00      | 9.82 | 6.66 | 156.48 | 8.73 | 111.10    | 0.00 | 6.17  | 124.03      | 124.42      | -17.26               | 389.64                | 0.00                 | 389.64                    | 53.08            | 442.72          | 49.96         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 21/Feb/2019**

Position as on 6.30 Hrs of 22/Feb/2019

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                            |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                                                                                            |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                            |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                                                                                          |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                    |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                          |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.                                                                                        |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                                                                                                          |               |
| MSPGCL                | Uran Unit B0            | 120      | 08/09/2018   | 12.19        |            | Continued. | T/F Shifting Work.                                                                                                         |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2018   | 22.08        |            | Continued. | Withdrawn Due To B0 & U-7                                                                                                  |               |
| MSPGCL                | Paras Unit 3            | 250      | 15/09/2018   | 00.55        |            | Continued. | Stator Earth Fault                                                                                                         |               |
| IPP                   | RPL(AMT) U-4            | 270      | 20/09/2018   | 00.01        |            | Continued. | Zero Schedule.                                                                                                             |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                                                                                               |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.                                                                                                             |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL) |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 14/12/2018   | 03.00        |            | Continued. | Zero Schedule.                                                                                                             |               |
| IPP                   | RPL(AMT) U-3            | 270      | 14/12/2018   | 16.30        |            | Continued. | Zero Schedule.                                                                                                             |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                                                                                                |               |
| IPP                   | RPL(AMT) U-2            | 270      | 27/12/2018   | 19.30        |            | Continued. | Zero Schedule.                                                                                                             |               |
| IPP                   | RPL(AMT) U-5            | 270      | 28/12/2018   | 19.30        |            | Continued. | Zero Schedule.                                                                                                             |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                                                                              |               |
| MSPGCL                | Nasik Unit 3            | 210      | 09/01/2019   | 19.30        |            | Continued. | Zero Schedule                                                                                                              |               |
| IPP                   | Dhariwal                | 300      | 12/01/2019   | 10.15        |            | Continued. | Coal Shortage                                                                                                              |               |
| MSPGCL                | Parli Unit 8            | 250      | 12/01/2019   | 12.00        |            | Continued. | Zero Schedule by MSEDCL                                                                                                    |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                                                                              |               |
| MSPGCL                | Koradi Unit 7           | 210      | 19/01/2019   | 18.21        |            | Continued. | Poor Coal Receipt                                                                                                          |               |
| IPP                   | RPL(AMT) U-1            | 270      | 27/01/2019   | 02.17        |            | Continued. | Withdrawn On RSD.                                                                                                          |               |
| MSPGCL                | Nasik Unit 4            | 210      | 08/02/2019   | 05.18        |            | Continued. | Zero schedule                                                                                                              |               |
| MSPGCL                | Khaparkheda Unit 3      | 210      | 18/02/2019   | 17:21        | 21/02/2019 | 00.20      | Boiler Tube Leakage                                                                                                        |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 20/02/2019   | 22.07        |            | Continued. | Rotor Earth Fault                                                                                                          |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 21/Feb/2019**

Position as on 6.30 Hrs of 22/Feb/2019

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                   | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------|---------------|
| MSPGCL             | Uran Unit 5             | 108      | 21/02/2019   | 02.44        | 21/02/2019 | 04.47      | Generator Protection Tripped.                      |               |
| MSPGCL             | Chandrapur Unit-8       | 500      | 21/02/2019   | 19.39        |            | Continued. | BFP common Dischagre Header Leakage Attending work |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 21/Feb/2019**

**Statement-VII**

Position as on 6.30 Hrs of 22/Feb/2019

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                        |
| Ektuni-Akola II Ckt 2                  | IntraState                | 20/02/2019   | 23.48        | 21/02/2019 | 00.35      | T           | Distance Protection,Y PH,Z1.59.9KM.5.2KA From Akola                                                                                    |
| <b>500 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                        |
| Chandrapur - Padghe Hvdc Pole 1        | IntraState                | 22/02/2019   | 21.15        | 22/02/2019 | 23.22      | HT          | RED HOTSPOT ATTENDING WORK ON BASE FILTER.                                                                                             |
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                     | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                               |
| Dhule Sar'Sarovar II                   | InterState                | 18/02/2019   | 18.16        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Dabhol New koyna I                     | InterState                | 21/02/2019   | 09.07        | 22/02/2019 | 20.32      | PO          | Insulator Replacement Work                                                                                                             |
| Kolhapur(M)-Kolhapur(GIS) ckt1         | InterState                | 21/02/2019   | 09.49        | 21/02/2019 | 20.00      | PO          | Quarterly Maintainance Work                                                                                                            |
| Kalwa - Talegaon(PG)                   | IntraState                | 16/02/2019   | 08.59        |            | Continued. | PO          | Construction Work for height raising.                                                                                                  |
| Kalwa - Kharghar                       | IntraState                | 16/02/2019   | 09.46        |            | Continued. | PO          | Construction Work for height raising.                                                                                                  |
| Jaigad-Karad Ckt-I                     | IntraState                | 19/02/2019   | 20.23        | 21/02/2019 | 09.42      | HT          | Over Voltage                                                                                                                           |
| Bhusawal-Aurangabad                    | IntraState                | 20/02/2019   | 21.39        | 21/02/2019 | 07.23      | HT          | Over Voltage                                                                                                                           |
| Padghe - Nagothane - I                 | IntraState                | 21/02/2019   | 06.30        | 21/02/2019 | 14.15      | T           | Distance Protection                                                                                                                    |
| Deepnagar Taptitanda                   | IntraState                | 21/02/2019   | 07.32        | 21/02/2019 | 19.53      | PO          | Replacement of Dead end & MID span joint                                                                                               |
| Karad - Jaigad - II                    | IntraState                | 21/02/2019   | 09.46        | 22/02/2019 | 09.47      | PO          | Quarterly Maintainance Work (RFC 18.10 21.02.2019)                                                                                     |
| Bableshtar- Aurangabad (Waluj)         | IntraState                | 21/02/2019   | 10.22        | 21/02/2019 | 20.08      | PO          | Annual Maintenance Work                                                                                                                |
| Khadka-Aurangabad (Waluj)              | IntraState                | 21/02/2019   | 20.18        | 22/02/2019 | 07.11      | HT          | Over Voltage                                                                                                                           |
| Girwali- Lonikand 2                    | IntraState                | 22/02/2019   | 10.05        | 22/02/2019 | 15.03      | PO          | HARDWARE TIGHTENING & FITTING WORK.                                                                                                    |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe    | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                                                                                              |
| 400/220/33 Kv 500 MVA ICT-III @Girwali | IntraState                | 21/02/2019   | 09.23        | 21/02/2019 | 21.14      | PO          | RRS Scheme                                                                                                                             |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                    | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                    | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| Chandrapur GCR - Warora - I            | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.                   |
| Chandrapur GCR - Wani                  | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107. |
| BOISAR BORIVALI                        | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading.                                                                                                               |
| Gadchandur-Ultratech II                | IntraState                | 13/02/2019   | 18.00        | 22/02/2019 | 16.49      | PO          | Metering C.T.Replacement Work.                                                                                                         |
| Khadka-Chalisgaon-1                    | IntraState                | 19/02/2019   | 09.16        |            | Continued. | PO          | For Erection Of Inline Tower.                                                                                                          |
| Khadka-Chalisgaon-2                    | IntraState                | 19/02/2019   | 09.28        |            | Continued. | PO          | For Erection Of Inline Tower.                                                                                                          |
| Nalasopara-Boisar                      | IntraState                | 21/02/2019   | 05.05        | 21/02/2019 | 07.55      | T           | Distance Protection                                                                                                                    |
| Kalwa - Taloja                         | IntraState                | 21/02/2019   | 09.40        | 21/02/2019 | 18.24      | PO          | CT Tan delta Measurement                                                                                                               |
| Urse-Chinchwad                         | IntraState                | 21/02/2019   | 09.41        | 21/02/2019 | 14.42      | PO          | DSN Work                                                                                                                               |
| Jejuri-Phursungi 2                     | IntraState                | 21/02/2019   | 09.50        | 21/02/2019 | 17.18      | PO          | Half yearly maintenance work                                                                                                           |
| Urse - Talegaon (Ambi) Ckt 2           | IntraState                | 21/02/2019   | 11.48        | 21/02/2019 | 18.46      | PO          | DTN Hardware conversion work                                                                                                           |
| Gadchandur - Virur-I                   | IntraState                | 21/02/2019   | 16.33        | 21/02/2019 | 16.51      | T           | Distance Protection                                                                                                                    |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 21/Feb/2019**

**Statement-VII**

Position as on 6.30 Hrs of 22/Feb/2019

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                    |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------|
| Gadchandur - Virur-li                    | IntraState                | 21/02/2019   | 16.33        | 21/02/2019 | 23.40      | T           | LA BURST AT VIRUR END.                                              |
| TPC Borivali Aarey Line 1                | IntraState                | 22/02/2019   | 00.39        | 22/02/2019 | 06.22      | PO          | safety purpose for metro work.                                      |
| Padghe - Nalasopara                      | IntraState                | 22/02/2019   | 09.00        | 22/02/2019 | 09.25      | T           | Distance Protection                                                 |
| Anandnagar - Pal                         | IntraState                | 22/02/2019   | 10.05        | 22/02/2019 | 19.05      | PO          | REPLACEMENT OF EXISTING DISTANCE RELAY.                             |
| Mudshingi-Wathar                         | IntraState                | 22/02/2019   | 10.17        | 22/02/2019 | 17.38      | PO          | INSULATOR STRING REPLACEMENT.                                       |
| Jejuri (400 Kv)- Baramati li             | IntraState                | 22/02/2019   | 18.22        | 22/02/2019 | 20.13      | HT          | Attending Hot Spot                                                  |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                     |
| 220/66 Kv 150 Mva Emco lct 2 @Gadchandur | IntraState                | 13/02/2019   | 11.35        |            | Continued. | PO          | LV Bushing Replacement,Work For 10 Days                             |
| 220/132 Kv 200mva Ptr No 1 @Theur        | IntraState                | 21/02/2019   | 13.08        | 21/02/2019 | 16.20      | PO          | Replacement of Bucholz relay                                        |
| 220/33 Kv 50 Mva Imp Ptr 2 @Sonkar       | IntraState                | 22/02/2019   | 08.44        | 22/02/2019 | 18.25      | PO          | Attending Oil Leakage                                               |
| 220/22 Kv 50 Mva Alstom Ptr 2 @Taloja    | IntraState                | 22/02/2019   | 09.55        | 22/02/2019 | 16.11      | PO          | DIAGNOSTIC TESTING.                                                 |
| 220/132-110 Kv 100mva lct 1 @Jath        | IntraState                | 22/02/2019   | 13.25        | 22/02/2019 | 15.25      | PO          | CT & BUSHING TAN DELTA MEASUREMENT.                                 |
| <b>132 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                     |
| Mansar Pench                             | InterState                | 22/10/2018   | 18.40        |            | Continued. | HT          | CB Closed At Pench & In view Of Outage On 132kv Kanhan-Mansar Line. |
| Kanhan-Pench                             | IntraState                | 22/01/2019   | 18.44        |            | Continued. | HT          | After Completion of Outage.                                         |
| Solapur II(Bale)-Naldurg                 | IntraState                | 20/02/2019   | 16.27        | 21/02/2019 | 02.00      | T           | Distance Protection Z1,R-YPH,1.26KA,62km.                           |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage