

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/Mar/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	153.046	3308.162	1) Gujrat	2.447	57.932
2) Hydro	9.333	230.427	2) Madhya Pradesh	8.571	110.234
3) Gas	2.307	83.960	3) Chattisgarh	5.420	89.770
Total MSPGCL	164.686	3622.549	4) Maharashtra	166.241	3458.253
B) 1) APLM	71.036	1414.501	5) Goa (Amona)	-1.335	-33.564
2) JSWEL	19.888	519.094	Total	181.344	3682.625
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.777	657.815
4) RPL(AMT)	31.191	635.901	b) Mumbai Drawl	36.202	770.771
5) SWPGPL	9.379	210.143	c) MSEDCL Bilateral *	70.311	1778.488
6) Other IPP	33.443	827.977	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.777	657.815
C) 1) TPCL Thermal	10.201	225.181	Include PX	0.000	0.000
2) TPCL Hydro	4.386	65.533	Standby	0.000	0.000
3) TPCL Gas	2.000	57.368	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.661	222.101	1) MSEDCL	493.812	10453.583
D) STATE			2) Mumbai Discoms	61.450	1340.954
1) Thermal	336.845	7363.060	3) Other Discoms	10.269	212.209
(A1+C1+C4+(B1-B6))			TOTAL STATE	565.531	12006.746
2) Hydro (A2+C2)	13.719	295.960			
3) Gas (A3+B7+C3)	4.307	141.328			
4) Wind	13.957	243.297			
6) SOLAR	15.359	280.476			
TOTAL STATE	384.187	8324.121			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6326	6370	6994	5814
MSPGCL Hydro	282	224	1686	256
MSPGCL Gas	67	79	122	112
MSPGCL Total Generation	6675	6673	8802	6182
Central Sector Receipt	9085	8704	7190	6361
WIND	222	265	519	844
CPP / IPP Thermal	6840	6843	6859	6920
CPP / IPP Gas	0	0	0	0
SOLAR	1982	2026	0	0
Exchange with Mumbai	-1666	-1679	-1566	-1247
MSEDCL DEMAND MET	22683	22392	21328	18735
Load Shedding	0	0	0	0
MSEDCL DEMAND	22683	22392	21328	18735
TPCL GENERATION	826	794	859	527
AEML GENERATION	486	492	385	299
MUMBAI DEMAND	2978	2965	2810	2073
OTHER DISCOM DEMAND	455	440	476	325
STATE DEMAND MET	26116	25797	24614	21133
STATE DEMAND	26116	25797	24614	21133
Frequency (Hz)	50.01	49.98	50.01	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 18.03 Hrs	49.7 Hz at 14.43 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 21/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.36	94.33	195	165
Unit 8	0.05	183.98	51	0
Unit 9	13.33	280.70	585	499
Unit 10	12.20	164.06	585	426
Total	29.94	723.06		
Bhusawal				
Unit 3	3.06	68.62	160	110
Unit 4	9.54	198.88	490	280
Unit 5	9.88	209.60	500	280
Total	22.47	477.10		
Parli				
Unit 6	4.10	96.76	250	147
Unit 7	4.11	94.86	248	140
Unit 8	3.59	73.84	175	141
Total	11.80	265.46		
Chandrapur				
Unit 3	3.26	73.60	160	122
Unit 4	3.15	67.38	147	117
Unit 5	0.00	90.01	0	0
Unit 6	8.79	180.57	400	340
Unit 7	8.22	175.02	428	290
Unit 8	11.20	223.09	495	286
Unit 9	11.33	191.43	499	348
Total	45.94	1001.10		
Paras				
Unit 3	5.46	95.68	237	211
Unit 4	5.60	109.62	242	223
Total	11.07	205.30		
Khaparkheda				
Unit 1	2.54	57.12	115	85
Unit 2	2.87	63.54	130	108
Unit 3	3.71	74.75	183	130
Unit 4	3.78	80.79	192	127
Unit 5	11.48	219.56	500	350
Total	24.38	495.75		
Nasik				
Unit 3	0.00	0.97	0	0
Unit 4	3.86	65.90	177	124
Unit 5	3.58	73.53	170	120
Total	7.44	140.40		
Uran				
All Units	2.31	83.96	126	67
Total	2.31	83.96		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	2.56	31	0
Total	0.06	2.56		
Koyna				
Stage 1-2	1.64	54.50	425	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.26	52.81	676	0
Stage 3	1.19	23.60	282	0
Total	4.08	130.92		
Hydro				
KDPH	0.86	17.70	36	36
VTRNA	1.09	22.80	61	0
TILLARI	0.46	5.91	58	0
BHIRA T.R.	0.00	2.71	0	0
SMLHY_PTN	2.77	47.83	118	110
GHATGHAR	0.00	0.00	0	0
Total	5.19	96.95		
Wind				
Total	13.96	243.30	0	0
Total	13.96	243.30		
CPP				
APML(Mus)	71.04	1414.50	0	0
JSWEL(Mus)	19.89	519.09	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.19	635.90	0	0
SWPGPL-Mus	9.38	210.14	0	0
Dhariwal	5.88	125.71	248	241
IEPL	4.74	104.23	199	196
Other(Mus)	22.82	598.03	0	0
Total	164.94	3607.62		
SOLAR				
Total	15.36	280.48	0	0
Total	15.36	280.48		
Tata				
Trombay 5	6.82	149.40	423	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.07	33.67	45	43
Trombay 7B	0.93	23.69	40	38
TATA Hydro	4.39	65.53	384	40
Trombay 8	3.38	75.78	216	130
Total	16.59	348.08		
AEML				
DTPS U-1&2	8.66	222.10	496	299
Total	8.66	222.10		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	153.05	3308.16	MSPGCL Total	164.69	3622.55
			MSPGCL Thml+Gas	155.35	3392.12	Koyna 1,2 & 4 Total	2.90	107.32
			MSPGCL Hydro	9.33	230.43	State Total	384.19	8324.12

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 21/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5395	252	111	5758	1129	6895	0	0	6560	6801	-1508	18692	0	18692	2381	383	21456	49.96
2	5566	328	112	6006	1091	6907	0	0	6248	6424	-1363	18715	0	18715	2208	350	21273	49.99
3	5814	256	112	6182	844	6920	0	0	6235	6361	-1247	18735	0	18735	2073	325	21133	49.98
4	5840	261	112	6213	867	6941	0	0	6390	6277	-1146	18813	0	18813	1990	339	21142	49.98
5	5961	287	112	6360	1002	6922	0	0	6391	6501	-1126	19323	0	19323	1969	336	21628	49.96
6	6584	310	109	7003	793	6914	0	0	6853	6784	-1225	19882	0	19882	2069	387	22338	49.98
7	6954	465	73	7492	704	6896	0	32	7224	7103	-1249	20572	0	20572	2164	406	23142	49.99
8	6873	366	74	7313	537	6909	0	404	7643	7710	-1293	21159	0	21159	2245	421	23825	50.03
9	6438	287	77	6802	333	6865	0	1045	7908	8397	-1580	21413	0	21413	2502	449	24364	50.04
10	6390	293	76	6759	255	6895	0	1564	8289	8285	-1664	21644	0	21644	2733	450	24827	49.98
11	6133	466	75	6674	272	6851	0	1886	8840	8982	-1510	22708	0	22708	2903	447	26058	50.06
12	6326	282	67	6675	222	6840	0	1982	8881	9085	-1666	22683	0	22683	2978	455	26116	50.01
13	6370	224	79	6673	265	6843	0	2026	9005	8704	-1679	22392	0	22392	2965	440	25797	49.98
14	6126	191	79	6396	310	6826	0	2021	9020	8727	-1824	22002	0	22002	2881	454	25337	50.03
15	6180	194	83	6457	433	6846	0	1751	9062	8855	-1892	21990	0	21990	2913	460	25363	49.84
16	6220	209	81	6510	521	6863	0	1391	8905	8820	-1939	21693	0	21693	2956	473	25122	49.98
17	6557	430	81	7068	530	6871	0	863	8186	8179	-1862	21154	0	21154	2956	495	24605	50.06
18	6754	478	80	7312	586	6840	0	374	7953	7716	-1726	20618	0	20618	2897	484	23999	49.98
19	6926	579	95	7600	523	6844	0	20	7264	7455	-1619	20346	0	20346	2827	477	23650	50.02
20	6994	1686	122	8802	519	6859	0	0	7029	7190	-1566	21328	0	21328	2810	476	24614	50.01
21	7018	677	125	7820	465	6862	0	0	6919	6865	-1403	20149	0	20149	2680	460	23289	49.97
22	6939	296	126	7361	510	6859	0	0	6752	6672	-1341	19608	0	19608	2548	453	22609	50.01
23	6571	254	122	6947	549	6828	0	0	6933	6642	-1389	19139	0	19139	2433	438	22010	49.99
24	6117	263	124	6504	697	6841	0	0	6761	6808	-1385	19054	0	19054	2369	411	21834	50.01
MUs	153.05	9.33	2.31	164.69	13.96	164.94	0.00	15.36	181.25	181.34	-36.20	493.81	0.00	493.81	61.45	10.27	565.53	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 21/Mar/2023

Position as on 6.30 Hrs of 22/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U1	300	19/03/2023	17:29		Continued.	Zero Schedule	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Nasik Unit 3	210	10/03/2023	15:22		Continued.	Axial shift high	23/03/2023
MSPGCL	Koradi Unit 8	660	15/03/2023	02:06	21/03/2023	23:07	Boiler Tube Leakage	
MSPGCL	Uran Unit 6	108	18/03/2023	12:44		Continued.	ZERO SCHEDULE.	
MSPGCL	Chandrapur Unit 5	500	19/03/2023	11:15		Continued.	Drum Door Leakage Attending work	22/03/2023
MSPGCL	Uran Unit B0	120	21/03/2023	05:50	21/03/2023	06:34	Tripped on turbine rear end bearing temp high	
MSPGCL	Uran Unit B0	120	21/03/2023	06:37	21/03/2023	07:23	Tripped on turbine rear end bearing temp high	
MSPGCL	Uran Unit B0	120	21/03/2023	07:30	21/03/2023	18:29	Tripped on turbine rear end bearing temp high	
MSPGCL	Koradi Unit 8	660	22/03/2023	00:58	22/03/2023	05:08	WDC VALVE INOPERATIVE.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 22/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500 MVA ICT-2 @ KORADI 3	IntraState	22/03/2023	09:07	22/03/2023	19:19	PO	Annual Maintenance of ICT-2
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	21/03/2023	07:34	21/03/2023	10:15	T	Bird fault on DC Filter Capacitor String.
400 KV TIEBAY Outages/Trippings							
TIE BAY 418 OF YELWAN CKT - 2 @ AKOLA	IntraState	22/03/2023	12:40	22/03/2023	22:15	PO	1. For CTR Trails 2. REF stability and trials by testing team 3. Charging of new ICT-3
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 419 OF 400/200KV 500MVA ICT III	IntraState	22/03/2023	12:40	22/03/2023	21:58	PO	1. For CTR Trails 2. REF stability and trials by testing team 3. Charging of new ICT-3
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
PADGHE - TARAPUR CKT - 1	InterState	21/03/2023	05:31	21/03/2023	07:58	T	Distance Protection
DHULE - KHANDWA CKT - 1	InterState	21/03/2023	15:57	21/03/2023	17:05	HT	H/T for LR to be taken in service.
PADGHE - NAGOTHANE CKT - 2	IntraState	20/03/2023	10:07			PO	CB replacement work
AKOLA - KHADKA (BHUSAWAL)	IntraState	21/03/2023	06:38	21/03/2023	19:50	PO	String replacement work will be carried out by engaging agency which are detected punctured in PID testing.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/03/2023	07:29	21/03/2023	22:54	HT	HT for Load Management
220 KV CHANDRAPUR GCR - CHANDRAPUR 2 CKT	IntraState	21/03/2023	09:20	21/03/2023	20:54	PO	Trip Coil-2 supervision relay wiring and commission work
KARAD - TALANDGE CKT - 2	IntraState	21/03/2023	15:35	21/03/2023	19:23	PO	PID Faulty string replacement work & cold line washing work
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	21/03/2023	16:46	21/03/2023	17:26	EO	for removing of hanging Tarpoline cover from 400KV line wavetrap.
MAIN BUS - 1 @ LAMBOTI	IntraState	22/03/2023	10:28	22/03/2023	14:58	PO	Routine Maintenance activities
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	IntraState	21/03/2023	12:10	21/03/2023	19:10	PO	ICT Painting Work
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	22/03/2023	08:21	22/03/2023	19:08	PO	1.Dismantling of existing ICT-2 LV bay and reorientation to new 220KV bay through new D type tower 2. Removing of control cables from existing breaker, CT, Isolator and shifting to new bay MB 3. 220KV bus bar out, CT injection , stability and trials by testing team
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	22/03/2023	17:23	22/03/2023	17:35	EO	For removing of plastic paper stuck on Bph LV LA at 400 kV Talandge.
400 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ DHARIWAL	IntraState	18/03/2023	10:28			PO	STU CTU bus connection as per CERC order
400 KV BR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 22/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS REACTOR (80 MVar) - 2 @ BABHALESHWAR	IntraState	21/03/2023	17:10	21/03/2023	22:05	PO	REF Relay,CT tan D
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
MIRAJ - ICHALKARANJI	IntraState	20/03/2023	19:30	21/03/2023	00:27	PO	For proper load management at 220 kv Ichalkaranji & 220 kv Miraj S/S as on dt.20.03.2023 outage proposed on 220 kv Talandage-Ichalkaranji Ckt 1 . 220 kv Miraj Ichalkaranji line needs to be kept off at 220kv Ichalkaranji S/S ens, line will be in service from 220 kv Miraj S/S end .
TALANDGE - ICHALKARANJI 1	IntraState	20/03/2023	19:45	21/03/2023	01:09	PO	For attending hotspot at T.L. No:- 06, For cold line insulator cleaning of line insulators, replacement of critical insulator strings found in P.I.D.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	21/03/2023	10:47	21/03/2023	21:09	HT	for load management
LOTEPARSHURAM- DASTURI LINE	IntraState	21/03/2023	12:10	21/03/2023	20:47	PO	For cold washing of line insulator strings.
KARAD - VITA CKT- 2	IntraState	21/03/2023	12:38	21/03/2023	12:57	T	Tripped on Distance Protection at only Vita end.
ONGC PANVEL - TSS PANVEL	IntraState	21/03/2023	13:30	21/03/2023	21:05	PO	1. Stringing of lilo line on Monopole from loc no 1 to tower no. 1A for charging of LILO transmission line to processed 220kv Karanjade TSS and 220kv Karanjade TSS.
TALANDGE - MUDSHINGI CKT - 2	IntraState	21/03/2023	16:56	21/03/2023	20:07	PO	For insulator strings cleaning by cold line method at tower loc no. 312 to 320
ALKUD - VITA	IntraState	21/03/2023	17:18	21/03/2023	23:12	PO	Quarterly maintenance work
TROMBAY DHARAVI - 5	IntraState	21/03/2023	23:05	22/03/2023	06:55	PO	Third Party Work - Diversion of Line at Sejal Shakti Project site
TROMBAY - SALSETTE CKT - 1	IntraState	21/03/2023	23:05	22/03/2023	07:10	PO	Third Party Work - Diversion of Line at Sejal Shakti Project site
VERSOVA - GHODBUNDER	IntraState	22/03/2023	00:40	22/03/2023	04:43		MMRDA Project Work (Metro Line 9 : Dahisar to MiraBhayander) : erection of Pier cap and U&G Girders.
KANHAN-SURYALAKSHMI	IntraState	22/03/2023	03:13	22/03/2023	11:18	PO	FOR 1)CONVERSION OF SINGLE CONDUCTOR JUMPERS INTO TWIN CONDUCTOR JUMPERS AT BOTH ENDS. 2)220KV BUS SECTION ISOLATOR OF KANHAN BAY SIDE WILL BE OPENED FOR JUMPERING WORK FROM 220KV MAIN BUS TO BUS ISOLATOR AT SURYALAXMI END.3)JUMPERING FOR LINE SIDE WILL BE CARRIED OUT AT KANHAN END.
CHIKHALI-JALNA I	IntraState	22/03/2023	07:53	22/03/2023	19:53	HT	For Outage On 400Kv Akola ICT 2
CHIKHALI-JALNA II	IntraState	22/03/2023	07:57	22/03/2023	19:52	HT	For Outage On 400Kv Akola ICT 2
TEMGHAR - KALWA	IntraState	22/03/2023	10:04	22/03/2023	14:01	EO	Hot spot Attending work at Bph Bus isoator bus side jaw (159 degree) after shifting the line on TBC.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 22/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WARDHA-YEOTMAL	IntraState	22/03/2023	10:53	22/03/2023	15:35	PO	FOR DIAGNOSTIC TESTING WORK (TAN DELTA OF CT & CC AND CRM & TIMING OF CB, IR MEASUREMENT OF CT,CC,LA,CB).
LAMBOTI - PANDHARPUR	IntraState	22/03/2023	14:40	22/03/2023	15:55	HT	abnormal sound observed on CC at Lamboti end, hence CC is bypassed
PADGHE - TEMGHAR - 2	IntraState	22/03/2023	15:23	22/03/2023	18:55	EO	Shifting of 220kV Padghe - Temghar - 2 line on TBC for attending hotspot between T joint of A & B Bus Isolator by replacing twin conductor
CREEK SIDE BUS @ KALWA	IntraState	22/03/2023	22:08		Continued.	PO	Jumpering between 220kV Main Bus to Main Bus Side Isolator of Kalwa - Salsette-5 Line work by Tata.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 100 MVA ICT I	IntraState	22/03/2023	11:07	22/03/2023	16:26	PO	To Attend SF6 Gas Leakage From 220/132 KV 100MVA ICT 1-LV CB (132KV CB, Alstom Make)
220 KV BUSBAR Outages/Trippings							
GIS BUS - 1 @ SALSETTE	IntraState	17/03/2023	09:33	21/03/2023	17:19	PO	KS # 5 New Bay connection to GIS BUS.
GIS BUS - 2 @ SALSETTE	IntraState	22/03/2023	04:49			PO	KS # 5 New Bay connection to GIS BUS
BUSBAR PROTECTION @ BABHALESHWAR	IntraState	22/03/2023	09:10	22/03/2023	19:36	PO	UFR relay testing outage not required
132 KV MAINBAY Outages/Trippings							
132KV DHARANGAON -RAILWAY TSS CKT 2	IntraState	22/03/2023	12:05	22/03/2023	13:50	PO	Work AT Railway TSS.
132KV DHARANGAON TSS CKT 2	IntraState	22/03/2023	13:57	22/03/2023	16:00	PO	For Testing Work At 132Kv TSS End.
132 KV ICT Outages/Trippings							
132/33 KV 25 MVA PTR 1	IntraState	22/03/2023	13:55	22/03/2023	21:13	T	R PH LA BLAST
110 KV LINE Outages/Trippings							
WAGHIVALI - MANKHURD	IntraState	21/03/2023	23:15	22/03/2023	05:07	PO	Project work- work in vicinity of line for Installation of tie beams by using crane at tower location 80 N
110 KV BUSBAR Outages/Trippings							
ZONE 1 (BUS SECTION 1+2+3) @ BHIVPURI	IntraState	20/03/2023	23:57	21/03/2023	04:58	PO	Unit-11 Breaker MBS GOD to Breaker Jumper Connection

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage