

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/Mar/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.618	3390.436	1) Gujrat	0.596	91.827
2) Hydro	6.611	184.017	2) Madhya Pradesh	10.587	253.410
3) Gas	6.847	141.811	3) Chattisgarh	6.340	96.390
Total MSPGCL	173.076	3716.264	4) Maharashtra	196.654	3681.940
B) 1) APLM	72.689	1302.562	5) Goa (Amona)	-1.934	-38.334
2) JSWEL	26.310	556.742	Total	212.243	4085.233
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.727	624.931
4) RPL(AMT)	25.574	591.402	b) Mumbai Drawl	37.426	703.039
5) SWPGPL	12.283	247.491	c) MSEDCL Bilateral *	102.395	2072.444
6) Other IPP	35.098	919.905	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.727	624.931
C) 1) TPCL Thermal	10.836	226.654	Include PX	0.000	0.000
2) TPCL Hydro	5.727	88.300	Standby	0.000	0.000
3) TPCL Gas	3.820	74.104	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.248	188.790	1) MSEDCL	537.859	11146.532
D) STATE			2) Mumbai Discoms	67.057	1280.882
1) Thermal	351.656	7423.982	3) Other Discoms	11.208	226.811
(A1+C1+C4+(B1-B6))			TOTAL STATE	616.124	12654.225
2) Hydro	12.338	272.317			
3) Gas	10.667	215.915			
4) Wind	12.232	282.352			
6) SOLAR	16.988	361.495			
TOTAL STATE	403.881	8556.061			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6419	7015	6976	6439
MSPGCL Hydro	241	245	692	194
MSPGCL Gas	272	273	284	296
MSPGCL Total Generation	6932	7533	7952	6929
Central Sector Receipt	9429	9760	9201	7895
WIND	383	180	229	765
CPP / IPP Thermal	7080	7175	7374	7245
CPP / IPP Gas	0	0	0	0
SOLAR	2354	910	0	0
Exchange with Mumbai	-2078	-1712	-1524	-1205
MSEDCL DEMAND MET	23593	23321	22725	21272
Load Shedding	0	0	0	0
MSEDCL DEMAND	23593	23321	22725	21272
TPCL GENERATION	769	1074	1039	645
AEML GENERATION	496	497	476	314
MUMBAI DEMAND	3343	3283	3039	2164
OTHER DISCOM DEMAND	507	525	507	358
STATE DEMAND MET	27443	27129	26271	23793
STATE DEMAND	27443	27129	26271	23793
Frequency (Hz)	49.97	50.02	49.97	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 18:02 Hrs	49.79 Hz at 15:21 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 21/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.46	79.62	195	170
Unit 8	13.66	284.11	626	535
Unit 9	13.77	198.92	611	528
Unit 10	0.00	189.91	0	0
Total	31.88	752.57		
Bhusawal				
Unit 3	3.52	72.20	180	120
Unit 4	0.00	188.08	0	0
Unit 5	11.37	154.02	500	365
Total	14.89	414.30		
Parli				
Unit 6	4.03	85.18	240	130
Unit 7	4.28	83.71	245	144
Unit 8	4.39	65.30	250	144
Total	12.70	234.19		
Chandrapur				
Unit 3	3.47	68.72	158	125
Unit 4	3.67	61.32	174	122
Unit 5	8.59	175.00	415	275
Unit 6	8.85	175.42	445	275
Unit 7	7.14	171.78	435	236
Unit 8	10.14	198.42	430	409
Unit 9	11.60	211.49	496	452
Total	53.45	1062.15		
Paras				
Unit 3	5.65	115.72	242	219
Unit 4	5.85	119.50	256	209
Total	11.50	235.22		
Khaparkheda				
Unit 1	3.79	77.98	175	115
Unit 2	4.51	83.67	200	170
Unit 3	3.87	80.28	175	144
Unit 4	4.10	84.38	191	136
Unit 5	11.61	221.42	500	460
Total	27.88	547.72		
Nasik				
Unit 3	3.72	13.78	180	121
Unit 4	3.59	74.89	168	121
Unit 5	0.00	55.61	0	0
Total	7.31	144.29		
Uran				
All Units	6.85	141.81	299	267
Total	6.85	141.81		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	2.13	42	0
Total	0.15	2.13		
Koyna				
Stage 1-2	1.70	39.03	265	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	28.29	0	0
Stage 3	0.33	15.29	160	0
Total	2.03	82.61		
Hydro				
KDPH	0.86	18.14	36	36
VTRNA	0.69	13.92	60	0
TILLARI	0.50	9.90	64	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.53	55.19	113	99
GHATGHAR	0.00	4.26	0	0
Total	4.58	101.41		
Wind				
Total	12.23	282.35	0	0
Total	12.23	282.35		
CPP				
APML(Mus)	72.69	1302.56	0	0
JSWEL(Mus)	26.31	556.74	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.57	591.40	0	0
SWPGPL-Mus	12.28	247.49	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.75	120.56	220	157
Other(Mus)	28.79	716.17	0	0
JPL	1.55	83.18	66	63
Total	171.95	3618.10		
SOLAR				
Total	16.99	361.50	0	0
Total	16.99	361.50		
Tata				
Trombay 5	7.22	149.34	367	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.34	45.05	108	51
Trombay 7B	1.48	29.05	66	44
TATA Hydro	5.73	88.30	427	124
Trombay 8	3.62	77.32	208	131
Total	20.38	389.06		
AEML				
DTPS U-1&2	9.25	188.79	501	286
Total	9.25	188.79		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.62	3390.44	MSPGCL Total	173.08	3716.26
			MSPGCL Thml+Gas	166.46	3532.25	Koyna 1,2 & 4 Total	1.70	67.32
			MSPGCL Hydro	6.61	184.02	State Total	403.88	8556.06

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 21/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6622	193	296	7111	612	7337	0	0	8050	7721	-1309	21042	0	0	21042	2459	430	23931	49.98
2	6463	213	296	6972	605	7357	0	0	7874	7923	-1279	21188	0	0	21188	2296	390	23874	49.96
3	6439	194	296	6929	765	7245	0	0	7932	7895	-1205	21272	0	0	21272	2164	358	23793	49.97
4	6394	189	297	6880	828	7106	0	0	8035	8076	-1140	21370	0	0	21370	2078	380	23828	49.98
5	6569	193	298	7060	857	7374	0	0	8113	8117	-1109	21912	0	0	21912	2042	387	24341	49.98
6	6609	192	299	7100	1001	7375	0	0	8554	8646	-1118	22599	0	0	22599	2110	406	25114	49.99
7	6904	254	293	7451	1047	7405	0	34	8713	8835	-1142	23187	0	5	23187	2233	443	25863	49.99
8	6694	245	293	7232	935	7358	0	427	8526	8591	-1299	22785	0	1	22785	2449	460	25693	50.02
9	6607	249	294	7150	1076	7158	0	1166	8143	8430	-1563	22934	0	0	22934	2754	483	26171	50.02
10	6213	244	283	6740	991	6544	0	1745	8687	9113	-1845	22795	0	0	22795	3050	493	26338	50.02
11	6396	241	277	6914	659	6740	0	2170	8991	9550	-1972	23559	0	8	23559	3264	502	27325	50.04
12	6419	241	272	6932	383	7080	0	2354	9449	9429	-2078	23593	0	15	23593	3343	507	27443	49.97
13	6385	236	271	6892	232	6853	0	2304	9463	9165	-1962	22981	0	16	22981	3329	503	26813	49.99
14	6349	246	270	6865	160	6671	0	2124	8977	9107	-1851	22591	0	16	22591	3225	485	26301	50.04
15	6307	379	267	6953	131	6627	0	1862	9751	9734	-1872	22924	0	15	22924	3277	511	26712	49.91
16	6819	245	270	7334	137	7104	0	1472	9860	9560	-1827	23260	0	12	23260	3323	519	27103	49.92
17	7015	245	273	7533	180	7175	0	910	9960	9760	-1712	23321	0	11	23321	3283	525	27129	50.02
18	6845	299	278	7422	210	7246	0	391	9920	9601	-1668	22686	0	4	22686	3188	516	26390	50.03
19	6951	377	281	7609	204	7336	0	29	9190	9133	-1624	22184	0	0	22184	3067	503	25754	50.01
20	6976	692	284	7952	229	7374	0	0	9314	9201	-1524	22725	0	0	22725	3039	507	26271	49.97
21	6943	424	286	7653	229	7362	0	0	8942	8778	-1525	21992	0	0	21992	2912	505	25409	50.01
22	6951	222	290	7463	243	7364	0	0	8679	8723	-1593	21709	0	0	21709	2781	491	24981	50.00
23	6860	253	292	7405	249	7377	0	0	8658	8640	-1604	21606	0	0	21606	2707	461	24774	49.98
24	6888	345	291	7524	269	7386	0	0	8395	8515	-1605	21645	0	0	21645	2684	444	24773	49.98
MUs	159.62	6.61	6.85	173.08	12.23	171.95	0.00	16.99	212.18	212.24	-37.43	537.86	0.00	0.10	537.86	67.06	11.21	616.12	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR Carried out due to 132kv BBLR- Rahuri line Overload 488Amp/104MW at 132kv Rahuri s/stn

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 21/Mar/2024

Position as on 6.30 Hrs of 22/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 5	210	19/03/2024	17:40		Continued.	Withdrawn On Tolling.	
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-1	125	11/03/2024	18:40		Continued.	GM Link Fault	22/03/2024
MSPGCL	Uran Unit 6	108	12/03/2024	20:15		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Ghatghar Unit-2	125	14/03/2024	18:15		Continued.	GM Link Fault	22/03/2024
MSPGCL	Koradi Unit-10	660	17/03/2024	11:05		Continued.	Boiler Tube Leakage	22/03/2024
MSPGCL	Bhusawal Unit 4	500	19/03/2024	17:45	22/03/2024	03:00	Boiler Tube Leakage	22/03/2024
Total Capacity MSPGCL		1638						
IPP								
IPP	RPL(AMT) U-5	270	11/03/2024	03:00		Continued.	Air heater problem	23/03/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2228						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
IPP	JPL Unit 2	150	20/03/2024	00:00		Continued.	Non availability of schedule	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 21/Mar/2024

Position as on 6.30 Hrs of 22/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	JPL Unit 1	150	22/03/2024	00:00		Continued.	Non availability of schedule	
Total Capacity IPP		1288						
Total Capacity FORCED OUTAGE DUE TO NO PPA		1288						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 22/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	21/03/2024	16:51	21/03/2024	17:27	T	Tripped at Padghe end due to high supply temp. to thyristor valve
400 KV TIEBAY Outages/Trippings							
TIE BAY - 417 OF IEPL @ KORADI-2	IntraState	17/03/2024	12:19			PO	Overhauling of Circuit breaker
TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	21/03/2024	10:39	21/03/2024	19:57	PO	Diagnostic testing and Maintenance
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	21/03/2024	10:39	21/03/2024	19:56	PO	Diagnostic testing and Maintenance
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	19/03/2024	12:23			PO	Major maintenance of GIS bay no.18
PADGHE - TARAPUR CKT - 1	InterState	21/03/2024	13:40	21/03/2024	15:04	T	Tripped on Distance protection
PADGHE - TARAPUR CKT - 1	InterState	21/03/2024	15:22	21/03/2024	19:26	T	Tripped on distance protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar -Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
DABHOL - NEW KOYNA CKT - 2	IntraState	21/03/2024	10:34	21/03/2024	18:06	PO	Cold Washing Work, Diagnostic testing & Relay testing work , Routine maint. Work
EKTUNI - BABLESHWAR CKT - 2	IntraState	21/03/2024	13:36	21/03/2024	20:30	PO	Line Maintenance and Bay Maintenance Works
220 KV KORADI (400 KV) - BUTIBORI CKT	IntraState	21/03/2024	16:57	21/03/2024	17:42	HT	Compressor problem
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
400/220kv 500MVA ICT-2 @ TAPTITANDA	IntraState	21/03/2024	09:29	21/03/2024	18:39	PO	Diagnostic Testing work and quarterly maintenance work
400/220 KV 167MVA SPARE ICT @ LONIKAND 2	IntraState	21/03/2024	10:38	21/03/2024	20:07	PO	Dignostic testing and RRS work
400/220kv SPARE ICT @ JEJURI	IntraState	21/03/2024	11:05	21/03/2024	20:36	PO	For RRS related protection & CB trials work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 22/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	IntraState	21/03/2024	13:06	21/03/2024	21:41	PO	R.Ph.unit radiator oil leakage attending work by removing radiator limb and repair by cold welding and refitted work
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	21/03/2024	13:13	21/03/2024	20:15	PO	For RRS related protection & CB trials work.
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	21/03/2024	10:37	21/03/2024	19:00	PO	1) Diagnostic Testing work 2) Bay maint work
220 KV TBC Outages/Trippings							
BUS COUPLER @ AMRAPUR	IntraState	21/03/2024	14:30	21/03/2024	16:25	PO	QUARTERLY BAY MAINTENANCE WORK
220 KV MAINBAY Outages/Trippings							
220KV AMALNER - JPL CKT 2	IntraState	21/03/2024	10:24	21/03/2024	18:52	PO	Transmission line tower jumper tightness work
220KV PADEGAON WALUJ CKT 3	IntraState	21/03/2024	10:32	21/03/2024	19:33	PO	Isolator overhauling work.
TBC @ RANJANGAON	IntraState	21/03/2024	10:48	21/03/2024	12:50	PO	220KV CT Tan delta & CB CRM & Timing measurement , General bay maintenance
220KV AUXILLARY BUS	IntraState	21/03/2024	11:00	21/03/2024	17:00	PO	Auxiliary bus and jumper measurement of Auxiliary bus to bus isolator at 220kv Bhokardan s/s
220KV MAIN BUS 1	IntraState	21/03/2024	11:42	21/03/2024	13:48	PO	CT Tan delta testing, IR Measurement and C.B Timing and CRM Alongwith relay testing
220 KV LINE Outages/Trippings							
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kv cable at 220kv Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kv KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kv Karad-Koyana line
ALEPHATA-PARGAON(KATHAPUR)	IntraState	16/03/2024	01:34			HT	Hand Tripped
CHIKHALI-JALNA II	IntraState	20/03/2024	11:17	21/03/2024	02:22	HT	Overhed stringing over loc no 12 of jalna chikhli for 220kv lilo line for 220kv nagewadi ss.
CHIKHALI-JALNA I	IntraState	20/03/2024	11:17	21/03/2024	00:20	HT	Overhed stringing over loc no 12 of jalna chikhli for 220kv lilo line for 220kv nagewadi ss.
PHURSUNGI-SERUM	IntraState	21/03/2024	10:06	21/03/2024	21:04	PO	1) Restrstring conductor (R, Y, and B) between span of L.N.-76 to 70 & 76 to 79 through AMC. Minimum Ground Clearance. 2) Disc cleaning by Cold line cleaning through AMC. 3) Opening jump at L.N.-3 of 220 kV Theur & Jejuri & Serum Phursungi line. 4) Bunching of Theur Jejuri & Serum Phursungi at both side of CP L.N.-3. Due to which form the Theur Serum & 220 kV Jejuri Phursungi III (will open at Phursungi).

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 22/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
THEUR-JEJURI	IntraState	21/03/2024	10:06	21/03/2024	19:46	PO	1) Restranging conductor (R, Y, and B) between span of L.N.-76 to 70 & 76 to 79 through AMC. 2) Disc cleaning by Cold line cleaning through AMC. 3) Opening jump at L.N.-3 of 220 kV Theur & Serum Phursungi line. 4) Bunching of Theur Jejuri & Serum Phursungi at both side of CP L.N.-3. Due to which form the Theur Serum & 220 kV Jejuri Phursungi III (will open at Phursungi).
220KV PANDHARKAWDA - WANI CKT I	IntraState	21/03/2024	10:50	21/03/2024	19:23	EO	Tan delta testing of CT work & Relay testing work.
DASTURI-KANDALGAON LINE	IntraState	21/03/2024	11:26	21/03/2024	18:10	PO	Retrofitting work of Distance Protection Relay of 220KV Dasturi - Kandalgaon line.
URAN - ULWE GIS CKT - 1	IntraState	21/03/2024	12:09	21/03/2024	17:45	PO	For Relay testing and Diagnostic testing work
AMRAPUR - TAPTITANDA CKT - 2	IntraState	21/03/2024	14:06	21/03/2024	16:45	PO	220 KV Amrapur-Thaptitanda ckt 2 Bay - Quarterly Maintenance work
LOTEPARSHURAM- DASTURI LINE	IntraState	21/03/2024	18:37	22/03/2024	03:02	PO	Retrofitting work of Distance Protection Relay of 220KV Dasturi - Lote line.
MIRAJ - ICHALKARANJI	IntraState	21/03/2024	18:46	21/03/2024	22:34	PO	Attending minor hotspots at TL No 25 Rph & 46 Rph
CHALISGAON -BABHALESHWAR	IntraState	21/03/2024	18:51	21/03/2024	19:49	EO	Removal of Cloth
TALANDGE - ICHALKARANJI 2	IntraState	21/03/2024	18:53	21/03/2024	22:16	PO	For attending minor hotspots at TL No 21 Rph
KALWA - BORIVALI	IntraState	21/03/2024	22:50			PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KHARGHAR - BORIVALI CKT - 2	IntraState	21/03/2024	22:51			PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
GIS BHANDUP - BORIVALI	IntraState	21/03/2024	22:56			PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
BORIVALI - CTRLS CKT	IntraState	21/03/2024	22:59			PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
PADGHE - NALASOPARA - VASAI (T)	IntraState	22/03/2024	05:11			PO	In r/o work of shifting /diversion of existing 220kV D/C Padghe-Nalasopara- Vasai tap line between loc.no. 57to 59 & 61 to 62 for M/s Rajprabha Developers Pvt. Ltd following work is proposed on 22.03.2024: 1) Jumper will be reconnected at Loc no. 56 & 63 of 220kV Nalasopara-Vasai Link Line. 2) After removing bunching at Loc no. 55, line orientation will restore to 220kV Padgha-Nalasopara-Vasai Line and line will be charged at 08:00 am on same day i.e 22.03.2024.
CHALISGAON -BABHALESHWAR	IntraState	22/03/2024	06:15			T	Distance Protection
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 22/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/33KV 100MVA TF No.2 @ BOTHE	IntraState	20/03/2024	12:14	21/03/2024	21:54	PO	Oil filtration of 220/33kv 100MVA T/F-II
220/132 100MVA ICT-2 @ AMRAPUR	IntraState	21/03/2024	09:40	21/03/2024	17:01	PO	Quarterly Maintenance work
220/132 100MVA ICT-1 @ AMRAPUR	IntraState	21/03/2024	09:40	21/03/2024	17:01	PO	ICT I & II � Quarterly Maintenance work
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	21/03/2024	10:00	21/03/2024	13:35	PO	Outage for Diagnostic Testing work on ICT-1
220/100 KV 200 MVA ICT 1 @ KOLSHET	IntraState	21/03/2024	10:03	21/03/2024	16:16	PO	Preventive maintenance of CTR along with M/s. CTR representative.
STATION TRANSFORMER - 4 @ EKLAHARE (GCR)	IntraState	21/03/2024	10:55	21/03/2024	18:10	PO	Routine maintenance , Diagnostic testing work
220/132 KV 200 MVA ICT 1 @ CHALISGAON	IntraState	21/03/2024	11:24	21/03/2024	13:35	EO	Attend oil leakage and Hot spot work.
220/132 KV 200MVA ICT 2 @ KURKUMBH	IntraState	21/03/2024	14:00	21/03/2024	18:08	PO	Outage for Diagnostic Testing work on ICT-2
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	22/03/2024	00:26	22/03/2024	05:01	PO	Formation of 110 kv Waghivali Chembur Mankhurd Three Terminal Line
110 KV BUSBAR Outages/Trippings							
ZONE - 2 @ KALYAN	IntraState	21/03/2024	05:45	21/03/2024	06:51	PO	110KV Main Bus extension to the new 110KV Cap Bank MBS GOD A phase.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage