

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/May/2024 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	182.160	3584.645	1) Gujrat	0.997	9.851
2) Hydro	26.524	400.166	2) Madhya Pradesh	0.601	135.856
3) Gas	7.610	147.423	3) Chattisgarh	3.690	86.600
Total MSPGCL	216.294	4132.234	4) Maharashtra	192.403	3894.983
B) 1) APLM	63.041	1340.521	5) Goa (Amona)	-2.353	-41.366
2) JSWEL	27.246	575.312	Total	195.338	4085.924
3) VIPL	0.000	0.000	a) Mumbai Schedule	52.879	902.921
4) RPL(AMT)	25.628	628.832	b) Mumbai Drawl	49.122	933.385
5) SWPGPL	12.282	256.997	c) MSEDCL Bilateral *	79.158	1692.067
6) Other IPP	15.658	356.735	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	52.879	902.921
C) 1) TPCL Thermal	13.700	261.070	Include PX	0.000	0.000
2) TPCL Hydro	5.631	102.134	Standby	0.000	0.000
3) TPCL Gas	4.121	82.005	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.293	206.034	1) MSEDCL	522.515	10840.689
D) STATE			2) Mumbai Discoms	83.867	1584.622
1) Thermal	351.008	7210.146	3) Other Discoms	12.044	241.582
(A1+C1+C4+(B1-B6))			TOTAL STATE	618.426	12666.893
2) Hydro	32.155	502.300			
(A2+C2)					
3) Gas	11.731	229.428			
(A3+B7+C3)					
4) Wind	12.320	286.296			
6) SOLAR	15.874	352.805			
TOTAL STATE	423.088	8580.975			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	7129	7929	7605	7529
MSPGCL Hydro	628	934	1292	430
MSPGCL Gas	278	358	361	290
MSPGCL Total Generation	8036	9222	9258	8248
Central Sector Receipt	9116	9199	7693	8097
WIND	287	451	984	364
CPP / IPP Thermal	5047	6037	6744	5648
CPP / IPP Gas	0	0	0	0
SOLAR	2158	1369	0	516
Exchange with Mumbai	-2289	-2549	-1999	-1820
MSEDCL DEMAND MET	21789	23178	22135	20569
Load Shedding	0	0	0	0
MSEDCL DEMAND	21789	23178	22135	20569
TPCL GENERATION	1069	1259	1249	653
AEML GENERATION	498	498	498	340
MUMBAI DEMAND	3856	4306	3746	2813
OTHER DISCOM DEMAND	566	551	546	484
STATE DEMAND MET	26210	28034	26426	23866
STATE DEMAND	26210	28034	26426	23866
Frequency (Hz)	49.99	50.03	49.98	50.05

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 07:58 Hrs	49.81 Hz at 13:41 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 21/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.41	74.52	190	170
Unit 8	13.78	160.23	642	532
Unit 9	13.32	284.30	590	520
Unit 10	12.80	291.23	560	515
Total	44.32	810.29		
Bhusawal				
Unit 3	3.47	66.46	170	120
Unit 4	10.04	185.16	470	295
Unit 5	10.36	197.16	495	265
Total	23.88	448.78		
Parli				
Unit 6	4.34	93.51	248	140
Unit 7	4.28	88.52	241	140
Unit 8	3.77	87.55	191	144
Total	12.39	269.58		
Chandrapur				
Unit 3	3.66	75.28	165	125
Unit 4	3.69	77.18	164	128
Unit 5	8.98	183.16	425	275
Unit 6	8.89	132.94	420	280
Unit 7	6.50	190.56	456	0
Unit 8	10.36	216.18	460	300
Unit 9	10.80	230.91	481	340
Total	52.87	1106.21		
Paras				
Unit 3	5.32	95.59	243	161
Unit 4	5.59	115.21	254	172
Total	10.91	210.80		
Khaparkheda				
Unit 1	3.70	73.14	170	80
Unit 2	4.70	88.28	205	174
Unit 3	4.13	82.29	178	162
Unit 4	4.10	81.11	188	155
Unit 5	11.48	204.00	490	440
Total	28.10	528.82		
Nasik				
Unit 3	3.35	62.27	159	124
Unit 4	3.17	75.03	140	126
Unit 5	3.17	72.86	149	116
Total	9.69	210.16		
Uran				
All Units	7.61	147.42	380	278
Total	7.61	147.42		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	5.19	0	0
Total	0.00	5.19		
Koyna				
Stage 1-2	7.16	93.04	550	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	11.23	171.21	948	0
Stage 3	4.15	58.97	320	0
Total	22.55	323.22		
Hydro				
KDPH	0.56	13.51	24	23
VTRNA	0.89	17.33	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.02	41.00	90	79
GHATGHAR	0.50	5.11	250	0
Total	3.98	76.95		
Wind				
Total	12.32	286.30	0	0
Total	12.32	286.30		
CPP				
APML(Mus)	63.04	1340.52	0	0
JSWEL(Mus)	27.25	575.31	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.63	628.83	0	0
SWPGPL-Mus	12.28	257.00	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.79	110.25	269	227
Other(Mus)	5.79	146.99	0	0
JPL	4.08	99.49	270	134
Total	143.86	3158.40		
SOLAR				
Total	15.87	352.80	0	0
Total	15.87	352.80		
Tata				
Trombay 5	9.10	179.41	471	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.58	50.83	108	105
Trombay 7B	1.54	31.18	65	63
TATA Hydro	5.63	102.13	438	55
Trombay 8	4.60	81.66	225	130
Total	23.45	445.21		
AEML				
DTPS U-1&2	11.29	206.03	498	340
Total	11.29	206.03		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	182.16	3584.64	MSPGCL Total	216.29	4132.23
			MSPGCL Thml+Gas	189.77	3732.07	Koyna 1,2 & 4 Total	18.39	264.25
			MSPGCL Hydro	26.52	400.17	State Total	423.09	8580.98

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 21/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7862	1053	288	9203	680	6506	0	0	7741	7721	-1827	21836	0	7	21836	3383	447	25666	50.00
2	7731	1348	288	9368	591	5790	0	0	8099	7916	-1918	21349	0	0	21349	3141	398	24888	50.02
3	7908	1434	288	9630	570	6264	0	0	7381	7335	-1820	21595	0	0	21595	2942	383	24920	50.01
4	7842	1208	290	9340	456	6075	0	0	7366	7270	-1723	21057	0	0	21057	2804	360	24222	50.00
5	7833	1336	290	9458	449	6066	0	0	7229	7288	-1617	21237	0	0	21237	2724	408	24368	50.00
6	8051	1480	291	9822	470	6331	0	0	7180	7132	-1617	21694	0	0	21694	2722	443	24860	50.02
7	8016	728	291	9036	480	6417	0	113	7575	7216	-1584	21221	0	4	21221	2681	457	24358	50.02
8	7529	430	290	8248	364	5648	0	516	7806	8097	-1820	20569	0	6	20569	2813	484	23866	50.05
9	7376	790	278	8444	242	5176	0	1019	8148	8359	-2124	20575	0	2	20575	3162	542	24278	50.07
10	7558	408	281	8246	247	5192	0	1552	8376	8409	-2113	20995	0	5	20995	3543	539	25076	50.00
11	6882	700	281	7864	214	5076	0	1910	9321	8982	-2262	21231	0	0	21231	3756	552	25540	49.95
12	7129	628	278	8036	287	5047	0	2158	9299	9116	-2289	21789	0	0	21789	3856	566	26210	49.99
13	7015	628	311	7954	280	5022	0	2226	9349	9064	-2309	21686	0	0	21686	3856	550	26092	49.97
14	6918	594	358	7870	311	5002	0	2064	9313	9264	-2341	21635	0	0	21635	3836	535	26006	49.93
15	7574	896	358	8828	335	5249	0	1723	9290	9357	-2387	22579	0	23	22579	4033	527	27138	50.05
16	7929	934	358	9222	451	6037	0	1369	9466	9199	-2549	23178	0	42	23178	4306	551	28034	50.03
17	7761	1194	354	9310	578	6054	0	809	9194	8964	-2470	22689	0	27	22689	4203	555	27448	49.96
18	7603	1340	283	9226	700	6487	0	363	8705	8619	-2517	22295	0	0	22295	4022	582	26900	49.99
19	7550	1486	284	9320	876	6581	0	52	8195	7688	-2300	21632	0	6	21632	3806	585	26024	50.03
20	7605	1292	361	9258	984	6744	0	0	8426	7693	-1999	22135	0	1	22135	3746	546	26426	49.98
21	7696	1294	374	9364	807	6770	0	0	7805	7701	-1905	22209	0	0	22209	3664	528	26400	50.04
22	7673	1586	378	9638	783	6771	0	0	7469	7362	-1878	22150	0	0	22150	3618	526	26294	50.04
23	7606	1840	377	9822	544	6770	0	0	7704	7762	-1873	22525	0	0	22525	3617	500	26642	50.00
24	7513	1896	380	9788	621	6780	0	0	8025	7824	-1880	22652	0	0	22652	3633	481	26766	50.02
MUs	182.16	26.52	7.61	216.29	12.32	143.85	0.00	15.87	198.46	195.34	-49.12	522.51	0.00	0.12	522.51	83.87	12.04	618.43	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR carried out due to overload of 132 KV BBLSR-Rahuri line.2) DLS implemented due to overload of 220KV BBLSR-Alephata and Urse-Chinchwad line. 132KV Chinchwad-Rahatani line.3) power cut due to transmission constraints in Palghar circle.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 21/May/2024

Position as on 6.30 Hrs of 22/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Chandrapur Unit 7	500	21/05/2024	17.18		Continued.	Boiler Tube Leakage	24/05/2024
Total Capacity MSPGCL		620						
IPP								
IPP	RPL(AMT) U-3	270	20/05/2024	12:15		Continued.	Furnace Pressure High	23/05/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1210						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	18/05/2024	01:58	21/05/2024	12:30	No Schedule from MSEDCL	
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	21/05/2024	17:02	21/05/2024	18:56	No Schedule from MSEDCL	
MSPGCL	Uran Unit 6	108	22/05/2024	01:55		Continued.	No Schedule from MSEDCL	
Total Capacity MSPGCL		432						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		432						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaoor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/May/2024

Statement-VII

Position as on 6.30 Hrs of 22/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
400 KV AKOLA - AURANGABAD(PG) CKT -2	InterState	20/05/2024	16:21	21/05/2024	01:00	T	Tripped on distance protection
AURANGABAD(MS) - AURANGABAD(PG) CKT -1	InterState	20/05/2024	19:00	21/05/2024	00:55	T	Safety purpose for attending fault on 400 kV Aurangabad PG Akola ckt 2
DHULE - KHANDWA CKT - 1	InterState	21/05/2024	08:39	21/05/2024	22:10	PO	Work at Khandwa end
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
STATION TRANSFORMER - 1 @ NANDGAON PETH	IntraState	18/05/2024	06:20			PO	Following work will be carried out during Station Transformer-1 outage Period :- 1. ST#1- OLTC maintenance work(Before & After DCRM testing, oil Filtration & Diverter Switch Maintenance) 2. Complete ST#1 transformer testing. 3. FDS & SFRA test of transformer. 4. Testing of LA, MCT & MCVT.
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	20/05/2024	19:18	21/05/2024	23:52	PO	Repairing of broken conductor strands
DABHOL - NEW KOYNA CKT - 1	IntraState	21/05/2024	12:20			PO	Cold Washing Work
KHADKA-AURANGABAD (WALUJ)	IntraState	22/05/2024	07:00			PO	Restrining of missing Earth wire in between span 118 - 120
AKOLA 2 (YELWAN) - AKOLA 1 CKT - 1	IntraState	22/05/2024	07:24			PO	Routine Maintenance & testing Work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	20/05/2024	17:50	21/05/2024	03:27	PO	Outage required for pre-monsoon activity. Q/M of bay. Diagnostic testing will be carried out.
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	20/05/2024	23:34	21/05/2024	02:18	T	LBB protection operated due to 220kV Kondhwa line near LA was flashover
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	20/05/2024	23:34	21/05/2024	00:35	T	LBB protection operated due to 220kV Kondhwa line near LA was flashover
400/220/33 KV 500 MVA ICT - 2 @ DHULE	IntraState	21/05/2024	06:50			PO	1) R ph, Y ph & B ph unit NIFPS system TCIV valve replacement with dampers. 2) Faulty conservator MOG replacement of Y ph unit 3) Pre-monsoon Maintenance.
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	21/05/2024	10:39	21/05/2024	20:17	PO	Pre-Monsoon activity, CT diagnostic and relay testing work, routine maintenance work
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	21/05/2024	10:39	21/05/2024	20:17	PO	Routine maintenance and testing work
220 KV TBC Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/May/2024

Statement-VII

Position as on 6.30 Hrs of 22/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TBC @ WATHAR	IntraState	21/05/2024	09:10	21/05/2024	10:45	PO	Quarterly maintainance works.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
MAIN BUS @ SAWANTWADI	IntraState	21/05/2024	09:30	21/05/2024	11:00	PO	Annual Maintenance of 220kV Main Bus and allied bay equipment & Premonsoon activities to be carried out.
220 KV LINE Outages/Trippings							
AAREY - AEML SAKI CKT - 2	IntraState	08/05/2024	21:48			T	Tripped on Yph to ground fault
TALANDAGE - FIVE STAR MIDC 2	IntraState	20/05/2024	13:25	21/05/2024	00:23	PO	For STN to DTN work at loc no. 8 & 9.
TALANDAGE - FIVE STAR MIDC 2	IntraState	20/05/2024	13:25	21/05/2024	00:23	PO	Retrofitting of Numerical O/C E/F back up relay.
JEJURI - BARAMATI	IntraState	20/05/2024	23:34	21/05/2024	01:16	T	LBB protection operated due to 220kV Kondhwa line near LA was flashover
JEJURI-PHURSUNGI 1	IntraState	20/05/2024	23:34	21/05/2024	00:01	T	LBB protection operated due to 220kV Kondhwa line near LA was flashover
JEJURI - KONDHWA	IntraState	20/05/2024	23:34	21/05/2024	09:09	T	LBB protection operated due to 220kV Kondhwa line near LA was flashover
JEJURI (400 KV)-JEJURI- II	IntraState	20/05/2024	23:34	21/05/2024	02:25	T	LBB protection operated due to 220kV Kondhwa line near LA was flashover
JEJURI-PHURSUNGI 2	IntraState	20/05/2024	23:34	21/05/2024	02:31	T	LBB protection operated due to 220kV Kondhwa line near LA was flashover
JEJURI (400kV) - LONAND CKT - 1	IntraState	20/05/2024	23:34	21/05/2024	00:57	T	LBB protection operated due to 220kV Kondhwa line near LA was flashover
DAHANU - GHODBUNDER CKT - 1	IntraState	21/05/2024	04:18	21/05/2024	10:16	PO	Shifting of OPGW Cables, Hardware fitting (Y Phase) and replacement of temporary used steel bolts with GI Jumper Bolts (02 Towers).
KHADKI- CENTURY ENKA	IntraState	21/05/2024	08:08	21/05/2024	19:20	PO	Stringing of conductor loc 30A-30B & 31-32
220 KV KHADKA(400 KV) - KEKATNIBHORA CKR	IntraState	21/05/2024	08:31	21/05/2024	16:26	PO	LBB relay retrofitting work
TALANDGE - SAWANTWADI	IntraState	21/05/2024	09:04	21/05/2024	21:35	PO	Retrofitting of O/C E/F relay.
AMRAPUR - TAPTITANDA CKT - 2	IntraState	21/05/2024	10:15	21/05/2024	14:55	PO	Maintenance work
220 KV BAMBHORI - DEEPNAGAR CKT	IntraState	21/05/2024	12:14	21/05/2024	21:02	PO	Replacement of Old faulty insulators
WARORA - WARDHA	IntraState	21/05/2024	14:19	21/05/2024	16:40	T	Distance Protection
BARAMATI - KURKUMBH	IntraState	21/05/2024	15:27	21/05/2024	19:22	PO	Replacement of B-ph LA
MHAISAL - ALKUD	IntraState	21/05/2024	16:40	21/05/2024	19:57	PO	Jump Tightening Work
PEDAMBE-KALAMBANI(TSS)	IntraState	21/05/2024	17:18	21/05/2024	18:47	PO	Outage for Taking SCADA trial for Circuit Breaker, Bay (premonsoon) maintenance work & IR test of LA.
RANJANGAON - U TECH SUGAR CKT	IntraState	21/05/2024	18:19	21/05/2024	19:19	T	Tripped on distance protection
NEW KOYNA - NIWALI	IntraState	21/05/2024	22:44	21/05/2024	23:37	T	Tripped on distance protection
PEDHAMBE ONI LINE	IntraState	21/05/2024	22:45			T	Tripped on distance protection
NIWALI - PAWAS LINE	IntraState	21/05/2024	23:10	22/05/2024	00:41	T	Tripped on distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/May/2024

Statement-VII

Position as on 6.30 Hrs of 22/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - GHODBUNDER CKT - 2	IntraState	22/05/2024	04:13	22/05/2024	09:28	PO	Shifting of OPGW Cables and replacement of temporary used steel bolts with GI Jumper Bolts (02 Towers).
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	IntraState	22/05/2024	06:57	22/05/2024	08:33	PO	ASH POND WORK IN VICINITY
220 KV ICT Outages/Trippings							
220/132KV 200MVA ICT-1 @ KOPARGAON	IntraState	21/05/2024	08:12	21/05/2024	12:06	PO	For Pre Monsoon Maintenance work and Bay maintenance
220/132 KV 200 MVA ICT 1@AKOLA	IntraState	21/05/2024	08:45	21/05/2024	10:30	PO	Testing work
220/132KV 100MVA ICT - 2 @ KALWAN	IntraState	21/05/2024	09:10	21/05/2024	11:13	PO	Pe-monsoon ICT & bay maintenance work
220/132 KV 100 MVA ICT 1 @ YAVATMAL	IntraState	21/05/2024	09:11	21/05/2024	16:50	PO	Testing work
220/132 KV 100 MVA ICT 2 @ SAWANGI	IntraState	21/05/2024	09:50	21/05/2024	18:05	PO	Testing work
220/33KV 50MVA PTR 2@ PETH	IntraState	21/05/2024	10:01	21/05/2024	16:39	PO	Pre monsoon Maintenance Work
220/132KV 200MVA ICT 4 @ EKLHARE (OCR)	IntraState	21/05/2024	10:10	21/05/2024	12:32	PO	Pre monsoon maintenance work
220/33KV 50MVA PTR 2 @ VITA	IntraState	21/05/2024	10:30	21/05/2024	13:10	PO	1.OLTC Overhauling Work 2.Replacement of PRV of OLTC 3.Isolator Maintenance Work
100 MVA 220/132 KV ICT - II @ NARANGWADI	IntraState	21/05/2024	11:21	21/05/2024	13:58	PO	R.M.work
220/132-110 KV 200MVA ICT - 3 @ OGLEWADI	IntraState	21/05/2024	14:35	21/05/2024	18:39	PO	1.Replacement of drive mechanism gear box 2.Replacement of R, Y & B Ph LV Side LA 3.OLTC Overhauling Work
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	22/05/2024	08:36			PO	OLTC servicing & premonsoon maintenance work.
220/132KV 200MVA ICT 1 @ LONAND	IntraState	22/05/2024	09:15			PO	Premonsoon maintenance Work
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ JEJURI	IntraState	21/05/2024	05:05	21/05/2024	09:09	HT	To attend 220kv Kondhwa line near LA was flashover
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	22/05/2024	07:34			PO	BIRD NEST REMOVAL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage