

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 21/Jun/2020 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 81.315         | 1894.889        | 1) Gujrat                      | 13.068         | 136.561         |
| 2) Hydro            | 6.581          | 170.842         | 2) Madhya Pradesh              | 6.951          | 123.017         |
| 3) Gas              | 3.040          | 61.171          | 3) Chattisgarh                 | 6.280          | 111.080         |
| <b>Total MSPGCL</b> | <b>90.936</b>  | <b>2126.902</b> | 4) Maharashtra                 | 123.640        | 2438.236        |
| B) 1) APMIL         | 29.813         | 817.519         | 5) Goa (Amona)                 | -0.308         | -6.688          |
| 2) JSWEL            | 16.822         | 352.145         | <b>Total</b>                   | <b>149.631</b> | <b>2802.206</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 21.441         | 421.913         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 20.296         | 411.440         |
| 5) WPCL             | 2.669          | 54.300          | c) MSEDCL Bilateral *          | 37.169         | 754.738         |
| 6) Other IPP        | 6.924          | 158.382         | Include PX                     | 14.255         | 250.315         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 21.441         | 421.913         |
| C) 1) TPCL Thermal  | 8.068          | 163.720         | Include PX                     | 12.977         | 273.947         |
| 2) TPCL Hydro       | 3.651          | 94.633          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.387          | 92.299          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 8.951          | 205.351         | 1) MSEDCL                      | 322.150        | 6636.830        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 45.353         | 967.436         |
| 1) Thermal          | 154.562        | 3646.306        | <b>TOTAL STATE</b>             | <b>367.503</b> | <b>7604.266</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 10.232         | 265.475         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 7.427          | 153.470         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 39.906         | 618.766         |                                |                |                 |
| 6) SOLAR            | 5.745          | 118.050         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>217.872</b> | <b>4802.067</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 9 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 21 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|--------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 3042                     | 3425                  | 3587                      | 3345                      |
| MSPGCL Hydro             | 165                      | 429                   | 277                       | 105                       |
| MSPGCL Gas               | 134                      | 132                   | 128                       | 136                       |
| MSPGCL Total Generation  | 3341                     | 3986                  | 3992                      | 3586                      |
| Central Sector Receipt   | 7276                     | 6516                  | 5985                      | 5541                      |
| WIND                     | 1891                     | 1741                  | 1659                      | 1620                      |
| CPP / IPP Thermal        | 2205                     | 2358                  | 2415                      | 2429                      |
| CPP / IPP Gas            | 0                        | 0                     | 0                         | 0                         |
| SOLAR                    | 464                      | 724                   | 0                         | 0                         |
| Exchange with Mumbai     | -904                     | -857                  | -664                      | -896                      |
| <b>MSEDCL DEMAND MET</b> | <b>14273</b>             | <b>14468</b>          | <b>13387</b>              | <b>12280</b>              |
| Load Shedding            | 0                        | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 14273                    | 14468                 | 13387                     | 12280                     |
| TPCL GENERATION          | 507                      | 699                   | 1004                      | 559                       |
| AEML GENERATION          | 372                      | 372                   | 373                       | 373                       |
| <b>MUMBAI DEMAND</b>     | <b>1783</b>              | <b>1928</b>           | <b>2041</b>               | <b>1828</b>               |
| STATE DEMAND MET         | 16056                    | 16396                 | 15428                     | 14108                     |
| <b>STATE DEMAND</b>      | <b>16056</b>             | <b>16396</b>          | <b>15428</b>              | <b>14108</b>              |
| Frequency (Hz)           | 50.10                    | 49.99                 | 49.98                     | 50.06                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.29 Hz at 09.56 Hrs | 49.85 Hz at 19.47 Hrs | 50.04         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 21/Jun/2020

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 0.00         | 0.00           | 0        | 0        |
| Unit 9             | 0.00         | 18.14          | 0        | 0        |
| Unit 10            | 0.00         | 18.21          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>36.35</b>   |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 2.50           | 0        | 0        |
| Unit 5             | 0.00         | 4.40           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>6.91</b>    |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 0.00         | 2.61           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>2.61</b>    |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 4.14         | 73.87          | 185      | 163      |
| Unit 4             | 3.89         | 69.22          | 170      | 159      |
| Unit 5             | 9.55         | 167.36         | 430      | 365      |
| Unit 6             | 9.73         | 177.77         | 450      | 360      |
| Unit 7             | 9.63         | 199.28         | 440      | 350      |
| Unit 8             | 10.05        | 212.91         | 450      | 360      |
| Unit 9             | 10.28        | 207.40         | 460      | 360      |
| <b>Total</b>       | <b>57.27</b> | <b>1107.83</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 0.00         | 91.58          | 0        | 0        |
| Unit 4             | 0.00         | 95.88          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>187.46</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.94         | 83.01          | 175      | 155      |
| Unit 2             | 0.80         | 83.52          | 160      | 0        |
| Unit 3             | 4.17         | 80.97          | 193      | 160      |
| Unit 4             | 4.14         | 86.31          | 190      | 162      |
| Unit 5             | 11.00        | 219.92         | 500      | 365      |
| <b>Total</b>       | <b>24.04</b> | <b>553.73</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 3.04         | 61.17          | 138      | 122      |
| <b>Total</b>       | <b>3.04</b>  | <b>61.17</b>   |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.09         | 2.66           | 35       | 0        |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.09</b>  | <b>2.66</b>    |          |          |
| <b>Koyna</b>    |              |                |          |          |
| Stage 1-2       | 2.40         | 63.38          | 285      | 35       |
| Stage 4         | 0.35         | 38.98          | 291      | 0        |
| Stage 3         | 1.30         | 25.51          | 140      | 0        |
| <b>Total</b>    | <b>4.04</b>  | <b>127.86</b>  |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.62         | 8.74           | 26       | 26       |
| VTRNA           | 0.00         | 0.00           | 0        | 0        |
| TILLARI         | 0.74         | 13.70          | 62       | 0        |
| BHTGR/VEER      | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.28         | 2.86           | 40       | 0        |
| RNGR+BHTSA      | 0.28         | 4.98           | 12       | 11       |
| BHANDARDRA      | 0.42         | 9.00           | 18       | 17       |
| ELDARY          | 0.00         | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.20         | 3.70           | 9        | 8        |
| GHATGHAR        | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>    | <b>2.54</b>  | <b>42.98</b>   |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 39.91        | 618.77         | 0        | 0        |
| <b>Total</b>    | <b>39.91</b> | <b>618.77</b>  |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 29.81        | 817.52         | 0        | 0        |
| JSWEL(Mus)      | 16.82        | 352.14         | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00           | 0        | 0        |
| WPCL(Mus)       | 2.67         | 54.30          | 0        | 0        |
| Other(Mus)      | 6.92         | 158.38         | 0        | 0        |
| <b>Total</b>    | <b>56.23</b> | <b>1382.35</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 5.74         | 118.05         | 0        | 0        |
| <b>Total</b>    | <b>5.74</b>  | <b>118.05</b>  |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 8.07         | 163.72         | 448      | 301      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 2.81         | 58.93          | 117      | 116      |
| Trombay 7B      | 1.58         | 33.37          | 67       | 65       |
| Trombay 8       | 0.00         | 0.00           | 0        | 0        |
| TATA Hydro      | 3.65         | 94.63          | 401      | 18       |
| <b>Total</b>    | <b>16.11</b> | <b>350.65</b>  |          |          |
| <b>AEML</b>     |              |                |          |          |
| DTPS U-1&2      | 8.95         | 205.35         | 375      | 371      |
| <b>Total</b>    | <b>8.95</b>  | <b>205.35</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 81.32       | 1894.89       | MSPGCL Total        | 90.94       | 2126.90       |
|                |             |         | MSPGCL Thml+Gas | 84.36       | 1956.06       | Koyna 1,2 & 4 Total | 2.75        | 102.36        |
|                |             |         | MSPGCL Hydro    | 6.58        | 170.84        | State Total         | 217.87      | 4802.07       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 21/Jun/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|-------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |       |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 3587        | 185  | 125  | 3897  | 1710  | 2438      | 0    | 0     | 5958        | 5663        | -965                 | 12743                 | 0                    | 12743                     | 2175             | 14918           | 49.99         |
| 2                  | 3145        | 255  | 125  | 3525  | 1709  | 2374      | 0    | 0     | 5714        | 5858        | -1044                | 12422                 | 0                    | 12422                     | 1999             | 14421           | 50.03         |
| 3                  | 3256        | 168  | 126  | 3550  | 1855  | 2403      | 0    | 0     | 5485        | 5621        | -970                 | 12459                 | 0                    | 12459                     | 1903             | 14362           | 50.08         |
| 4                  | 3345        | 105  | 136  | 3586  | 1620  | 2429      | 0    | 0     | 5452        | 5541        | -896                 | 12280                 | 0                    | 12280                     | 1828             | 14108           | 50.06         |
| 5                  | 3515        | 115  | 126  | 3756  | 1524  | 2417      | 0    | 0     | 5552        | 5624        | -825                 | 12496                 | 0                    | 12496                     | 1791             | 14287           | 50.03         |
| 6                  | 3612        | 100  | 125  | 3837  | 1457  | 2416      | 0    | 0     | 6212        | 6358        | -748                 | 13320                 | 0                    | 13320                     | 1776             | 15096           | 50.01         |
| 7                  | 3643        | 299  | 127  | 4069  | 1501  | 2408      | 0    | 45    | 6970        | 6969        | -807                 | 14185                 | 0                    | 14185                     | 1737             | 15922           | 50.03         |
| 8                  | 3555        | 150  | 126  | 3831  | 1642  | 2366      | 0    | 206   | 7149        | 7073        | -750                 | 14368                 | 0                    | 14368                     | 1743             | 16111           | 50.08         |
| 9                  | 3042        | 165  | 134  | 3341  | 1891  | 2205      | 0    | 464   | 7278        | 7276        | -904                 | 14273                 | 0                    | 14273                     | 1783             | 16056           | 50.10         |
| 10                 | 2999        | 170  | 125  | 3294  | 2087  | 2117      | 0    | 634   | 7268        | 6746        | -906                 | 13972                 | 0                    | 13972                     | 1831             | 15803           | 50.16         |
| 11                 | 2992        | 160  | 125  | 3277  | 2125  | 1913      | 0    | 641   | 6884        | 6707        | -913                 | 13750                 | 0                    | 13750                     | 1832             | 15582           | 50.18         |
| 12                 | 3228        | 798  | 123  | 4149  | 1624  | 2142      | 0    | 418   | 6092        | 6364        | -903                 | 13794                 | 0                    | 13794                     | 1830             | 15624           | 50.11         |
| 13                 | 3218        | 405  | 123  | 3746  | 1725  | 2321      | 0    | 554   | 6106        | 6341        | -893                 | 13794                 | 0                    | 13794                     | 1823             | 15617           | 50.12         |
| 14                 | 3070        | 419  | 123  | 3612  | 1760  | 2150      | 0    | 808   | 6419        | 6727        | -924                 | 14133                 | 0                    | 14133                     | 1891             | 16024           | 50.04         |
| 15                 | 3425        | 429  | 132  | 3986  | 1741  | 2358      | 0    | 724   | 6336        | 6516        | -857                 | 14468                 | 0                    | 14468                     | 1928             | 16396           | 49.99         |
| 16                 | 3606        | 284  | 122  | 4012  | 1671  | 2433      | 0    | 565   | 6424        | 6442        | -808                 | 14315                 | 0                    | 14315                     | 1901             | 16216           | 50.00         |
| 17                 | 3465        | 289  | 122  | 3876  | 1646  | 2414      | 0    | 418   | 6035        | 6349        | -788                 | 13915                 | 0                    | 13915                     | 1840             | 15755           | 50.04         |
| 18                 | 3296        | 399  | 122  | 3817  | 1595  | 2387      | 0    | 223   | 5907        | 6201        | -888                 | 13335                 | 0                    | 13335                     | 1790             | 15125           | 50.00         |
| 19                 | 3459        | 267  | 126  | 3852  | 1497  | 2404      | 0    | 45    | 6025        | 5807        | -887                 | 12718                 | 0                    | 12718                     | 1798             | 14516           | 49.99         |
| 20                 | 3607        | 273  | 126  | 4006  | 1441  | 2413      | 0    | 0     | 6159        | 6188        | -727                 | 13321                 | 0                    | 13321                     | 1902             | 15223           | 49.94         |
| 21                 | 3587        | 277  | 128  | 3992  | 1659  | 2415      | 0    | 0     | 6117        | 5985        | -664                 | 13387                 | 0                    | 13387                     | 2041             | 15428           | 49.98         |
| 22                 | 3572        | 262  | 138  | 3972  | 1468  | 2413      | 0    | 0     | 5477        | 5717        | -680                 | 12890                 | 0                    | 12890                     | 2045             | 14935           | 50.01         |
| 23                 | 3552        | 377  | 127  | 4056  | 1483  | 2440      | 0    | 0     | 5491        | 5707        | -721                 | 12965                 | 0                    | 12965                     | 2058             | 15023           | 50.02         |
| 24                 | 3539        | 230  | 128  | 3897  | 1475  | 2452      | 0    | 0     | 5606        | 5851        | -828                 | 12847                 | 0                    | 12847                     | 2108             | 14955           | 50.05         |
| MUs                | 81.32       | 6.58 | 3.04 | 90.94 | 39.91 | 56.23     | 0.00 | 5.75  | 148.12      | 149.63      | -20.30               | 322.15                | 0.00                 | 322.15                    | 45.35            | 367.50          | 50.04         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 21/Jun/2020**

Position as on 6.30 Hrs of 22/Jun/2020

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                            | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |           |            |                                                                                             |               |
| IPP                  | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                     |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | No PPA                                                                                      |               |
| CPP                  | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                               |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                               |               |
| MSPGCL               | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs) |               |
| MSPGCL               | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL               | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |           | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)                          |               |
| IPP                  | RPL(AMT) U-3            | 270      | 11/02/2020   | 18.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                  | RPL(AMT) U-5            | 270      | 11/02/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 3            | 210      | 17/02/2020   | 00:00        |           | Continued. | C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)             |               |
| MSPGCL               | Ghatghar Unit-1         | 125      | 18/02/2020   | 00.25        |           | Continued. | Severe Hunting In Hydro Conduit Across MIV                                                  |               |
| MSPGCL               | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |           | Continued. | Gas shortage                                                                                |               |
| IPP                  | RPL(AMT) U-1            | 270      | 04/03/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Ghatghar Unit-2         | 125      | 09/03/2020   | 10:50        |           | Continued. | Expansion joint leakage.                                                                    |               |
| IPP                  | RPL(AMT) U-2            | 270      | 09/03/2020   | 20.15        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Parli Unit 6            | 250      | 21/03/2020   | 17.31        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Nasik Unit 4            | 210      | 25/03/2020   | 19.45        |           | Continued. | Reserve Shut Down.(Converted zero schedule from 25.03.2020)                                 |               |
| MSPGCL               | Uran Unit 5             | 108      | 06/04/2020   | 13.23        |           | Continued. | Gas shortage                                                                                |               |
| TPC_G                | Trombay 8               | 250      | 11/04/2020   | 16.55        |           | Continued. | Zero Schedule.                                                                              |               |
| CPP                  | SWPGL U-3               | 135      | 25/04/2020   | 00.08        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | JSW (J) U3              | 300      | 30/04/2020   | 15.13        |           | Continued. | No Schedule                                                                                 |               |
| MSPGCL               | Parli Unit 7            | 250      | 12/05/2020   | 19.34        |           | Continued. | Zero Schedule.                                                                              |               |
| MSPGCL               | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |           | Continued. | Shaft position                                                                              |               |
| MSPGCL               | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |           | Continued. | Shaft Position                                                                              |               |
| MSPGCL               | Koradi Unit-8           | 660      | 31/05/2020   | 22.56        |           | Continued. | Heavy steam Leakage in super heater.(Converted in                                           |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 21/Jun/2020**

**Position as on 6.30 Hrs of 22/Jun/2020**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                        | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------|---------------|
|                    |                         |          |              |              |           |            | To Zero schedule w.e.f 03.06.2020 01.28)                |               |
| MSPGCL             | Bhusawal Unit 4         | 500      | 01/06/2020   | 07.16        |           | Continued. | Zero Schedule By MSEDCL                                 |               |
| MSPGCL             | Bhusawal Unit 5         | 500      | 01/06/2020   | 12.21        |           | Continued. | Zero schedule By MSEDCL                                 |               |
| MSPGCL             | Parli Unit 8            | 250      | 01/06/2020   | 13.13        |           | Continued. | Zero schedule By MSEDCL                                 |               |
| MSPGCL             | Koradi Unit 9           | 660      | 02/06/2020   | 15.42        |           | Continued. | Converted Zero Schedule from 03.06.2020                 |               |
| MSPGCL             | Koradi Unit 10          | 660      | 03/06/2020   | 02.20        |           | Continued. | Zero Schedule By MSEDCL.                                |               |
| IPP                | Adani U-1               | 660      | 03/06/2020   | 15.02        |           | Continued. | Converted zero schedule from 03.06.2020                 |               |
| IPP                | Adani U-5               | 660      | 04/06/2020   | 12.29        |           | Continued. | Zero Schedule.                                          |               |
| IPP                | Adani U-4               | 660      | 12/06/2020   | 10.30        |           | Continued. | Zero Schedule                                           |               |
| MSPGCL             | Koyana STG- IV Unit - 1 | 250      | 17/06/2020   | 08.00        |           | Continued. | Work Of Main Inlet Spherical Valve Servomotor Cylinder. |               |
| MSPGCL             | Paras Unit 3            | 250      | 19/06/2020   | 01.58        |           | Continued. | Zero schedule.                                          |               |
| MSPGCL             | Paras Unit 4            | 250      | 19/06/2020   | 04.00        |           | Continued. | Zero schedule.                                          |               |
| MSPGCL             | Khaparkheda Unit 2      | 210      | 21/06/2020   | 06.47        |           | Continued. | Low Air Flow                                            |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 21/Jun/2020**

**Statement-VII**

Position as on 6.30 Hrs of 22/Jun/2020

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                   |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                    |
| Karad Solapur (PG)                     | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403           |
| Chandrapur Bhadravati I                | InterState                | 14/06/2020   | 17.48        |            | Continued. | HT          | Over Voltage                                                       |
| Dhule Khandwa I                        | InterState                | 14/06/2020   | 18.02        |            | Continued. | T           | Bus-II B Phase CVT Burst                                           |
| Jaigad-Karad Ckt-I                     | IntraState                | 10/06/2020   | 23.22        |            | Continued. | HT          | Over Voltage                                                       |
| BABHALESHWAR - RPL(NASHIK) CKT - 1     | IntraState                | 11/06/2020   | 10.40        |            | Continued. | HT          | Kept out due to No generation available at sinner ent.             |
| Khadka-Aurangabad (Waluj)              | IntraState                | 12/06/2020   | 17.00        |            | Continued. | HT          | Over Voltage                                                       |
| Padghe - Kalwa- I                      | IntraState                | 15/06/2020   | 21.16        |            | Continued. | HT          | Over Voltage                                                       |
| karad -kolhapur-II                     | IntraState                | 17/06/2020   | 16.46        |            | Continued. | HT          | Over Voltage                                                       |
| Babhaleshwar - Padghe-II               | IntraState                | 18/06/2020   | 20.48        |            | Continued. | HT          | Over Voltage                                                       |
| Padghe - Nagothane - II                | IntraState                | 19/06/2020   | 18.08        |            | Continued. | HT          | Over Voltage                                                       |
| Dhule- Bableswhar - I                  | IntraState                | 19/06/2020   | 19.51        |            | Continued. | HT          | Over Voltage                                                       |
| Lonikand I - Koyna stage-IV            | IntraState                | 21/06/2020   | 01.14        |            | Continued. | HT          | Over Voltage                                                       |
| Pune(GIS)-A'bad(Waluj) Ckt 2           | IntraState                | 21/06/2020   | 18.39        | 21/06/2020 | 20.48      | EO          | SF6 Gas Rifilling at pune GIS end                                  |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                    |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe    | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                           |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                    |
| Mudshingi Chikodi                      | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.                                                       |
| Talandage - Chikodi                    | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                            |
| BOISAR BORIVALI                        | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                       |
| Borivali - Ghodbunder                  | IntraState                | 30/01/2020   | 12.05        |            | Continued. | PO          | Isolation of 220KV Cables on MSETCL Tower NO.240                   |
| Flagship-Chinchwad                     | IntraState                | 20/06/2020   | 15.57        |            | Continued. | PO          | BIRD NEST REMOVAL                                                  |
| Sawantwadi-Bidri                       | IntraState                | 20/06/2020   | 23.49        | 21/06/2020 | 13.00      | HT          | Over Voltage                                                       |
| Trombay Dharavi 6                      | IntraState                | 21/06/2020   | 09.04        | 21/06/2020 | 16.13      | PO          | work in vicinity of TS-Carnac line                                 |
| Trombay Salsette 1 Backbay             | IntraState                | 21/06/2020   | 09.04        | 21/06/2020 | 21.25      | PO          | Loop opening of 220KV Trombay-Salsette1/Carnac 7 line at Loc.No.11 |
| Kalwa-TIFIL                            | IntraState                | 21/06/2020   | 09.20        | 21/06/2020 | 18.52      | PO          | MMRDA pile foundation work                                         |
| Kharghar-Borivali ckt I                | IntraState                | 21/06/2020   | 09.56        | 21/06/2020 | 19.06      | PO          | MMRDA pile foundation work                                         |
| Chandrapur(MIDC)-Ballarshah II         | IntraState                | 21/06/2020   | 16.42        | 21/06/2020 | 17.10      | T           | Distance Protection                                                |
| Sawantwadi-Bidri                       | IntraState                | 21/06/2020   | 23.15        |            | Continued. | HT          | Over Voltage                                                       |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                    |
| 220/132 KV 100MVA ICT-I @ Shivajinagar | IntraState                | 13/06/2020   | 01.24        |            | Continued. | T           | Differential protection & main Buchholz trip.                      |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage