

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 21/Oct/2020 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 145.220        | 2769.844        | 1) Gujrat                      | -0.127         | 40.415          |
| 2) Hydro            | 6.013          | 136.023         | 2) Madhya Pradesh              | 6.255          | 117.278         |
| 3) Gas              | 6.201          | 119.070         | 3) Chattisgarh                 | 6.270          | 114.790         |
| <b>Total MSPGCL</b> | <b>157.434</b> | <b>3024.937</b> | 4) Maharashtra                 | 107.571        | 2425.117        |
| B) 1) APLM          | 60.713         | 1288.683        | 5) Goa (Amona)                 | -1.607         | -28.896         |
| 2) JSWEL            | 24.709         | 493.417         | <b>Total</b>                   | <b>118.362</b> | <b>2668.704</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 17.134         | 435.776         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 20.979         | 475.881         |
| 5) WPCL             | 6.988          | 125.302         | c) MSEDCL Bilateral *          | 31.243         | 663.384         |
| 6) Other IPP        | 7.697          | 180.942         | Include PX                     | 0.652          | 56.435          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 17.134         | 434.199         |
| C) 1) TPCL Thermal  | 15.760         | 235.077         | Include PX                     | 6.353          | 159.502         |
| 2) TPCL Hydro       | 4.897          | 102.710         | Standby                        | 0.000          | 1.578           |
| 3) TPCL Gas         | 4.363          | 89.919          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 11.495         | 207.910         | 1) MSEDCL                      | 363.863        | 7636.614        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 57.494         | 1111.494        |
| 1) Thermal          | 272.582        | 5301.175        | <b>TOTAL STATE</b>             | <b>421.357</b> | <b>8748.108</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro (A2+C2)    | 10.910         | 238.733         |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 10.564         | 208.989         |                                |                |                 |
| 4) Wind             | 3.580          | 222.771         |                                |                |                 |
| 6) SOLAR            | 5.359          | 107.739         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>302.995</b> | <b>6079.407</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6253                      | 6136                  | 6346                      | 5269                      |
| MSPGCL Hydro             | 160                       | 334                   | 658                       | 115                       |
| MSPGCL Gas               | 267                       | 257                   | 280                       | 279                       |
| MSPGCL Total Generation  | 6680                      | 6727                  | 7284                      | 5663                      |
| Central Sector Receipt   | 5665                      | 5379                  | 5247                      | 4390                      |
| WIND                     | 83                        | 219                   | 122                       | 174                       |
| CPP / IPP Thermal        | 3978                      | 3929                  | 4875                      | 3745                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 731                       | 386                   | 0                         | 0                         |
| Exchange with Mumbai     | -1184                     | -1189                 | -1007                     | -482                      |
| <b>MSEDCL DEMAND MET</b> | <b>15953</b>              | <b>15451</b>          | <b>16521</b>              | <b>13490</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 15953                     | 15451                 | 16521                     | 13490                     |
| TPCL GENERATION          | 1186                      | 1096                  | 1131                      | 896                       |
| AEML GENERATION          | 370                       | 501                   | 500                       | 500                       |
| <b>MUMBAI DEMAND</b>     | <b>2740</b>               | <b>2786</b>           | <b>2638</b>               | <b>1878</b>               |
| STATE DEMAND MET         | 18693                     | 18237                 | 19159                     | 15368                     |
| <b>STATE DEMAND</b>      | <b>18693</b>              | <b>18237</b>          | <b>19159</b>              | <b>15368</b>              |
| Frequency (Hz)           | 50.00                     | 50.00                 | 50.03                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.16 Hz at 13.20 Hrs | 49.85 Hz at 06.11 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 21/Oct/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.89        | 186.59        | 575      | 370      |
| Unit 9             | 11.51        | 151.61        | 532      | 370      |
| Unit 10            | 8.40         | 171.60        | 354      | 340      |
| <b>Total</b>       | <b>31.80</b> | <b>509.80</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.66         | 203.66        | 500      | 280      |
| Unit 5             | 9.54         | 203.27        | 495      | 280      |
| <b>Total</b>       | <b>19.20</b> | <b>406.92</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 4.30         | 72.27         | 239      | 114      |
| Unit 7             | 4.70         | 73.83         | 248      | 169      |
| Unit 8             | 5.13         | 79.93         | 251      | 170      |
| <b>Total</b>       | <b>14.13</b> | <b>226.02</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.45         | 18.24         | 160      | 115      |
| Unit 4             | 3.39         | 62.62         | 152      | 120      |
| Unit 5             | 9.05         | 197.86        | 430      | 275      |
| Unit 6             | 9.04         | 180.11        | 420      | 280      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.27        | 216.34        | 475      | 450      |
| Unit 9             | 11.10        | 215.05        | 470      | 450      |
| <b>Total</b>       | <b>47.30</b> | <b>890.23</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.08         | 96.27         | 236      | 180      |
| Unit 4             | 5.42         | 105.73        | 250      | 182      |
| <b>Total</b>       | <b>10.50</b> | <b>202.00</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.06         | 69.94         | 145      | 115      |
| Unit 2             | 3.28         | 81.18         | 180      | 120      |
| Unit 3             | 3.51         | 74.79         | 180      | 130      |
| Unit 4             | 3.46         | 82.50         | 180      | 130      |
| Unit 5             | 5.65         | 204.74        | 450      | 0        |
| <b>Total</b>       | <b>18.96</b> | <b>513.14</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.33         | 21.71         | 190      | 129      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>3.33</b>  | <b>21.71</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.20         | 119.07        | 280      | 223      |
| <b>Total</b>       | <b>6.20</b>  | <b>119.07</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.21         | 14.98         | 27       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.21</b>   | <b>14.98</b>   |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 2.06          | 52.40          | 325      | 35       |
| Stage 4         | 0.41          | 24.10          | 215      | 0        |
| Stage 3         | 1.00          | 19.03          | 160      | 0        |
| <b>Total</b>    | <b>3.47</b>   | <b>95.52</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.74          | 4.76           | 37       | 18       |
| VTRNA           | 0.00          | 0.49           | 0        | 0        |
| TILLARI         | 0.00          | 3.99           | 0        | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.36          | 7.05           | 40       | 0        |
| RNGR+BHTSA      | 0.35          | 3.61           | 15       | 14       |
| BHANDARDRA      | 0.00          | 0.80           | 0        | 0        |
| ELDARY          | 0.36          | 10.72          | 15       | 15       |
| SMLHY_PTN       | 0.42          | 3.92           | 18       | 17       |
| GHATGHAR        | 0.31          | 5.15           | 125      | 0        |
| <b>Total</b>    | <b>2.54</b>   | <b>40.50</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 3.58          | 222.77         | 0        | 0        |
| <b>Total</b>    | <b>3.58</b>   | <b>222.77</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 60.71         | 1288.68        | 0        | 0        |
| JSWEL(Mus)      | 24.71         | 493.42         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 0.00          | 0.00           | 0        | 0        |
| WPCL(Mus)       | 6.99          | 125.30         | 0        | 0        |
| Other(Mus)      | 7.70          | 180.94         | 0        | 0        |
| <b>Total</b>    | <b>100.11</b> | <b>2088.34</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 5.36          | 107.74         | 0        | 0        |
| <b>Total</b>    | <b>5.36</b>   | <b>107.74</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 10.27         | 190.48         | 448      | 396      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.79          | 58.40          | 117      | 102      |
| Trombay 7B      | 1.58          | 31.52          | 67       | 61       |
| Trombay 8       | 5.49          | 44.60          | 234      | 223      |
| TATA Hydro      | 4.90          | 102.71         | 352      | 42       |
| <b>Total</b>    | <b>25.02</b>  | <b>427.71</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 11.50         | 207.91         | 502      | 283      |
| <b>Total</b>    | <b>11.50</b>  | <b>207.91</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 145.22      | 2769.84       | MSPGCL Total        | 157.43      | 3024.94       |
|                |             |         | MSPGCL Thml+Gas | 151.42      | 2888.91       | Koyna 1,2 & 4 Total | 2.47        | 76.49         |
|                |             |         | MSPGCL Hydro    | 6.01        | 136.02        | State Total         | 303.00      | 6079.41       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 21/Oct/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5679        | 105  | 258  | 6042   | 259  | 3959      | 0    | 0     | 4436        | 4276        | -750                 | 13786                 | 0                    | 13786                     | 2251             | 16037           | 50.00         |
| 2                  | 5498        | 110  | 269  | 5877   | 208  | 3980      | 0    | 0     | 4299        | 4188        | -599                 | 13654                 | 0                    | 13654                     | 2091             | 15745           | 49.99         |
| 3                  | 5316        | 110  | 259  | 5685   | 199  | 3825      | 0    | 0     | 4417        | 4428        | -569                 | 13568                 | 0                    | 13568                     | 1964             | 15532           | 49.99         |
| 4                  | 5269        | 115  | 279  | 5663   | 174  | 3745      | 0    | 0     | 4369        | 4390        | -482                 | 13490                 | 0                    | 13490                     | 1878             | 15368           | 49.99         |
| 5                  | 5562        | 225  | 259  | 6046   | 178  | 3808      | 0    | 0     | 4386        | 4441        | -398                 | 14075                 | 0                    | 14075                     | 1834             | 15909           | 49.97         |
| 6                  | 6319        | 330  | 270  | 6919   | 173  | 3887      | 0    | 0     | 4473        | 4518        | -413                 | 15084                 | 0                    | 15084                     | 1853             | 16937           | 49.98         |
| 7                  | 6734        | 130  | 270  | 7134   | 213  | 4127      | 0    | 9     | 4909        | 4566        | -442                 | 15607                 | 0                    | 15607                     | 1887             | 17494           | 50.01         |
| 8                  | 6667        | 111  | 270  | 7048   | 196  | 4645      | 0    | 125   | 4886        | 4980        | -542                 | 16452                 | 0                    | 16452                     | 2000             | 18452           | 50.01         |
| 9                  | 6666        | 125  | 259  | 7050   | 136  | 4778      | 0    | 488   | 5026        | 4758        | -896                 | 16314                 | 0                    | 16314                     | 2235             | 18549           | 49.99         |
| 10                 | 6617        | 143  | 257  | 7017   | 98   | 4282      | 0    | 605   | 5371        | 5197        | -1188                | 16011                 | 0                    | 16011                     | 2520             | 18531           | 50.01         |
| 11                 | 6253        | 160  | 267  | 6680   | 83   | 3978      | 0    | 731   | 5692        | 5665        | -1184                | 15953                 | 0                    | 15953                     | 2740             | 18693           | 50.00         |
| 12                 | 6133        | 160  | 257  | 6550   | 66   | 3962      | 0    | 737   | 5689        | 5496        | -1155                | 15656                 | 0                    | 15656                     | 2844             | 18500           | 50.01         |
| 13                 | 5841        | 160  | 256  | 6257   | 108  | 3977      | 0    | 736   | 5592        | 5280        | -1149                | 15209                 | 0                    | 15209                     | 2823             | 18032           | 50.00         |
| 14                 | 5373        | 234  | 246  | 5853   | 117  | 3952      | 0    | 724   | 5532        | 5524        | -1078                | 15092                 | 0                    | 15092                     | 2733             | 17825           | 50.05         |
| 15                 | 5403        | 434  | 256  | 6093   | 128  | 3924      | 0    | 600   | 5476        | 5784        | -1121                | 15408                 | 0                    | 15408                     | 2774             | 18182           | 50.00         |
| 16                 | 6136        | 334  | 257  | 6727   | 219  | 3929      | 0    | 386   | 5494        | 5379        | -1189                | 15451                 | 0                    | 15451                     | 2786             | 18237           | 50.00         |
| 17                 | 6193        | 296  | 256  | 6745   | 164  | 4061      | 0    | 185   | 5297        | 5228        | -1116                | 15267                 | 0                    | 15267                     | 2715             | 17982           | 49.96         |
| 18                 | 6245        | 351  | 258  | 6854   | 101  | 4579      | 0    | 33    | 5016        | 4927        | -949                 | 15545                 | 0                    | 15545                     | 2620             | 18165           | 50.01         |
| 19                 | 6300        | 906  | 260  | 7466   | 101  | 4832      | 0    | 0     | 5017        | 5107        | -1038                | 16468                 | 0                    | 16468                     | 2642             | 19110           | 50.04         |
| 20                 | 6346        | 658  | 280  | 7284   | 122  | 4875      | 0    | 0     | 5298        | 5247        | -1007                | 16521                 | 0                    | 16521                     | 2638             | 19159           | 50.03         |
| 21                 | 6274        | 164  | 258  | 6696   | 104  | 4466      | 0    | 0     | 5040        | 5055        | -951                 | 15370                 | 0                    | 15370                     | 2541             | 17911           | 50.02         |
| 22                 | 6177        | 369  | 233  | 6779   | 109  | 4264      | 0    | 0     | 4629        | 4947        | -915                 | 15184                 | 0                    | 15184                     | 2430             | 17614           | 49.99         |
| 23                 | 6209        | 159  | 244  | 6612   | 166  | 4220      | 0    | 0     | 4602        | 4520        | -909                 | 14609                 | 0                    | 14609                     | 2367             | 16976           | 50.01         |
| 24                 | 6010        | 124  | 223  | 6357   | 158  | 4052      | 0    | 0     | 4727        | 4461        | -939                 | 14089                 | 0                    | 14089                     | 2328             | 16417           | 50.03         |
| MUs                | 145.2<br>2  | 6.01 | 6.20 | 157.43 | 3.58 | 100.11    | 0.00 | 5.36  | 119.67      | 118.36      | -20.98               | 363.86                | 0.00                 | 363.86                    | 57.49            | 421.36          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 21/Oct/2020**

Position as on 6.30 Hrs of 22/Oct/2020

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                            | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |            |            |                                                                                             |               |
| IPP                  | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                     |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                 |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                 |               |
| IPP                  | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                      |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                                               |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                                               |               |
| MSPGCL               | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |            | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs) |               |
| MSPGCL               | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |            | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL               | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)                          |               |
| IPP                  | RPL(AMT) U-3            | 270      | 11/02/2020   | 18.00        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                  | RPL(AMT) U-5            | 270      | 11/02/2020   | 19.30        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 3            | 210      | 17/02/2020   | 00:00        |            | Continued. | C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)             |               |
| MSPGCL               | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |            | Continued. | Gas shortage                                                                                |               |
| IPP                  | RPL(AMT) U-1            | 270      | 04/03/2020   | 19.30        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-2            | 270      | 09/03/2020   | 20.15        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL               | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL               | Chandrapur Unit 7       | 500      | 29/09/2020   | 01.58        |            | Continued. | Tripped On Generator Protection.                                                            |               |
| MSPGCL               | Ghatghar Unit-1         | 125      | 30/09/2020   | 18.05        |            | Continued. | Turbine Guide Bearing problem                                                               |               |
| MSPGCL               | Koyna Unit 7            | 80       | 21/10/2020   | 08.00        | 21/10/2020 | 18.00      | Maintenance work                                                                            |               |
| MSPGCL               | Khaparkheda Unit 5      | 500      | 21/10/2020   | 13.52        |            | Continued. | Boiler Tube Leakage                                                                         |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 21/Oct/2020**

**Statement-VII**

Position as on 6.30 Hrs of 22/Oct/2020

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                         |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                          |
| Chandrapur - Padghe Hvdc Pole 2                   | IntraState                | 19/10/2020   | 23.01        |            | Continued. | PO          | Abnormal sound from main tank of smoothing reactor.                                                      |
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                          |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                 |
| Dhule Sar'Sarovar I                               | InterState                | 20/10/2020   | 17.06        |            | Continued. | HT          | Over Voltage                                                                                             |
| Karad - Jaigad - II                               | IntraState                | 16/09/2020   | 23.34        |            | Continued. | HT          | Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).                                     |
| Jaigad-Karad Ckt-I                                | IntraState                | 27/09/2020   | 18.59        |            | Continued. | T           | Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).                               |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 20/10/2020   | 20.16        | 21/10/2020 | 09.44      | HT          | Over Voltage                                                                                             |
| Dhule- Bableshwar - I                             | IntraState                | 20/10/2020   | 23.37        | 21/10/2020 | 11.01      | HT          | Over Voltage                                                                                             |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 21/10/2020   | 20.25        |            | Continued. | HT          | Over Voltage                                                                                             |
| Dhule - Bableshwar - II                           | IntraState                | 21/10/2020   | 21.06        |            | Continued. | HT          | Over Voltage                                                                                             |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                          |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe               | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                                                                 |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/09/2020   | 09.58        |            | Continued. | PO          | Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.                                                    |
| 400/220/33 Kv 315 Mva Ict 2 @Dhule                | IntraState                | 23/09/2020   | 09.12        |            | Continued. | PO          | Augmentation work of 400/220 315MVA ICT-II to 501MVA                                                     |
| 400/220/33kv, 500 Mva Ict-2 @Khaparkheda          | IntraState                | 21/10/2020   | 09.51        | 21/10/2020 | 17.23      | PO          | Diagnostic Testing Work.                                                                                 |
| 400/220KV 500MVA ICT 2@koradi 2                   | IntraState                | 21/10/2020   | 11.31        | 21/10/2020 | 13.16      | T           | 220KV Busbar Protection Operated.                                                                        |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                          |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.                                                                                             |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                                                                  |
| Kharghar-Borivali ckt II                          | IntraState                | 11/08/2020   | 01.45        |            | Continued. | T           | Special Repair Cable work.                                                                               |
| Theur-Phursungi                                   | IntraState                | 14/08/2020   | 09.46        |            | Continued. | HT          | Outage Arrangement HTLS Work.                                                                            |
| Theur- Magar Patta City                           | IntraState                | 14/08/2020   | 10.27        |            | Continued. | HT          | Outage Arrangement HTLS Work.                                                                            |
| Parli 3 (Old Gcr)-Girwali Ckt-3                   | IntraState                | 20/08/2020   | 13.05        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                                |
| Parli 3(Old Gcr)- Girwali Ckt 4                   | IntraState                | 20/08/2020   | 13.06        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                                |
| Kandalgaon - ONGC Panvel                          | IntraState                | 20/10/2020   | 17.41        | 21/10/2020 | 03.15      | T           | Distance Protection                                                                                      |
| Padgha - Temghar I                                | IntraState                | 20/10/2020   | 22.36        | 21/10/2020 | 02.12      | EO          | B PH CT Sparking.                                                                                        |
| Mahad - Pedambe                                   | IntraState                | 21/10/2020   | 00.23        | 21/10/2020 | 00.55      | T           | Distance Protection                                                                                      |
| Jejuri-Phursungi ckt-2                            | IntraState                | 21/10/2020   | 09.56        | 21/10/2020 | 16.23      | PO          | Replacement Of String At LOC No.83.                                                                      |
| Adlabs - Pedambe                                  | IntraState                | 21/10/2020   | 10.55        | 21/10/2020 | 18.24      | PO          | Replacement Of Flash over Polymer Insulator At LOC No. 500 Bottom Phase By Long rod Porcelain Insulator. |
| MALEGAON - KALWAN CKT-1                           | IntraState                | 21/10/2020   | 11.09        | 21/10/2020 | 15.26      | PO          | Quarterly Maintenance Work                                                                               |
| Kolhapur-Bidri                                    | IntraState                | 21/10/2020   | 11.10        | 21/10/2020 | 14.57      | PO          | For Replacement Of Jumper.                                                                               |
| Nadgaonpeth-Amravati                              | IntraState                | 21/10/2020   | 11.39        | 21/10/2020 | 17.40      | PO          | Routine Maintenance Work                                                                                 |
| Nagothane - ACCIL                                 | IntraState                | 21/10/2020   | 17.17        | 21/10/2020 | 17.47      | T           | Distance Protection                                                                                      |
| Kamba - Kolshet                                   | IntraState                | 21/10/2020   | 17.40        |            | Continued. | T           | Distance Protection                                                                                      |
| Aurangabad PG (Chitepimpalgaon)-Shedra I          | IntraState                | 21/10/2020   | 17.48        | 21/10/2020 | 22.44      | T           | Distance Protection                                                                                      |
| Trombay - Kalwa                                   | IntraState                | 21/10/2020   | 18.07        | 21/10/2020 | 23.14      | T           | Distance Protection                                                                                      |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 21/Oct/2020**

**Statement-VII**

Position as on 6.30 Hrs of 22/Oct/2020

| Name of Line                        | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage   |
|-------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|--------------------|
| <b>220 KV ICT Outages/Trippings</b> |                              |                 |                 |            |               |                |                    |
| 100MVA T/F NO.4@ Mulund             | IntraState                   | 21/10/2020      | 09.04           | 21/10/2020 | 18.05         | PO             | Attending Hot Spot |