

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/Nov/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	125.720	2975.342	1) Gujrat	-7.833	-174.847
2) Hydro	10.913	172.813	2) Madhya Pradesh	-0.422	-38.327
3) Gas	2.818	41.317	3) Chattisgarh	6.550	129.150
Total MSPGCL	139.451	3189.472	4) Maharashtra	168.927	3553.108
B) 1) APML	68.827	1371.742	5) Goa (Amona)	-1.479	-29.035
2) JSWEL	11.510	259.566	Total	165.743	3440.049
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.348	662.160
4) RPL(AMT)	26.600	558.481	b) Mumbai Drawl	31.546	753.015
5) SWPGPL	8.511	153.076	c) MSEDCL Bilateral *	69.143	1470.471
6) Other IPP	40.955	703.933	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.348	662.158
C) 1) TPCL Thermal	10.941	226.082	Include PX	0.000	0.000
2) TPCL Hydro	2.660	74.884	Standby	0.000	0.002
3) TPCL Gas	1.770	9.647	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.804	182.944	1) MSEDCL	445.186	9266.920
D) STATE			2) Mumbai Discoms	55.721	1246.572
1) Thermal	301.868	6431.166	3) Other Discoms	9.548	195.654
(A1+C1+C4+(B1-B6))			TOTAL STATE	510.455	10709.146
2) Hydro (A2+C2)	13.573	247.697			
3) Gas (A3+B7+C3)	4.588	50.964			
4) Wind	13.070	287.241			
6) SOLAR	11.613	252.029			
TOTAL STATE	344.712	7269.097			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5796	5355	5738	4297
MSPGCL Hydro	574	381	1669	125
MSPGCL Gas	92	98	138	99
MSPGCL Total Generation	6462	5834	7545	4521
Central Sector Receipt	8382	8433	6514	5778
WIND	284	131	299	1091
CPP / IPP Thermal	6774	6706	6958	5765
CPP / IPP Gas	0	0	0	0
SOLAR	1590	1707	1	0
Exchange with Mumbai	-1660	-1697	-1471	-924
MSEDCL DEMAND MET	21398	20674	19388	15921
Load Shedding	0	0	0	0
MSEDCL DEMAND	21398	20674	19388	15921
TPCL GENERATION	688	639	846	489
AEML GENERATION	491	489	373	282
MUMBAI DEMAND	2839	2825	2690	1695
OTHER DISCOM DEMAND	434	440	458	310
STATE DEMAND MET	24671	23939	22536	17926
STATE DEMAND	24671	23939	22536	17926
Frequency (Hz)	49.95	49.96	50.02	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 00.01 Hrs	49.79 Hz at 13.44 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 21/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.75	97.92	215	140
Unit 7	0.00	0.00	0	0
Unit 8	12.14	267.14	620	366
Unit 9	11.87	266.85	575	375
Unit 10	11.94	125.71	561	375
Total	40.70	757.63		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	172.62	0	0
Unit 5	9.02	196.49	435	280
Total	9.02	369.12		
Parli				
Unit 6	4.04	83.65	220	130
Unit 7	3.68	79.01	241	101
Unit 8	4.00	70.79	213	143
Total	11.72	233.45		
Chandrapur				
Unit 3	3.17	65.72	140	122
Unit 4	2.62	60.85	112	100
Unit 5	6.73	135.69	300	265
Unit 6	0.55	107.80	182	0
Unit 7	7.89	154.02	379	294
Unit 8	9.01	202.28	473	284
Unit 9	0.00	167.33	0	0
Total	29.96	893.69		
Paras				
Unit 3	5.10	102.58	239	139
Unit 4	2.92	47.73	241	0
Total	8.02	150.32		
Khaparkheda				
Unit 1	2.67	56.40	125	100
Unit 2	2.76	56.80	140	90
Unit 3	3.70	66.46	180	126
Unit 4	3.20	71.68	149	125
Unit 5	7.86	198.80	395	270
Total	20.19	450.14		
Nasik				
Unit 3	2.99	4.38	140	88
Unit 4	3.12	57.62	151	113
Unit 5	0.00	58.99	0	0
Total	6.11	121.00		
Uran				
All Units	2.82	41.32	194	92
Total	2.82	41.32		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	11.44	26	0
Total	0.07	11.44		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.30	47.54	465	40
Stage 4	3.11	39.39	737	0
Stage 3	1.72	19.29	240	0
Total	8.13	106.22		
Hydro				
KDPH	0.43	7.22	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.46	4.94	58	0
BHIRA T.R.	0.14	3.95	40	0
SMLHY_PTN	1.42	33.74	65	53
GHATGHAR	0.26	5.32	125	0
Total	2.71	55.16		
Wind				
Total	13.07	287.24	0	0
Total	13.07	287.24		
CPP				
APML(Mus)	68.83	1371.74	0	0
JSWEL(Mus)	11.51	259.57	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.60	558.48	0	0
SWPGPL-Mus	8.51	153.08	0	0
Other(Mus)	40.96	703.93	0	0
Total	156.40	3046.80		
SOLAR				
Total	11.61	252.03	0	0
Total	11.61	252.03		
Tata				
Trombay 5	7.45	153.30	392	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.95	5.71	42	39
Trombay 7B	0.82	3.93	37	33
TATA Hydro	2.66	74.88	328	13
Trombay 8	3.49	72.79	171	131
Total	15.37	310.61		
AEML				
DTPS U-1&2	8.80	182.94	497	281
Total	8.80	182.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	125.72	2975.34	MSPGCL Total	139.45	3189.47
			MSPGCL Thml+Gas	128.54	3016.66	Koyna 1,2 & 4 Total	6.41	86.93
			MSPGCL Hydro	10.91	172.81	State Total	344.71	7269.10

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 21/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4188	123	97	4408	1234	5581	0	0	6293	6257	-1070	16069	0	16069	1877	341	18287	50.06
2	4271	173	98	4542	1127	5301	0	0	5868	6274	-995	15916	0	15916	1771	333	18020	50.03
3	4297	125	99	4521	1091	5765	0	0	5764	5778	-924	15921	0	15921	1695	310	17926	50.04
4	4325	116	98	4539	1023	6009	0	0	5742	5825	-866	16233	0	16233	1642	297	18172	50.01
5	4494	116	98	4708	923	6308	0	0	5870	6271	-858	17032	0	17032	1647	320	18999	50.01
6	4985	116	99	5200	813	6718	0	0	6226	6435	-985	17811	0	17811	1777	370	19958	50.01
7	5305	352	98	5755	727	6998	0	14	6661	6856	-1101	18880	0	18880	1936	369	21185	49.99
8	5680	1025	99	6804	637	6762	0	287	6801	7139	-1220	20022	0	20022	2100	387	22509	49.98
9	5713	772	97	6582	379	6742	0	834	7300	7404	-1388	20150	0	20150	2374	403	22927	49.97
10	5759	513	104	6376	339	6766	0	1250	7672	7774	-1496	20589	0	20589	2679	420	23688	49.94
11	5796	574	92	6462	284	6774	0	1590	8198	8382	-1660	21398	0	21398	2839	434	24671	49.95
12	5756	362	95	6213	157	6772	0	1732	8472	8164	-1721	20877	0	20877	2879	440	24196	49.98
13	5355	381	98	5834	131	6706	0	1707	8256	8433	-1697	20674	0	20674	2825	440	23939	49.96
14	5501	426	110	6037	130	6746	0	1581	7733	7775	-1591	20274	0	20274	2717	404	23395	49.93
15	5509	274	125	5908	118	6717	0	1281	8402	8313	-1543	20386	0	20386	2732	408	23526	49.94
16	5542	225	135	5902	114	6733	0	880	8308	8388	-1485	20110	0	20110	2764	422	23296	50.02
17	5638	726	134	6498	123	6811	0	410	7246	7482	-1405	19485	0	19485	2756	434	22675	50.01
18	5692	1391	137	7220	180	7017	0	46	6298	6648	-1435	19226	0	19226	2669	450	22345	50.01
19	5738	1669	138	7545	299	6958	0	1	6295	6514	-1471	19388	0	19388	2690	458	22536	50.02
20	5741	481	139	6361	469	6720	0	0	7017	6585	-1442	18246	0	18246	2547	447	21240	50.02
21	5629	314	142	6085	567	6749	0	0	6273	5742	-1426	17274	0	17274	2400	443	20117	49.98
22	5188	278	142	5608	511	6483	0	0	5887	5733	-1347	16558	0	16558	2263	430	19251	49.97
23	4751	213	150	5114	795	6098	0	0	5839	5991	-1240	16347	0	16347	2130	411	18888	49.92
24	4867	168	194	5229	899	6169	0	0	5758	5580	-1180	16320	0	16320	2012	377	18709	49.96
MUs	125.72	10.91	2.82	139.45	13.07	156.40	0.00	11.61	164.18	165.74	-31.55	445.19	0.00	445.19	55.72	9.55	510.45	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 21/Nov/2022

Position as on 6.30 Hrs of 22/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
CENT.SECTOR	Tarapur 3	540	07/11/2022	02:00		Continued.	For maintenance on reactor side	22/11/2022
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.	23/11/2022
MSPGCL	Chandrapur Unit 6	500	16/11/2022	14:06	21/11/2022	20:22	ID Fan Problem	21/11/2022
MSPGCL	Chandrapur Unit 9	500	18/11/2022	21:28		Continued.	withdrawn due to LPBP warm line leakage	22/11/2022
MSPGCL	Koyna STG-IV Unit-3	250	19/11/2022	09:25		Continued.	Trunnion Seal repair work.	22/11/2022
MSPGCL	Paras Unit 4	250	19/11/2022	10:57	21/11/2022	09:30	Boiler Tube Leakage	22/11/2022
MSPGCL	Bhusawal Unit 4	500	19/11/2022	18:31	22/11/2022	07:35	Boiler Tube Leakage	22/11/2022
MSPGCL	Nasik Unit 5	210	19/11/2022	23:20		Continued.	Boiler Tube Leakage	24/11/2022
MSPGCL	Uran Unit 6	108	20/11/2022	18:32	21/11/2022	09:20	Gas shortage	
MSPGCL	Uran Unit B0	120	20/11/2022	19:06	21/11/2022	13:25	boiler protection. Synchronised	
IPP	RPL(AMT) U-4	270	21/11/2022	06:59		Continued.	Ash Evacuation problem.	23/11/2022
MSPGCL	Uran Unit 6	108	21/11/2022	13:29	21/11/2022	22:46	Gas shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 21/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 22/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Tripping							
TIE BAY - 702 OF EKTUNI-AKOLA II ckt-2 @ EKTUNI	IntraState	21/11/2022	10:48	21/11/2022	17:19	PO	Diagnostic Testing of CB & Routine Maintenance
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	18/11/2022	00:36			PO	For Pole 1 Scheduled Annual Outage and Pole1 Y Phase Converter Transformer replacement work.
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (407) OF STATION TF - 2 @ KORADI - 2	IntraState	21/11/2022	09:59	21/11/2022	17:38	PO	Diagnostic Testing of CT & CB and routine bay maintenance work
400 KV LINE Outages/Tripping							
PADGHE - BOISAR (PG)	InterState	21/11/2022	15:58	22/11/2022	00:13	T	Tripped on distance protection
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KARAD - TALANDGE CKT - 1	IntraState	15/11/2022	17:03	21/11/2022	17:01	PO	Overhauling of A bus, B Bus PG isolators.
PADGHE - PADGHE HVDC CKT- 1	IntraState	18/11/2022	00:36			PO	1) Bay Maint work 2) Diagnostic Testing work 3)A Bus :- PG Isolator replacement of 400kV HVDC-I Y&B-ph ₂ 4) Bhel CB Pole Overhauling work. If pole overhauling not completed within outage period line will be charge on TBC.
LONIKAND I - KOYNA STAGE-IV	IntraState	19/11/2022	18:23			EO	For shifting 400kV Lonikand-Stage IV line on 400kV TBC due to hotspot on 29 B Isolator B phase on hanger rod assembly
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	20/11/2022	12:16	21/11/2022	07:59	PO	For replacement of faulty disc insulators by LRP strings
JAIGAD - KARAD CKT - 2	IntraState	20/11/2022	20:20	21/11/2022	09:47	HT	H/T FOR O/V
LONIKAND I - KOYNA STAGE-IV	IntraState	20/11/2022	22:05	21/11/2022	08:02	HT	For controlling overvoltage
PADGHE - NAGOTHANE CKT - 1	IntraState	21/11/2022	03:30	21/11/2022	08:14	HT	To control Overvoltage
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	21/11/2022	08:29	21/11/2022	18:12	PO	1) String Disc Replacement Work 2) Maintenance Work
BUS - 2 @ NEW KOYNA	IntraState	21/11/2022	12:51			PO	1) 21/11/2022 to 22/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 23/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 3) 24/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 25/11/2022 Bus Insulator replacement work at section Koyna - I & II and damage conductor replacement work 5) 26/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 27/11/2022 to 28/11/2022 Bus Insulator replacement work at section Jaigad - I & II
JAIGAD - KARAD CKT - 1	IntraState	21/11/2022	21:55			HT	H/T FOR O/V
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	22/11/2022	06:18			PO	1) String Disc Replacement Work 2) Maintenance Work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 22/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV ICT Outages/Trippings							
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	21/11/2022	07:25	21/11/2022	13:23	PO	Erection of 400 kV bushing & testing of ICT-I unit after internal inspection is required for internal inspection of ICT-I R ph unit & taking R ph unit in service & spare ICT-I unit is to be taken out from RRS & kept on humming.
400/220 KV 167 MVA ICT @ PARLI	IntraState	21/11/2022	08:47	21/11/2022	15:01	PO	(1) C & Tan delta measurement of ICT unit & CT. (2) Bay maintenance work.
400/220/33 KV 315MVA ICT - 3 @ KHADKA	IntraState	21/11/2022	09:10	21/11/2022	18:22	PO	For quarterly ICT & bay maintenance work
400/11kV STN-4A @ DEEPNAGAR	IntraState	21/11/2022	12:15	21/11/2022	19:46	EO	Emergency outage required on 400/21.75 KV 80 MVA Station Transformer 4A for attending oil leakage and oil top up work at MAHAGENCO Premises.
220 KV LINE Outages/Trippings							
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no. SS 82 to facilitate the following project work: DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no. SS 82 to facilitate the following project work: DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
EKLAHARE (OCR) - PADGHE	IntraState	20/11/2022	07:42			HT	for load management
MIRAJ - ICHALKARANJI	IntraState	21/11/2022	09:02	21/11/2022	18:50	HT	Load management
TALANDGE - ICHALKARANJI 1	IntraState	21/11/2022	09:14	21/11/2022	14:24	PO	For Cleaning of Insulator strings by using high voltage insulator cleaner & protector (Chemical Cleaning)
TALANDGE - ICHALKARANJI 1	IntraState	21/11/2022	09:14	21/11/2022	14:24	PO	1) Quarterly bay maintenance work at 220 kV Tilawani end. 2) Faulty String insulator discs replacement work.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	21/11/2022	09:28	21/11/2022	21:02	HT	Load management
TALANDAGE - FIVE STAR MIDC 1	IntraState	21/11/2022	12:22	21/11/2022	19:08	PO	For STN string replacement at loc. no. Guid tower (B ph) & at loc no. 9 (R ph) as per PID report.
TALANDGE - ICHALKARANJI 2	IntraState	21/11/2022	14:44	21/11/2022	18:47	PO	1) For Quarterly bay maintenance work. 2) Faulty string insulator disc replacement work
TALANDGE - ICHALKARANJI 2	IntraState	21/11/2022	14:44	21/11/2022	18:47	PO	For cleaning of insulator strings by using high voltage insulator cleaner & protector (Chemical Cleaning)
SADAWAGHAPUR KARAD CKT 2	IntraState	21/11/2022	21:20			T	Tripped on distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 22/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/33KV 50MVA BBL T/F @ OGLEWADI	IntraState	21/11/2022	09:59	21/11/2022	19:06	PO	1.Diagnostic testing Work 2.Quarterly Maintenance Work 3.Oil leakage attending work
220/132 KV 200 MVA ICT 2 @ BOISAR-II	IntraState	21/11/2022	10:07	21/11/2022	16:41	EO	Hot spot attending (Hotline work) on 220kV B-Bus jumper of ICT-2 bay. 1. Rph, 220kV B-Bus to Isolator jumper crimping at Isolator end. (69.2OC, Image.IR001410).
220/33KV 100MVA PTR 2 @ 5 STAR MIDC, KAGAL	IntraState	21/11/2022	10:35	21/11/2022	14:50	PO	For diagnostic testing and quarterly maintenance work on dt. 21.11.2022
220/33 KV 50 MVA PTR NO 1 @ BHIGWAN	IntraState	21/11/2022	13:30	21/11/2022	15:20	PO	To top up oil in main tank of TF
110 KV LINE Outages/Trippings							
KHOPOLI - BHIVPURI CKT - 2	IntraState	21/11/2022	10:33	21/11/2022	14:28	PO	R/M & Protection testing at Khopoli

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage