

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/Nov/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	169.211	3509.360	1) Gujrat	3.820	68.980
2) Hydro	6.496	151.562	2) Madhya Pradesh	3.106	90.273
3) Gas	6.864	121.164	3) Chattisgarh	6.730	162.730
Total MSPGCL	182.571	3782.086	4) Maharashtra	210.765	4273.702
B) 1) APMIL	37.146	955.898	5) Goa (Amona)	-1.848	-32.548
2) JSWEL	23.878	507.953	Total	222.573	4563.137
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.613	806.691
4) RPL(AMT)	25.365	512.220	b) Mumbai Drawl	44.373	868.888
5) SWPGPL	10.482	223.696	c) MSEDCL Bilateral *	102.761	2020.572
6) Other IPP	32.659	521.641	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.613	806.674
C) 1) TPCL Thermal	11.526	244.177	Include PX	0.000	0.000
2) TPCL Hydro	3.397	54.722	Standby	0.000	0.017
3) TPCL Gas	2.244	48.035	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.136	159.124	1) MSEDCL	507.836	10448.042
D) STATE			2) Mumbai Discoms	67.676	1374.926
1) Thermal	316.403	6634.069	3) Other Discoms	10.529	218.464
(A1+C1+C4+(B1-B6))			TOTAL STATE	586.041	12041.432
2) Hydro (A2+C2)	9.893	206.284			
3) Gas (A3+B7+C3)	9.108	169.199			
4) Wind	13.318	192.611			
6) SOLAR	14.746	276.152			
TOTAL STATE	363.468	7478.315			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	7220	6836	7319	6803
MSPGCL Hydro	533	230	849	106
MSPGCL Gas	282	278	284	293
MSPGCL Total Generation	8035	7344	8452	7202
Central Sector Receipt	10811	10520	8524	7565
WIND	645	481	383	839
CPP / IPP Thermal	5213	4739	6604	5477
CPP / IPP Gas	0	0	0	0
SOLAR	2001	2164	0	0
Exchange with Mumbai	-2319	-2231	-1524	-1824
MSEDCL DEMAND MET	23911	22575	21952	18816
Load Shedding	0	0	0	0
MSEDCL DEMAND	23911	22575	21952	18816
TPCL GENERATION	711	809	1260	592
AEML GENERATION	225	240	451	305
MUMBAI DEMAND	3255	3280	3235	2721
OTHER DISCOM DEMAND	475	441	487	443
STATE DEMAND MET	27641	26297	25674	21980
STATE DEMAND	27641	26297	25674	21980
Frequency (Hz)	49.99	49.89	49.99	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 16:02 Hrs	49.69 Hz at 09:15 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 21/Nov/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.28	85.50	185	170
Unit 8	14.79	238.54	631	600
Unit 9	12.86	219.92	622	152
Unit 10	14.17	293.33	603	570
Total	46.10	837.30		
Bhusawal				
Unit 3	3.50	4.90	170	125
Unit 4	10.72	187.27	470	355
Unit 5	10.54	206.80	480	390
Total	24.76	398.98		
Parli				
Unit 6	4.22	97.84	249	143
Unit 7	4.16	85.80	227	144
Unit 8	4.49	106.16	247	147
Total	12.87	289.79		
Chandrapur				
Unit 3	0.58	68.75	150	0
Unit 4	0.05	71.19	53	0
Unit 5	10.28	217.34	460	400
Unit 6	8.08	170.46	355	305
Unit 7	7.38	160.30	325	264
Unit 8	11.06	227.28	490	443
Unit 9	11.42	233.42	482	463
Total	48.86	1148.76		
Paras				
Unit 3	5.66	114.43	245	224
Unit 4	5.19	113.78	234	158
Total	10.85	228.21		
Khaparkheda				
Unit 1	3.50	73.00	170	115
Unit 2	1.98	47.70	122	61
Unit 3	1.78	76.80	162	0
Unit 4	4.38	58.47	186	176
Unit 5	10.08	197.94	450	390
Total	21.71	453.91		
Nasik				
Unit 3	1.43	64.33	138	0
Unit 4	0.00	53.00	0	0
Unit 5	2.64	35.10	145	0
Total	4.06	152.42		
Uran				
All Units	6.86	121.16	296	272
Total	6.86	121.16		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.32	13.76	47	0
Total	0.32	13.76		
Koyna				
Stage 1-2	1.74	40.94	250	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.84	17.55	250	0
Stage 3	0.56	13.94	240	0
Total	3.14	72.43		
Hydro				
KDPH	0.00	6.08	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	2.54	0	0
SMLHY_PTN	1.63	52.49	76	59
GHATGHAR	1.41	4.27	125	0
Total	3.04	65.37		
Wind				
Total	13.32	192.61	0	0
Total	13.32	192.61		
CPP				
APML(Mus)	37.15	955.90	0	0
JSWEL(Mus)	23.88	507.95	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.36	512.22	0	0
SWPGPL-Mus	10.48	223.70	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.41	110.26	267	202
Other(Mus)	27.25	406.57	0	0
JPL	0.00	4.81	0	0
Total	129.53	2721.41		
SOLAR				
Total	14.75	276.15	0	0
Total	14.75	276.15		
Tata				
Trombay 5	7.68	160.14	451	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.25	27.37	108	39
Trombay 7B	1.00	20.67	65	36
TATA Hydro	3.40	54.72	423	62
Trombay 8	3.85	84.04	231	132
Total	17.17	346.93		
AEML				
DTPS U-1&2	6.14	159.12	452	150
Total	6.14	159.12		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	169.21	3509.36	MSPGCL Total	182.57	3782.09
			MSPGCL Thml+Gas	176.08	3630.52	Koyna 1,2 & 4 Total	2.58	58.49
			MSPGCL Hydro	6.50	151.56	State Total	363.47	7478.32

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 21/Nov/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6737	116	291	7144	551	4960	0	0	8895	8887	-1799	19346	0	0	19346	2583	397	22326	49.99
2	6869	114	294	7277	607	5194	0	0	8672	8646	-1697	19668	0	0	19668	2398	358	22425	50.01
3	6979	114	295	7388	532	4990	0	0	8539	8648	-1568	19648	0	0	19648	2254	342	22244	50.01
4	7047	114	294	7455	566	4892	0	0	8515	8654	-1461	19766	0	0	19766	2165	340	22271	50.02
5	7057	120	296	7473	606	5096	0	0	8789	8877	-1418	20286	0	0	20286	2124	348	22758	50.04
6	7125	114	296	7535	631	5217	0	0	9508	9313	-1480	20839	0	0	20839	2178	376	23394	50.00
7	7127	265	294	7686	600	5112	0	24	9723	9768	-1535	21234	0	4	21234	2274	421	23929	49.92
8	7382	166	292	7840	638	5583	0	367	9534	9536	-1713	21803	0	7	21803	2441	448	24692	49.99
9	7393	161	288	7842	531	5540	0	1000	10240	10006	-1982	22464	0	21	22464	2754	473	25691	50.00
10	7301	271	284	7856	596	5396	0	1596	10837	10845	-2211	23590	0	15	23590	3041	489	27119	49.89
11	7220	533	282	8035	645	5213	0	2001	11248	10811	-2319	23911	0	50	23911	3255	475	27641	49.99
12	7064	305	277	7646	603	4882	0	2162	10837	10895	-2342	23371	0	91	23371	3323	476	27169	50.06
13	6836	230	278	7344	481	4739	0	2164	10597	10520	-2231	22575	0	187	22575	3280	441	26297	49.89
14	6613	235	277	7125	407	4721	0	2029	10479	10352	-2219	21954	0	44	21954	3166	460	25581	49.97
15	6858	225	272	7355	373	4891	0	1711	10823	10761	-2156	22474	0	12	22474	3233	461	26168	50.00
16	6821	329	272	7422	308	5092	0	1165	10906	10862	-2222	22151	0	1	22151	3286	476	25913	49.99
17	7067	497	276	7840	263	5711	0	466	9739	9559	-1963	21388	0	0	21388	3252	488	25128	49.98
18	7275	814	276	8365	272	6363	0	61	8345	8326	-1510	21394	0	0	21394	3218	483	25095	49.92
19	7319	849	284	8452	383	6604	0	0	8442	8524	-1524	21952	0	0	21952	3235	487	25674	49.99
20	7298	399	286	7983	483	6499	0	0	8452	8273	-1749	21010	0	0	21010	3092	478	24581	49.97
21	7124	207	288	7619	636	6157	0	0	7755	7477	-1808	19601	0	0	19601	2926	480	23007	50.02
22	6916	106	286	7308	900	5691	0	0	7964	7681	-1854	19269	0	0	19269	2791	457	22517	50.02
23	6803	106	293	7202	839	5477	0	0	7662	7565	-1824	18816	0	0	18816	2721	443	21980	49.96
24	6980	106	293	7379	867	5512	0	0	7467	7787	-1788	19325	0	0	19325	2686	432	22443	49.95
MUs	169.21	6.50	6.86	182.57	13.32	129.53	0.00	14.75	223.97	222.57	-44.37	507.84	0.00	0.43	507.84	67.68	10.53	586.04	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out due to overloading of 220KV BBLR -1&2 and 132KV Satana-Dindori line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 21/Nov/2023

Position as on 6.30 Hrs of 22/Nov/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Nasik Unit 4	210	19/11/2023	15:48		Continued.	Stator Earth Fault (Converted into AOH from 00:00 hrs dt.20/11/2023)	12/12/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	23/11/2023
IPP	JPL Unit 1	150	03/11/2023	00:01		Continued.	Under shutdown condition Due to low net sales Realization cost.	23/11/2023
IPP	Adani U-1	660	12/11/2023	14:11	21/11/2023	14:32	Zero Schedule	
IPP	Adani U-5	660	16/11/2023	23:16		Continued.	Zero Schedule	
AEML	AEML Unit 1	250	20/11/2023	18:56	21/11/2023	16:11	Leakage at boiler high pressure drain valve.	21/11/2023
MSPGCL	Chandrapur Unit 4	210	21/11/2023	00:23		Continued.	HP TURBINE CONTROL VALVE PROBLEM	23/11/2023
MSPGCL	Chandrapur Unit 3	210	21/11/2023	03:55		Continued.	DRUM LEVEL HIGH	22/11/2023
MSPGCL	Nasik Unit 3	210	21/11/2023	10:45		Continued.	Economizer Tube Leakage.	23/11/2023
MSPGCL	Khaparkheda Unit 3	210	21/11/2023	11:57		Continued.	Air heater problem	23/11/2023
MSPGCL	Nasik Unit 5	210	21/11/2023	12:45	21/11/2023	14:44	Furnace Pressure High	
IPP	JSW (J) U1	300	22/11/2023	09:54		Continued.	CW Pump Discharge pipe heavy leakage.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 21/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 22/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
408 TIE BAY OF EKTUNI CKT 1 AND BUS REACTOR	InterState	20/11/2023	13:04			PO	CB mechanism overhauling work by M/s CGL service engineer.
400 KV MAINBAY Outages/Trippings							
400/11.5 KV 110MVA STN T/F 6A @ DEEPNAGAR	InterState	09/11/2023	15:36			PO	For alignment work of 89L isolator of Station Transformer 6A
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
KORADI - BHILAI	InterState	21/11/2023	13:40	21/11/2023	16:10	T	Tripped on distance protection
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\epsilon Y \epsilon$ phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/11/2023	09:06			HT	For managing over load on 400 kv PUNEGIS- TALEGAONPG line .
KHADKA-AURANGABAD (WALUJ)	IntraState	20/11/2023	22:54	21/11/2023	06:40	HT	HT due to Overvoltage
JAIGAD - KARAD CKT - 1	IntraState	21/11/2023	03:29	21/11/2023	09:54	HT	HT due to Overvoltage
NAGOTHANE - DABHOL CKT - 1	IntraState	21/11/2023	08:30	21/11/2023	18:46	PO	Cold washing & Earthwire replcement
JAIGAD - KARAD CKT - 1	IntraState	21/11/2023	12:05	21/11/2023	19:38	PO	Quarterly maintenance work.
JAIGAD - KARAD CKT - 1	IntraState	21/11/2023	19:38			HT	For voltage management
NAGOTHANE - DABHOL CKT - 2	IntraState	22/11/2023	00:54	22/11/2023	03:58	HT	Emergency outage to attend hotspot on R-ph CT
NAGOTHANE - DABHOL CKT - 2	IntraState	22/11/2023	04:48			HT	Emergency outage to attend oil leakage in R-ph CT bolt
JAIGAD - KARAD CKT - 2	IntraState	22/11/2023	14:28			PO	Quarterly maintenance work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	28/10/2023	22:20			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	28/10/2023	22:27			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	28/10/2023	22:32			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
105 MVA SPARE ICT @ AKOLA	IntraState	21/11/2023	09:23	21/11/2023	17:25	PO	DCRM, Tandelta for CT & routine maintenance work
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	22/11/2023	10:44			PO	(1) REF & NDR relays testing work. (2) Bay maintenance work.
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ NEW KOYNA	IntraState	20/11/2023	12:42			PO	Black Start Mockdrill of Koyana HPS.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 22/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TBC @ BABHLESHWAR	IntraState	21/11/2023	11:35	21/11/2023	15:50	PO	CB ,DCRM and Timing CT Tan Delta
220 KV LINE Outages/Trippings							
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	26/10/2023	20:16	21/11/2023	13:27	HT	Charged from Navsary end only
OSMANABAD - PARLY (PG)	IntraState	16/11/2023	12:23	21/11/2023	16:18	PO	For HTLS Reconductoring works of 400kV Parli-Parli(M) line-Ckt#2
EKLAHARE (OCR) - PADGHE	IntraState	20/11/2023	17:31			HT	HT for load management from Padghe end
THEUR-PHURSUNGI CKT I	IntraState	21/11/2023	09:50	21/11/2023	17:06		Bay Diagnostic testing and half yearly maintenance work
VSNL - STT GIS CKT - 1	IntraState	21/11/2023	10:15	21/11/2023	15:52	PO	Testing Work at both SS
220 KV SICOM - CFP CKT - 2	IntraState	21/11/2023	10:56	21/11/2023	16:22	PO	Routine Maintenance work
220 KV GIRWALI (400 KV) -MURUD CKT	IntraState	21/11/2023	11:06	21/11/2023	17:13	PO	Reconductoring work
GHATGHAR - BAPGAON	IntraState	21/11/2023	13:28	21/11/2023	20:48	HT	To reduce emergency load sheddind in Nashik region. Line handtripped at Bapgaon end only.
GHATGHAR - JINDAL	IntraState	21/11/2023	13:37	21/11/2023	22:09	HT	To reduce emergency load sheddind in Nashik region. Line handtripped at Jindal end only.
VITA - MIRAJ	IntraState	21/11/2023	15:41	21/11/2023	22:56	PO	Cold Washing of Insulator
MAIN BUS - 2 @ GORAI	IntraState	22/11/2023	09:38			PO	Preventive Maintenance of Main Bus-2 & Bus-2 side Isolators
VSNL - STT GIS CKT - 2	IntraState	22/11/2023	10:15			PO	Testing Work at Both Sstn
MALINAGAR - TEMBHURNI	IntraState	22/11/2023	10:50			PO	Outage is required for Quarterly Maintenance
MAIN BUS @ TEMBHURNI	IntraState	22/11/2023	10:50			PO	Outage is required for Quarterly Maintenance
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
250 MVA ICT-4 @ TROMBAY	IntraState	18/11/2023	09:05			PO	1.Transformer complete gasket replacement (except bell tank) 2.Transformer complete oil filtration post gasket replacement 3.Cooler cabinet replacement 4.Radiator replacement at Trombay Generating Station.
220/132-110KV 100MVA PTR 2 @ WATHAR	IntraState	21/11/2023	09:54	21/11/2023	16:55	PO	Diagonstic testing work by TCC Team
220/22 KV 50 MVA PTR 2 @ PADGHE	IntraState	21/11/2023	10:17			PO	For chargingof 22kV GIS s/s at 100/22kV s/s Padghe
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	21/11/2023	10:35	21/11/2023	15:50	PO	Diagnostic testing of ICT 01 by Mobile testing unit, Pune
220/132 KV 200 MVA ICT 3	IntraState	21/11/2023	11:13	21/11/2023	16:48	PO	Tan Delta testing work
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	21/11/2023	16:02	21/11/2023	18:05	PO	Diagnostic testing of ICT 02 by mobile testing unit Pune
220/33 KV 50 MVA PTR 1 @ BABHLESHWAR	IntraState	21/11/2023	18:08	21/11/2023	18:45	PO	To Attend Hot spot Y phase HV bushings and hotspot at LV Y ph Bus Isolator.
220/132 KV 100 MVA ICT 2 @ BELWANDI	IntraState	22/11/2023	10:10	22/11/2023	14:57	PO	For NIFPS-AMC, Winding and Bushing TanD, CT TanD tests to be done

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 22/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	22/11/2023	10:42				1. Diagnostic testing work of CT, CB, T/F 2. Bay maintenance work 3. Attending hotspot (If any)
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage