

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 21/Dec/2021 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	153.441	2836.945	1) Gujrat	-10.300	-146.312
2) Hydro	10.103	155.587	2) Madhya Pradesh	2.452	25.211
3) Gas	5.765	99.310	3) Chattisgarh	6.240	121.910
Total MSPGCL	169.309	3091.842	4) Maharashtra	135.675	2829.413
B) 1) APLM	63.871	1251.194	5) Goa (Amona)	-1.592	-35.433
2) JSWEL	14.093	297.149	Total	132.475	2794.789
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.171	521.304
4) RPL(AMT)	26.630	544.131	b) Mumbai Drawl	26.823	562.576
5) SWPGPL	8.032	162.632	c) MSEDCL Bilateral *	53.005	1033.482
6) Other IPP	39.806	780.320	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.171	521.304
C) 1) TPCL Thermal	7.529	169.388	Include PX	0.000	1.590
2) TPCL Hydro	4.744	89.739	Standby	0.000	0.000
3) TPCL Gas	2.422	63.619	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.471	202.948	1) MSEDCL	427.913	8466.042
D) STATE			2) Mumbai Discoms	50.989	1088.267
1) Thermal	322.873	6244.707	3) Other Discoms	9.716	204.991
(A1+C1+C4+(B1-B6))			TOTAL STATE	488.618	9759.300
2) Hydro	14.847	245.326			
(A2+C2)					
3) Gas	8.187	162.929			
(A3+B7+C3)					
4) Wind	2.796	189.185			
6) SOLAR	7.440	122.367			
TOTAL STATE	356.143	6964.514			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	7076	6677	6898	5074
MSPGCL Hydro	901	501	453	223
MSPGCL Gas	234	239	236	239
MSPGCL Total Generation	8211	7417	7587	5536
Central Sector Receipt	6837	7103	5688	5030
WIND	64	64	80	60
CPP / IPP Thermal	7048	6306	6993	5591
CPP / IPP Gas	0	0	0	0
SOLAR	983	1130	0	0
Exchange with Mumbai	-1368	-1560	-1059	-1099
MSEDCL DEMAND MET	15219	13990	12105	9207
Load Shedding	0	0	0	0
MSEDCL DEMAND	15219	13990	12105	9207
TPCL GENERATION	730	656	980	404
AEML GENERATION	486	388	501	351
MUMBAI DEMAND	2584	2604	2540	1854
OTHER DISCOM DEMAND	364	359	399	328
STATE DEMAND MET	24359	23064	21829	16972
STATE DEMAND	24359	23064	21829	16972
Frequency (Hz)	50.03	50.02	49.94	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 13:03 Hrs	49.78 Hz at 07:27 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 21/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.66	75.38	190	115
Unit 7	0.00	0.00	0	0
Unit 8	14.74	286.90	660	420
Unit 9	14.44	152.67	660	415
Unit 10	13.04	274.01	590	395
Total	45.89	788.96		
Bhusawal				
Unit 3	3.14	39.68	170	115
Unit 4	9.04	181.62	460	280
Unit 5	9.42	181.46	475	280
Total	21.60	402.75		
Parli				
Unit 6	4.27	29.78	234	156
Unit 7	4.12	13.83	216	134
Unit 8	4.19	65.69	214	151
Total	12.58	109.30		
Chandrapur				
Unit 3	3.80	42.96	179	121
Unit 4	3.67	65.21	172	123
Unit 5	8.43	107.24	385	300
Unit 6	8.92	157.45	430	277
Unit 7	6.74	162.86	332	235
Unit 8	8.94	191.65	416	285
Unit 9	9.16	193.36	430	280
Total	49.67	920.74		
Paras				
Unit 3	4.39	89.71	230	135
Unit 4	4.24	91.64	219	143
Total	8.63	181.35		
Khaparkheda				
Unit 1	0.00	24.87	0	0
Unit 2	0.00	25.46	0	0
Unit 3	0.00	27.06	0	0
Unit 4	0.00	20.47	0	0
Unit 5	8.96	199.96	445	284
Total	8.96	297.82		
Nasik				
Unit 3	3.11	34.36	180	118
Unit 4	0.00	33.17	0	0
Unit 5	3.02	68.49	172	115
Total	6.12	136.03		
Uran				
All Units	5.76	99.31	255	226
Total	5.76	99.31		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.26	3.09	47	0
Total	0.26	3.09		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.91	47.38	275	35
Stage 4	1.89	17.34	501	0
Stage 3	1.07	15.14	80	0
Total	4.87	79.86		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.06	0	0
TILLARI	0.41	6.53	58	0
BHIRA T.R.	0.20	5.33	77	0
SMLHY_PTN	4.63	63.80	206	173
GHATGHAR	0.00	0.00	0	0
Total	5.23	75.72		
Wind				
Total	2.80	189.18	0	0
Total	2.80	189.18		
CPP				
APML(Mus)	63.87	1251.19	0	0
JSWEL(Mus)	14.09	297.15	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.63	544.13	0	0
SWPGPL-Mus	8.03	162.63	0	0
Other(Mus)	39.81	780.32	0	0
Total	152.43	3035.43		
SOLAR				
Total	7.44	122.37	0	0
Total	7.44	122.37		
Tata				
Trombay 5	7.53	147.59	456	250
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.36	38.00	88	49
Trombay 7B	1.07	25.62	58	40
Trombay 8	0.00	21.80	0	0
TATA Hydro	4.74	89.74	434	0
Total	14.70	322.75		
AEML				
DTPS U-1&2	9.47	202.95	501	331
Total	9.47	202.95		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	153.44	2836.94	MSPGCL Total	169.31	3091.84
			MSPGCL Thml+Gas	159.21	2936.26	Koyna 1,2 & 4 Total	3.80	64.72
			MSPGCL Hydro	10.10	155.59	State Total	356.14	6964.51

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 21/Dec/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5091	242	242	5575	122	5712	0	0	5060	4815	-937	14984	0	14984	1702	303	16989	49.95
2	5012	217	242	5471	117	5698	0	0	5058	4973	-850	15115	0	15115	1595	294	17004	49.94
3	5318	223	253	5794	177	5721	0	0	5041	4623	-788	15257	0	15257	1516	270	17043	49.92
4	5524	224	243	5991	176	5705	0	0	5006	4631	-737	15497	0	15497	1473	269	17239	49.96
5	5855	217	255	6327	252	5673	0	0	5016	4698	-754	15924	0	15924	1473	272	17669	50.01
6	6360	230	243	6833	230	6062	0	0	5297	5158	-844	17146	0	17146	1559	293	18998	49.99
7	6798	243	242	7283	250	6460	0	2	5296	5172	-771	18086	0	18086	1691	310	20087	49.94
8	7125	647	251	8023	206	6662	0	109	5323	5114	-860	18918	0	18918	1886	336	21140	49.90
9	7237	1094	241	8572	155	7199	0	430	5697	4962	-1061	19899	0	19899	2169	358	22426	50.01
10	6926	835	247	8008	117	6800	0	747	6598	6490	-1281	20505	0	20505	2423	376	23304	50.02
11	7076	901	234	8211	64	7048	0	983	6722	6837	-1368	21411	0	21411	2584	364	24359	50.03
12	6953	659	233	7845	84	6941	0	1092	6959	6661	-1405	20845	0	20845	2625	373	23843	50.01
13	6677	501	239	7417	64	6306	0	1130	7157	7103	-1560	20101	0	20101	2604	359	23064	50.02
14	6713	382	228	7323	59	6161	0	1034	7069	6727	-1519	19432	0	19432	2468	353	22253	50.04
15	6833	384	227	7444	54	6224	0	928	7130	7169	-1532	19929	0	19929	2469	358	22756	49.98
16	6862	393	226	7481	41	6467	0	652	6846	6549	-1437	19387	0	19387	2473	366	22226	49.99
17	6826	516	241	7583	59	6835	0	285	5893	5915	-1244	19070	0	19070	2479	363	21912	49.97
18	6920	459	233	7612	59	7074	0	48	5092	4780	-1030	18152	0	18152	2479	391	21022	49.94
19	6898	453	236	7587	80	6993	0	0	5591	5688	-1059	18890	0	18890	2540	399	21829	49.94
20	7238	334	238	7810	144	7140	0	0	4897	4634	-1172	18165	0	18165	2455	391	21011	50.00
21	6681	242	246	7169	94	6564	0	0	4826	4327	-1131	16638	0	16638	2320	385	19343	50.02
22	5790	249	236	6275	72	5744	0	0	5586	5423	-1178	15985	0	15985	2158	351	18494	50.01
23	5654	235	250	6139	60	5652	0	0	5572	4996	-1206	15298	0	15298	1994	343	17635	49.94
24	5074	223	239	5536	60	5591	0	0	5493	5030	-1099	14790	0	14790	1854	328	16972	50.01
MUs	153.44	10.10	5.76	169.31	2.80	152.43	0.00	7.44	138.23	132.48	-26.82	429.42	0.00	429.42	50.99	8.21	488.62	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 21/Dec/2021

Position as on 6.30 Hrs of 22/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vibration high	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 4	210	08/12/2021	21:00		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 3	210	09/12/2021	00:01		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 1	210	09/12/2021	00:56		Continued.	CHP coal feeding problem	
MSPGCL	Nasik Unit 4	210	11/12/2021	21:22		Continued.	withdrawn against case 4 to dhariwal	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 22/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV 1500 MVA ICT-2 @ KORADI 3	IntraState	21/12/2021	11:11	21/12/2021	19:39	PO	Annual Maintenance of 765/400KV ICT-2
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ BABHALESHWAR	IntraState	21/12/2021	07:29	21/12/2021	09:18	T	Bus Operated due to Reactor B-ph Pole Burst
400 KV LINE Outages/Trippings							
PARLI(MS) - PARLI (PG) CKT -1	InterState	22/12/2021	12:00	22/12/2021	2137	PO	For Bay AMP works
AKOLA - KHADKA (BHUSAWAL)	IntraState	11/12/2021	09:34		Continued.	PO	for replacement of 400 KV Damage Main Bus (1&2) section of Akola & Aurangabad bay
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadraple CB. 3) Measurement of Timing, DCRM and CRM of CB.
PADGHE - NAGOTHANE CKT - 1	IntraState	20/12/2021	09:21	21/12/2021	17:22	PO	1) For CB mechanism Overhauling work and Diagnostic Testing work. 2) A & B Bus PG Isolator maintenance work
JAIGAD - KARAD CKT - 1	IntraState	20/12/2021	23:34	21/12/2021	09:27	HT	HAND TRIPPED DUE TO OVER VOLTAGE
BABHALESHWAR - PADGHE CKT-1	IntraState	21/12/2021	07:29	21/12/2021	08:48	T	Bus Operated due to Reactor B-ph Pole Burst.
EKTUNI - BABLESHWAR CKT - 1	IntraState	21/12/2021	07:29	21/12/2021	08:23	T	Bus Operated due to Reactor B-ph Pole Burst.
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	21/12/2021	07:29	21/12/2021	08:13	T	Bus Operated due to Reactor B-ph Pole Burst
DHULE- - BABLESHWAR - I	IntraState	21/12/2021	07:29	21/12/2021	11:02	T	Bus operated due to Reactor B-ph pole burst
JAIGAD - KARAD CKT - 2	IntraState	21/12/2021	21:07	22/12/2021	09:44	HT	HT OV
MAIN BUS - 2 @ LAMBOTI	IntraState	22/12/2021	11:35	22/12/2021	17:28	PO	400kV Main Bus II, 406-89B Isolator Alignment Work
JAIGAD - KARAD CKT - 1	IntraState	22/12/2021	22:40		Continued.	HT	Handtripped for controlling system Over voltage
LONIKAND I - KOYNA STAGE-IV	IntraState	22/12/2021	23:29		Continued.	HT	Hand Tripped for controlling System Over voltage
400 KV ICT Outages/Trippings							
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	21/12/2021	07:29	21/12/2021	08:47	T	Bus Operated due to Reactor B-ph Pole Burst
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	21/12/2021	07:29	21/12/2021	08:25	T	Bus Operated due to Reactor B-ph Pole Burst
220 KV MAINBAY Outages/Trippings							
MAIN BAY(208) OF 220KV-SOLAPUR-FUTURE 1 @SOLAPUR (PG)-220 KV	InterState	20/12/2021	17:22		Continued.	PO	reorientation work along with the disconnection of 220KV Bale-Tuljapur line at Loc.NO. 37 and establishment of link between Solapur PG to 220KV Bale substation will be carried out by utilizing D/C portion of Solapur PG -Bale line and jumpering work at substation end.
220 KV LINE Outages/Trippings							
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01		Continued.	HT	air leakage in CB

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 21/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 22/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
SOLAPUR(BALE) - TULJAPUR	IntraState	20/12/2021	10:54		Continued.	PO	Outage is required 1. Testing & communication work of line and bay at both substation (Bale & PGCIL) 2. Jumpering work at loc 37 on 220kV PGCIL Bale Line 3. Shifting of WT, CC & LMU (in existing Tuljapur bay) at 220kV Bale Substaion.
TALANDAGE - CHIKODI	IntraState	21/12/2021	09:44	21/12/2021	18:36	PO	1. QM Work 2. Annual diagnostic testing work
APTA - TAMBATI	IntraState	21/12/2021	11:36	21/12/2021	14:15	PO	For removing of Bunching at LILO Loc.No.1 to 2 of 220kV Apta-Tambati-Adlab line for providing of missing earthwire at Loc.No.4 to 5.
TAMBATI - ADLABS	IntraState	21/12/2021	11:40	21/12/2021	16:44	PO	Removing of bunching at LILO Loc no. 1 to 2 of 220KV APTA - Tambati - ADLAB line. Providing of missing earthwire at Loc no. LILO 4 to 5.
CHAKAN-BHOSARI 1	IntraState	21/12/2021	12:05	21/12/2021	15:12	PO	CRM measurement of CB & timing test of CB
URAN - KHARGHAR 2	IntraState	21/12/2021	12:26	21/12/2021	20:13	T	distance protection trip
KAMBA - KOLSHET	IntraState	21/12/2021	13:00	21/12/2021	14:09	PO	Replace the breaker spring charging faulty motor by new one
BHOSARI- BHOSARI 2	IntraState	21/12/2021	15:44	21/12/2021	17:46	PO	CRM measurement of CB & timing test of CB
PARANDA-BARSHI	IntraState	22/12/2021	09:31	22/12/2021	15:45	PO	Outages is required for Quarterly Maintenance
ADLABS - PEDAMBE	IntraState	22/12/2021	09:57	22/12/2021	18:55	PO	1) Emergency tree cutting at Loc.No.205-206,209-211,233-234,301-302,309-311,325-326,403-406 and other line maintenance work
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	22/12/2021	10:21	22/12/2021	15:35	PO	For replacement of flashover polymer insulator at Loc.No.16- New line (Top phase). Emergency tree cutting and other routine maintenance work.
TROMBAY - MULUND	IntraState	22/12/2021	10:25	22/12/2021	17:47	PO	Online Shifting of 220 kv Trombay line from 220 kV Bus-1 to 220 kV Bus-2 through Center breaker-1 for BUS-1 DEAD Purpose for 220 KV Bus Coupler Isolator BUS-1 Side Isolator Alignment work. And TF-4 29 A isolator Alignment work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 21/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 22/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA - MULUND 1	IntraState	22/12/2021	10:25	22/12/2021	17:34	PO	Online Shifting of 220 kv Kalwa-1 line from 220 kV Bus-1 to 220 kV Bus-2 through Center breaker-1 for BUS-1 DEAD Purpose for 220 KV Bus Coupler Isolator BUS-1 Side Isolator Alignment work. And Kalwa-1 line 29 A isolator and TF-4 29 A isolator Alignment work.
RANJANGAON - U TECH SUGAR CKT	IntraState	22/12/2021	10:50	22/12/2021	17:40	T	Distance Protection
MAIN BUS SECTION - 1 @ EKLHARE (GCR)	IntraState	22/12/2021	12:18	22/12/2021	17:50	PO	for attending hotspot &diagnostic testting work
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	22/12/2021	15:50		Continued.	PO	For routine maintenance work and emergency tree cutting work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 2 @ PADGHE	IntraState	20/12/2021	09:56	21/12/2021	20:00	PO	1. Replacement of Y LA (LCM Value- 324 ȳA) 2. Painting Of ICT 3. Attending hotspot 4. Retrofitting of REF relay of MTAMC remaining Work
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	IntraState	20/12/2021	10:32	21/12/2021	07:30	PO	For 132kv Rph LV torret CT terminal plate replacement, OLTC & PRV replacement work.
220/22-22 KV 50 MVA PTR 4 @ MULUND	IntraState	21/12/2021	09:09	21/12/2021	17:22	PO	1. Diagnostic testing work. 2. Transformer painting work
220/132kv 100MVA ICT -1 @ LONI DEOKAR	IntraState	21/12/2021	11:15	21/12/2021	15:35	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	21/12/2021	11:37	21/12/2021	16:46	HT	RM works
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	21/12/2021	11:39	21/12/2021	14:20	HT	RM Works
220/132kv 100MVA ICT -2 @ LONI DEOKAR	IntraState	21/12/2021	15:40	21/12/2021	17:22	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK
220/33 KV 50 MVA PTR 3 @ SONKAR	IntraState	22/12/2021	08:33	22/12/2021	12:40	PO	1.OLTC extra pipe connected for oil sample 2.OLTC Oil Top up 3.Damaged jumper replacement of 33 KV Bus section-3
220/22-22 KV 50 MVA PTR 4 @ MULUND	IntraState	22/12/2021	09:12	22/12/2021	18:17	PO	1. Diagnostic testing work. 2. Transformer painting work
220/33 KV 50 MVA 1 PTR @ SHIRSUPHAL	IntraState	22/12/2021	10:00	22/12/2021	14:25	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK
220/22 KV 50 MVA PTR 1 @ WADKHAL (GIS)	IntraState	22/12/2021	10:44	22/12/2021	15:40	PO	For bushing tandelta, SFRA, DFR and renovation of existing earthpit, cold welding for attending oil leakage.
220/33 KV 50 MVA 2 PTR @ SHIRSUPHAL	IntraState	22/12/2021	14:40	22/12/2021	17:40	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK
220/22 KV 50 MVA PTR 2 @ WADKHAL (GIS)	IntraState	22/12/2021	15:52	22/12/2021	19:06	PO	For Bushing tandelta, SFRA, DFR and renovation of existing earthpit, cold welding for attending oil leakage.
132 KV LINE Outages/Trippings							
DHARANI - NEPANAGAR	InterState	22/12/2021	11:50	22/12/2021	17:36	PO	Diagnostics Testing & Routine maint.
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	22/12/2021	09:19	22/12/2021	16:06	PO	ATTENDING HOT SPOT

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage