

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Jan/2019 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.552	3138.138	1) Gujrat	1.374	47.690
2) Hydro	9.796	147.673	2) Madhya Pradesh	12.398	191.984
3) Gas	7.334	149.981	3) Chattisgarh	4.050	84.420
Total MSPGCL	153.682	3435.792	4) Maharashtra	111.705	2112.820
B) 1) APLM	56.049	1487.040	5) Goa (Amona)	-0.154	-5.016
2) JSWEL	22.887	496.113	Total	129.373	2431.898
3) VIPL	0.000	81.108	a) Mumbai Schedule	28.225	456.035
4) RPL(AMT)	3.644	26.848	b) Mumbai Drawl	30.195	537.071
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	6.798	216.393
6) Other IPP	12.993	311.258	Include PX	-5.514	-108.612
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.615	449.737
C) 1) TPCL Thermal	5.312	198.421	Include PX	14.820	119.319
2) TPCL Hydro	5.645	86.104	Standby	0.610	6.298
3) TPCL Gas	4.382	96.170	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.027	111.790	1) MSEDCL	366.489	8005.259
D) STATE			2) Mumbai Discoms	50.560	1029.553
1) Thermal	242.464	5850.716	TOTAL STATE	417.049	9034.812
(A1+C1+C4+(B1-B6))					
2) Hydro	15.441	233.777			
(A2+C2)					
3) Gas	11.716	246.151			
(A3+B7+C3)					
4) Wind	12.279	147.014			
6) SOLAR	5.777	125.259			
TOTAL STATE	287.677	6602.917			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6177	6123	5482	5242
MSPGCL Hydro	1072	432	558	326
MSPGCL Gas	299	293	297	314
MSPGCL Total Generation	7548	6848	6338	5882
Central Sector Receipt	6450	5708	5513	4070
WIND	259	611	474	588
CPP / IPP Thermal	4593	4421	4344	3188
CPP / IPP Gas	0	0	0	0
SOLAR	712	880	0	0
Exchange with Mumbai	-1581	-1596	-1448	-815
MSEDCL DEMAND MET	17982	16873	15220	12914
Load Shedding	0	0	0	0
MSEDCL DEMAND	17982	16873	15220	12914
TPCL GENERATION	797	771	823	388
AEML GENERATION	252	218	200	192
MUMBAI DEMAND	2630	2585	2471	1395
STATE DEMAND MET	20612	19458	17692	14308
STATE DEMAND	20612	19458	17692	14308
Frequency (Hz)	50.00	50.04	49.99	49.92

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.28 Hz at 02.00 Hrs	49.67 Hz at 06.39 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 22/Jan/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.89	56.77	225	180
Unit 7	0.00	63.84	0	0
Unit 8	9.94	149.88	430	386
Unit 9	12.61	198.95	630	400
Unit 10	0.00	149.01	0	0
Total	27.44	618.46		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.40	211.76	500	350
Unit 5	9.30	211.61	490	350
Total	18.70	423.36		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	56.43	0	0
Total	0.00	56.43		
Chandrapur				
Unit 3	4.29	93.42	190	163
Unit 4	4.24	87.61	183	160
Unit 5	9.38	202.74	405	365
Unit 6	10.33	214.87	455	365
Unit 7	10.07	208.26	445	366
Unit 8	11.00	231.73	487	360
Unit 9	8.46	228.66	490	0
Total	57.77	1267.29		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	3.05	116.43	224	42
Total	3.05	116.43		
Khaparkheda				
Unit 1	3.82	80.86	170	145
Unit 2	3.86	80.39	170	150
Unit 3	3.89	82.48	170	157
Unit 4	3.89	81.70	175	155
Unit 5	9.94	217.10	450	375
Total	25.39	542.53		
Nasik				
Unit 3	0.00	22.11	0	0
Unit 4	4.20	91.53	204	160
Unit 5	0.00	0.00	0	0
Total	4.20	113.64		
Uran				
All Units	7.33	149.98	318	290
Total	7.33	149.98		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.02	0.94	18	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.02	0.94		
Koyna				
Stage 1-2	2.38	40.92	310	40
Stage 4	2.82	11.15	552	0
Stage 3	0.81	11.60	160	0
Total	6.01	63.67		
Hydro				
KDPH	0.44	8.18	19	19
VTRNA	0.52	11.24	60	0
TILLARI	0.48	9.68	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.14	4.23	80	0
RNGR+BHTSA	0.30	6.47	13	12
BHANDARDRA	0.00	0.06	0	0
ELDARY	0.00	2.78	0	0
SMLHY_PTN	0.45	8.88	27	16
GHATGHAR	1.44	32.49	250	0
Total	3.78	84.00		
Wind				
Total	12.28	147.01	0	0
Total	12.28	147.01		
CPP				
APML(Mus)	56.05	1487.04	0	0
JSWEL(Mus)	22.89	496.11	0	0
VIPL(Mus)	0.00	81.11	0	0
RPLAMT(Mus)	3.64	26.85	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	12.99	311.26	0	0
Total	95.57	2402.37		
SOLAR				
Total	5.78	125.26	0	0
Total	5.78	125.26		
Tata				
Trombay 5	0.00	83.46	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	60.90	117	115
Trombay 7B	1.60	35.27	67	66
Trombay 8	5.31	114.96	238	201
TATA Hydro	5.64	86.10	431	0
Total	15.34	380.70		
AEML				
DTPS U-1&2	5.03	111.79	253	192
Total	5.03	111.79		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.55	3138.14	MSPGCL Total	153.68	3435.79
			MSPGCL Thml+Gas	143.89	3288.12	Koyna 1,2 & 4 Total	5.21	52.07
			MSPGCL Hydro	9.80	147.67	State Total	287.68	6602.92

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 22/Jan/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5233	112	314	5658	994	3125	0	0	4264	4361	-1016	13122	0	13122	1618	14740	50.01
2	5248	86	316	5650	877	3142	0	0	4122	4205	-917	12958	0	12958	1494	14452	50.09
3	5244	86	315	5646	837	3151	0	0	3908	4382	-847	13168	0	13168	1425	14594	50.03
4	5242	326	314	5882	588	3188	0	0	3936	4070	-815	12914	0	12914	1395	14308	49.92
5	5214	136	305	5656	364	3256	0	0	4810	4998	-817	13456	0	13456	1395	14852	49.99
6	5655	92	316	6062	348	3483	0	0	5547	5587	-930	14550	0	14550	1538	16088	50.02
7	5994	400	316	6710	241	3969	0	4	5994	6304	-1055	16174	0	16174	1751	17924	49.89
8	6187	918	317	7422	221	4444	0	60	6067	6287	-1145	17288	0	17288	1947	19236	49.97
9	6217	1064	318	7598	192	4529	0	279	6112	6281	-1323	17556	0	17556	2218	19774	50.05
10	6227	1084	311	7622	213	4559	0	539	6253	6594	-1433	18094	0	18094	2456	20550	49.99
11	6177	1072	299	7548	259	4593	0	712	6333	6450	-1581	17982	0	17982	2630	20612	50.00
12	6172	978	295	7446	354	4571	0	805	6320	6033	-1569	17640	0	17640	2640	20280	50.02
13	6123	432	293	6848	611	4421	0	880	6252	5708	-1596	16873	0	16873	2585	19458	50.04
14	5858	166	292	6316	631	4098	0	845	5918	5761	-1477	16175	0	16175	2433	18608	50.01
15	5863	280	290	6432	625	4079	0	716	5776	5701	-1475	16078	0	16078	2451	18530	49.94
16	5873	330	302	6506	597	3996	0	554	5743	5562	-1445	15770	0	15770	2465	18234	49.91
17	5830	366	292	6488	488	4264	0	312	5412	5393	-1443	15502	0	15502	2477	17978	49.99
18	5897	180	295	6372	450	4343	0	71	5027	5008	-1421	14822	0	14822	2457	17280	49.96
19	5904	314	306	6524	429	4340	0	0	5227	5272	-1450	15114	0	15114	2481	17596	49.96
20	5482	558	297	6338	474	4344	0	0	5283	5513	-1448	15220	0	15220	2471	17692	49.99
21	5407	264	308	5978	501	4348	0	0	5071	5073	-1335	14566	0	14566	2317	16882	49.96
22	5226	232	310	5768	548	3952	0	0	5200	5105	-1275	14098	0	14098	2147	16244	49.99
23	5171	208	301	5680	682	3721	0	0	4844	5045	-1206	13922	0	13922	1975	15898	50.04
24	5108	110	312	5530	755	3657	0	0	4779	4679	-1176	13446	0	13446	1795	15240	50.03
MUs	136.55	9.80	7.33	153.68	12.28	95.57	0.00	5.78	128.20	129.37	-30.19	366.49	0.00	366.49	50.56	417.05	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Jan/2019

Position as on 6.30 Hrs of 23/Jan/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 5	210	22/11/2018	03.50		Continued.	Boiler Tube Leakage Work Completed On 24/11/2018. Available Against Case 4 From 25/11/2018.Converted To COH From 00:00 Hrs of 05/12/2018 (Converted COH to Zero sch by MSEDCL from 29.01.2019)	
TPC-G	Trombay 5	500	11/01/2019	23.56		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-2	250	14/01/2019	09:40	22/01/2019	12:35	Routine Maintenance work.	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
MSPGCL	Koyna Unit 1	70	26/11/2018	00.00		Continued.	Oil Cooler Leakage.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	14/12/2018	16.30		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	RPL(AMT) U-2	270	27/12/2018	19.30		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/01/2019	19.30		Continued.	Zero Schedule	
IPP	Dhariwal	300	12/01/2019	10.15		Continued.	Coal Shortage	
MSPGCL	Parli Unit 8	250	12/01/2019	12.00		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Koradi Unit 10	660	15/01/2019	23.25		Continued.	Condenser Tube Cleaning	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Jan/2019

Position as on 6.30 Hrs of 23/Jan/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							Work & PCR.	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
IPP	RPL(AMT) U-1	270	18/01/2019	19.30	22/01/2019	05.30	Zero Schedule.	
MSPGCL	Koradi Unit 7	210	19/01/2019	18.21		Continued.	Poor Coal Receipt	
AEML	AEML Unit 1	250	21/01/2019	11.11	23/01/2019	03.58	Turbine Vibration	
IPP	Adani U-2	660	21/01/2019	17.32		Continued.	Hot PA Duct Bellow Leakage.	
MSPGCL	Chandrapur Unit 9	500	22/01/2019	19.03	23/01/2019	11.12	Tripping of Primary Water Pumps.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 23/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	20/01/2019	16.39	22/01/2019	10.22	HT	Over Voltage
Kolhapur(M)-Kolhapur(GIS) cktII	InterState	22/01/2019	08.31	22/01/2019	19.02	HT	As Heavy Sparking Observed At Isolator BPL.Code 2241 Issue For Work Permit At 10.33HRS.
Kolhapur(M)-Kolhapur(GIS) ckt1	InterState	22/01/2019	11.09	22/01/2019	15.41	HT	As Heavy Sparking Observed At R PH CT.Code 2253 Issue For Work Permit.
Dhule Sar'Sarovar I	InterState	22/01/2019	17.30		Continued.	HT	Over Voltage
Padgha Tarapur I	InterState	23/01/2019	09.04	23/01/2019	19.32	EO	Work at Tarapur End
Kolhapur(M)-Kolhapur(GIS) ckt1	InterState	23/01/2019	17.08	23/01/2019	22.08	EO	Attending Hot Spot
Jaigad-New Koyna Ckt-I	IntraState	21/01/2019	10.07	22/01/2019	09.31	PO	Insulator Replacement & Maintenance Work.
Khadka-Aurangabad (Waluj)	IntraState	21/01/2019	18.44	22/01/2019	07.11	HT	Over Voltage
Deepnagar Taptitanda	IntraState	22/01/2019	07.20	22/01/2019	20.35	PO	Repl. of Dead End & Mid Span Joint.
Warora-Tirora-Ii	IntraState	22/01/2019	08.48	22/01/2019	18.56	PO	Annual Maintenance Work
Jaigad-New Koyna Ckt-II	IntraState	22/01/2019	10.04	22/01/2019	17.44	PO	Insulator Replacement Work.
Khadka-Aurangabad (Waluj)	IntraState	22/01/2019	21.37	23/01/2019	06.42	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	23/01/2019	01.25	23/01/2019	07.38	HT	Over Voltage
Deepnagar Taptitanda	IntraState	23/01/2019	07.14	23/01/2019	16.33	PO	Rept.of Dead End & MID Span Joint
Koradi-Bhusawal	IntraState	23/01/2019	07.26	23/01/2019	15.09	PO	Rept. of Y & B PH Conductors at loc no 17 & 18
N.Koyna-Karad -Ckt I	IntraState	23/01/2019	09.03	23/01/2019	15.58	PO	Attending Hot Spot
Akola II - Akola I Ckt-I	IntraState	23/01/2019	09.11	23/01/2019	17.30	PO	Routine Maintenance Work
Parly(MS)- Nanded ckt I	IntraState	23/01/2019	11.12	23/01/2019	15.16	T	Distance Protection
Khadka-Aurangabad (Waluj)	IntraState	23/01/2019	17.50		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220KV 315MVA ICT-I@bhusawal(khadka)	IntraState	22/01/2019	08.33	22/01/2019	21.22	PO	For Commissioning of CSD Relay.
400/220KV 500MVA ICT-II@Taptitanda	IntraState	22/01/2019	10.11	22/01/2019	19.49	EO	Testing & Maintenance.
400/220KV 105MVASpare ICT@Akola	IntraState	22/01/2019	12.21	22/01/2019	16.08	EO	For Removing Bird Nest At Y-PH Gantry Structure.
400/220/33kv, 500 MVA ICT-I @Khaparkheda	IntraState	23/01/2019	08.49	23/01/2019	17.33	PO	Diagnostic Testing work
400/220KV 315MVA ICT3@Bhusawal II (khadaka)	IntraState	23/01/2019	13.56	23/01/2019	17.45	PO	Commissioning of CSD Relay
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Mudshingi Chikodi	InterState	22/01/2019	07.00	22/01/2019	16.43	T	Distance Protection, PDR Optd, IC-9.4KA,10.8KM, Z1, B-PH, At LOC No-285 B-PH String Flashover.
Talandage - Chikodi	InterState	22/01/2019	07.02	22/01/2019	20.23	T	Distance Protection, Zone 2.
PARLY (PG) - OSMANABAD	InterState	23/01/2019	05.27	23/01/2019	06.00	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 23/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.
Nanded - Parli Ext. Ckt I	IntraState	06/12/2018	07.02	22/01/2019	08.50	HT	Waghala-Kumbhargaoon CKT O/L.
Talandge(400kv)- Ichalkaranji 2	IntraState	22/01/2019	07.02	22/01/2019	09.01	T	Distance Protection, B-PH, IC-1.07 KA.
Pusad - Hingoli	IntraState	22/01/2019	07.30	22/01/2019	18.46	HT	In View Outage On Wardha-Yavatmal CKT.
Nanded-Parbhani	IntraState	22/01/2019	07.38	22/01/2019	11.028	HT	In View Outage On 220KV Wardha-Yavatmal CKT.
Pusad-Ghatodi	IntraState	22/01/2019	07.45	22/01/2019	18.47	HT	In View Outage On 220KV Wardha-Yavatmal CKT.
Khadka-Chalisgaon-1	IntraState	22/01/2019	08.23	22/01/2019	21.46	HT	For Outage On Khadka ICT.
Karad(400kv) - Ogalewadi Ckt 2	IntraState	22/01/2019	08.39	22/01/2019	23.12	PO	Restrining of Conductor Between LOC 1 to 9 R-PH.18.57HRS Trail Taken from Kard End, Tripped Due To R PH CC Blast At Ogalewadi End.
New Koyna - Loteparshuram	IntraState	22/01/2019	09.41	22/01/2019	13.31	PO	Washing Insulator String.
Eklahare (Gcr) - Ghatghar	IntraState	22/01/2019	09.53	22/01/2019	19.08	PO	For Earth Wire Replacement of Ghatghar m/c line.
Nigade- Peth Line	IntraState	22/01/2019	10.00	22/01/2019	11.30	PO	Quarterly Maintenance Work & CT Leakages Attending Work.
Ghatghar - Bapgaon	IntraState	22/01/2019	10.25	22/01/2019	19.35	PO	For Earth Wire Replacement of Ghatghar m/c line.
Taloja II - OCIL-I	IntraState	22/01/2019	11.09	22/01/2019	11.51	EO	For Removing Bird Nest At Y-PH Gantry Structure.
Nanded - Parli Ext. Ckt I	IntraState	22/01/2019	11.23		Continued.	HT	For Nanded-Nanded Loading.
Khaparkheda-Ambazari-Ii	IntraState	22/01/2019	12.24	22/01/2019	13.22	PO	For Connecting PT Supply.
Babhaleshwar-Nagar-I	IntraState	22/01/2019	13.22	22/01/2019	17.18	PO	Flash Over Insulator Replacement.
Koradi-Ambazari-Ii	IntraState	22/01/2019	13.49	22/01/2019	14.37	PO	For Connecting PT Supply.
Koradi-Ambazari-I	IntraState	22/01/2019	14.42	22/01/2019	15.27	PO	For Connecting PT Supply.
Kharghar-Borivali ckt I	IntraState	22/01/2019	16.37	22/01/2019	20.40	T	Distance Protection, R-PH E/F.
Trombay - Mulund	IntraState	23/01/2019	07.10	23/01/2019	09.12	PO	Attending Hot Spot
Eklahare (Gcr) - Ghatghar	IntraState	23/01/2019	09.57	23/01/2019	18.27	PO	Earth wire replacement work
Talandge-Mudshingi Ckt-I	IntraState	23/01/2019	10.06	23/01/2019	13.12	PO	Quarterly Maintenance Work
Gorai MSETCL Borivali Line-1	IntraState	23/01/2019	10.22	23/01/2019	18.54	PO	Testing Work
Ghatghar - Bapgaon	IntraState	23/01/2019	10.30	23/01/2019	18.54	PO	Earth Wire Replacement work
Karad - Kadegaon	IntraState	23/01/2019	10.49	23/01/2019	16.28	PO	Diagnostic Testing Work
BOISAR BORIVALI	IntraState	23/01/2019	11.01	23/01/2019	15.39	PO	Diagnostic Testing work
Pirangut - Hinjawadi 2	IntraState	23/01/2019	11.22	23/01/2019	14.40	PO	Diagnostic Testing work
Kalwa - Mulund 1	IntraState	23/01/2019	11.56	23/01/2019	16.19	PO	Diagnostic Testing Work
Topworth - Kharghar	IntraState	23/01/2019	12.38	23/01/2019	19.19	PO	Line Bunching Work
Kadegaon-Miraj	IntraState	23/01/2019	17.00	23/01/2019	18.32	PO	Diagnostic Testing Work
220 KV ICT Outages/Trippings							
220/132 kV 200MVA ICT-V @ Nashik	IntraState	22/01/2019	09.05	22/01/2019	11.21	PO	Replacement of Winding Temperature Indicator Meter of Tertiary.
220/132 kV 200 MVA ICT- I @ Nanded	IntraState	22/01/2019	13.45	22/01/2019	18.08	PO	Measurment of Tan Delta of CT Diagnostic Testing Work SFRA Test of ICT.
220/132kV 100MVA ICT-1@Jeur	IntraState	23/01/2019	12.30	23/01/2019	18.20	PO	Quarterly Maintainance Work
132 KV LINE Outages/Trippings							

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 23/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Mansar Pench	InterState	22/01/2019	18.40		Continued.	HT	After Completion of Outage.
Pusad-Jambazar	IntraState	22/01/2019	07.45	22/01/2019	18.51	HT	In View Outage On 220KV Wardha-Yavatmal CKT.
Waghala (Nanded2) - Elichpur	IntraState	22/01/2019	07.48	22/01/2019	18.55	HT	In View Outage On 220KV Wardha-Yavatmal CKT.
Killari Tap On Ujani-Omerga	IntraState	22/01/2019	13.18	22/01/2019	16.38	T	Distance Protection Operated Zone 15.5KM B-PH.
Kanhan-Pench	IntraState	22/01/2019	18.44		Continued.	HT	After Completion of Outage.
110 KV LINE Outages/Trippings							
Kalyan Kalwa Salsette 1	IntraState	23/01/2019	10.00	23/01/2019	18.02	PO	Tree Trimming

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage