

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Jan/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	131.096	3169.394	1) Gujrat	-4.732	-143.395
2) Hydro	10.738	259.419	2) Madhya Pradesh	4.729	109.537
3) Gas	5.974	103.001	3) Chattisgarh	5.490	129.340
Total MSPGCL	147.808	3531.814	4) Maharashtra	132.868	2873.801
B) 1) APLM	63.781	1498.029	5) Goa (Amona)	-1.712	-31.892
2) JSWEL	14.830	310.419	Total	136.643	2937.391
3) VIPL	0.000	0.000	a) Mumbai Schedule	19.154	475.678
4) RPL(AMT)	22.741	555.450	b) Mumbai Drawl	24.911	518.107
5) SWPGPL	7.557	131.380	c) MSEDCL Bilateral *	73.717	1277.788
6) Other IPP	39.780	841.953	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	19.154	475.556
C) 1) TPCL Thermal	12.480	228.884	Include PX	0.000	0.000
2) TPCL Hydro	4.043	86.868	Standby	0.000	0.123
3) TPCL Gas	0.000	9.340	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.704	191.369	1) MSEDCL	436.917	9437.935
D) STATE			2) Mumbai Discoms	47.138	1034.567
1) Thermal	297.969	6926.878	3) Other Discoms	7.975	204.567
(A1+C1+C4+(B1-B6))			TOTAL STATE	492.030	10677.069
2) Hydro (A2+C2)	14.781	346.287			
3) Gas (A3+B7+C3)	5.974	112.341			
4) Wind	28.299	209.432			
6) SOLAR	8.364	144.741			
TOTAL STATE	355.387	7739.679			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6066	5690	5818	4525
MSPGCL Hydro	987	426	452	268
MSPGCL Gas	258	245	246	267
MSPGCL Total Generation	7311	6361	6516	5060
Central Sector Receipt	7359	6294	4963	5267
WIND	1123	1262	1455	1462
CPP / IPP Thermal	6983	6863	6674	5052
CPP / IPP Gas	0	0	0	0
SOLAR	1050	1209	0	0
Exchange with Mumbai	-1389	-1381	-1060	-1006
MSEDCL DEMAND MET	19914	18210	15854	13671
Load Shedding	0	0	0	0
MSEDCL DEMAND	19914	18210	15854	13671
TPCL GENERATION	770	780	963	460
AEML GENERATION	247	247	245	242
MUMBAI DEMAND	2406	2408	2268	1708
OTHER DISCOM DEMAND	360	343	385	309
STATE DEMAND MET	24843	23016	20816	17543
STATE DEMAND	24843	23016	20816	17543
Frequency (Hz)	50.01	50.00	50.00	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 00.04 Hrs	49.78 Hz at 16.58 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 22/Jan/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.48	65.74	185	120
Unit 7	0.00	0.00	0	0
Unit 8	12.78	295.59	592	389
Unit 9	12.53	254.81	582	399
Unit 10	12.32	257.31	540	390
Total	41.12	873.46		
Bhusawal				
Unit 3	3.00	60.52	145	115
Unit 4	0.00	100.73	0	0
Unit 5	8.70	188.24	450	285
Total	11.70	349.48		
Parli				
Unit 6	4.04	87.11	249	129
Unit 7	4.13	86.29	249	119
Unit 8	3.86	87.55	219	142
Total	12.03	260.95		
Chandrapur				
Unit 3	0.00	49.03	0	0
Unit 4	0.00	58.23	0	0
Unit 5	7.64	168.77	360	290
Unit 6	8.04	182.87	430	270
Unit 7	7.84	118.12	402	288
Unit 8	0.00	197.03	0	0
Unit 9	10.01	205.60	464	288
Total	33.52	979.66		
Paras				
Unit 3	4.13	96.33	244	143
Unit 4	3.93	82.20	234	137
Total	8.06	178.53		
Khaparkheda				
Unit 1	3.07	57.64	150	110
Unit 2	0.00	0.00	0	0
Unit 3	3.43	68.07	183	124
Unit 4	2.00	56.04	144	0
Unit 5	9.71	215.42	460	280
Total	18.21	397.18		
Nasik				
Unit 3	3.26	65.42	181	121
Unit 4	0.00	18.28	0	0
Unit 5	3.18	46.44	192	117
Total	6.44	130.14		
Uran				
All Units	5.97	103.00	267	235
Total	5.97	103.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	5.90	30	0
Total	0.12	5.90		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.38	52.76	355	35
Stage 4	0.07	31.37	71	0
Stage 3	0.48	18.82	160	0
Total	2.93	102.95		
Hydro				
KDPH	0.43	6.41	18	18
VTRNA	0.72	12.57	60	0
TILLARI	0.52	11.48	58	0
BHIRA T.R.	0.20	5.06	40	0
SMLHY_PTN	5.18	118.89	218	213
GHATGHAR	0.76	2.05	125	0
Total	7.81	156.47		
Wind				
Total	28.30	209.43	0	0
Total	28.30	209.43		
CPP				
APML(Mus)	63.78	1498.03	0	0
JSWEL(Mus)	14.83	310.42	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	22.74	555.45	0	0
SWPGPL-Mus	7.56	131.38	0	0
Other(Mus)	39.78	841.95	0	0
Total	148.69	3337.23		
SOLAR				
Total	8.36	144.74	0	0
Total	8.36	144.74		
Tata				
Trombay 5	8.26	149.95	464	253
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	5.17	0	0
Trombay 7B	0.00	4.17	0	0
Trombay 8	4.22	78.93	224	129
TATA Hydro	4.04	86.87	444	0
Total	16.52	325.09		
AEML				
DTPS U-1&2	5.70	191.37	249	211
Total	5.70	191.37		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	131.10	3169.39	MSPGCL Total	147.81	3531.81
			MSPGCL Thml+Gas	137.07	3272.40	Koyna 1,2 & 4 Total	2.45	84.13
			MSPGCL Hydro	10.74	259.42	State Total	355.39	7739.68

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 22/Jan/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5206	268	251	5725	453	5593	0	0	5526	5373	-984	15868	0	15868	1622	292	17782	50.06
2	5212	269	260	5741	428	5623	0	0	5491	5485	-889	16119	0	16119	1525	269	17913	50.04
3	5234	272	250	5756	634	5922	0	0	5464	4875	-833	16091	0	16091	1461	263	17815	50.01
4	5302	274	261	5837	639	5969	0	0	5396	5068	-801	16452	0	16452	1424	260	18136	50.00
5	5366	274	251	5891	733	6103	0	0	5430	5107	-807	16754	0	16754	1422	273	18449	50.02
6	5545	271	251	6067	892	6428	0	0	5456	5226	-888	17434	0	17434	1498	291	19223	50.02
7	5863	271	241	6375	974	6762	0	2	5930	5519	-992	18322	0	18322	1604	318	20244	50.01
8	6177	336	261	6774	917	6859	0	99	6008	5596	-917	18998	0	18998	1742	330	21070	49.97
9	6290	778	260	7328	966	6993	0	454	6107	5996	-1061	20332	0	20332	1977	344	22653	49.96
10	6047	939	240	7226	1077	6988	0	815	6756	7062	-1237	21580	0	21580	2229	351	24160	50.01
11	6066	987	258	7311	1123	6983	0	1050	7391	7359	-1389	22077	0	22077	2406	360	24843	50.01
12	6074	742	236	7052	1239	6991	0	1141	7163	6852	-1415	21515	0	21515	2455	345	24315	49.91
13	5690	426	245	6361	1262	6863	0	1209	6880	6294	-1381	20265	0	20265	2408	343	23016	50.00
14	5344	419	235	5998	1514	6218	0	1194	6153	6229	-1303	19505	0	19505	2262	345	22112	50.02
15	5276	390	235	5901	1682	5961	0	1020	6503	6118	-944	19389	0	19389	2245	349	21983	49.97
16	5145	398	235	5778	1651	5865	0	818	6576	6096	-867	18989	0	18989	2217	352	21558	49.95
17	4945	660	245	5850	1632	5620	0	438	5812	6091	-858	18402	0	18402	2211	371	20984	49.93
18	5369	589	237	6195	1587	5729	0	124	5205	5247	-861	17641	0	17641	2208	380	20229	50.01
19	5486	459	246	6191	1524	6029	0	0	5285	5628	-933	18053	0	18053	2286	386	20725	50.02
20	5818	452	246	6516	1455	6674	0	0	5300	4963	-1060	18163	0	18163	2268	385	20816	50.00
21	5257	348	257	5862	1510	6370	0	0	5334	4836	-1147	17056	0	17056	2140	375	19571	50.01
22	5088	375	258	5721	1441	5705	0	0	5326	5230	-1227	16526	0	16526	1985	344	18855	49.99
23	4771	273	248	5292	1504	5389	0	0	5263	5126	-1111	15860	0	15860	1835	340	18035	49.94
24	4525	268	267	5060	1462	5052	0	0	5200	5267	-1006	15526	0	15526	1708	309	17543	49.98
MUs	131.10	10.74	5.97	147.81	28.30	148.69	0.00	8.36	140.95	136.64	-24.91	436.92	0.00	436.92	47.14	7.97	492.03	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 22/Jan/2022

Position as on 6.30 Hrs of 23/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 4	210	16/01/2022	23:52	22/01/2022	05:50	Extension of Boiler Steaming Validity.	
AEML	AEML Unit 2	250	20/01/2022	08:54		Continued.	Boiler Validity Renevoation	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
TPC-G	Trombay 7A	120	04/01/2022	19:40		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/01/2022	20:00		Continued.	Gas shortage	
MSPGCL	Nasik Unit 4	210	07/01/2022	22:00		Continued.	CONDENSER TUBE LEAKAGE	
IPP	JSW (J) U3	300	15/01/2022	07:46		Continued.	non availability of load schedule.	
MSPGCL	Chandrapur Unit 4	210	18/01/2022	23:47		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 3	210	19/01/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	20/01/2022	12:42		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	20/01/2022	21:15		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 8	500	21/01/2022	23:04		Continued.	Boiler Tube Leakage	
MSPGCL	Ghatghar Unit-2	125	21/01/2022	23:05	22/01/2022	00:52	HS FAULT	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 23/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
Main bay 704 of Koradi 3 ckt 2 @ 765 KV Tiroda	IntraState	22/01/2022	09:34		Continued.	PO	-For (704-52) CB Maintenance & for attending SF6 gas leakage
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	22/01/2022	09:15	22/01/2022	18:31	PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	23/01/2022	10:03	23/01/2022	16:58	HT	Line outage required for replacement of tension insulator at tower nos. 483, 516 and 572.
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	04/01/2022	15:46			PO	Height raising work of 400kV Waluj-Babhleshwar line at Loc No. 239 to 240 crossing to Samruddhi Highway i.e. 1. Dismantling of loc No. 239,240,241 (all DA+01) 2. Erection of new towers at loc No.239, 240,241 (All DD+9) 3. Restraining between Loc No. 237 to 242
TBC 2 @ CHANDRAPUR	IntraState	20/01/2022	12:35			EO	It is very necessary to attend the SF6 gas leakage considering the emergency and urgency. Low gas alarm is continuously appearing in short duration, Hence the problem needs to attend. To attend the SF6 gas leakage from NRV valve of R-ph pole of 400KV BHEL make Cicuit Breaker.
AKOLA-NANDGAONPETH (RPL-AMT)	IntraState	21/01/2022	22:15	22/01/2022	02:17	EO	For attending Hotspot in 413 89 B in U clamp from Isolator to CT side
BABHALESHWAR - PADGHE CKT-1	IntraState	21/01/2022	23:29	22/01/2022	01:55	T	DISTANCE PROTECTION
BABHALESHWAR - PADGHE CKT-1	IntraState	21/01/2022	23:29	22/01/2022	01:55	T	tripped on dist. protn
JAIGAD - KARAD CKT - 2	IntraState	22/01/2022	00:11	22/01/2022	10:36	HT	H/T FOR O/V
NEW KOYNA - DABHOL CKT - 2	IntraState	22/01/2022	06:06	23/01/2022	09:58	T	TRIPPED ON DIST. PROTN
KHARGHAR - TALEGAON (PG)	IntraState	22/01/2022	14:37	22/01/2022	19:18	PO	For AMP Work
BABHALESHWAR - PADGHE CKT-1	IntraState	22/01/2022	21:40	23/01/2022	02:19	EO	Fixing of rod type bird guard at loc no. 60
JAIGAD - KARAD CKT - 1	IntraState	22/01/2022	22:21	23/01/2022	09:57	HT	H/T FOR O/V
JAIGAD - KARAD CKT - 2	IntraState	23/01/2022	20:46			HT	overvoltage
PADGHE - NAGOTHANE CKT - 1	IntraState	23/01/2022	22:52			HT	Overvoltage
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	IntraState	22/01/2022	20:17	23/01/2022	11:53	PO	For MTAMC project related work and oil leakage attending work
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	23/01/2022	12:36	23/01/2022	20:57	PO	All diagnostic testing work, Bay maintenance work
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	20/01/2022	09:30			PO	Annual Maintenance of 220kV Ghodbunder to Dahanu Line -1 & 2
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 23/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18	23/01/2022	19:48	PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
PADGHE - NALASOPARA - VASAI (T)	IntraState	19/12/2021	10:06	23/01/2022	19:48	PO	1) 220KV Padgha Nalasopara - Vasai Tap line 2 Jumper will open at loc.33 ,35 and loc no.204 after that link line i.e. 220kV Nalasopara- Vasai link line will be charged at 12:00 hrs on dtd: 19.12.2021. this link line will be in service for 43 days continuous i.e 1024 hrs.
PADGHE - TEMGHAR - 2	IntraState	02/01/2022	23:25			HT	conductor replacement work
TEMGHAR - KALWA	IntraState	13/01/2022	23:10				As safety precaution for the replacement of CB pole of 220/22 kV, 50MVA PTR-2
DAHANU - GHODBUNDER CKT - 1	IntraState	20/01/2022	09:23				Modification / relocation of existing tower no LS 45 to 47 at Vangoan for NHRCL Project. 2) Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Towers. 4. Re-stringing of conductors & OPGW cable.
DAHANU - GHODBUNDER CKT - 2	IntraState	20/01/2022	09:27				Modification / relocation of existing tower no LS 45 to 47 at Vangoan for NHRCL Project.2) Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out:1. De-stringing of existing conductors & OPGW cable.2. Dismantling of existing towers.3. Erection of Towers.4. Re-stringing of conductors & OPGW cable.
TPC BORIVALI - AAREY	IntraState	20/01/2022	09:32			PO	For shifting to new GIS with cable extension with transition joint
GOREGAON - AAREY CKT - 2	IntraState	22/01/2022	03:55	22/01/2022	12:00	T	TRIPPED ON DIST.PROTN
ADLABS - PEDAMBE	IntraState	22/01/2022	06:13	22/01/2022	14:10	T	TRIPPED ON DIST. PROTN
PEDAMBE-KALAMBANI(TSS)	IntraState	22/01/2022	06:53	22/01/2022	13:55	T	TRIPPED ON DIST. PROTN
MAHAPE - RELIANCE GIS	IntraState	22/01/2022	09:02	22/01/2022	11:25	PO	For attending hotspot on B-ph Line CT clamp 100C by replacement of palm
KHADKI- CENTURY ENKA	IntraState	22/01/2022	10:22	22/01/2022	17:13	PO	CB overhauling and HYM
BOMBAY DYEING - SAHARA	IntraState	22/01/2022	11:48	22/01/2022	17:53	PO	Work :- Restranging of conductors loc 130-131 (3.46m,Bph) Loc-146-147(4.03m) YPh
KANDALGAON - PIRANGUT	IntraState	23/01/2022	04:57	23/01/2022	05:55	T	TRIPPED ON DIST PROTN

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 22/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 23/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - TARAPUR	IntraState	23/01/2022	06:07	23/01/2022	16:12	PO	For safety purpose only caution permit will be taken . no work will be carried out .
KAMBA - VASAI	IntraState	23/01/2022	07:10	23/01/2022	14:47	PO	1) 220V Kamba-Vasai Line & 220KV Borivali-PGCIL was Temporarily converted to 220KV PGCIL-Vasai Line for ORC work of DFCCIL making tapping arrangement at loc no.204. 2) Now work is completed and Circuit is to be normalized by Availing outage on Temporarily formed 220KV PGCIL-Vasai Line for removal of tapping arrangement at Loc no. 204 between 220KV Borivali-PGCIL & 220KV Kamba-Vasai Line and reconnecting jumper at loc no. 205. 3) After removal of tapping two line will be separated and it will become 220KV PGCIL-Borivali line and 220KV Kamba-Vasai line as before & same to be taken in service.
220 KV ICT Outages/Tripping							
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kv K'gaon S/s
220/22KV 50 MVA PTR - 3 @ AKP	IntraState	22/01/2022	09:12	22/01/2022	17:35	PO	1) Diagnostic testing work , 2) 50 MVA TF Incommer -3 Y ph CT Hot Spot attending work and R&M work. 3) Bus Isolator & C Isolator maintenance by removing jumper through Hot Line team.
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	22/01/2022	09:36	22/01/2022	14:09	PO	ICT diagnostic testing, Bay maint. work
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	22/01/2022	16:05	22/01/2022	16:45	PO	MAIN TANK OIL TOP UP WORK
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	22/01/2022	16:28	22/01/2022	17:40	PO	MAIN TANK OIL TOP UP WORK
220/110/33KV 250 MVA ICT-5 @ MAHALAXMI GIS (T)	IntraState	23/01/2022	12:02	23/01/2022	16:47	PO	FOR SILICON COATING
220/22 KV 50 MVA PTR 2 @ VASAI	IntraState	23/01/2022	14:25			EO	For attending hot spot on Bph LV bushing of 50VA T/F no.2 (Temp: 99.9 deg c)
220 KV BUSBAR Outages/Tripping							
BUS - B @ PADGHE	IntraState	22/01/2022	01:05		Continued.	PO	For making Stub Bus Twin arrangement of 220Kv Padghe-Temghar-2 Line above the A Bus at Padghe end.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage