

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Feb/2016 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	111.104	2354.884	1) Gujrat	-1.962	-73.628
2) Hydro	7.293	125.888	2) Madhya Pradesh	12.933	191.914
3) Gas	10.606	217.240	3) Chattisgarh	5.500	114.820
Total MSPGCL	129.003	2698.012	4) Maharashtra Net	76.533	1677.581
B) 1) APML	66.477	1342.896	5) Goa (Amona)	-0.448	-10.284
2) JSWEL	25.088	549.246	6) TAPS 1&2 Injection	3.831	74.856
3) VIPL	12.510	216.721	7) RGPPL Injection	11.724	255.568
4) RPL(AMT)	16.722	442.854	8) Pench (MS)	0.897	11.168
5) WPCL	2.926	98.761	9) Pench (Excess)	-0.897	-11.104
6) Other IPP	9.546	198.904	Total	107.214	2219.723
C) 1) TPCL Thermal	9.717	182.347	a) Mumbai Schedule	17.896	359.748
2) TPCL Hydro	3.210	77.441	b) Mumbai Drawl	22.757	496.791
3) TPCL Gas	4.133	83.213	c) MSEDCL Bilateral *	31.086	644.626
4) R-INFRA Thermal	11.423	231.864	Include PX	-0.284	-70.063
D) STATE			d) Mumbai Bilateral *	17.896	359.748
1) Thermal	265.513	5618.477	Include PX	2.159	21.916
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	10.503	203.329	H) ENERGY CATERED (MUs)		
3) Gas	14.739	300.453	1) MSEDCL	352.217	7448.407
4) Wind	4.268	151.006	2) Mumbai Discoms	51.240	1071.650
6) SOLAR	1.220	27.075	TOTAL STATE	403.457	8520.057
TOTAL STATE	296.243	6300.340			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4992	4933	4943	4126
MSPGCL Hydro	1098	243	172	107
MSPGCL Gas	445	417	438	454
MSPGCL Total Generation	6535	5593	5553	4687
Central Sector Receipt	4779	5090	4645	3540
WIND	21	67	203	285
CPP / IPP	5812	5923	6001	4851
SOLAR	140	198	0	0
Exchange with Mumbai	-1096	-1142	-1222	-570
MSEDCL DEMAND MET	16191	15729	15180	12793
Load Shedding	4	4	5	4
MSEDCL DEMAND	16195	15733	15185	12797
TPCL GENERATION	1034	1029	724	463
R-INFRA GENERATION	515	517	517	404
MUMBAI DEMAND	2645	2688	2463	1437
STATE DEMAND MET	18836	18417	17643	14230
STATE DEMAND	18840	18421	17648	14234
Frequency (Hz)	49.97	49.93	49.97	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 18:02 Hrs	49.68 Hz at 12:38 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 22/Feb/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	62.24	0	0
Unit 6	0.00	0.00	0	0
Unit 7	3.56	15.35	170	130
Unit 8	8.52	127.69	370	345
Total	12.09	205.29		
Bhusawal				
Unit 2	4.08	87.92	180	160
Unit 3	4.12	77.94	185	165
Unit 4	0.00	121.46	0	0
Unit 5	10.18	170.56	500	350
Total	18.38	457.90		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	4.40	76.34	202	148
Unit 4	4.39	91.40	202	160
Unit 5	10.23	205.33	475	365
Unit 6	0.00	196.73	0	0
Unit 7	9.98	149.06	456	360
Total	29.00	718.86		
Paras				
Unit 3	5.59	106.88	256	186
Unit 4	5.59	108.07	258	190
Total	11.18	214.94		
Khaparkheda				
Unit 1	4.06	80.36	190	155
Unit 2	4.07	74.07	185	155
Unit 3	4.40	65.92	201	159
Unit 4	4.02	85.58	191	157
Unit 5	10.87	217.34	500	366
Total	27.43	523.28		
Nasik				
Unit 3	4.42	56.64	205	160
Unit 4	4.27	89.81	195	160
Unit 5	4.34	84.91	200	160
Total	13.02	231.36		
Uran				
All Units	10.61	217.24	456	417
Total	10.61	217.24		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.90	11.17	43	10
Total	0.90	11.17		
Koyna				
Stage 1-2	3.64	47.99	540	40
Stage 4	0.70	8.14	230	0
Stage 3	1.35	13.52	160	0
Total	5.69	69.66		
Hydro				
KDPH	0.62	8.97	36	17
VTRNA	0.00	0.28	0	0
TILLARI	0.17	1.69	62	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.10	4.87	40	0
RNGR+BHTSA	0.25	4.84	11	10
BHANDARDRA	0.00	4.89	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.47	15.51	20	19
GHATGHAR	0.00	15.18	0	0
Total	1.60	56.23		
Wind				
Total	4.27	151.01	0	0
Total	4.27	151.01		
CPP				
APML(Mus)	66.48	1342.90	0	0
JSWEL(Mus)	25.09	549.25	0	0
VIPL(Mus)	12.51	216.72	0	0
RPLAMT(Mus)	16.72	442.85	0	0
WPCL(Mus)	2.93	98.76	0	0
Other(Mus)	9.55	198.90	0	0
Total	133.27	2849.38		
SOLAR				
Total	1.22	27.08	0	0
Total	1.22	27.08		
Tata				
Trombay 5	9.72	146.57	494	314
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.58	51.01	115	89
Trombay 7B	1.56	32.20	68	58
Trombay 8	0.00	35.77	0	0
TATA Hydro	3.21	77.44	420	0
Total	17.06	343.00		
R-INFRA				
1-2	11.42	231.86	519	403
Total	11.42	231.86		

Infirm Power	Chandrapur 8	0.00	Koradi 9	0.00
---------------------	--------------	------	----------	------

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	111.10	2354.88
MSPGCL Thml+Gas	121.71	2572.12

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	7.29	125.89
MSPGCL Total	129.00	2698.01

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	4.34	56.13
State Total	296.24	6300.34

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 22/Feb/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	4116	107	453	4676	366	5005	0	4492	4195	-820	13422	5	13427	1689	15116	49.95
2	4125	107	454	4686	297	4864	0	4514	4139	-681	13305	4	13309	1548	14857	49.98
3	4113	107	435	4655	313	4858	0	4488	4021	-603	13244	4	13248	1470	14718	50.00
4	4126	107	454	4687	285	4851	0	4336	3540	-570	12793	4	12797	1437	14234	49.98
5	4104	107	455	4666	267	4770	0	4346	4661	-583	13781	4	13785	1452	15237	49.97
6	4414	237	454	5105	211	5088	0	4485	4352	-669	14087	4	14091	1567	15658	49.94
7	4754	117	452	5323	235	5515	0	4851	4964	-686	15351	4	15355	1764	17119	49.95
8	4923	575	456	5954	141	5704	11	4885	4866	-684	15992	4	15996	1938	17934	49.92
9	4954	570	446	5970	59	5773	58	4895	5117	-808	16169	4	16173	2168	18341	49.96
10	4977	972	444	6393	40	5791	120	4909	4930	-913	16361	4	16365	2427	18792	49.96
11	4992	1098	445	6535	21	5812	140	5009	4779	-1096	16191	4	16195	2645	18840	49.97
12	4971	764	425	6160	27	5869	185	5061	4878	-1149	15970	4	15974	2693	18667	49.93
13	4933	243	417	5593	67	5923	198	5084	5090	-1142	15729	4	15733	2688	18421	49.93
14	4822	218	417	5457	141	5702	153	5060	4720	-1068	15105	5	15110	2499	17609	50.01
15	4710	466	422	5598	131	5550	153	5029	5036	-1053	15415	5	15420	2501	17921	49.94
16	4807	567	424	5798	167	5782	114	5025	4814	-1073	15602	5	15607	2500	18107	49.96
17	4973	106	431	5510	194	5976	62	4972	4324	-1147	14919	5	14924	2518	17442	49.98
18	4931	86	437	5454	241	5984	26	4127	3450	-1172	13983	5	13988	2466	16454	49.99
19	4947	113	439	5499	240	6001	0	4234	3365	-1168	13937	5	13942	2437	16379	49.94
20	4943	172	438	5553	203	6001	0	5056	4645	-1222	15180	5	15185	2463	17648	49.97
21	4727	172	447	5346	183	5883	0	4964	4041	-1184	14269	5	14274	2364	16638	49.98
22	4273	93	454	4820	176	5685	0	4658	4262	-1229	13714	5	13719	2163	15882	49.96
23	4259	92	452	4803	132	5485	0	4615	4547	-1125	13842	5	13847	2026	15873	49.96
24	4210	97	455	4762	131	5397	0	4615	4478	-912	13856	5	13861	1817	15678	49.99
MUs	111.10	7.29	10.61	129.00	4.27	133.27	1.22	113.71	107.21	-22.76	352.22	0.11	352.32	51.24	403.56	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 22/Feb/2016

Position as on 6.30 Hrs of 23/Feb/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CENT.SECTOR	Tarapur 2	160	10/09/2015	12.55		Continued.	Refuelling work	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 3	210	14/06/2015	12.58		Continued.	Water Shortage	
IPP	WPCL U-2	135	16/06/2015	00.00		Continued.	No Schdule	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown	
MSPGCL	Chandrapur Unit-8	500	10/11/2015	12.10		Continued.	Drum level low	
RGPPL	Dabhol 3B	230	07/01/2016	17:51		Continued.	Change Over.	
MSPGCL	Chandrapur Unit 2	210	12/01/2016	04.47		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit 5	108	19/01/2016	14.34		Continued.	Overhauling	
RGPPL	Dabhol 3X	290	03/02/2016	15:36		Continued.	Change Over	
TPC_G	Trombay 8	250	07/02/2016	17.40		Continued.	Boiler Maintenance Work,Bearing Inspection.	
MSPGCL	Ghatghar Unit-2	125	09/02/2016	18.00		Continued.	oil filtration work.	
MSPGCL	Bhusawal Unit 4	500	14/02/2016	12.10		Continued.	Zero Schedule Given by MSEDCL.	
MSPGCL	Ghatghar Unit-1	125	15/02/2016	00.00		Continued.	Attending Water valve Leakage.	
IPP	RPL(AMT) U-2	270	16/02/2016	01.14		Continued.	Due to Zero Schedule Given by MSEDCL.	
IPP	RPL(AMT) U-3	270	16/02/2016	01.17		Continued.	Due to Zero Schedule Given by MSEDCL.	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	Change Over , No Schedule	
MSPGCL	Koradi Unit 5	200	18/02/2016	11.21		Continued.	MSEDCL Zero Shedule.	
CENT.SECTOR	TARAPUR 4	540	21/02/2016	10:33		Continued.	Transient Electric fault in Nuclear reactor.	
MSPGCL	Chandrapur Unit 6	500	21/02/2016	15.19		Continued.	Boiler Tube Leakage	
CPP	WPCL U-4	135	22/02/2016	04.14	22/02/2016	11.15	R Ph CT Burst @ 220KV Warora of Wardha Ckt.	
IPP	WPCL U-3	135	22/02/2016	04.14	22/02/2016	14.40	R Ph CT Burst @ 220KV	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Feb/2016

Position as on 6.30 Hrs of 23/Feb/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							Warora of Wardha Ckt.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Feb/2016

Statement-VII

Position as on 6.30 Hrs of 23/Feb/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi III - Akola II- ckt-II	IntraState	19/02/2016	09:28		Continued.	PO	Annual Maintenance Work
400 KV LINE Outages/Trippings							
Dhule Sar'Sarovar I	InterState	21/02/2016	17.20	22/02/2016	06.41	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	21/02/2016	17.33	22/02/2016	06.36	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	22/02/2016	09.06	23/02/2016	06.48	PO	Maintenance Work.
Dhule Sar'Sarovar II	InterState	22/02/2016	10.10	22/02/2016	16.33	PO	PID Testing.
Akola Aurangabad(PG) I	InterState	22/02/2016	13.46	22/02/2016	16.48	HT	Remove L/R @ Aurangabad PG End
Kolhapur Solapur (PG) II	InterState	22/02/2016	21.36	23/02/2016	06.52	HT	Over Voltage
Akola II - Taptitanda ckt-II	IntraState	31/12/2015	18.16		Continued.	HT	Change over
Bhusawal-Aurangabad	IntraState	11/02/2016	14.05		Continued.	HT	Over Voltage
Babhaleshwar-Taptitanda ckt-II	IntraState	11/02/2016	18.40		Continued.	HT	CHANGE OVER
karad -kolhapur-I	IntraState	21/02/2016	16.03	22/02/2016	08.42	HT	Over Voltage
Karad - Jaigad - II	IntraState	21/02/2016	16.39	22/02/2016	08.45	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	21/02/2016	17.25	22/02/2016	08.56	HT	Over Voltage
Chandrapur-Parali III	IntraState	22/02/2016	08.30	22/02/2016	21.04	PO	Line Spacer & Vibration Damper Work.
Padghe - Kalwa- I	IntraState	22/02/2016	09.02	22/02/2016	18.37	PO	OPGW Work.
Khadka - Bableswhar	IntraState	22/02/2016	11.50	22/02/2016	18.48	EO	Bus Bar Zone-II CT Blocked Indication Arrived.
N.Koyna-Karad -Ckt II	IntraState	22/02/2016	16.11		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	22/02/2016	17.23		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220 Kv 315 Mva Ict -2 @New Koyana	IntraState	22/02/2016	09.45	22/02/2016	20.53	PO	R Ph Unit Filtration.
400/220 Kv 500 MVA ICT 3 @Kolhapur	IntraState	22/02/2016	09.54	22/02/2016	20.43	PO	Diagnostic Testing & Maintenance Work.
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	23/02/2016	00.47	23/02/2016	01.03	EO	Emergency Shifting of Oil Tank Required @ 220KV Boiser S/S.
220 KV LINE Outages/Trippings							
Hingoli- Girawali	InterState	14/02/2016	12.37		Continued.	HT	To Improve Voltage @ Hingoli.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Kalwa - Borivali	IntraState	10/01/2016	09:15		Continued.	PO	Tower Erection Work.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Padghe - Vasai	IntraState	24/01/2016	08.32		Continued.	PO	For Formation of Temp. Padgha-Borivali (Charge upto 51/1).
Bableswhar- Alephata	IntraState	03/02/2016	06.28		Continued.	HT	controlling bblsr ICT Overloading
Bableswhar- Ranjangaon	IntraState	03/02/2016	07.12		Continued.	HT	controlling bblsr ICT Overloading
Padghe - Jambhul 1	IntraState	19/02/2016	15.10		Continued.	PO	Strengthening of A and B Bus structure(For 8 Days),Taken on TBC.
Salsette Borivli 2	IntraState	21/02/2016	07.58	22/02/2016	08.55	PO	Routine Maintenance Work
Hinjawadi I- Chinchwad	IntraState	21/02/2016	20.31	22/02/2016	05.20	HT	Chinchwad Outage.
Chakan-Chinchwad	IntraState	21/02/2016	20.49	22/02/2016	05.03	PO	Narrow Base Multi Circuit Tower Work.
Telco- Chinchwad	IntraState	21/02/2016	21.05	22/02/2016	05.07	PO	Narrow Base Multi Circuit Tower Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Feb/2016

Statement-VII

Position as on 6.30 Hrs of 23/Feb/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Warora - Warora Rly Tss 2	IntraState	22/02/2016	04.14	22/02/2016	05.35	T	R Ph CT Burst,Bus Bar Operated(Warora,Wani,WPCL Gen. Affected).
Wpcl-Warora 2	IntraState	22/02/2016	04.14	22/02/2016	05.44	T	R Ph CT Burst,Bus Bar Operated(Warora,Wani,WPCL Gen. Affected).
V Warora - Waroralytss1	IntraState	22/02/2016	04.14	22/02/2016	06.19	T	R Ph CT Burst,Bus Bar Operated(Warora,Wani,WPCL Gen. Affected).
Warora - Wardha	IntraState	22/02/2016	04.14		Continued.	T	R Ph CT Burst,Bus Bar Operated(Warora,Wani,WPCL Gen. Affected).
Warora - Hinganghat	IntraState	22/02/2016	04.14	22/02/2016	05.33	T	R Ph CT Burst,Bus Bar Operated(Warora,Wani,WPCL Gen. Affected).
Wpcl-Warora 1	IntraState	22/02/2016	04.14	22/02/2016	05.44	T	R Ph CT Burst,Bus Bar Operated(Warora,Wani,WPCL Gen. Affected).
Flagship-Nandedcity	IntraState	22/02/2016	05.19	22/02/2016	21.30	HT	Control Line Loading.
Miraj - Ichalkaranji II	IntraState	22/02/2016	09.07		Continued.	HT	To Control Loading of ICT @ Kolhapur TO Avail Outage.
Kalwa - Airoli Knowledge Park	IntraState	22/02/2016	10.00	22/02/2016	16.02	PO	Diagnostic Testing & Maintenance Work.
Gorai MSETCL Borivali Line-1	IntraState	22/02/2016	10.40	22/02/2016	14.47	PO	Annual Maintenance Work
Karad(400kv) -Nigade	IntraState	22/02/2016	11.21	22/02/2016	18.00	PO	Line Signature Analysis.
Waluj - Jalna 1	IntraState	22/02/2016	11.47	22/02/2016	14.38	PO	Fixing of Repair Sleeves.
Karad - Kadegaon	IntraState	22/02/2016	13.15	22/02/2016	13.31	T	Distance Protection
Karad - Kadegaon	IntraState	22/02/2016	13.46	22/02/2016	16.33	T	Distance Protection
Padghe - Jindal	IntraState	22/02/2016	14.14	22/02/2016	20.20	PO	Testing Work
Chikhli-Jalna-II	IntraState	22/02/2016	15.05		Continued.	HT	For Akola ICT Over Loading.
Chikhli-Jalna-I	IntraState	22/02/2016	15.05		Continued.	HT	For Akola ICT Over Loading.
Chakan-Chinchwad	IntraState	22/02/2016	21.34	23/02/2016	05.43	PO	M/C Tower Erection Work.
Telco- Chinchwad	IntraState	22/02/2016	21.56	23/02/2016	05.47	PO	M/C Tower Erection Work.
Flagship-Nandedcity	IntraState	23/02/2016	05.34		Continued.	HT	Control Line Loading.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 Kv 200 Mva Ict - 2 @Harangul	IntraState	15/02/2016	13.04		Continued.	PO	Work of Oil Filtration of ICT.
220/33kV 100 MVA ICT-II @ Boisar	IntraState	20/02/2016	14.51		Continued.	T	Differential Protn.Optd./Internal Fault.Declared Faulty.
220/33kV 100 MVA Transformer 1 @Ghodbunder R/S	IntraState	22/02/2016	09.17	22/02/2016	19.46	PO	Annual Maintenance Work
132 KV LINE Outages/Trippings							
Chinchwad-Rahatani	IntraState	22/02/2016	13.31		Continued.	T	Distance Protection R Pole Burst.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage