

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Feb/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	138.732	3397.675	1) Gujrat	-4.781	-172.456
2) Hydro	27.087	351.177	2) Madhya Pradesh	9.911	124.709
3) Gas	3.952	172.796	3) Chattisgarh	6.180	144.160
Total MSPGCL	169.771	3921.648	4) Maharashtra	177.344	3196.401
B) 1) APLM	54.585	1393.330	5) Goa (Amona)	-1.646	-31.230
2) JSWEL	14.982	317.993	Total	187.008	3261.584
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.473	445.524
4) RPL(AMT)	25.227	598.362	b) Mumbai Drawl	27.061	505.177
5) SWPGPL	9.184	186.333	c) MSEDCL Bilateral *	82.038	1547.569
6) Other IPP	40.384	891.642	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.469	444.927
C) 1) TPCL Thermal	10.696	200.160	Include PX	0.000	0.000
2) TPCL Hydro	4.285	82.603	Standby	0.004	0.597
3) TPCL Gas	2.181	78.634	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.763	182.460	1) MSEDCL	480.283	10269.822
D) STATE			2) Mumbai Discoms	50.986	1049.035
1) Thermal	300.553	7167.955	3) Other Discoms	8.505	182.768
(A1+C1+C4+(B1-B6))			TOTAL STATE	539.774	11501.625
2) Hydro (A2+C2)	31.372	433.780			
3) Gas (A3+B7+C3)	6.133	251.430			
4) Wind	5.442	199.996			
6) SOLAR	9.266	186.879			
TOTAL STATE	352.766	8240.040			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	5997	6030	5578	5682
MSPGCL Hydro	1681	1036	1721	340
MSPGCL Gas	254	223	158	151
MSPGCL Total Generation	7932	7289	7457	6173
Central Sector Receipt	9309	9438	7404	6659
WIND	144	87	221	247
CPP / IPP Thermal	5949	5918	5985	5913
CPP / IPP Gas	0	0	0	0
SOLAR	1259	1282	0	0
Exchange with Mumbai	-1533	-1570	-1129	-894
MSEDCL DEMAND MET	22795	22183	19678	17916
Load Shedding	0	0	0	0
MSEDCL DEMAND	22795	22183	19678	17916
TPCL GENERATION	820	717	1039	504
AEML GENERATION	279	282	283	282
MUMBAI DEMAND	2632	2569	2451	1680
OTHER DISCOM DEMAND	393	387	387	307
STATE DEMAND MET	25820	25139	22516	19903
STATE DEMAND	25820	25139	22516	19903
Frequency (Hz)	50.05	50.05	50.02	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 12:02 Hrs	49.55 Hz at 07:15 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 22/Feb/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.02	82.66	180	155
Unit 7	0.00	0.00	0	0
Unit 8	13.05	303.51	592	511
Unit 9	0.00	268.33	0	0
Unit 10	12.07	277.58	515	490
Total	29.14	932.08		
Bhusawal				
Unit 3	0.00	64.29	0	0
Unit 4	9.82	61.90	495	345
Unit 5	9.95	218.10	480	350
Total	19.78	344.29		
Parli				
Unit 6	3.86	86.71	171	150
Unit 7	3.77	87.63	173	144
Unit 8	3.62	83.54	172	141
Total	11.25	257.89		
Chandrapur				
Unit 3	4.38	59.15	186	180
Unit 4	4.13	49.83	175	150
Unit 5	7.55	162.08	335	265
Unit 6	0.00	120.17	0	0
Unit 7	9.12	182.44	410	300
Unit 8	0.00	213.08	0	0
Unit 9	9.92	218.80	426	387
Total	35.10	1005.55		
Paras				
Unit 3	3.41	104.31	224	0
Unit 4	5.74	102.52	244	234
Total	9.16	206.83		
Khaparkheda				
Unit 1	3.49	70.64	155	115
Unit 2	3.44	42.63	150	130
Unit 3	4.36	84.63	194	134
Unit 4	4.05	74.32	181	155
Unit 5	11.22	233.43	500	440
Total	26.56	505.66		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.08	77.11	188	127
Unit 5	3.67	68.27	175	123
Total	7.74	145.38		
Uran				
All Units	3.95	172.80	254	141
Total	3.95	172.80		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.16	4.71	37	0
Total	0.16	4.71		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	6.06	63.35	475	35
Stage 4	9.90	80.13	754	0
Stage 3	3.34	31.12	240	0
Total	19.30	174.60		
Hydro				
KDPH	0.43	13.20	18	18
VTRNA	0.00	14.56	0	0
TILLARI	0.52	10.27	58	0
BHIRA T.R.	0.28	4.44	80	0
SMLHY_PTN	6.55	124.33	292	257
GHATGHAR	0.00	9.79	0	0
Total	7.79	176.58		
Wind				
Total	5.44	200.00	0	0
Total	5.44	200.00		
CPP				
APML(Mus)	54.58	1393.33	0	0
JSWEL(Mus)	14.98	317.99	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.23	598.36	0	0
SWPGPL-Mus	9.18	186.33	0	0
Other(Mus)	40.38	891.64	0	0
Total	144.36	3387.66		
SOLAR				
Total	9.27	186.88	0	0
Total	9.27	186.88		
Tata				
Trombay 5	7.10	119.74	380	256
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.19	47.85	64	44
Trombay 7B	0.99	30.78	50	37
TATA Hydro	4.28	82.60	402	0
Trombay 8	3.59	80.42	209	130
Total	17.16	361.40		
AEMIL				
DTPS U-1&2	6.76	182.46	286	279
Total	6.76	182.46		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	138.73	3397.68	MSPGCL Total	169.77	3921.65
			MSPGCL Thml+Gas	142.68	3570.47	Koyna 1,2 & 4 Total	15.96	143.48
			MSPGCL Hydro	27.09	351.18	State Total	352.77	8240.04

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 22/Feb/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5682	340	151	6173	247	6038	0	0	6804	6659	-894	17916	0	17916	1680	307	19903	49.98
2	5734	328	151	6213	338	6122	0	0	6663	6592	-787	18200	0	18200	1568	278	20046	50.00
3	5793	330	162	6285	322	6045	0	0	6688	6553	-704	18250	0	18250	1489	251	19990	50.00
4	5731	324	152	6207	274	5956	0	0	6951	6759	-678	18248	0	18248	1463	270	19981	49.99
5	5790	338	152	6280	264	5978	0	0	6937	6981	-670	18560	0	18560	1460	273	20293	50.02
6	5809	1123	163	7095	302	6005	0	0	6914	6846	-746	19194	0	19194	1567	308	21069	49.99
7	5807	1635	152	7594	268	6106	0	5	6427	7301	-720	20211	0	20211	1728	343	22282	49.82
8	5848	1770	163	7781	232	6085	0	153	6623	7440	-690	20650	0	20650	1933	351	22934	49.84
9	6002	1725	151	7878	174	6088	0	535	7735	8058	-858	21492	0	21492	2213	383	24088	50.06
10	6009	1642	210	7861	199	6062	0	878	8432	8751	-1181	22186	0	22186	2445	384	25015	50.04
11	6011	1698	236	7945	191	6090	0	1118	9242	9240	-1398	22794	0	22794	2597	392	25783	50.04
12	5997	1681	254	7932	144	6077	0	1259	9256	9309	-1533	22795	0	22795	2632	393	25820	50.05
13	6030	1036	223	7289	87	6044	0	1282	9676	9438	-1570	22183	0	22183	2569	387	25139	50.05
14	6032	803	143	6978	92	6000	0	1232	9313	9653	-1472	22096	0	22096	2441	387	24924	50.02
15	5989	742	141	6872	85	5974	0	1139	9648	9731	-1481	21944	0	21944	2458	376	24778	50.01
16	5852	940	141	6933	75	5948	0	885	9683	9726	-1515	21654	0	21654	2494	398	24546	49.90
17	5690	1497	153	7340	56	6018	0	578	8522	8796	-1481	20909	0	20909	2488	398	23795	49.98
18	5664	1634	146	7444	107	6035	0	195	7252	7709	-1317	19780	0	19780	2450	393	22623	49.98
19	5585	1528	145	7258	159	6070	0	7	7169	7222	-1177	19137	0	19137	2432	402	21971	50.00
20	5578	1721	158	7457	221	6112	0	0	7396	7404	-1129	19678	0	19678	2451	387	22516	50.02
21	5578	1399	148	7125	346	6109	0	0	6818	6869	-1346	18721	0	18721	2324	382	21427	50.00
22	5547	919	148	6614	369	6024	0	0	6779	6819	-1331	18124	0	18124	2190	371	20685	50.02
23	5452	1374	159	6985	470	5768	0	0	6268	6265	-1262	17861	0	17861	2029	365	20255	50.00
24	5522	560	150	6232	420	5608	0	0	7173	6887	-1121	17697	0	17697	1885	329	19911	49.98
MUs	138.73	27.09	3.95	169.77	5.44	144.36	0.00	9.27	184.37	187.01	-27.06	480.28	0.00	480.28	50.99	8.50	539.77	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 22/Feb/2022

Position as on 6.30 Hrs of 23/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
IPP	JSW (J) U4	300	14/02/2022	16:08		Continued.	No Schedule	
IPP	RPL(AMT) U-3	270	16/02/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 6	500	16/02/2022	23:20		Continued.	Turbine bearing Vibration high	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-2	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Koyna Unit 9	80	19/02/2022	10:50		Continued.	Stator Earth Fault	
MSPGCL	Bhusawal Unit 3	210	20/02/2022	22:03		Continued.	Coal Shortage	
MSPGCL	Uran Unit 6	108	21/02/2022	00:37		Continued.	Gas shortage	
IPP	Adani U-2	660	21/02/2022	01:11		Continued.	APH-B support bearing abnormal sound	
MSPGCL	Chandrapur Unit 8	500	21/02/2022	04:40		Continued.	Furnace Pressure High	
MSPGCL	Koradi Unit 9	660	21/02/2022	12:42		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit 5	108	21/02/2022	21:57		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	21/02/2022	21:57		Continued.	Gas shortage	
MSPGCL	Koyna STG-IV Unit-4	250	22/02/2022	05:37	22/02/2022	21:55	Excitation Transformer Differential fault along with Excitation Major fault	22/02/2022
MSPGCL	Paras Unit 3	250	22/02/2022	15:45		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Feb/2022

Position as on 6.30 Hrs of 23/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	Adani U-5	660	22/02/2022	22:14		Continued.	Furnace Pressure High	
TPC-G	Trombay 7B	60	23/02/2022	02:12		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	23/02/2022	02:22		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 23/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (712) OF AKOLA CKT - 2 @ KORADI 3	IntraState	22/02/2022	10:24	22/02/2022	18:55	PO	Annual Maintenance of Bay Equipments
500 KV TBC Outages/Trippings							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	21/02/2022	21:17	22/02/2022	01:23	EO	for urgent attending hotspot of temprature 223 deg and hotspot having temprature in between 100 -150 deg.
400 KV MAINBAY Outages/Trippings							
TBC @ Lonikand-1	IntraState	22/02/2022	12:30			EO	400 kv B ph CT replacement due to oil leakage.
400 KV LINE Outages/Trippings							
KARAD - SOLAPUR (PG)	InterState	22/02/2022	08:50				Commissioning of 400 kv 80 MVA Kanohar make line shunt reactor with allied equipments under LE scheme
THAPTI TANDA - WALUJ	IntraState	01/02/2022	13:01			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
DEEPNAGAR - THAPTI TANDA	IntraState	01/02/2022	13:11			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	04/02/2022	14:43			HT	H/T TO CONTROL 400KV TALEGAON PG -CHAKAN LINE LOADING.
NEW KOYNA - STAGE IV CKT - 2	IntraState	19/02/2022	10:01			PO	C.B. Overhauling work Shitting on TBC
RPL(AMT) NANDGAON PETH - AKOLA II LINE II	IntraState	21/02/2022	13:17	22/02/2022	01:25	PO	Annual Maintenance of Line Equipments
CHANDRAPUR 2 - CHD SWITCHING CKT - 2	IntraState	22/02/2022	12:14	22/02/2022	19:04	EO	For replacement of damaged conductor on line CT at 400/220 KV Chandrapur 2 Substation & also diagnostic testing work at both substations(400KV Chandrapur-2 & 400KV Switching S/stn)
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	23/02/2022	07:21			PO	for replacement of polymer insulator by Long Rod porcelain insulator.
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	21/02/2022	11:40			PO	1) ICT Painting Work 2)Diagnostic Testing Work 3) Routine Maintenance Work
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	21/02/2022	11:40			PO	220kv CB overhauling work
400/220 KV 500 MVA ICT @ ALKUD	IntraState	22/02/2022	10:18	22/02/2022	17:29	PO	QM Work
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	22/02/2022	16:36	22/02/2022	18:57	EO	To attend Hot Spot
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 23/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GOREGAON - AAREY CKT - 2	IntraState	15/02/2022	09:20			PO	Under MMRC Line Diversion scheme for Metro-3 project 220kV Outdoor termination of 220kV AEML Aarey and overhead connection at MMRC pylon yard .
BORIVALI - TARAPUR	IntraState	18/02/2022	09:16			PO	1. Dismantling of existing loc.no. 37, erection proposed on loc.37a & 38a. 2.Railway crossing stringing between loc.no.36 & 37a-38a-38
BOISAR II - TARAPUR	IntraState	18/02/2022	09:33			PO	1. Dismantling of existing loc.no. 37, erection proposed on loc.37a & 38a. 2.Railway crossing stringing between loc.no.36 & 37a-38a-38
GHODBUNDER - GORAI	IntraState	20/02/2022	03:56			PO	Project activity 1) Modification / relocation of existing tower no LS 275 to 277 at Mira Road for Metro 09 Project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable
VERSOVA - GHODBUNDER	IntraState	20/02/2022	04:00			PO	Project activity 1) Modification / relocation of existing tower no LS 275 to 277 at Mira Road for Metro 09 Project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable
ALKUD - MENDHEGIRI CKT - 2	IntraState	21/02/2022	10:45			PO	Line maintenance work by M/s Suzlon
VARKUTI- HIWARWADI	IntraState	22/02/2022	08:57	22/02/2022	18:57	PO	Restranging of conductor & cold line washing work at Loc No.188 to 200
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	22/02/2022	10:16			PO	SHIFTING OF EXI. 220KV NAVSARI - NASIK LINE NO 1 & 2 (D/C)CROSSING AT NHRCL PRO.CH:- 233/720 (EXI. CROSSING CH:- 233/895)
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	22/02/2022	10:17			PO	SHIFTING OF EXI. 220KV NAVSARI - NASIK LINE NO 1 & 2 (D/C)CROSSING AT NHRCL PRO.CH:- 233/720 (EXI. CROSSING CH:- 233/895)
NIGADE- PETH LINE	IntraState	22/02/2022	10:19	22/02/2022	13:07	PO	B Ph CT oil leakage attending work & quarterly maintenance work
VITA - GHATNANDRE	IntraState	22/02/2022	11:03	22/02/2022	17:00	PO	String replacement at various locations
TROMBAY - SALSETTE CKT - 1	IntraState	22/02/2022	23:15	23/02/2022	06:09	PO	MERTO-4 WORK
TROMBAY SALSETTE LINE-2	IntraState	22/02/2022	23:15	23/02/2022	06:19	PO	METRO-4 WORK
KALWA SALSETTE - 3	IntraState	23/02/2022	06:28			PO	TREE TRIMMING
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 23/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferential protection and Declare faulty
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	IntraState	21/02/2022	20:50	22/02/2022	00:32	PO	For HV & LV CB CRM measurement
220/100 KV 200 MVA ICT 3 @ APTA	IntraState	22/02/2022	11:24	22/02/2022	16:12	PO	100 KV BUS 2 OUTAGE planned for testing of earlier commissioned busbar and bus side isolator & bus isolator nut bolt tightening work. Hence outage required on ICT -3 & 4
220/100 KV 200 MVA ICT 4 @ APTA	IntraState	22/02/2022	11:24	22/02/2022	16:53	PO	100 KV BUS 2 OUTAGE planned for testing of earlier commissioned busbar and bus side isolator & bus isolator nut bolt tightening work. Hence outage required on ICT -3 & 4
220/22 KV 50 MVA PTR 2 @ LONIKAND	IntraState	22/02/2022	11:40			PO	ATTENDING HOT SPOT ON 29A ISO B-PH BUS SIDE BY HOT LINE TEAM
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	22/02/2022	16:25	22/02/2022	20:30	PO	Tan delta testing of ICT & quarterly maintenance work
220 KV BUSBAR Outages/Trippings							
GIS BUS - 1 @ KARANJADE	IntraState	15/02/2022	08:59			PO	BUS-1 EXTENSION FOR REACTOR CONNECTION
MAIN BUS @ JATH	IntraState	22/02/2022	11:27	22/02/2022	17:05	PO	Bus bar relay testing work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage