

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 22/Mar/2022 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 161.690        | 3452.680        | 1) Gujrat                      | -5.668         | -135.867         |
| 2) Hydro            | 45.971         | 518.298         | 2) Madhya Pradesh              | 9.687          | 206.081          |
| 3) Gas              | 5.906          | 93.712          | 3) Chattisgarh                 | 4.710          | 115.080          |
| <b>Total MSPGCL</b> | <b>213.567</b> | <b>4064.690</b> | 4) Maharashtra                 | 162.893        | 3649.106         |
| B) 1) APLM          | 74.992         | 1606.028        | 5) Goa (Amona)                 | -1.526         | -28.409          |
| 2) JSWEL            | 20.486         | 430.352         | <b>Total</b>                   | <b>170.096</b> | <b>3805.991</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 25.242         | 620.167          |
| 4) RPL(AMT)         | 25.737         | 557.039         | b) Mumbai Drawl                | 27.511         | 672.220          |
| 5) SWPGPL           | 6.370          | 131.126         | c) MSEDCL Bilateral *          | 90.321         | 2146.909         |
| 6) Other IPP        | 39.265         | 860.465         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 25.216         | 619.956          |
| C) 1) TPCL Thermal  | 14.032         | 286.692         | Include PX                     | 0.000          | 5.604            |
| 2) TPCL Hydro       | 5.832          | 105.322         | Standby                        | 0.025          | 0.211            |
| 3) TPCL Gas         | 3.654          | 37.748          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 11.618         | 204.561         | 1) MSEDCL                      | 533.564        | 10991.464        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 62.645         | 1306.541         |
| 1) Thermal          | 354.190        | 7528.943        | 3) Other Discoms               | 8.788          | 191.795          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>604.997</b> | <b>12489.800</b> |
| 2) Hydro (A2+C2)    | 51.803         | 623.620         |                                |                |                  |
| 3) Gas (A3+B7+C3)   | 9.560          | 131.460         |                                |                |                  |
| 4) Wind             | 12.279         | 227.094         |                                |                |                  |
| 6) SOLAR            | 7.071          | 172.694         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>434.903</b> | <b>8683.811</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 24 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal             | 6603                      | 6620                  | 6768                      | 6796                       |
| MSPGCL Hydro               | 1833                      | 1492                  | 2282                      | 1868                       |
| MSPGCL Gas                 | 188                       | 177                   | 307                       | 229                        |
| MSPGCL Total Generation    | 8624                      | 8289                  | 9357                      | 8893                       |
| Central Sector Receipt     | 8755                      | 9013                  | 6358                      | 5919                       |
| WIND                       | 552                       | 303                   | 201                       | 372                        |
| CPP / IPP Thermal          | 7037                      | 7003                  | 7130                      | 7111                       |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                          |
| SOLAR                      | 1079                      | 1159                  | 0                         | 0                          |
| Exchange with Mumbai       | -1500                     | -1543                 | -1122                     | -1043                      |
| <b>MSEDCL DEMAND MET</b>   | <b>24154</b>              | <b>23826</b>          | <b>21533</b>              | <b>20918</b>               |
| Load Shedding              | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND              | 24154                     | 23826                 | 21533                     | 20918                      |
| TPCL GENERATION            | 1116                      | 1016                  | 1173                      | 964                        |
| AEML GENERATION            | 495                       | 490                   | 500                       | 482                        |
| <b>MUMBAI DEMAND</b>       | <b>3111</b>               | <b>3049</b>           | <b>2795</b>               | <b>2489</b>                |
| <b>OTHER DISCOM DEMAND</b> | <b>393</b>                | <b>397</b>            | <b>391</b>                | <b>334</b>                 |
| STATE DEMAND MET           | 27658                     | 27273                 | 24719                     | 23741                      |
| <b>STATE DEMAND</b>        | <b>27658</b>              | <b>27273</b>          | <b>24719</b>              | <b>23741</b>               |
| Frequency (Hz)             | 49.98                     | 49.98                 | 49.92                     | 49.71                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|----------------------|-----------------------|---------------|---------------------|
| 50.2 Hz at 18:02 Hrs | 49.55 Hz at 22:20 Hrs | 49.9          | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 22/Mar/2022

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 3.90         | 89.98          | 170      | 160      |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 14.33        | 302.17         | 607      | 584      |
| Unit 9             | 12.83        | 288.72         | 566      | 503      |
| Unit 10            | 10.80        | 222.13         | 515      | 384      |
| <b>Total</b>       | <b>41.86</b> | <b>903.01</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 44.63          | 0        | 0        |
| Unit 4             | 10.46        | 204.98         | 450      | 430      |
| Unit 5             | 10.47        | 71.88          | 450      | 425      |
| <b>Total</b>       | <b>20.93</b> | <b>321.49</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 6             | 5.33         | 101.60         | 250      | 208      |
| Unit 7             | 0.00         | 66.38          | 0        | 0        |
| Unit 8             | 3.73         | 74.57          | 163      | 146      |
| <b>Total</b>       | <b>9.05</b>  | <b>242.55</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 4.44         | 62.70          | 188      | 183      |
| Unit 4             | 4.08         | 86.67          | 172      | 168      |
| Unit 5             | 8.58         | 169.29         | 377      | 330      |
| Unit 6             | 9.67         | 124.20         | 420      | 380      |
| Unit 7             | 8.91         | 196.94         | 410      | 335      |
| Unit 8             | 10.71        | 187.06         | 465      | 425      |
| Unit 9             | 10.13        | 226.95         | 438      | 401      |
| <b>Total</b>       | <b>56.52</b> | <b>1053.81</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 5.09         | 115.10         | 255      | 204      |
| Unit 4             | 4.98         | 113.49         | 217      | 136      |
| <b>Total</b>       | <b>10.07</b> | <b>228.59</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.26         | 73.99          | 150      | 115      |
| Unit 2             | 3.42         | 77.88          | 160      | 130      |
| Unit 3             | 4.49         | 79.73          | 190      | 185      |
| Unit 4             | 4.30         | 89.27          | 190      | 160      |
| Unit 5             | 0.00         | 217.88         | 0        | 0        |
| <b>Total</b>       | <b>15.47</b> | <b>538.76</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.18         | 0.18           | 78       | 0        |
| Unit 4             | 4.44         | 90.20          | 193      | 162      |
| Unit 5             | 3.17         | 74.10          | 144      | 56       |
| <b>Total</b>       | <b>7.79</b>  | <b>164.48</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 5.91         | 93.71          | 316      | 141      |
| <b>Total</b>       | <b>5.91</b>  | <b>93.71</b>   |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.16         | 3.50           | 37       | 0        |
| <b>Total</b>       | <b>0.16</b>  | <b>3.50</b>    |          |          |
| <b>Koyna</b>       |              |                |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 8.66          | 113.30         | 535      | 95       |
| Stage 4         | 22.33         | 181.46         | 1010     | 740      |
| Stage 3         | 6.55          | 62.99          | 320      | 160      |
| <b>Total</b>    | <b>37.54</b>  | <b>357.75</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.86          | 14.49          | 36       | 36       |
| VTRNA           | 0.69          | 2.49           | 60       | 0        |
| TILLARI         | 0.23          | 2.49           | 58       | 0        |
| BHIRA T.R.      | 0.38          | 6.07           | 77       | 0        |
| SMLHY_PTN       | 6.12          | 131.51         | 266      | 241      |
| GHATGHAR        | 0.00          | 0.00           | 0        | 0        |
| <b>Total</b>    | <b>8.28</b>   | <b>157.05</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 12.28         | 227.09         | 0        | 0        |
| <b>Total</b>    | <b>12.28</b>  | <b>227.09</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 74.99         | 1606.03        | 0        | 0        |
| JSWEL(Mus)      | 20.49         | 430.35         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 25.74         | 557.04         | 0        | 0        |
| SWPGPL-Mus      | 6.37          | 131.13         | 0        | 0        |
| Other(Mus)      | 39.26         | 860.46         | 0        | 0        |
| <b>Total</b>    | <b>166.85</b> | <b>3585.01</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 7.07          | 172.69         | 0        | 0        |
| <b>Total</b>    | <b>7.07</b>   | <b>172.69</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 8.59          | 190.38         | 375      | 341      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.22          | 22.59          | 114      | 63       |
| Trombay 7B      | 1.44          | 15.16          | 67       | 51       |
| TATA Hydro      | 5.83          | 105.32         | 392      | 55       |
| Trombay 8       | 5.44          | 96.32          | 239      | 167      |
| <b>Total</b>    | <b>23.52</b>  | <b>429.76</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 11.62         | 204.56         | 500      | 408      |
| <b>Total</b>    | <b>11.62</b>  | <b>204.56</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 161.69      | 3452.68       | MSPGCL Total        | 213.57      | 4064.69       |
|                |             |         | MSPGCL Thml+Gas | 167.60      | 3546.39       | Koyna 1,2 & 4 Total | 30.98       | 294.76        |
|                |             |         | MSPGCL Hydro    | 45.97       | 518.30        | State Total         | 434.90      | 8683.81       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 22/Mar/2022

### Annexure-2

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | LOAD SHED DING | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|-------|-----------|------|-------|----------|----------|----------------|------------------|----------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |       | THM       | GAS  |       |          |          |                |                  |                |                      |               |                     |              |            |
| 1            | 6804        | 1818  | 309  | 8931   | 1109  | 7044      | 0    | 0     | 6118     | 6111     | -1001          | 21876            | 0              | 21876                | 2479          | 318                 | 24673        | 49.92      |
| 2            | 6817        | 1901  | 310  | 9028   | 967   | 7072      | 0    | 0     | 6100     | 6030     | -963           | 21838            | 0              | 21838                | 2307          | 296                 | 24441        | 49.94      |
| 3            | 6792        | 1907  | 300  | 8999   | 911   | 7040      | 0    | 0     | 5991     | 6144     | -809           | 22004            | 0              | 22004                | 2157          | 281                 | 24442        | 49.91      |
| 4            | 6791        | 1843  | 310  | 8944   | 763   | 6962      | 0    | 0     | 6243     | 6153     | -878           | 21661            | 0              | 21661                | 2051          | 283                 | 23995        | 49.86      |
| 5            | 6759        | 1978  | 316  | 9053   | 704   | 6989      | 0    | 0     | 6233     | 6292     | -761           | 21975            | 0              | 21975                | 2018          | 302                 | 24295        | 49.95      |
| 6            | 6752        | 1946  | 287  | 8985   | 712   | 7068      | 0    | 0     | 6479     | 6436     | -716           | 22168            | 0              | 22168                | 2060          | 317                 | 24545        | 49.88      |
| 7            | 6702        | 2001  | 141  | 8844   | 700   | 7036      | 0    | 3     | 6926     | 6873     | -766           | 22331            | 0              | 22331                | 2149          | 359                 | 24839        | 49.91      |
| 8            | 6723        | 1812  | 260  | 8795   | 730   | 7048      | 0    | 91    | 6812     | 6950     | -859           | 22368            | 0              | 22368                | 2267          | 387                 | 25022        | 50.00      |
| 9            | 6689        | 1904  | 241  | 8834   | 625   | 6959      | 0    | 269   | 6764     | 6912     | -1064          | 22143            | 0              | 22143                | 2529          | 392                 | 25064        | 49.94      |
| 10           | 6684        | 2108  | 259  | 9051   | 559   | 6876      | 0    | 562   | 7642     | 7703     | -1282          | 23072            | 0              | 23072                | 2820          | 397                 | 26289        | 49.82      |
| 11           | 6649        | 1902  | 159  | 8710   | 653   | 6960      | 0    | 844   | 8483     | 8548     | -1439          | 23856            | 0              | 23856                | 3035          | 420                 | 27311        | 49.91      |
| 12           | 6603        | 1833  | 188  | 8624   | 552   | 7037      | 0    | 1079  | 8726     | 8755     | -1500          | 24154            | 0              | 24154                | 3111          | 393                 | 27658        | 49.98      |
| 13           | 6620        | 1492  | 177  | 8289   | 303   | 7003      | 0    | 1159  | 9111     | 9013     | -1543          | 23826            | 0              | 23826                | 3049          | 397                 | 27273        | 49.98      |
| 14           | 6667        | 1619  | 190  | 8476   | 262   | 6692      | 0    | 998   | 8977     | 9406     | -1613          | 23837            | 0              | 23837                | 2912          | 383                 | 27133        | 50.00      |
| 15           | 6680        | 1702  | 226  | 8608   | 183   | 6802      | 0    | 882   | 9523     | 9282     | -1698          | 23671            | 0              | 23671                | 2950          | 388                 | 27009        | 49.91      |
| 16           | 6663        | 2069  | 204  | 8936   | 162   | 6789      | 0    | 642   | 8897     | 9091     | -1519          | 23699            | 0              | 23699                | 3020          | 402                 | 27121        | 49.77      |
| 17           | 6695        | 2151  | 205  | 9051   | 168   | 6383      | 0    | 381   | 8009     | 8280     | -1392          | 22451            | 0              | 22451                | 3002          | 420                 | 25873        | 49.85      |
| 18           | 6733        | 1967  | 231  | 8931   | 150   | 6566      | 0    | 142   | 7256     | 7170     | -1285          | 21258            | 0              | 21258                | 2913          | 416                 | 24587        | 49.98      |
| 19           | 6756        | 1931  | 237  | 8924   | 162   | 7033      | 0    | 18    | 6137     | 6194     | -1191          | 20728            | 0              | 20728                | 2841          | 412                 | 23981        | 49.99      |
| 20           | 6768        | 2282  | 307  | 9357   | 201   | 7130      | 0    | 0     | 6068     | 6358     | -1122          | 21533            | 0              | 21533                | 2795          | 391                 | 24719        | 49.92      |
| 21           | 6804        | 1961  | 306  | 9071   | 377   | 7098      | 0    | 0     | 5545     | 5437     | -1056          | 20530            | 0              | 20530                | 2671          | 397                 | 23598        | 49.83      |
| 22           | 6840        | 1960  | 297  | 9097   | 477   | 7075      | 0    | 0     | 5355     | 5242     | -973           | 20563            | 0              | 20563                | 2539          | 355                 | 23457        | 49.86      |
| 23           | 6903        | 2017  | 217  | 9137   | 477   | 7077      | 0    | 0     | 5513     | 5796     | -1038          | 21102            | 0              | 21102                | 2483          | 347                 | 23932        | 49.76      |
| 24           | 6796        | 1868  | 229  | 8893   | 372   | 7111      | 0    | 0     | 5718     | 5919     | -1043          | 20918            | 0              | 20918                | 2489          | 334                 | 23741        | 49.71      |
| MUs          | 161.69      | 45.97 | 5.91 | 213.57 | 12.28 | 166.85    | 0.00 | 7.07  | 168.63   | 170.10   | -27.51         | 533.56           | 0.00           | 533.56               | 62.65         | 8.79                | 605.00       | 49.90      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 22/Mar/2022**

**Position as on 6.30 Hrs of 23/Mar/2022**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                | Nasik Unit 3            | 210      | 26/01/2022   | 20:26        | 22/03/2022 | 21:07      | Annual Overhaul                                                                                                                                         |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                                                 |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                                                                                  |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/03/2023    |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                                                                                   |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 31/03/2023    |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 17/02/2022   | 21:55        |            | Continued. | SFC HEAVY FAULT                                                                                                                                         |               |
| IPP                   | SWPGPL U-4              | 135      | 25/02/2022   | 16:47        |            | Continued. | Turbine Vibration                                                                                                                                       |               |
| IPP                   | RPL(AMT) U-1            | 270      | 07/03/2022   | 02:39        |            | Continued. | Generator Protection operated. (from 15/03/2022 due to coal shortage)                                                                                   |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 11/03/2022   | 01:25        |            | Continued. | TRIPPED ON SFC HEAVY FAULT WHILE TAKING ON PUMPING MODE.( PUMPING TRIAL CARRIED OUT SUCCESSFULLY FROM 20:35HRS TO 22:35HRS DT.10/03/22 )                |               |
| MSPGCL                | Parli Unit 7            | 250      | 15/03/2022   | 23:10        |            | Continued. | Furnace Pressure High                                                                                                                                   |               |
| IPP                   | JSW (J) U1              | 300      | 16/03/2022   | 23:16        |            | Continued. | Turbine Vibration                                                                                                                                       |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 20/03/2022   | 07:00        |            | Continued. | Coal Shortage                                                                                                                                           |               |
| MSPGCL                | Khaparkhedda Unit 5     | 500      | 21/03/2022   | 09:14        |            | Continued. | suspected BTL                                                                                                                                           |               |
| MSPGCL                | Uran Unit A0            | 120      | 22/03/2022   | 05:59        |            | Continued. | Maintenance work                                                                                                                                        | 22/03/2022    |
| MSPGCL                | Uran Unit 6             | 108      | 22/03/2022   | 05:59        | 22/03/2022 | 07:03      | Maintenance work                                                                                                                                        | 22/03/2022    |
| MSPGCL                | Uran Unit 5             | 108      | 22/03/2022   | 05:59        | 22/03/2022 | 08:54      | CARD MALOPERATE                                                                                                                                         | 22/03/2022    |
| MSPGCL                | Uran Unit 5             | 108      | 22/03/2022   | 09:43        | 22/03/2022 | 17:47      | Fuel Gas valve issue.                                                                                                                                   |               |
| MSPGCL                | Uran Unit 5             | 108      | 22/03/2022   | 22:00        |            | Continued. | Gas shortage                                                                                                                                            |               |
| MSPGCL                | Koyna STG-IV Unit-4     | 250      | 22/03/2022   | 22:45        |            | Continued. | due to oil leakage through spiral case air drain valve                                                                                                  |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 22/Mar/2022**

Position as on 6.30 Hrs of 23/Mar/2022

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage      | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------|---------------|
|                    |                         |          |              |              |            |            | oil line              |               |
| MSPGCL             | Nasik Unit 5            | 210      | 22/03/2022   | 23:40        |            | Continued. | Withdrawn             |               |
| MSPGCL             | Koradi Unit 6           | 210      | 23/03/2022   | 06:58        | 23/03/2022 | 10:14      | Flame Failure         |               |
| MSPGCL             | Parli Unit 6            | 250      | 23/03/2022   | 08:00        | 23/03/2022 | 10:29      | Furnace Pressure High |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Mar/2022**

**Statement-VII**

Position as on 6.30 Hrs of 23/Mar/2022

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                       |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                        |
| CHANDRAPUR - PADGHE HVDC POLE 2           | IntraState                | 12/03/2022   | 15:01        | 23/03/2022 | 04:58      | T           | Pole-2 tripped at Padghe end. Black smoke observed near pole 2, B phase converter transformer's 3A bushing - turret. Fire looked external and it was extinguished in 10-15 minutes using fire tenders and fire hydrant |
| CHANDRAPUR - PADGHE HVDC POLE 2           | IntraState                | 23/03/2022   | 05:46        | 23/03/2022 | 08:20      | T           | B-phase Earth Fault Protection                                                                                                                                                                                         |
| <b>400 KV MAINBAY Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                                                                                                        |
| MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA  | IntraState                | 23/03/2022   | 12:50        |            |            | PO          | Diagnostic testing & Routine maintenance work                                                                                                                                                                          |
| <b>400 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                        |
| BABHALESHWAR - RPL(NSK) CKT - 2           | IntraState                | 21/03/2022   | 16:45        |            |            | PO          | for 400kV Quad Moose conductor's stringing work across the samruddhi Maha marg road.                                                                                                                                   |
| LONIKAND I - CHAKAN                       | IntraState                | 21/03/2022   | 22:29        | 22/03/2022 | 01:54      | EO          | Earth wire dislocated and fall on cross arm need to be fixed.                                                                                                                                                          |
| KARAD - TALANDGE CKT - 1                  | IntraState                | 22/03/2022   | 19:38        | 22/03/2022 | 23:21      | EO          | For replacement of faulty LBB Relay. Currently, LBB is bypassed.                                                                                                                                                       |
| <b>400 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                        |
| 400/220/33 KV 315 MVA ICT - 2 @ PARLI     | IntraState                | 22/03/2022   | 09:45        | 22/03/2022 | 17:03      | PO          | 1) IV Backup relay & CTs Testing work. 2) Bay maintenance work.                                                                                                                                                        |
| 400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2 | IntraState                | 22/03/2022   | 22:02        | 23/03/2022 | 00:04      | EO          | To attend hotspot of 70.3 deg C on Yph CT Line Side (LV Side Bay 205)                                                                                                                                                  |
| 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2 | IntraState                | 23/03/2022   | 00:37        | 23/03/2022 | 02:09      | EO          | To attend hotspot of 80.7 deg C on Rph CT Bus Side (LV Side CT Bay 204)                                                                                                                                                |
| 400/220 KV 315MVA ICT - 1 @ KARAD         | IntraState                | 23/03/2022   | 07:53        |            |            | PO          | Detailed internal inspection of 400/220 kv 105 MVA ICT 1 R ph unit due to rising trend in gases & possible thermal fault.                                                                                              |
| 400/220KV 105 MVA SPARE ICT @ KARAD       | IntraState                | 23/03/2022   | 10:14        |            |            | EO          | Spare ICT -1 will be taken into service through RRS in place of ICT-I R ph unit due to rising trend of various gases in ICT-I R ph unit                                                                                |
| <b>400 KV BR Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                        |
| 400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2  | InterState                | 23/03/2022   | 09:07        |            |            | PO          | Diagnostic testing and allied bay maintenance work                                                                                                                                                                     |
| <b>220 KV TIEBAY Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                        |
| MAIN BUS SECTION ISOLATOR @ KURKUMBH      | IntraState                | 23/03/2022   | 17:25        |            |            | PO          | ISOLATOR REPLACEMENT WORK                                                                                                                                                                                              |
| <b>220 KV TBC Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                        |
| TBC @ CHAKAN                              | IntraState                | 22/03/2022   | 10:44        | 22/03/2022 | 14:21      | PO          | For work of CB Testing                                                                                                                                                                                                 |
| <b>220 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                        |
| JEUR - SOLAPUR PG                         | InterState                | 23/03/2022   | 12:29        |            |            | PO          | Fixing of bird diverter                                                                                                                                                                                                |
| MULUND - GIS BHANDUP                      | IntraState                | 29/01/2022   | 15:44        |            |            | T           | CABLE FAULT                                                                                                                                                                                                            |
| PADGHE - KAMBA 2                          | IntraState                | 21/03/2022   | 20:28        | 22/03/2022 | 01:13      | EO          | abnormal Humming noise observed in B phase CT of 220kV Padghe-Kambha ckt-2 line at padghe end                                                                                                                          |
| FLAGSHIP-CHINCHWAD                        | IntraState                | 22/03/2022   | 10:05        | 22/03/2022 | 20:15      | PO          | CT replacement work due to Higher tan-delta values in LE scheme                                                                                                                                                        |
| PETH- MUDSHINGI 1 LINE                    | IntraState                | 22/03/2022   | 10:27        | 22/03/2022 | 11:50      | PO          | R Ph CT oil leakage attending work                                                                                                                                                                                     |
| LAMBOTI - SOLAPUR 2(BALE) CKT-2           | IntraState                | 22/03/2022   | 12:47        | 22/03/2022 | 13:49      | T           | TRIPPED ON DIST.PROTN                                                                                                                                                                                                  |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Mar/2022**

**Statement-VII**

Position as on 6.30 Hrs of 23/Mar/2022

| Name of Line                                    | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                   |
|-------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| LAMBOTI - SOLAPUR 2(BALE) CKT - 1               | IntraState                | 22/03/2022   | 13:10        | 22/03/2022 | 13:48      | T           | TRIPPED ON DIST.PROTN                                                                                                                                                                                                                              |
| LONIKAND1-LONIKAND2 (INTER CONNECTOR)           | IntraState                | 22/03/2022   | 17:02        | 22/03/2022 | 18:26      | EO          | To attend hotspot of 104 deg C on 29D Iso CB side                                                                                                                                                                                                  |
| LONIKAND 2 - BHOSARI                            | IntraState                | 23/03/2022   | 05:45        | 23/03/2022 | 06:30      | T           | LBB OPERATE AT BHOSARI S/STN                                                                                                                                                                                                                       |
| CHAKAN-BHOSARI 1                                | IntraState                | 23/03/2022   | 05:48        | 23/03/2022 | 06:30      | T           | LBB OPERATE AT BHOSARI S/STN                                                                                                                                                                                                                       |
| BHOSARI- BHOSARI 2                              | IntraState                | 23/03/2022   | 05:48        | 23/03/2022 | 06:30      | T           | LBB OPERATE AT BHOSARI S/STN                                                                                                                                                                                                                       |
| CENTURI ENKA- BHOSARI                           | IntraState                | 23/03/2022   | 05:48        | 23/03/2022 | 06:30      | T           | LBB OPERATE AT BHOSARI S/STN                                                                                                                                                                                                                       |
| PARANDA-BARSHI                                  | IntraState                | 23/03/2022   | 09:37        | 23/03/2022 | 13:46      | PO          | Outage is required for Quarterly Maintenance                                                                                                                                                                                                       |
| TALANDAGE - FIVE STAR MIDC 2                    | IntraState                | 23/03/2022   | 10:15        |            |            | PO          | For overhauling work of CB                                                                                                                                                                                                                         |
| BUS SECTIONIZER @ BIDRI                         | IntraState                | 23/03/2022   | 10:30        | 23/03/2022 | 12:45      | PO          | For QMW                                                                                                                                                                                                                                            |
| GHODBUNDER - MSETCL BOISAR                      | IntraState                | 23/03/2022   | 13:17        | 23/03/2022 | 16:28      | T           | tripped on dist.protn                                                                                                                                                                                                                              |
| <b>220 KV ICT Outages/Trippings</b>             |                           |              |              |            |            |             |                                                                                                                                                                                                                                                    |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE       | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                                                                   |
| 220/22 KV 50 MVA PTR 1 @ KANDALGAON             | IntraState                | 14/12/2021   | 16:55        |            |            | EO          | For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s                                                                                                                                                                                            |
| 220/132 KV 200 MVA ICT 3 @ BABHLESHWAR          | IntraState                | 20/12/2021   | 22:45        |            |            | T           | Tripped on Diferrential protection and Declare faulty                                                                                                                                                                                              |
| 220/132 KV 100 MVA ICT 1 @ LONIKAND 2           | IntraState                | 01/03/2022   | 18:17        |            |            | T           | Differential Protection                                                                                                                                                                                                                            |
| 220 / 110 / 22kV 250MVA ICT 1 @ BORIVALI (TATA) | IntraState                | 17/03/2022   | 12:30        |            |            | PO          | Shifting to new GIS                                                                                                                                                                                                                                |
| 220/33KV 25MVA PTR 1 @ HALKARNI                 | IntraState                | 21/03/2022   | 09:15        |            |            | PO          | For Transformer Internal Inspection, Oil Filtration, Vaccum Process and Testing work                                                                                                                                                               |
| 220/33KV 50MVA PTR 2 @ 5 STAR MIDC, KAGAL       | IntraState                | 21/03/2022   | 11:00        | 22/03/2022 | 13:24      | PO          | For HV CB overhauling and oil leakage attending work                                                                                                                                                                                               |
| 220/22 KV 50 MVA PTR 1 @ CHAKAN                 | IntraState                | 22/03/2022   | 14:24        | 22/03/2022 | 17:34      | PO          | For Carry out CB Testing Work                                                                                                                                                                                                                      |
| 220/132 KV 100 MVA ICT 1 @ BHENDA               | IntraState                | 22/03/2022   | 15:40        | 22/03/2022 | 20:59      | T           | transformer internal fault                                                                                                                                                                                                                         |
| 220/22-22 KV 50 MVA PTR 2 @ COLOURCHEM          | IntraState                | 23/03/2022   | 03:04        |            |            | PO          | 220/22KV Transformer no. 2 Augmentation work by replacing existing 50MVA TF to repaired 80 MVA TF.                                                                                                                                                 |
| 220/132-110 KV 100MVA ICT No-01 @ OGLEWADI      | IntraState                | 23/03/2022   | 10:27        |            |            | PO          | Attending tap change problem on electric mode                                                                                                                                                                                                      |
| 220/132-110/11KV 200MVA VID ICT 1 @ MIRAJ       | IntraState                | 23/03/2022   | 14:10        |            |            | PO          | Erection of lattice type structure of HV side isolator, alignment of isolator, connection of jump. For safety purpose ICT will be kept off                                                                                                         |
| <b>110 KV LINE Outages/Trippings</b>            |                           |              |              |            |            |             |                                                                                                                                                                                                                                                    |
| WAGHIVALI - MANKHURD                            | IntraState                | 04/02/2022   | 10:30        |            |            | PO          | Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi. |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Mar/2022**

**Statement-VII**

Position as on 6.30 Hrs of 23/Mar/2022

| Name of Line                  | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                   |
|-------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| WAGHIVALI - CHEMBUR           | IntraState                   | 04/02/2022      | 10:30           |            |               | PO             | Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi. |
| TATA BORIVLI MSETCL BORIVLI 1 | IntraState                   | 21/03/2022      | 22:35           | 22/03/2022 | 02:41         | EO             | ATTENDING HOT SPOT AT BMC END                                                                                                                                                                                                                      |
| KALYAN KALWA SALSETTE 2       | IntraState                   | 23/03/2022      | 15:30           | 23/03/2022 | 18:00         | PO             | ATTENDING HOT SPOT AT LOC -29                                                                                                                                                                                                                      |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage