

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Apr/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	174.516	3620.981	1) Gujrat	-4.214	-91.624
2) Hydro	20.109	687.473	2) Madhya Pradesh	8.804	206.677
3) Gas	5.922	146.492	3) Chattisgarh	5.660	102.300
Total MSPGCL	200.547	4454.946	4) Maharashtra	193.244	3856.043
B) 1) APLM	52.684	1491.576	5) Goa (Amona)	-1.451	-35.122
2) JSWEL	22.221	433.101	Total	202.043	4038.274
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.220	646.725
4) RPL(AMT)	31.671	682.087	b) Mumbai Drawl	35.762	719.850
5) SWPGPL	6.358	180.831	c) MSEDCL Bilateral *	77.076	1619.178
6) Other IPP	31.338	735.726	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.800	645.803
C) 1) TPCL Thermal	16.243	347.638	Include PX	0.000	0.858
2) TPCL Hydro	7.747	86.956	Standby	0.421	0.922
3) TPCL Gas	2.285	70.252	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.954	254.828	1) MSEDCL	519.458	11604.343
D) STATE			2) Mumbai Discoms	73.991	1479.533
1) Thermal	346.985	7746.768	3) Other Discoms	9.287	198.092
(A1+C1+C4+(B1-B6))			TOTAL STATE	602.736	13281.968
2) Hydro (A2+C2)	27.856	774.429			
3) Gas (A3+B7+C3)	8.207	216.744			
4) Wind	9.358	314.306			
6) SOLAR	8.287	191.438			
TOTAL STATE	400.693	9243.685			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	7498	7464	6832	6806
MSPGCL Hydro	852	857	828	517
MSPGCL Gas	246	247	257	257
MSPGCL Total Generation	8596	8568	7917	7580
Central Sector Receipt	10008	9850	7232	7632
WIND	375	312	858	795
CPP / IPP Thermal	5640	5779	6554	6624
CPP / IPP Gas	0	0	0	0
SOLAR	1148	945	0	0
Exchange with Mumbai	-1905	-1987	-1466	-1475
MSEDCL DEMAND MET	23449	23052	20668	20769
Load Shedding	0	767	301	0
MSEDCL DEMAND	23449	23819	20969	20769
TPCL GENERATION	1113	1120	1203	1199
AEML GENERATION	498	493	497	497
MUMBAI DEMAND	3516	3600	3166	3171
OTHER DISCOM DEMAND	413	415	427	387
STATE DEMAND MET	27378	27067	24261	24327
STATE DEMAND	27378	27834	24562	24327
Frequency (Hz)	49.83	49.82	49.93	49.91

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.12 Hz at 18.01 Hrs	49.66 Hz at 06.20 Hrs	49.92	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 22/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.37	88.56	205	155
Unit 7	0.00	0.00	0	0
Unit 8	10.53	297.81	593	0
Unit 9	13.25	302.10	562	540
Unit 10	12.68	83.15	550	460
Total	40.82	771.62		
Bhusawal				
Unit 3	3.21	53.73	155	120
Unit 4	9.10	207.56	415	315
Unit 5	8.51	211.04	425	285
Total	20.82	472.34		
Parli				
Unit 6	5.10	96.52	245	173
Unit 7	5.02	95.00	223	158
Unit 8	3.31	73.86	151	128
Total	13.43	265.38		
Chandrapur				
Unit 3	4.19	92.19	178	158
Unit 4	3.73	83.29	161	123
Unit 5	7.91	178.07	360	315
Unit 6	9.66	160.95	415	360
Unit 7	9.81	196.06	423	388
Unit 8	10.40	231.54	451	405
Unit 9	10.50	224.66	444	430
Total	56.20	1166.77		
Paras				
Unit 3	5.38	118.89	250	165
Unit 4	5.14	111.03	234	161
Total	10.52	229.92		
Khaparkheda				
Unit 1	3.34	69.88	150	120
Unit 2	3.14	71.47	155	115
Unit 3	4.38	87.48	195	172
Unit 4	3.30	74.77	149	130
Unit 5	10.70	239.83	480	425
Total	24.87	543.43		
Nasik				
Unit 3	3.75	84.88	190	0
Unit 4	0.00	63.85	0	0
Unit 5	4.10	22.80	188	126
Total	7.85	171.53		
Uran				
All Units	5.92	146.49	266	226
Total	5.92	146.49		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	2.78	30	0
Total	0.10	2.78		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.98	144.88	510	40
Stage 4	4.36	274.50	501	0
Stage 3	2.21	90.72	160	0
Total	11.55	510.11		
Hydro				
KDPH	0.77	18.26	32	32
VTRNA	0.87	17.03	59	0
TILLARI	0.52	10.46	58	0
BHIRA T.R.	0.43	3.82	73	0
SMLHY_PTN	5.76	120.58	255	229
GHATGHAR	0.11	4.43	110	0
Total	8.46	174.58		
Wind				
Total	9.36	314.31	0	0
Total	9.36	314.31		
CPP				
APML(Mus)	52.68	1491.58	0	0
JSWEL(Mus)	22.22	433.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.67	682.09	0	0
SWPGPL-Mus	6.36	180.83	0	0
Other(Mus)	31.34	735.73	0	0
Total	144.27	3523.32		
SOLAR				
Total	8.29	191.44	0	0
Total	8.29	191.44		
Tata				
Trombay 5	10.70	232.17	458	421
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.24	42.23	83	48
Trombay 7B	1.04	28.02	55	41
TATA Hydro	7.75	86.96	442	174
Trombay 8	5.54	115.47	238	210
Total	26.28	504.85		
AEML				
DTPS U-1&2	11.95	254.83	502	492
Total	11.95	254.83		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	174.52	3620.98	MSPGCL Total	200.55	4454.95
			MSPGCL Thml+Gas	180.44	3767.47	Koyna 1,2 & 4 Total	9.34	419.39
			MSPGCL Hydro	20.11	687.47	State Total	400.69	9243.68

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 22/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7215	1442	226	8883	490	5725	0	0	7624	7985	-1453	21308	1175	22483	3009	322	25814	49.99
2	7239	1415	247	8901	389	5725	0	0	7535	7927	-1255	21369	1626	22995	2797	318	26110	49.94
3	7315	1337	227	8879	193	5734	0	0	7501	8108	-1099	21516	1350	22866	2597	299	25762	49.92
4	7452	1289	247	8988	191	5726	0	0	7810	8160	-1016	21764	645	22409	2462	285	25156	49.92
5	7474	1268	226	8968	256	5717	0	0	8043	8247	-980	21902	521	22423	2390	306	25119	49.94
6	7486	1186	247	8919	233	5731	0	0	7977	7721	-930	21333	570	21903	2438	341	24682	49.90
7	7481	1053	227	8761	262	5716	0	22	7955	7863	-966	21284	517	21801	2436	374	24612	49.84
8	7511	752	266	8529	256	5646	0	206	7893	8034	-1050	21219	331	21550	2533	402	24485	49.99
9	7531	533	247	8311	197	5631	0	498	8374	8223	-1311	21136	284	21420	2823	413	24656	49.98
10	7128	576	257	7961	195	5629	0	806	9636	9360	-1590	21938	99	22037	3154	423	25614	49.90
11	7276	689	257	8222	285	5638	0	1021	9992	10024	-1795	22983	0	22983	3400	412	26795	49.90
12	7498	852	246	8596	375	5640	0	1148	10108	10008	-1905	23449	0	23449	3516	413	27378	49.83
13	7555	726	247	8528	396	5596	0	1153	10104	10183	-1916	23523	0	23523	3513	417	27453	49.84
14	7535	618	247	8400	355	5587	0	1103	10021	10160	-1861	23348	51	23399	3448	396	27243	49.98
15	7464	857	247	8568	312	5779	0	945	9913	9850	-1987	23052	767	23819	3600	415	27834	49.82
16	7432	790	247	8469	370	6187	0	758	9537	9366	-2058	22667	1021	23688	3721	425	27834	49.83
17	7484	600	256	8340	300	6515	0	442	8715	8680	-1928	21918	840	22758	3649	431	26838	49.90
18	7383	656	237	8276	254	6560	0	161	8136	8099	-1788	21116	444	21560	3466	446	25472	49.97
19	7079	519	257	7855	399	6494	0	24	7635	7656	-1519	20465	313	20778	3217	444	24439	49.93
20	6832	828	257	7917	858	6554	0	0	7475	7232	-1466	20668	301	20969	3166	427	24562	49.93
21	6757	433	257	7447	603	6622	0	0	7106	6932	-1420	19756	313	20069	3125	428	23622	50.02
22	6654	370	246	7270	762	6650	0	0	7144	6858	-1444	19687	60	19747	3112	409	23268	49.96
23	6806	517	257	7580	795	6624	0	0	7538	7632	-1475	20769	0	20769	3171	387	24327	49.91
24	6929	804	247	7980	632	6845	0	0	7465	7734	-1550	21287	0	21287	3248	354	24889	49.86
MUs	174.52	20.11	5.92	200.55	9.36	144.27	0.00	8.29	201.24	202.04	-35.76	519.46	11.23	530.69	73.99	9.29	613.96	49.92

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Apr/2022

Position as on 6.30 Hrs of 23/Apr/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	03/05/2022
MSPGCL	Nasik Unit 4	210	16/04/2022	20:58		Continued.	Condenser Tube Leakage (Unit 4 was not available due to Critical coal stock since from Unit 5 synchronization 04:53 hrs. of 17.04.2022)	24/04/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	SWPGPL U-4	135	20/04/2022	16:55		Continued.	PA Fan Vibration Problem	23/04/2022
MSPGCL	Uran Unit 5	108	20/04/2022	16::27		Continued.	Gas shortage	
MSPGCL	Nasik Unit 3	210	21/04/2022	23:00	22/04/2022	01:35	EARTHFAULT PROTECTION OPERATED	
MSPGCL	Koradi Unit 8	660	22/04/2022	17:45	22/04/2022	21:47	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 23/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Trippings							
Pole-1 Non base AC filter Z4 (80 MVAR) @Chandrapur HVDC	IntraState	22/04/2022	09:20			PO	For Refurbishment & RTV Coating of AC Filter Air Core reactor through Expert Agency as per OEM M/s Trench Austria guidelines hence this work to be carried out on top priority to avoid Failure of Air Core Reactor
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	20/04/2022	11:23			HT	HT for Load Management
NEW KOYNA - DABHOL CKT - 2	IntraState	20/04/2022	13:11			PO	C.B. Overhauling work shifting TBC.
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	21/04/2022	10:53	22/04/2022	15:21	PO	PG Isolator overhauling work and Hot spot attending work by Hot Line Method of Rph 89A Iso.400kV Waluj-Babhleshwar Line remain Charged through TBC Bay A/R REQUIRED IN NON AUTO MODE
CHANDRAPUR-PARLI CKT-3	IntraState	21/04/2022	16:56			PO	line maintainance
NEW KOYNA - DABHOL CKT - 2	IntraState	22/04/2022	09:15			PO	Hill cutting work & stay erection Excavation work for tower loc. No.94 & Cold washing work & Diagnostic testing & Relay testing work
400 KV ICT Outages/Trippings							
400/220 KV 500 MVA ICT @ ALKUD	IntraState	22/04/2022	05:10	22/04/2022	06:20	T	y-ph breaker pole burst of tie breaker 402 while taking out the reactor
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	22/04/2022	09:30	22/04/2022	22:26	PO	For Pre-Monsoon Maintenance work along with Bushing Tan delta testing work.
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	22/04/2022	18:10			PO	1) Replacement of damaged jumper of Bph HV Bushing to gantry (Out of two conductor one conductor strands are broken 2) MTAMC Work 3) IPS tube reconnection work between A & B bus PG isolator 4) attending HOT spot work
220 KV TBC Outages/Trippings							
TBC @ VERSOVA (AEML)	IntraState	20/04/2022	09:19			PO	Safety Purpose during replacement of Bphase bushing of NGT-1.
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	13/04/2022	13:25			PO	Bunching work at Loc No. 723 & 62
BHOSARI 2 - TELCO	IntraState	21/04/2022	10:29			PO	1. Half yearly maintenace work 2. Annual testing of 220 KV Bhosari-2-Telco line
EKLAHARE (OCR) - PADGHE	IntraState	21/04/2022	15:31			HT	To control OD
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	21/04/2022	16:37			EO	Removing of bunching at Loc no.63 & 727 and restoration of 220KV Chembur-Trombay-3 line and 220KV Kalwa- Trombay line.
TROMBAY - KALWA	IntraState	21/04/2022	16:37			EO	Removing of bunching at Loc no.63 & 727 and restoration of 220KV Chembur-Trombay-3 line anf 220KV Kalwa- Trombay line.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 23/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - PAL DOMBIVALI	IntraState	22/04/2022	03:27	22/04/2022	06:55	PO	1)Charging of 220kV EHV cable between Loc no. 43 & 45 on 220kV Padgha - PAL line. 2) Cut - point formation on Loc No. 43 & 45 of 220 kV Padgha - PAL line.
PAL DOMBIVALI - PALAVA	IntraState	22/04/2022	04:27	22/04/2022	16:32	T	R-ph conductor snapped at tower 2 outside palava.
KALWA - BORIVALI	IntraState	22/04/2022	06:59	22/04/2022	08:57	PO	220KV B-ph CT leakage attending work. All Diagnostic testing work & Bay maintenance work.
POPHLI PEDHMBE LINE- 2	IntraState	22/04/2022	08:35	22/04/2022	15:25	PO	For bay RM work
KHARGHAR - TOPWORTH	IntraState	22/04/2022	08:42	22/04/2022	15:30	PO	Charging of 220KV Cable (KK line) for Soak test from Proposed Khandeshwar GIS to Proposed Panvel Timber Market (3KM)
PADGHE - KAMBA 2	IntraState	22/04/2022	09:05	22/04/2022	19:23	PO	For retrofitting of master 86 Relay /BO/BI testing & SCADA trial under MTAMC work
KARAD - VITA CKT- 2	IntraState	22/04/2022	09:33	22/04/2022	11:20	PO	Hotspot attending work at Loc No.23B out, 34Y (57.9 Deg), 45 Y, 78 R
BOMBAY DYEING - SAHARA	IntraState	22/04/2022	12:11	22/04/2022	17:45	T	DP
ALEPHATA-PARGAON(KATHAPUR)	IntraState	22/04/2022	15:24	22/04/2022	19:35	PO	Replacement of 29D isolator box.
NERLE- POPHALI	IntraState	22/04/2022	17:48	22/04/2022	18:30	T	Due to heavy rain and wind
NEW KOYNA - POPHALI	IntraState	22/04/2022	17:55	22/04/2022	23:15	T	Due to heavy rain and wind and DP
POPHLI PEDHMBE LINE- 2	IntraState	22/04/2022	17:55	22/04/2022	19:00	T	Due to heavy rain and wind
NEW KOYNA - PEDAMBE	IntraState	22/04/2022	18:05	22/04/2022	18:32	T	Due to heavy rain and wind
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	22/04/2022	19:40	22/04/2022	19:49	T	tripped at Lonand end
PIRANGUT - HINJAWADI 2	IntraState	22/04/2022	20:45			T	DP
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Differential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220/33 KV 50 MVA PTR 1	IntraState	20/04/2022	09:41			PO	50MVA BBL TF-1 Top plate gasket replacement work including radiators gasket and all allied works.
220/33 KV 125MVA TF-3 @ BORIVALI (AEML)	IntraState	21/04/2022	10:11			PO	1)Degassification of Transformer oil, installation of DGA & BMS system and 33kV Incomer Cable connection. 2. Annual and premonsoon Maintenance of Transformer
250 MVA ICT-5 @ TROMBAY	IntraState	22/04/2022	01:45	22/04/2022	03:09	EO	for tap changing activity to improve 110 KV Tata Trombay bus voltage
220/33kV 100 MVA TF 1 @ VERSOVA (AEML)	IntraState	22/04/2022	09:00	22/04/2022	10:45	PO	Removel of trapped air from NGT-1 after replacement of B phase Bushing.
220/22 KV 50 MVA PTR 3 @ MAHAPE	IntraState	22/04/2022	09:11			PO	50 MVA T/F-3 LV side Bus-bar strip hot spot attending work and LV Breaker maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 23/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22KV 50 MVA PTR - 3 @ AKP	IntraState	22/04/2022	09:45	22/04/2022	10:58	EO	EHV Y PH CT Hot spot attending work.
220/100 KV 100 MVA ICT 2 @ KANDALGAON	IntraState	22/04/2022	09:50	22/04/2022	17:42	PO	Spray Painting work of ICT-2, Diagnostic testing work by testing team
220/22 KV 50 MVA PTR 2 @ ANANDNAGAR	IntraState	22/04/2022	10:30	22/04/2022	16:34	PO	LV B Phase CT replacement work and hot spot attending work
220/132 KV 200 MVA ICT 1 @ BOISAR-II	IntraState	22/04/2022	11:20	22/04/2022	18:13	PO	OLTC Overhauling work.
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	22/04/2022	16:08	22/04/2022	22:54	T	Tripped on Buckholz
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/04/2022	17:23			T	Tripped on 132 KV feeder fault
220/132 KV 100 MVA ICT 1 @ BHENDA	IntraState	22/04/2022	18:25	22/04/2022	20:10	PO	PRE MANSOON MAINTENANCE WORK
220/132 KV 100 MVA ICT-3 @ BHENDA	IntraState	22/04/2022	20:15	22/04/2022	21:40	PO	PRE MANSOON MAINTENANCE WORK.
110 KV LINE Outages/Trippings							
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage