

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/May/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	147.491	3680.915	1) Gujrat	-5.030	-129.999
2) Hydro	10.498	451.249	2) Madhya Pradesh	2.780	117.177
3) Gas	3.210	131.698	3) Chattisgarh	3.150	76.700
Total MSPGCL	161.199	4263.862	4) Maharashtra	156.415	4124.809
B) 1) APML	47.213	1385.015	5) Goa (Amona)	-0.794	-28.563
2) JSWEL	14.635	406.755	Total	156.521	4160.124
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.459	770.979
4) RPL(AMT)	15.539	558.955	b) Mumbai Drawl	37.547	822.867
5) SWPGPL	8.085	181.921	c) MSEDCL Bilateral *	104.340	1637.011
6) Other IPP	16.798	449.652	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.459	770.859
C) 1) TPCL Thermal	13.521	318.714	Include PX	0.000	0.000
2) TPCL Hydro	2.195	89.597	Standby	0.000	0.121
3) TPCL Gas	0.000	55.388	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.780	246.368	1) MSEDCL	449.795	11230.930
D) STATE			2) Mumbai Discoms	63.043	1532.919
1) Thermal	273.062	7228.295	3) Other Discoms	9.074	206.978
(A1+C1+C4+(B1-B6))			TOTAL STATE	521.912	12970.827
2) Hydro	12.693	540.846			
(A2+C2)					
3) Gas	3.210	187.086			
(A3+B7+C3)					
4) Wind	66.187	657.931			
6) SOLAR	10.239	196.560			
TOTAL STATE	365.391	8810.718			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	5696	5813	6714	6601
MSPGCL Hydro	274	465	584	577
MSPGCL Gas	130	130	130	130
MSPGCL Total Generation	6100	6408	7428	7308
Central Sector Receipt	7027	7066	5723	6645
WIND	2637	2925	2887	2148
CPP / IPP Thermal	3967	3561	4922	4235
CPP / IPP Gas	0	0	0	0
SOLAR	721	893	0	367
Exchange with Mumbai	-1545	-1634	-1670	-1548
MSEDCL DEMAND MET	18499	18829	18897	18769
Load Shedding	0	0	0	0
MSEDCL DEMAND	18499	18829	18897	18769
TPCL GENERATION	471	651	631	443
AEML GENERATION	355	484	475	316
MUMBAI DEMAND	2371	2769	2776	2307
OTHER DISCOM DEMAND	408	390	393	386
STATE DEMAND MET	21278	21988	22066	21462
STATE DEMAND	21278	21988	22066	21462
Frequency (Hz)	50.24	50.00	49.98	50.13

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.35 Hz at 08.02 Hrs	49.72 Hz at 18.53 Hrs	50.03	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 22/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.54	86.36	165	120
Unit 7	0.00	0.00	0	0
Unit 8	12.59	291.63	592	374
Unit 9	11.84	268.96	578	370
Unit 10	10.59	282.83	580	0
Total	38.57	929.77		
Bhusawal				
Unit 3	2.94	68.96	135	115
Unit 4	8.60	169.60	470	275
Unit 5	8.06	193.70	420	280
Total	19.60	432.26		
Parli				
Unit 6	0.00	68.21	0	0
Unit 7	3.65	87.39	234	140
Unit 8	3.11	57.89	135	126
Total	6.76	213.49		
Chandrapur				
Unit 3	3.58	81.81	178	125
Unit 4	3.15	76.44	140	123
Unit 5	7.81	186.60	375	280
Unit 6	7.84	175.33	392	275
Unit 7	8.31	197.55	425	282
Unit 8	9.35	217.50	471	279
Unit 9	8.96	220.14	444	280
Total	49.00	1155.38		
Paras				
Unit 3	3.51	91.40	224	121
Unit 4	4.01	96.60	217	130
Total	7.52	187.99		
Khaparkheda				
Unit 1	3.02	64.80	145	110
Unit 2	3.28	77.52	155	115
Unit 3	3.75	77.25	184	130
Unit 4	2.20	69.74	139	0
Unit 5	9.49	241.40	475	275
Total	21.74	530.70		
Nasik				
Unit 3	0.00	79.46	0	0
Unit 4	1.36	75.15	159	0
Unit 5	2.95	76.72	174	106
Total	4.31	231.33		
Uran				
All Units	3.21	131.70	140	120
Total	3.21	131.70		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	2.57	20	0
Total	0.06	2.57		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.92	94.14	415	40
Stage 4	0.82	137.63	400	0
Stage 3	0.75	51.82	80	0
Total	4.49	283.59		
Hydro				
KDPH	0.62	11.51	26	26
VTRNA	0.00	17.34	0	0
TILLARI	0.00	8.24	0	0
BHIRA T.R.	0.09	4.26	77	0
SMLHY_PTN	4.76	115.62	208	187
GHATGHAR	0.48	8.11	125	0
Total	5.95	165.09		
Wind				
Total	66.19	657.93	0	0
Total	66.19	657.93		
CPP				
APML(Mus)	47.21	1385.02	0	0
JSWEL(Mus)	14.64	406.76	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	15.54	558.96	0	0
SWPGPL-Mus	8.08	181.92	0	0
Other(Mus)	16.80	449.65	0	0
Total	102.27	2982.30		
SOLAR				
Total	10.24	196.56	0	0
Total	10.24	196.56		
Tata				
Trombay 5	8.69	207.96	449	270
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	34.32	0	0
Trombay 7B	0.00	21.07	0	0
TATA Hydro	2.20	89.60	249	0
Trombay 8	4.83	110.75	233	134
Total	15.72	463.70		
AEML				
DTPS U-1&2	9.78	246.37	498	316
Total	9.78	246.37		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	147.49	3680.92	MSPGCL Total	161.20	4263.86
			MSPGCL Thml+Gas	150.70	3812.61	Koyna 1,2 & 4 Total	3.74	231.77
			MSPGCL Hydro	10.50	451.25	State Total	365.39	8810.72

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 22/May/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6809	385	140	7334	3025	5013	0	0	6622	6447	-1739	19742	0	19742	2918	338	22998	50.01
2	6802	274	130	7206	3002	4925	0	0	6780	6538	-1605	19754	0	19754	2779	312	22845	50.02
3	6813	274	140	7227	2890	4573	0	0	6544	6363	-1475	19278	0	19278	2623	300	22201	50.00
4	6843	273	140	7256	2674	4467	0	0	6437	6246	-1251	19082	0	19082	2516	310	21908	50.03
5	6884	319	140	7343	2583	4390	0	0	6398	6493	-1249	19242	0	19242	2438	318	21998	49.99
6	7000	501	140	7641	2510	4749	0	0	6358	6380	-1250	19687	0	19687	2416	343	22446	50.00
7	6968	648	140	7756	2215	4665	0	92	6248	6574	-1500	19426	0	19426	2328	376	22130	50.02
8	6601	577	130	7308	2148	4235	0	367	6511	6645	-1548	18769	0	18769	2307	386	21462	50.13
9	5696	274	130	6100	2637	3967	0	721	6868	7027	-1545	18499	0	18499	2371	408	21278	50.24
10	5203	346	130	5679	2692	3490	0	1007	7227	7124	-1543	18056	0	18056	2449	393	20898	50.22
11	5046	273	130	5449	2724	3484	0	1224	7167	7142	-1816	17808	0	17808	2550	399	20757	50.11
12	5067	604	130	5801	2592	3504	0	1325	6765	7116	-1714	18223	0	18223	2626	401	21250	50.01
13	5060	441	140	5641	2664	3518	0	1370	6903	7084	-1730	18153	0	18153	2666	394	21213	50.04
14	5034	338	120	5492	2575	3520	0	1289	7216	7189	-1746	17927	0	17927	2667	392	20986	50.04
15	5279	378	140	5797	2725	3540	0	1102	7418	7434	-1770	18435	0	18435	2737	393	21565	50.01
16	5813	465	130	6408	2925	3561	0	893	7235	7066	-1634	18829	0	18829	2769	390	21988	50.00
17	5621	514	120	6255	3076	3661	0	565	6658	6644	-1563	18220	0	18220	2723	418	21361	49.98
18	5674	793	140	6607	3011	3712	0	248	6015	6179	-1376	17962	0	17962	2607	419	20988	50.00
19	6240	525	130	6895	2945	4034	0	36	5726	5534	-1325	17700	0	17700	2557	419	20676	49.97
20	6783	478	130	7391	2985	4583	0	0	5729	5605	-1388	18763	0	18763	2664	413	21840	49.87
21	6431	697	140	7268	2975	4839	0	0	5822	5704	-1487	18905	0	18905	2745	394	22044	50.00
22	6714	584	130	7428	2887	4922	0	0	5771	5723	-1670	18897	0	18897	2776	393	22066	49.98
23	6550	271	140	6961	2906	5328	0	0	6252	6343	-1809	19340	0	19340	2857	389	22586	49.96
24	6560	266	130	6956	2821	5590	0	0	6440	5921	-1814	19097	0	19097	2954	377	22428	50.02
MUs	147.49	10.50	3.21	161.20	66.19	102.27	0.00	10.24	157.11	156.52	-37.55	449.80	0.00	449.80	63.04	9.07	521.91	50.03

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/May/2022

Position as on 6.30 Hrs of 23/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 5	108	16/05/2022	12:59		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	16/05/2022	23:53		Continued.	Coal Shortage	
TPC-G	Trombay 7B	60	16/05/2022	23:59		Continued.	Non availability of APM gas.	
IPP	Adani U-2	660	17/05/2022	06:31	22/05/2022	16:48	Withdrawn	22/05/2022
MSPGCL	Parli Unit 6	250	19/05/2022	20:00		Continued.	Boiler Tube Leakage	23/05/2022
MSPGCL	Nasik Unit 4	210	19/05/2022	22:45	22/05/2022	13:47	condenser tube leakage.	21/05/2022
MSPGCL	Khaparkheda Unit 4	210	20/05/2022	17:41	22/05/2022	05:18	Boiler Tube Leakage	22/05/2022
TPC-G	Trombay 7A	120	21/05/2022	01:26		Continued.	Gas shortage	
MSPGCL	Nasik Unit 3	210	21/05/2022	17:14		Continued.	Boiler Tube Leakage	24/05/2022
MSPGCL	Koradi Unit-10	660	22/05/2022	21:53	23/05/2022	02:20	for emergency outage of GT-10main bay 401 & tie bay 402 for attending hot spot.	
MSPGCL	Chandrapur Unit 5	500	23/05/2022	07:45		Continued.	Boiler Tube Leakage	26/05/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/May/2022

Statement-VII

Position as on 6.30 Hrs of 23/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR SS	IntraState	23/05/2022	14:15	23/05/2022	20:34	EO	"1. Measurement of Tan Delta and capacitance of R, Y & B-ph CTs which are due for this year. 2.To attend the defects of aux. contacts of Isolators. 3.Maintenance and alignments of Isolators."
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	22/05/2022	07:55	22/05/2022	16:03	T	TRIPPED ON O/V
DHULE - SSNNL CKT - 2	InterState	23/05/2022	09:01	23/05/2022	19:58	PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
PADGHE - TARAPUR CKT - 1	InterState	23/05/2022	09:06			PO	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM
PADGHE - KALWA CKT - 1	IntraState	22/05/2022	03:09	22/05/2022	05:56	EO	A)Work to be carried out by 400kV LMSD Kalwa - To attend Hot spot at Loc no. 1033 Y-Phase (177 deg C) B)Work to be carried out at Padghe end:- 1) Replacement of R-Ph Wavetrap due to conductor damage from Gantry to WT and nut bolt replacement of clamps is not possible. Hot spot temp 169deg 2) Attending Hot Spot on B bus Bph PG isolator 116deg
KHADKA - BABLESHWAR	IntraState	22/05/2022	05:29	22/05/2022	06:54	T	TRIPPED ON DIST. PROTECTION.
BABHALESHWAR - PADGHE CKT - 2	IntraState	22/05/2022	14:40	22/05/2022	18:51	PO	A] HVDC TL O&M Sub-Division, Padghe:- 1.To attend Broken/Faulty Disc Insulators replacement at Towers. Loc. No. 20 & 968. 2.Replacement of broken Earthwire Suspension clamps at Loc no. 939 & 940 (B-Phase side). 3.Fixing of Corona Rings at 2 Locs. 962, 968. 4.Fixing of Conductor Repair Sleeve at Loc 928, 967. 5.Jumper Nut-Bolt Tightening of Cut-Point Locations � 45 locs. 6.Chemical Cleaning at Tower Locations �21 nos. Of Bird shit/ Dust pollution Area / Highway Raod Crossing. B] HVDC TL O&M Sub-Division, Junnar:- 1.To attend Faulty Disc Insulators replacement at Towers. Loc. No. 750,761 & 763 under HVDC Junnar Lines Sub Division. 2.Jumper Nut-Bolt Tightening of Cut-Point Location � 21 locs. 3.Chemical Cleaning at Tower Locations � 22 nos. of Bird shit /Dust pollution Area /NH road Crossing.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/May/2022

Statement-VII

Position as on 6.30 Hrs of 23/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NAGOTHANE - DABHOL CKT - 1	IntraState	22/05/2022	19:02	23/05/2022	00:30	EO	Fixing of missing Insulators strings of B.Ph. At loc.no. 84
KARAD - LONIKAND I	IntraState	23/05/2022	15:27	23/05/2022	17:01	HT	To control line loading of Talegaon -Kharghare-Kalwa
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	23/05/2022	21:23		Continued.	EO	Attending Red Hot Spot on 29 D, Centre break isolator B phase
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	IntraState	21/05/2022	21:12	22/05/2022	04:59	PO	For carrying out pre-monsoon maintenance work.
400/220/33 KV 500 MVA ICT - 2 @ DHULE	IntraState	22/05/2022	17:12	22/05/2022	20:58	PO	Pre-monsoon outage
400/220/33 KV 315MVA ICT - 1 @ AKOLA	IntraState	23/05/2022	07:28	23/05/2022	17:37	PO	Routine maintenance & testing work
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	23/05/2022	08:17	23/05/2022	17:25	PO	For RTV coating to Tertiary 33 kv connection & Pre-Monsoon maintenance work
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	23/05/2022	17:58	23/05/2022	18:40	EO	To attend Hot spot at jack Bus above 220kV Main Bus 2
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	23/05/2022	08:45	23/05/2022	18:06	PO	For safety purpose during outage of 100 MVA TR-2
220 KV MAINBAY Outages/Trippings							
METERING BAY (CONSUMER) - 2 @ SERUM	IntraState	23/05/2022	16:05			EO	Replacement of 06 Nos. of 75/1 A CT to New 100/1 A CT
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
BORIVALI - TARAPUR	IntraState	18/05/2022	14:36			PO	Replacement of existing 0.5 ACSR MOOSE Conductor at loc. No. 11- 28, replacement of heavily Rusted Hardware , heavily rusted earth wire and all insulator strings of the line.
BUS SECTION-4 @ TEMGHAR	IntraState	20/05/2022	07:23			EO	For closing 220kv Bus section 3 isolator
VSNL - STT GIS CKT - 1	IntraState	20/05/2022	11:01	23/05/2022	13:02	PO	Addition of New 02 Nos of GIS T/F Bay to existing 220kv Bus 1 at 220KV STT GIS Substation end.
KANDALGAON - KOYNA (POPHALI)	IntraState	22/05/2022	05:16	22/05/2022	09:38	PO	For replacement of damaged tower (during flood at Chiplun) at Loc. No. 56 of 220kV New Koyna 2 Lote & 220kV Pophali 2 Kandalgaon D/C Line.
BOISAR II - TARAPUR	IntraState	22/05/2022	11:04	22/05/2022	15:45	EO	Emergency Outage is required for safety purpose for Replacement of heavily rusted earthwire atLoc No.13-14-15 on 220KV Borivali-Tarapur Line D/C tower.
BOMBAY DYEING - SAHARA	IntraState	22/05/2022	11:15	22/05/2022	21:00	PO	1) Replacement of dead end due to broken strands loc-113,R,Y,B phase. 2)Replacement of polymer to long rod insulator loc-145,146,147. 3) Insulator cleaning loc-85-87,loc-130-140.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 22/May/2022

Statement-VII

Position as on 6.30 Hrs of 23/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - NALASOPARA - VASAI (T)	IntraState	22/05/2022	11:28	22/05/2022	18:06	PO	1) Insulator cleaning work at 220kV Padgha-Nalasopara Line at Loc No. 08-13 and 100kV Vasai-Padgha Line loc. No. 84 - 93 (Insulator cleaning required due to DFCCIL project work going on nearby area hence dust deposited on insulator) 2) 220kV Padgha-Nallasopara Line at loc No.75 (R Y B- Pilot string replacement work as heavy chartering during Night Hours was reported by Sub-Station. 3) Premonsoon & Diagnostic Testing at 220KV Vasai S/stn.
EKLAHARA(OCR)-RAYMOND	IntraState	22/05/2022	12:36	22/05/2022	16:42	T	Tripped on DP
EKLAHARE (OCR) - PADGHE	IntraState	22/05/2022	12:36	22/05/2022	15:21	T	Tripped on DP
BOISAR - VERSOVA	IntraState	22/05/2022	18:03	22/05/2022	19:34	T	DP Trip
DAHANU - GHODBUNDER CKT - 1	IntraState	22/05/2022	19:27	22/05/2022	21:35	T	Tripped on DP
TILLARI - AMONA LINE	IntraState	22/05/2022	22:29	22/05/2022	23:15	T	TRIPPED ON DIST. PROTECTION
HALKARNI - TILARI LINE	IntraState	22/05/2022	22:29	22/05/2022	23:10	T	TRIPPED ON DIST. PROTECTION
BOMBAY DYEING - SAHARA	IntraState	23/05/2022	05:03	23/05/2022	17:09	T	TRIPPED ON DIST.PROTECTION
EKLAHARA(OCR)-RAYMOND	IntraState	23/05/2022	07:33	23/05/2022	09:12	EO	Attending red hot on R ph wave trap bottom side
MIRAJ - ICHALKARANJI	IntraState	23/05/2022	09:07	23/05/2022	12:38	PO	1) Hot spot attending work
CHINCHWAD- PARVATI	IntraState	23/05/2022	09:32	23/05/2022	18:09	PO	Replacement of R, Y & B ph CT due to higher Tandelta values
MAIN BUS-1 @ TALANDGE(5* MIDC KAGAL)	IntraState	23/05/2022	10:00	23/05/2022	14:53	PO	For shifting of 220KV Bus A load(TF1 and Talandage ckt-II) on 220KV Bus B as augmentation of 220/33KV,50MVA transformer in in process at 220 kV Five Star MIDC S/Stn.
OSMANABAD - SOLAPUR (BALE)	IntraState	23/05/2022	10:28	23/05/2022	14:56	PO	Conductor Mid span joint work at location No. 86-87 R phase, DI replacement 91 B phase
TALANDGE - MUDSHINGI CKT - 1	IntraState	23/05/2022	11:53	23/05/2022	18:53	PO	For stringing of earth wire between tower location no. M/C-18 to M/C-18 .
MUDSHINGI - CHIKODI	IntraState	23/05/2022	12:05	23/05/2022	19:11	PO	Earth wire stringing work at T.L. no. M/C-16 to M/C-18.
TROMBAY - KALWA	IntraState	23/05/2022	17:53	23/05/2022	18:50	EO	R-ph CC to LMU cable broken. Need to be connected immediately otherwise it will result in damage to CC.
MAIN BUS - 2 @ TALANDGE	IntraState	23/05/2022	17:58	23/05/2022	22:49	EO	To attend Hot spot at ICT-3 above Main Bus 2
EKLAHARE (OCR) - PADGHE	IntraState	23/05/2022	19:44	23/05/2022	22:07	HT	For load management
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/May/2022

Statement-VII

Position as on 6.30 Hrs of 23/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22-22 KV 100 MVA PTR 1 @ NALASOPARA	IntraState	22/05/2022	07:55	22/05/2022	21:03	PO	1) 80MVA 220/22-22kV PTR-1 for attending PTR LV Bushing oil leakage (minor) attending work. (By M/s Mahati Industries) 2) SFRA, Cap & Tan delta of Winding, bushing and CT, 10KV Excitation, CFR Winding, winding Resistance measurement, Tap Changer continuity and PI of PTR. (Above test will be carried out for verification of results due to increasing trend of gases) 3) Pre monsoon Maintenance activity. 4) OLTC overhauling of PTR.
220/132KV 100MVA ICT 2 @ CHAKAN PHASE II	IntraState	22/05/2022	20:37	22/05/2022	22:29	PO	Half yearly maintenance and pre monsoon maintenance.
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	23/05/2022	08:34	23/05/2022	10:32	PO	Pre monsoon maintenance work.
220/33kV 100 MVA TF 2 @ GHODBUNDER	IntraState	23/05/2022	08:40	23/05/2022	17:53	PO	Annual/premonsoon maintenance
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	IntraState	23/05/2022	09:00	23/05/2022	18:40	PO	For 1)Transformer diagnostic testing work 2) Premonsoon maintenance of ICT (3) Quarterly main work
220/33kV 125 MVA TF 2 @ AAREY	IntraState	23/05/2022	10:25	23/05/2022	12:10	PO	Premonsoon maintenance of Transformer, NGT and Bay Equipments
220/132kV 200MVA ICT-2 @ KOPARGAON	IntraState	23/05/2022	11:16			PO	For Pre-monsoon Maintenance work and testing work
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	23/05/2022	13:02	23/05/2022	14:56	PO	Pre monsoon maintenance work.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shifting these lines on new Multicircuit Towers between Darave to Vashi.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/May/2022

Statement-VII

Position as on 6.30 Hrs of 23/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De- Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage