

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Jun/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	142.206	3523.944	1) Gujrat	-7.894	-123.784
2) Hydro	15.292	275.385	2) Madhya Pradesh	6.094	100.699
3) Gas	3.084	91.679	3) Chattisgarh	3.410	55.810
Total MSPGCL	160.582	3891.008	4) Maharashtra	176.770	3735.351
B) 1) APLM	70.101	1542.811	5) Goa (Amona)	-0.959	-21.267
2) JSWEL	15.820	370.987	Total	177.421	3746.809
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.549	744.880
4) RPL(AMT)	25.061	551.773	b) Mumbai Drawl	37.363	821.664
5) SWPGPL	9.209	189.699	c) MSEDCL Bilateral *	70.679	1630.587
6) Other IPP	11.435	298.502	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.549	744.672
C) 1) TPCL Thermal	13.497	323.351	Include PX	0.000	0.000
2) TPCL Hydro	3.375	94.871	Standby	0.000	0.209
3) TPCL Gas	0.000	29.093	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.088	232.851	1) MSEDCL	444.423	10359.948
D) STATE			2) Mumbai Discoms	63.323	1501.831
1) Thermal	296.417	7033.918	3) Other Discoms	9.201	205.775
(A1+C1+C4+(B1-B6))			TOTAL STATE	516.947	12067.554
2) Hydro	18.667	370.256			
(A2+C2)					
3) Gas	3.084	120.772			
(A3+B7+C3)					
4) Wind	12.417	589.883			
6) SOLAR	8.941	205.915			
TOTAL STATE	339.526	8320.744			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5884	5948	6232	5391
MSPGCL Hydro	658	420	922	720
MSPGCL Gas	117	126	130	133
MSPGCL Total Generation	6658	6494	7284	6244
Central Sector Receipt	9478	9134	6793	6388
WIND	83	102	838	479
CPP / IPP Thermal	5394	5579	5533	5654
CPP / IPP Gas	0	0	0	0
SOLAR	1172	1211	18	0
Exchange with Mumbai	-1946	-1907	-1791	-1012
MSEDCL DEMAND MET	20418	20203	18237	17453
Load Shedding	0	0	0	0
MSEDCL DEMAND	20418	20203	18237	17453
TPCL GENERATION	762	762	917	476
AEML GENERATION	485	488	245	424
MUMBAI DEMAND	3193	3157	2953	1912
OTHER DISCOM DEMAND	422	411	438	300
STATE DEMAND MET	24032	23770	21628	19666
STATE DEMAND	24032	23770	21628	19666
Frequency (Hz)	49.93	49.99	49.96	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 16.04 Hrs	49.64 Hz at 21.15 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 22/Jun/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.00	89.35	140	105
Unit 7	0.00	0.00	0	0
Unit 8	9.04	267.86	532	0
Unit 9	9.86	248.03	435	332
Unit 10	11.80	255.81	525	415
Total	33.69	861.05		
Bhusawal				
Unit 3	3.33	71.96	150	125
Unit 4	9.66	224.78	455	330
Unit 5	9.72	205.29	450	320
Total	22.71	502.03		
Parli				
Unit 6	4.63	92.46	220	152
Unit 7	3.28	94.34	230	61
Unit 8	3.09	68.77	135	126
Total	11.00	255.57		
Chandrapur				
Unit 3	3.16	65.25	143	127
Unit 4	0.00	51.00	0	0
Unit 5	8.15	184.95	355	325
Unit 6	0.28	160.76	187	0
Unit 7	0.00	113.41	0	0
Unit 8	10.99	237.80	478	432
Unit 9	10.54	185.93	458	421
Total	33.13	999.10		
Paras				
Unit 3	4.93	106.77	219	188
Unit 4	4.50	101.92	205	158
Total	9.43	208.68		
Khaparkheda				
Unit 1	3.00	70.27	140	100
Unit 2	3.28	73.86	155	105
Unit 3	4.12	91.12	180	154
Unit 4	0.00	13.16	0	0
Unit 5	10.75	237.05	460	415
Total	21.16	485.47		
Nasik				
Unit 3	4.04	83.28	180	127
Unit 4	3.42	67.49	163	128
Unit 5	3.63	61.27	162	126
Total	11.08	212.04		
Uran				
All Units	3.08	91.68	133	117
Total	3.08	91.68		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	4.91	12	0
Total	0.12	4.91		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.31	64.68	460	35
Stage 4	2.02	46.93	500	0
Stage 3	1.66	27.38	240	0
Total	7.99	138.99		
Hydro				
KDPH	0.44	9.69	19	19
VTRNA	0.78	1.68	61	0
TILLARI	0.49	5.62	58	0
BHIRA T.R.	0.06	5.16	40	0
SMLHY_PTN	5.40	107.20	235	206
GHATGHAR	0.00	2.13	0	0
Total	7.18	131.48		
Wind				
Total	12.42	589.88	0	0
Total	12.42	589.88		
CPP				
APML(Mus)	70.10	1542.81	0	0
JSWEL(Mus)	15.82	370.99	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.06	551.77	0	0
SWPGPL-Mus	9.21	189.70	0	0
Other(Mus)	11.44	298.50	0	0
Total	131.63	2953.77		
SOLAR				
Total	8.94	205.92	0	0
Total	8.94	205.92		
Tata				
Trombay 5	8.94	210.17	458	272
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	17.72	0	0
Trombay 7B	0.00	11.38	0	0
TATA Hydro	3.38	94.87	371	8
Trombay 8	4.55	113.18	227	135
Total	16.87	447.32		
AEML				
DTPS U-1&2	9.09	232.85	488	233
Total	9.09	232.85		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	142.21	3523.94	MSPGCL Total	160.58	3891.01
			MSPGCL Thml+Gas	145.29	3615.62	Koyna 1,2 & 4 Total	6.33	111.61
			MSPGCL Hydro	15.29	275.38	State Total	339.53	8320.74

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 22/Jun/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5812	344	131	6286	1059	5373	0	0	6523	6551	-1125	17815	0	17815	2229	330	20374	49.96
2	5838	344	132	6314	769	5596	0	0	6286	6568	-1096	17834	0	17834	2089	318	20240	49.94
3	5828	490	131	6448	580	5646	0	0	6271	6469	-1057	17778	0	17778	1967	309	20054	49.84
4	5391	720	133	6244	479	5654	0	0	6244	6388	-1012	17453	0	17453	1912	300	19666	49.98
5	5344	914	123	6380	438	5673	0	0	6700	6908	-982	18106	0	18106	1883	311	20300	50.03
6	5527	562	133	6222	511	5635	0	0	7681	7704	-1101	18617	0	18617	1989	354	20960	50.02
7	5560	866	133	6558	417	5648	0	107	7934	7971	-1306	19026	0	19026	2104	370	21500	50.02
8	5699	1050	132	6880	367	5691	0	374	7434	7851	-1500	19260	0	19260	2267	403	21930	50.00
9	5822	650	132	6604	318	5632	0	753	7880	7994	-1707	19185	0	19185	2572	410	22166	50.01
10	5842	630	129	6602	272	5641	0	956	7944	8267	-1787	19534	0	19534	2916	416	22866	50.00
11	5801	598	127	6526	167	5342	0	1105	8720	8803	-1910	19611	0	19611	3138	422	23170	49.92
12	5884	658	117	6658	83	5394	0	1172	9218	9478	-1946	20418	0	20418	3193	422	24032	49.93
13	5948	420	126	6494	102	5579	0	1211	9193	9134	-1907	20203	0	20203	3157	411	23770	49.99
14	5990	390	128	6508	184	4862	0	1134	9432	8768	-1973	19068	0	19068	3045	415	22528	50.02
15	5851	498	127	6476	561	4513	0	959	9438	8918	-1762	19267	0	19267	3094	398	22760	50.00
16	6179	332	118	6630	877	4798	0	639	8147	7691	-1815	18430	0	18430	3145	390	21964	50.03
17	6077	348	128	6552	878	4722	0	339	7769	7813	-1966	17937	0	17937	3098	401	21436	49.99
18	6106	1000	129	7234	938	4794	0	174	6952	7541	-1897	18357	0	18357	3039	428	21824	49.97
19	6232	922	130	7284	838	5533	0	18	6475	6793	-1791	18237	0	18237	2953	438	21628	49.96
20	6261	1154	130	7544	665	5837	0	0	6178	6229	-1623	18239	0	18239	2913	414	21566	49.91
21	6167	814	130	7112	657	5989	0	0	6046	6236	-1606	17978	0	17978	2795	409	21182	49.85
22	6243	684	132	7060	561	6024	0	0	5995	5775	-1544	17474	0	17474	2685	402	20560	49.83
23	6326	530	121	6978	361	6031	0	0	5878	5991	-1500	17481	0	17481	2598	379	20458	49.77
24	6478	374	132	6984	335	6019	0	0	5792	5580	-1450	17117	0	17117	2542	351	20010	49.92
MUs	142.21	15.29	3.08	160.58	12.42	131.63	0.00	8.94	176.13	177.42	-37.36	444.42	0.00	444.42	63.32	9.20	516.95	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 22/Jun/2022

Position as on 6.30 Hrs of 23/Jun/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna STG-IV Unit-2	250	13/06/2022	00:00		Continued.	Commissioning and installation of New TSLG governor	30/06/2022
IPP	RPL(AMT) U-5	270	15/06/2022	00:00		Continued.	Annual Overhaul	25/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 5	108	11/06/2022	14:29		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	13/06/2022	00:25		Continued.	Gas shortage	
MSPGCL	Uran Unit 6	108	13/06/2022	00:25		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Turbine Gland steam temperature not maintained	22/06/2022
MSPGCL	Chandrapur Unit 4	210	18/06/2022	00:05		Continued.	Ash handling problem.	20/06/2022
TPC-G	Trombay 7B	60	18/06/2022	03:55		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	18/06/2022	04:12		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 6	500	18/06/2022	12:53	22/06/2022	22:03	Boiler Tube Leakage	21/06/2022
MSPGCL	Koradi Unit 8	660	22/06/2022	03:07	22/06/2022	06:59	air cycle B tripped	
AEML	AEML Unit 2	250	22/06/2022	16:43		Continued.	Boiler Tube Leakage	24/06/2022
MSPGCL	Koyna STG-IV Unit-4	250	23/06/2022	01:44	23/06/2022	07:00	GOVERNOR OIL SYSTEM PRESSURE FAULT	23/06/2022
IPP	SWPGPL U-2	135	23/06/2022	03:00		Continued.	BOILER BOTTOM ASH SYSTEM PROBLEM	25/06/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 22/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 23/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Tripping							
TIE BAY (412) OF KORADI-1 @ KHAPARKHEDA	IntraState	22/06/2022	15:33	22/06/2022	18:14	PO	DCRM,CB Timing & CRM of Tie Breaker Bay 412
400 KV MAINBAY Outages/Tripping							
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
MAIN BAY (411) OF KORADI-1 @ KHAPARKHEDA	IntraState	22/06/2022	11:32	22/06/2022	14:23	PO	DCRM,CB Timing & CRM of Main Breaker Bay 411
400 KV LINE Outages/Tripping							
WARORA - WARDHA (PG)	InterState	20/06/2022	10:10			PO	1. Tower Erection of loc. No. 01 under 400 kV Wardha-Warora line. 2. Connecting 400kV Warora (MSETCL) to 400kV Warora (PGCIL)
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/06/2022	16:32			HT	Load management
Akola II (Yelwan) - Akola I CKT - 1	IntraState	22/06/2022	10:04	22/06/2022	17:15	PO	Routine maintenance & testing work
LONIKAND I -JEJURI	IntraState	22/06/2022	13:20	22/06/2022	14:46	T	DP
BABHALESHWAR - PADGHE CKT-1	IntraState	22/06/2022	14:18	22/06/2022	22:16	T	R ph E/F Reason- Insulator decapping at loc. no.136
LONIKAND I -JEJURI	IntraState	22/06/2022	17:33	22/06/2022	21:45	EO	Attending hot spot on 29B isolator (Y ph & B Ph) by maintenance Unit (Temp < 131 ˚C)
THAPTI TANDA - WALUJ	IntraState	22/06/2022	22:37			T	TRIPPED ON DISTANCE PROTECTION
LONIKAND 2 - KARJAT CKT - 2	IntraState	23/06/2022	01:51	23/06/2022	07:19	T	TRIPPED ON DISTANCE PROTECTION
400 KV ICT Outages/Tripping							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	06/06/2022	12:33			PO	For CB replacement work. ICT will be in service through TBC.
400kv Stn. TF No 5 @ C'pur GCR	IntraState	22/06/2022	10:10			PO	1) Measurement of Capacitance and Tan delta of R, Y & B-ph CT's. 2) Measurement of Timing, Contact resistance and DCRM of CB. 3) In wording control cables in control panel along with glanding and termination and installation of MFM under MTAMC project. 4) Maintenance and alignment of Isolators.
220 KV MAINBAY Outages/Tripping							
BUS COUPLER @ SOUTH SOLAPUR	IntraState	22/06/2022	11:02	22/06/2022	15:53	PO	Outage is required for Quarterly Maintenance
220 KV LINE Outages/Tripping							
NARANGWADI - SOLAPUR PG CKT - 2	InterState	22/06/2022	17:44			EO	for attending the sparking on jump due to jump gent disconnected from Pilot; at Loc -8 B phase
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
PADGHE - TEMGHAR - 2	IntraState	15/06/2022	00:11			PO	Bunching of 220KV Padgha-Temghar -1 & 2 line at Loc no. 80 and jumper removing at Loc. no.80 & 81 for diversion of 220KV Padgha-Temghar 2 line bay to 220KV Padgha-Temghar-1 line bay at Padgha S/s by availing simultaneous outages on 220KV Padgha-Temghar -1 & 2 line.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 23/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR - VERSOVA	IntraState	15/06/2022	06:51			PO	Bunching on Tower no BTL 16, to facilitate Modification / relocation of existing tower no BTL 13 to BTL 15 for NHRCL projectNote: Post bunching of line, the configuration of line will change as below:1.220 kV Dahanu - Virar and 220 kV Viraj - Versova. 2.MSETCL Boisar will be disconnected from the AEML Versova and MSETCL Viraj for a period of 10 days (i.e.from 15/06/2022 to 24/06/2022). 3.Normalization of bunching shall be carried out on 25/06/2022
BOISAR II - VIRAJ	IntraState	15/06/2022	07:06			PO	Bunching on Tower no BTL 16, to facilitate Modification / relocation of existing tower no BTL 13 to BTL 15 for NHRCL projectNote: Post bunching of line, the configuration of line will change as below:1.220 kV Dahanu - Virar and 220 kV Viraj - Versova. 2.MSETCL Boisar will be disconnected from the AEML Versova and MSETCL Viraj for a period of 10 days (i.e.from 15/06/2022 to 24/06/2022). 3.Normalization of bunching shall be carried out on 25/06/2022
BORIVALI - BOISAR (PG)	IntraState	22/06/2022	02:47	22/06/2022	22:52	T	Distance Protection
BORIVALI - TARAPUR	IntraState	22/06/2022	02:47	22/06/2022	23:51	T	Distance Protection
PARANDA-BARSHI	IntraState	22/06/2022	10:10	22/06/2022	15:30	PO	Outage is required for Quarterly Maintenance
PANDHARPUR - MALINAGAR	IntraState	22/06/2022	11:42	22/06/2022	19:08	PO	Outage is required for Quarterly Maintenance
PANDHARPUR - MALINAGAR	IntraState	22/06/2022	11:42	22/06/2022	19:08	PO	Outage is required for Quarterly Maintenance
GHODBUNDER - MSETCL BOISAR	IntraState	22/06/2022	21:44			T	TRIPPED ON DIST. PROTECTION
BORIVALI - BOISAR II LINE	IntraState	22/06/2022	21:45			T	TRIPPED ON DIST. PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132-110 KV 100MVA ICT 1	IntraState	22/06/2022	10:30	22/06/2022	11:55	PO	OLTC overhauling work
220/100 KV 200 MVA ICT 1 @ KOLSHET	IntraState	22/06/2022	12:00	22/06/2022	18:29	PO	Outage for configuration of TF auxiliary monitoring system
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	22/06/2022	17:32	22/06/2022	21:45	T	Internal Fault
132 KV LINE Outages/Trippings							
WAGHDARI - SUKHBIR AGRO	IntraState	22/06/2022	15:05	22/06/2022	19:49	PO	Outage is required for Quarterly Maintenance
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 22/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 23/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage