

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 22/Jul/2021 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 83.614         | 2326.136        | 1) Gujrat                      | -9.460         | -147.873        |
| 2) Hydro            | 14.475         | 294.923         | 2) Madhya Pradesh              | 2.530          | 125.250         |
| 3) Gas              | 3.244          | 109.316         | 3) Chattisgarh                 | 3.870          | 87.960          |
| <b>Total MSPGCL</b> | <b>101.333</b> | <b>2730.375</b> | 4) Maharashtra                 | 110.370        | 3106.489        |
| B) 1) APLM          | 50.667         | 1398.528        | 5) Goa (Amona)                 | -1.644         | -16.695         |
| 2) JSWEL            | 17.873         | 394.463         | <b>Total</b>                   | <b>105.666</b> | <b>3155.131</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 27.586         | 635.113         |
| 4) RPL(AMT)         | 15.145         | 513.079         | b) Mumbai Drawl                | 27.285         | 650.345         |
| 5) SWPGPL           | 2.299          | 120.093         | c) MSEDCL Bilateral *          | 24.169         | 753.853         |
| 6) Other IPP        | 5.146          | 152.854         | Include PX                     | -2.237         | 126.162         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 27.586         | 632.356         |
| C) 1) TPCL Thermal  | 10.072         | 249.046         | Include PX                     | 12.779         | 297.226         |
| 2) TPCL Hydro       | 5.984          | 100.390         | Standby                        | 0.000          | 2.756           |
| 3) TPCL Gas         | 2.234          | 53.550          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 7.019          | 144.580         | 1) MSEDCL                      | 335.617        | 8648.055        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 52.594         | 1197.911        |
| 1) Thermal          | 191.835        | 5298.779        | <b>TOTAL STATE</b>             | <b>388.211</b> | <b>9845.966</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 20.459         | 395.313         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 5.478          | 162.866         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 61.913         | 709.842         |                                |                |                 |
| 6) SOLAR            | 2.860          | 124.035         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>282.545</b> | <b>6690.835</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 3571                      | 3665                  | 3978                      | 3336                      |
| MSPGCL Hydro             | 594                       | 618                   | 686                       | 494                       |
| MSPGCL Gas               | 137                       | 136                   | 135                       | 135                       |
| MSPGCL Total Generation  | 4302                      | 4419                  | 4799                      | 3965                      |
| Central Sector Receipt   | 5398                      | 4978                  | 4828                      | 2723                      |
| WIND                     | 2727                      | 2380                  | 1867                      | 3287                      |
| CPP / IPP Thermal        | 4059                      | 3886                  | 4760                      | 3402                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 234                       | 72                    | 0                         | 0                         |
| Exchange with Mumbai     | -1407                     | -1195                 | -1090                     | -852                      |
| <b>MSEDCL DEMAND MET</b> | <b>15313</b>              | <b>14540</b>          | <b>15164</b>              | <b>12525</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 15313                     | 14540                 | 15164                     | 12525                     |
| TPCL GENERATION          | 811                       | 895                   | 900                       | 549                       |
| AEML GENERATION          | 284                       | 286                   | 286                       | 285                       |
| <b>MUMBAI DEMAND</b>     | <b>2502</b>               | <b>2376</b>           | <b>2276</b>               | <b>1686</b>               |
| STATE DEMAND MET         | 17815                     | 16916                 | 17440                     | 14211                     |
| <b>STATE DEMAND</b>      | <b>17815</b>              | <b>16916</b>          | <b>17440</b>              | <b>14211</b>              |
| Frequency (Hz)           | 50.01                     | 50.00                 | 49.96                     | 50.04                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.15 Hz at 13.02 Hrs | 49.87 Hz at 15.08 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 22/Jul/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 9.93         | 212.73        | 511      | 346      |
| Unit 9             | 9.23         | 159.52        | 450      | 315      |
| Unit 10            | 9.30         | 168.39        | 490      | 349      |
| <b>Total</b>       | <b>28.46</b> | <b>540.64</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 7.20         | 172.38        | 465      | 285      |
| Unit 5             | 0.00         | 160.80        | 0        | 0        |
| <b>Total</b>       | <b>7.20</b>  | <b>333.18</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 22.08         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>22.08</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.94         | 71.23         | 139      | 115      |
| Unit 4             | 2.98         | 55.64         | 160      | 117      |
| Unit 5             | 6.79         | 164.87        | 335      | 270      |
| Unit 6             | 6.94         | 159.72        | 350      | 266      |
| Unit 7             | 6.86         | 60.98         | 325      | 251      |
| Unit 8             | 7.40         | 210.70        | 390      | 270      |
| Unit 9             | 0.00         | 138.21        | 0        | 0        |
| <b>Total</b>       | <b>33.91</b> | <b>861.34</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 83.94         | 0        | 0        |
| Unit 4             | 3.10         | 64.09         | 168      | 0        |
| <b>Total</b>       | <b>3.10</b>  | <b>148.03</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 0.00         | 7.76          | 0        | 0        |
| Unit 2             | 0.00         | 35.70         | 0        | 0        |
| Unit 3             | 0.00         | 41.57         | 0        | 0        |
| Unit 4             | 0.00         | 42.26         | 0        | 0        |
| Unit 5             | 7.80         | 220.23        | 385      | 290      |
| <b>Total</b>       | <b>7.80</b>  | <b>347.51</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 14.10         | 0        | 0        |
| Unit 5             | 3.14         | 59.25         | 137      | 125      |
| <b>Total</b>       | <b>3.14</b>  | <b>73.35</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 3.24         | 109.32        | 151      | 125      |
| <b>Total</b>       | <b>3.24</b>  | <b>109.32</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.20         | 4.25          | 25       | 0        |
| <b>Total</b>       | <b>0.20</b>  | <b>4.25</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 1.02         | 59.73          | 60       | 35       |
| Stage 4         | 0.39         | 64.70          | 301      | 0        |
| Stage 3         | 5.70         | 47.55          | 300      | 160      |
| <b>Total</b>    | <b>7.11</b>  | <b>171.97</b>  |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.00         | 0.00           | 0        | 0        |
| VTRNA           | 0.46         | 1.27           | 60       | 0        |
| TILLARI         | 1.39         | 3.07           | 58       | 58       |
| BHIRA T.R.      | 0.50         | 9.38           | 40       | 0        |
| SMLHY_PTN       | 5.01         | 106.56         | 231      | 185      |
| GHATGHAR        | 0.00         | 2.68           | 0        | 0        |
| <b>Total</b>    | <b>7.36</b>  | <b>122.95</b>  |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 61.91        | 709.84         | 0        | 0        |
| <b>Total</b>    | <b>61.91</b> | <b>709.84</b>  |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 50.67        | 1398.53        | 0        | 0        |
| JSWEL(Mus)      | 17.87        | 394.46         | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 15.14        | 513.08         | 0        | 0        |
| SWPGPL-Mus      | 2.30         | 120.09         | 0        | 0        |
| Other(Mus)      | 5.15         | 152.85         | 0        | 0        |
| <b>Total</b>    | <b>91.13</b> | <b>2579.02</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 2.86         | 124.04         | 0        | 0        |
| <b>Total</b>    | <b>2.86</b>  | <b>124.04</b>  |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 6.71         | 193.45         | 281      | 278      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 1.23         | 29.61          | 54       | 49       |
| Trombay 7B      | 1.01         | 23.94          | 44       | 41       |
| Trombay 8       | 3.36         | 55.60          | 162      | 137      |
| TATA Hydro      | 5.98         | 100.39         | 388      | 36       |
| <b>Total</b>    | <b>18.29</b> | <b>402.99</b>  |          |          |
| <b>AEML</b>     |              |                |          |          |
| DTPS U-1&2      | 7.02         | 144.58         | 381      | 284      |
| <b>Total</b>    | <b>7.02</b>  | <b>144.58</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 83.61       | 2326.14       | MSPGCL Total        | 101.33      | 2730.38       |
|                |             |         | MSPGCL Thml+Gas | 86.86       | 2435.45       | Koyna 1,2 & 4 Total | 1.41        | 124.42        |
|                |             |         | MSPGCL Hydro    | 14.48       | 294.92        | State Total         | 282.54      | 6690.84       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 22/Jul/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 3353        | 486   | 151  | 3990   | 3461  | 3380      | 0    | 0     | 3775        | 3006        | -1065                | 12772                 | 0                    | 12772                     | 1933             | 14705           | 50.04         |
| 2                  | 3332        | 509   | 125  | 3966   | 3397  | 3433      | 0    | 0     | 2733        | 2627        | -953                 | 12470                 | 0                    | 12470                     | 1816             | 14286           | 50.00         |
| 3                  | 3344        | 501   | 136  | 3981   | 3428  | 3439      | 0    | 0     | 2433        | 2555        | -903                 | 12500                 | 0                    | 12500                     | 1735             | 14235           | 50.02         |
| 4                  | 3336        | 494   | 135  | 3965   | 3287  | 3402      | 0    | 0     | 2686        | 2723        | -852                 | 12525                 | 0                    | 12525                     | 1686             | 14211           | 50.04         |
| 5                  | 3348        | 480   | 135  | 3963   | 3087  | 3403      | 0    | 0     | 3125        | 2952        | -848                 | 12557                 | 0                    | 12557                     | 1674             | 14231           | 50.03         |
| 6                  | 3346        | 478   | 135  | 3959   | 2789  | 3417      | 0    | 0     | 3995        | 3981        | -887                 | 13259                 | 0                    | 13259                     | 1735             | 14994           | 50.02         |
| 7                  | 3239        | 506   | 136  | 3881   | 2546  | 3445      | 0    | 10    | 4932        | 4999        | -925                 | 13956                 | 0                    | 13956                     | 1794             | 15750           | 50.00         |
| 8                  | 3389        | 846   | 135  | 4370   | 2548  | 3646      | 0    | 70    | 5251        | 5791        | -1078                | 15347                 | 0                    | 15347                     | 1969             | 17316           | 49.99         |
| 9                  | 3581        | 689   | 136  | 4406   | 2716  | 3961      | 0    | 172   | 5412        | 5400        | -1241                | 15414                 | 0                    | 15414                     | 2251             | 17665           | 50.01         |
| 10                 | 3571        | 594   | 137  | 4302   | 2727  | 4059      | 0    | 234   | 5707        | 5398        | -1407                | 15313                 | 0                    | 15313                     | 2502             | 17815           | 50.01         |
| 11                 | 3311        | 613   | 136  | 4060   | 2792  | 3737      | 0    | 345   | 5985        | 5596        | -1486                | 15044                 | 0                    | 15044                     | 2658             | 17702           | 50.03         |
| 12                 | 3349        | 611   | 136  | 4096   | 2543  | 3351      | 0    | 421   | 5907        | 5441        | -1464                | 14388                 | 0                    | 14388                     | 2673             | 17061           | 50.04         |
| 13                 | 3348        | 630   | 125  | 4103   | 2558  | 3325      | 0    | 402   | 5181        | 5058        | -1457                | 13989                 | 0                    | 13989                     | 2637             | 16626           | 50.04         |
| 14                 | 3358        | 650   | 136  | 4144   | 2684  | 3367      | 0    | 345   | 4612        | 4649        | -1371                | 13818                 | 0                    | 13818                     | 2538             | 16356           | 50.06         |
| 15                 | 3307        | 670   | 135  | 4112   | 2698  | 3388      | 0    | 314   | 4640        | 4828        | -1343                | 13997                 | 0                    | 13997                     | 2520             | 16517           | 49.99         |
| 16                 | 3364        | 633   | 135  | 4132   | 2596  | 3403      | 0    | 291   | 4800        | 4350        | -1219                | 13553                 | 0                    | 13553                     | 2487             | 16040           | 49.95         |
| 17                 | 3427        | 637   | 134  | 4198   | 2462  | 3487      | 0    | 175   | 4760        | 5024        | -1226                | 14120                 | 0                    | 14120                     | 2431             | 16551           | 49.98         |
| 18                 | 3665        | 618   | 136  | 4419   | 2380  | 3886      | 0    | 72    | 4675        | 4978        | -1195                | 14540                 | 0                    | 14540                     | 2376             | 16916           | 50.00         |
| 19                 | 3839        | 653   | 135  | 4627   | 1899  | 4198      | 0    | 9     | 5067        | 5035        | -1148                | 14620                 | 0                    | 14620                     | 2322             | 16942           | 49.99         |
| 20                 | 3978        | 686   | 135  | 4799   | 1867  | 4760      | 0    | 0     | 4736        | 4828        | -1090                | 15164                 | 0                    | 15164                     | 2276             | 17440           | 49.96         |
| 21                 | 4065        | 689   | 135  | 4889   | 1791  | 5270      | 0    | 0     | 4241        | 3989        | -1050                | 14890                 | 0                    | 14890                     | 2223             | 17112           | 49.99         |
| 22                 | 3787        | 626   | 135  | 4548   | 1708  | 4882      | 0    | 0     | 4298        | 4034        | -1013                | 14159                 | 0                    | 14159                     | 2158             | 16317           | 49.98         |
| 23                 | 3655        | 590   | 135  | 4380   | 1797  | 4489      | 0    | 0     | 4392        | 4269        | -1014                | 13921                 | 0                    | 13921                     | 2122             | 16043           | 50.00         |
| 24                 | 3322        | 586   | 135  | 4043   | 2152  | 4001      | 0    | 0     | 4445        | 4155        | -1050                | 13301                 | 0                    | 13301                     | 2078             | 15379           | 50.01         |
| MUs                | 83.61       | 14.47 | 3.24 | 101.33 | 61.91 | 91.13     | 0.00 | 2.86  | 107.79      | 105.67      | -27.29               | 335.62                | 0.00                 | 335.62                    | 52.59            | 388.21          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 22/Jul/2021**

**Position as on 6.30 Hrs of 23/Jul/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                  |               |
| IPP                   | RPL(AMT) U-3            | 270      | 15/07/2021   | 00.00        |            | Continued. | Annual Overhaul                                                                  |               |
| MSPGCL                | Chandrapur Unit 9       | 500      | 15/07/2021   | 02.00        |            | Continued. | Annual Overhaul                                                                  |               |
| MSPGCL                | Paras Unit 3            | 250      | 20/07/2021   | 00.35        |            | Continued. | Annual Overhaul                                                                  |               |
| MSPGCL                | Uran Unit 5             | 108      | 22/07/2021   | 00.06        |            | Continued. | Maintenance work                                                                 |               |
| MSPGCL                | Uran Unit A0            | 120      | 22/07/2021   | 00.06        |            | Continued. | Maintenance work                                                                 |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                  |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                          |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                             |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                             |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                           |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                          |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                           |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                            |               |
| MSPGCL                | Nasik Unit 3            | 210      | 03/12/2020   | 06.45        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).              |               |
| MSPGCL                | Koradi Unit 6           | 210      | 27/04/2021   | 19.59        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Parli Unit 6            | 250      | 04/05/2021   | 20.00        |            | Continued. | Zero Schedule By MSEDCL                                                          |               |
| MSPGCL                | Parli Unit 7            | 250      | 05/05/2021   | 19.00        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 08/06/2021   | 00.34        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Uran Unit 6             | 108      | 29/06/2021   | 22.18        |            | Continued. | Gas shortage                                                                     |               |
| MSPGCL                | Nasik Unit 4            | 210      | 04/07/2021   | 11.03        |            | Continued. | Boiler Tube Leakage(Converted into to Zero Schedule from 20.00Hrs DT.06-07-2021) |               |
| MSPGCL                | Parli Unit 8            | 250      | 12/07/2021   | 18.00        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Khaparkheda Unit 1      | 210      | 15/07/2021   | 23.57        |            | Continued. | Zero schedule                                                                    |               |
| MSPGCL                | Khaparkheda Unit 2      | 210      | 16/07/2021   | 00.12        |            | Continued. | Zero schedule                                                                    |               |
| MSPGCL                | Khaparkheda Unit 3      | 210      | 16/07/2021   | 00.29        |            | Continued. | Zero schedule                                                                    |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 16/07/2021   | 02.00        |            | Continued. | Zero schedule                                                                    |               |
| IPP                   | JSW (J) U4              | 300      | 16/07/2021   | 17.44        |            | Continued. | Air Preheater problem.                                                           |               |
| IPP                   | SWPGPL U-4              | 135      | 19/07/2021   | 23.45        |            | Continued. | Zero schedule.                                                                   |               |
| IPP                   | SWPGPL U-2              | 135      | 19/07/2021   | 23.51        |            | Continued. | Zero schedule.                                                                   |               |
| MSPGCL                | Bhusawal Unit 5         | 500      | 21/07/2021   | 14.08        |            | Continued. | Zero schedule.                                                                   |               |
| MSPGCL                | Paras Unit 4            | 250      | 22/07/2021   | 06.00        | 22/07/2021 | 09.20      | ID Fan Tripped.                                                                  |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Jul/2021**

**Statement-VII**

**Position as on 6.30 Hrs of 23/Jul/2021**

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                           |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                            |
| 765/400kv 1500MVA ICT @ Akola-II                  | IntraState                | 22/07/2021   | 02.17        | 22/07/2021 | 16.15      | T           | PRD Operated.                                                                                                                              |
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                            |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                   |
| Dhule Sar'Sarovar I                               | InterState                | 21/07/2021   | 02.06        | 22/07/2021 | 09.20      | T           | Tripped at SSP on over voltage DT received at dhule end.                                                                                   |
| Girwali - Lonikand 1                              | IntraState                | 14/07/2021   | 09.29        |            | Continued. | PO          | Dismantling / De-stringning, tower erection and stringing work between span 258-259 for LILO arrangement to proposed 400kv karjat station. |
| Chandrapur-Parali III                             | IntraState                | 21/07/2021   | 11.28        | 22/07/2021 | 08.09      | T           | Over Voltage                                                                                                                               |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 21/07/2021   | 20.50        | 22/07/2021 | 09.36      | HT          | Over Voltage                                                                                                                               |
| Akola II - RPL(Rattanindia) Ckt-II                | IntraState                | 22/07/2021   | 02.17        | 22/07/2021 | 16.53      | T           | Water clogging                                                                                                                             |
| Akola II - RPL(Rattanindia) Ckt I                 | IntraState                | 22/07/2021   | 02.17        | 22/07/2021 | 16.46      | T           | Water clogging                                                                                                                             |
| Akola II - Akola I Ckt-I                          | IntraState                | 22/07/2021   | 02.17        | 22/07/2021 | 17.13      | T           | Water clogging                                                                                                                             |
| Akola II - Akola I Ckt-II                         | IntraState                | 22/07/2021   | 02.17        | 22/07/2021 | 17.17      | T           | Water clogging                                                                                                                             |
| Chandrapur-II - Nanded ckt II                     | IntraState                | 22/07/2021   | 03.00        | 22/07/2021 | 21.22      | T           | Over Voltage                                                                                                                               |
| Karad - Jaigad - II                               | IntraState                | 22/07/2021   | 20.14        | 23/07/2021 | 13.46      | T           | Distance Protection                                                                                                                        |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 23/07/2021   | 13.18        |            | Continued. | HT          | Over Voltage                                                                                                                               |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                            |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                                                                      |
| 400/220/33kv 315MVA ICT2 @Lonikand                | IntraState                | 22/07/2021   | 08.06        | 23/07/2021 | 03.45      | PO          | Routine Maintenance Work                                                                                                                   |
| 400/220 KV 500 MVA ICT- III @Aurangabad (Waluj)   | IntraState                | 22/07/2021   | 11.36        | 23/07/2021 | 14.57      | PO          | Overhauling Of PG Isolator Work.                                                                                                           |
| 400/220/33kv 500MVA ICT 5 @ Padghe                | IntraState                | 23/07/2021   | 20.44        |            | Continued. | EO          | To attend Hot Spot                                                                                                                         |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                            |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                                                |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                                     |
| Tillari Amona                                     | InterState                | 23/07/2021   | 23.04        |            | Continued. | T           | Distance Protection                                                                                                                        |
| Wadkhal(GIS)-JSW(GIS) I                           | IntraState                | 16/07/2021   | 17.50        |            | Continued. | PO          | For replacement of existing 1200/1A GIS metering CTs with new 1600/1A GIS CTs.                                                             |
| Kandalgaon - ONGC Panvel                          | IntraState                | 22/07/2021   | 01.55        | 22/07/2021 | 12.36      | T           | Distance Protection                                                                                                                        |
| Kandalgaon - Koyna (Pophali)                      | IntraState                | 22/07/2021   | 05.07        |            | Continued. | T           | Distance Protection                                                                                                                        |
| Trombay - Kalwa                                   | IntraState                | 22/07/2021   | 10.08        | 22/07/2021 | 11.45      | PO          | Over Voltage                                                                                                                               |
| Kalmeshwar-Pandhurna                              | IntraState                | 22/07/2021   | 10.30        | 22/07/2021 | 18.14      | PO          | Line Maintenance work                                                                                                                      |
| Vsnl-512 Khadki                                   | IntraState                | 22/07/2021   | 14.13        | 22/07/2021 | 15.42      | PO          | Attending Hot Spot                                                                                                                         |
| Mahad-Kandalgaon                                  | IntraState                | 22/07/2021   | 19.35        |            | Continued. | T           | Distance Protection                                                                                                                        |
| Kandalgaon - Pirangut                             | IntraState                | 22/07/2021   | 19.37        |            | Continued. | T           | Distance Protection                                                                                                                        |
| Dasturi-Kandalgaon Line                           | IntraState                | 22/07/2021   | 22.37        | 23/07/2021 | 17.03      | T           | Distance Protection                                                                                                                        |
| Karad(400kv) -Mudshingi Ckt 2-Tak                 | IntraState                | 23/07/2021   | 08.40        | 23/07/2021 | 16.13      | T           | Distance Protection                                                                                                                        |
| Kharghar-Borivali ckt II                          | IntraState                | 23/07/2021   | 08.43        |            | Continued. | PO          | To Carry out bunching work.                                                                                                                |
| Adlabs - Pedambe                                  | IntraState                | 23/07/2021   | 08.45        | 23/07/2021 | 15.00      | T           | Y- PH CT To Line Conductor Damage.                                                                                                         |
| Mahape - TIFIL                                    | IntraState                | 23/07/2021   | 09.25        |            | Continued. | PO          | To Carry out bunching work.                                                                                                                |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Jul/2021**

**Statement-VII**

Position as on 6.30 Hrs of 23/Jul/2021

| Name of Line                          | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                     |
|---------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------|
| Theur-Phursungi ckt-2                 | IntraState                | 23/07/2021   | 09.30        | 23/07/2021 | 15.07      | PO          | Half yearly maintenance work                                                                                                                         |
| Khadka-Bhadli-1                       | IntraState                | 23/07/2021   | 10.08        | 23/07/2021 | 13.15      | PO          | Replacement of Damage jumper R PH line Isolator to Wave Trap. Replacement of Nut Bolt Clamps With Compressed Clamps of jumpers of LA,CC & Wave trap. |
| Ghatghar - Bapgaon                    | IntraState                | 23/07/2021   | 10.09        | 23/07/2021 | 17.03      | T           | LOC NO. 319 insulator string Decapped. Work in progress.                                                                                             |
| Midc Chandrapur-Gadchandur            | IntraState                | 23/07/2021   | 10.10        | 23/07/2021 | 10.42      | T           | PDR Operated.                                                                                                                                        |
| Kalwa-TIFIL                           | IntraState                | 23/07/2021   | 11.12        |            | Continued. | PO          | For Complete Tower erection work at loc no. 75A & 76 (behind M/s Siemens).                                                                           |
| Butibori-Abhijeet                     | IntraState                | 23/07/2021   | 12.29        | 23/07/2021 | 14.48      | PO          | Commissioning Work PT Selection panel.                                                                                                               |
| 220KV Chalisagaon-Kopergaon           | IntraState                | 23/07/2021   | 13.56        | 23/07/2021 | 17.26      | PO          | Work At Kopergaon End.                                                                                                                               |
| Akola-Paras Ckt No-I                  | IntraState                | 23/07/2021   | 15.27        | 23/07/2021 | 15.49      | T           | PDR Operated.                                                                                                                                        |
| Apta - Tambati                        | IntraState                | 23/07/2021   | 16.23        | 23/07/2021 | 18.15      | PO          | CB mechanism overhauling work by agency.                                                                                                             |
| Akola-Paras Ckt No-I                  | IntraState                | 23/07/2021   | 18.35        | 23/07/2021 | 19.05      | T           | PDR Operated.                                                                                                                                        |
| Uran - Kharghar I                     | IntraState                | 23/07/2021   | 22.57        | 23/07/2021 | 23.14      | T           | Distance Protection                                                                                                                                  |
| <b>220 KV ICT Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                                      |
| 220 Kv /132 Kv 100 Mva Ptr @Chitegaon | IntraState                | 18/07/2021   | 11.03        |            | Continued. | PO          | Attending oil leakage from main tank.                                                                                                                |
| 200/132KV 100MVA ICT-1@Butibori       | IntraState                | 23/07/2021   | 07.35        |            | Continued. | T           | Smoke observed From LV Side B - PH LA.                                                                                                               |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage