

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Jul/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	123.102	2892.989	1) Gujrat	3.947	36.901
2) Hydro	6.855	151.313	2) Madhya Pradesh	-0.813	98.811
3) Gas	0.000	1.185	3) Chattisgarh	1.460	49.070
Total MSPGCL	129.957	3045.487	4) Maharashtra	153.402	3570.732
B) 1) APML	41.871	1256.840	5) Goa (Amona)	-0.943	-23.112
2) JSWEL	19.474	433.831	Total	157.053	3732.402
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.036	770.340
4) RPL(AMT)	25.211	514.920	b) Mumbai Drawl	33.801	844.227
5) SWPGPL	6.657	192.527	c) MSEDCL Bilateral *	88.608	2008.386
6) Other IPP	6.262	141.233	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.036	769.489
C) 1) TPCL Thermal	9.941	177.777	Include PX	0.000	0.000
2) TPCL Hydro	3.923	103.264	Standby	0.000	0.851
3) TPCL Gas	2.754	73.634	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.356	195.467	1) MSEDCL	405.189	9457.668
D) STATE			2) Mumbai Discoms	58.775	1394.371
1) Thermal	240.874	5805.584	3) Other Discoms	9.774	215.967
(A1+C1+C4+(B1-B6))			TOTAL STATE	473.738	11068.006
2) Hydro (A2+C2)	10.778	254.577			
3) Gas (A3+B7+C3)	2.754	74.819			
4) Wind	57.597	990.250			
6) SOLAR	4.682	210.372			
TOTAL STATE	316.685	7335.602			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5651	5041	5319	4521
MSPGCL Hydro	257	176	751	251
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5908	5217	6070	4772
Central Sector Receipt	7611	7090	6447	5467
WIND	2420	2746	2285	2369
CPP / IPP Thermal	4238	3763	5083	3791
CPP / IPP Gas	0	0	0	0
SOLAR	423	641	0	0
Exchange with Mumbai	-1736	-1948	-1248	-970
MSEDCL DEMAND MET	18433	17091	18188	15107
Load Shedding	0	0	0	0
MSEDCL DEMAND	18433	17091	18188	15107
TPCL GENERATION	585	611	1024	655
AEML GENERATION	416	308	450	297
MUMBAI DEMAND	2737	2867	2722	1922
OTHER DISCOM DEMAND	431	418	449	322
STATE DEMAND MET	21601	20376	21359	17351
STATE DEMAND	21601	20376	21359	17351
Frequency (Hz)	49.99	49.95	50.04	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 22.03 Hrs	49.79 Hz at 12.53 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 22/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.51	78.70	170	120
Unit 8	11.67	216.07	543	362
Unit 9	11.46	262.14	625	391
Unit 10	0.00	111.14	0	0
Total	26.64	668.05		
Bhusawal				
Unit 3	3.05	63.73	135	110
Unit 4	9.36	210.59	447	284
Unit 5	9.90	217.55	470	290
Total	22.31	491.87		
Parli				
Unit 6	0.00	40.92	0	0
Unit 7	3.94	37.38	241	144
Unit 8	3.47	22.28	153	137
Total	7.42	100.59		
Chandrapur				
Unit 3	0.00	55.24	0	0
Unit 4	0.25	51.96	52	0
Unit 5	0.00	0.00	0	0
Unit 6	6.52	162.50	305	235
Unit 7	7.12	167.94	325	263
Unit 8	9.76	214.06	431	288
Unit 9	9.79	224.70	472	342
Total	33.44	876.41		
Paras				
Unit 3	2.32	85.09	218	0
Unit 4	4.06	94.93	185	140
Total	6.38	180.02		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	2.76	58.14	131	100
Unit 3	3.71	84.72	181	131
Unit 4	3.90	80.11	198	127
Unit 5	10.04	200.97	460	280
Total	20.40	423.94		
Nasik				
Unit 3	3.21	66.74	168	23
Unit 4	0.00	64.84	0	0
Unit 5	3.31	20.53	161	118
Total	6.51	152.11		
Uran				
All Units	0.00	1.18	0	0
Total	0.00	1.18		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.20	1.82	27	0
Total	0.20	1.82		
Koyna				
Stage 1-2	1.14	42.13	135	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.10	7.14	104	0
Stage 3	1.33	22.24	160	0
Total	2.58	71.50		
Hydro				
KDPH	0.00	0.14	0	0
VTRNA	0.00	0.64	0	0
TILLARI	0.00	1.16	0	0
BHIRA T.R.	0.46	9.60	80	0
SMLHY_PTN	3.32	60.74	144	130
GHATGHAR	0.31	5.71	125	0
Total	4.08	77.99		
Wind				
Total	57.60	990.25	0	0
Total	57.60	990.25		
CPP				
APML(Mus)	41.87	1256.84	0	0
JSWEL(Mus)	19.47	433.83	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.21	514.92	0	0
SWPGPL-Mus	6.66	192.53	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.04	113.07	268	155
Other(Mus)	1.23	28.16	0	0
Total	99.48	2539.35		
SOLAR				
Total	4.68	210.37	0	0
Total	4.68	210.37		
Tata				
Trombay 5	6.58	94.89	376	254
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.61	44.65	108	38
Trombay 7B	1.14	28.98	65	36
TATA Hydro	3.92	103.26	327	93
Trombay 8	3.36	82.88	169	130
Total	16.62	354.68		
AEML				
DTPS U-1&2	8.36	195.47	450	287
Total	8.36	195.47		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	123.10	2892.99	MSPGCL Total	129.96	3045.49
			MSPGCL Thml+Gas	123.10	2894.17	Koyna 1,2 & 4 Total	1.25	49.26
			MSPGCL Hydro	6.86	151.31	State Total	316.68	7335.60

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 22/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5173	216	0	5389	2568	3898	0	0	5497	4877	-1047	15313	0	0	15313	2153	372	17838	49.98
2	4695	262	0	4957	2432	3792	0	0	5758	5456	-1051	15238	0	0	15238	2019	348	17605	49.97
3	4521	251	0	4772	2369	3791	0	0	5524	5467	-970	15107	0	0	15107	1922	322	17351	49.98
4	5139	255	0	5394	2255	3785	0	0	5307	5133	-986	15268	0	0	15268	1875	313	17456	50.03
5	5294	250	0	5544	2360	3852	0	0	5629	5624	-1008	16033	0	0	16033	1891	339	18263	50.00
6	5288	252	0	5540	2379	3825	0	0	6647	6519	-1094	16792	0	0	16792	1963	377	19132	50.01
7	5426	250	0	5676	2659	4250	0	23	7257	7023	-1176	18047	0	0	18047	2085	408	20540	50.00
8	5499	288	0	5787	2592	3903	0	128	7614	7653	-1349	18283	0	0	18283	2226	431	20940	49.99
9	5580	245	0	5825	2514	4218	0	255	7362	7415	-1578	18203	0	0	18203	2467	446	21116	50.00
10	5651	257	0	5908	2420	4238	0	423	7561	7611	-1736	18433	0	0	18433	2737	431	21601	49.99
11	5558	174	0	5732	2514	4201	0	520	7571	7329	-1854	18022	0	0	18022	2889	420	21331	50.00
12	5376	179	0	5555	2515	3857	0	633	7890	7467	-2030	17575	0	0	17575	2929	422	20926	50.00
13	5041	176	0	5217	2746	3763	0	641	7725	7090	-1948	17091	0	0	17091	2867	418	20376	49.95
14	4217	192	0	4409	2631	3527	0	606	7525	7423	-1830	16352	0	0	16352	2740	414	19506	49.95
15	4236	237	0	4473	2411	3644	0	498	7498	7522	-1786	16370	0	0	16370	2727	392	19489	49.94
16	4668	245	0	4913	2325	3724	0	398	7275	7762	-1813	16889	0	0	16889	2701	420	20010	50.03
17	5063	296	0	5359	2469	3966	0	340	6833	7017	-1682	17026	0	0	17026	2679	443	20148	50.04
18	5333	265	0	5598	2395	4249	0	187	7045	6580	-1590	16985	0	0	16985	2660	434	20079	49.98
19	5285	336	0	5621	2447	4404	0	30	7010	6987	-1424	17594	0	0	17594	2701	471	20766	50.03
20	5319	751	0	6070	2285	5083	0	0	6623	6447	-1248	18188	0	0	18188	2722	449	21359	50.04
21	5317	497	0	5814	2139	5247	0	0	6091	6034	-1194	17609	0	0	17609	2639	431	20679	50.02
22	5241	407	0	5648	2218	5145	0	0	5883	5550	-1174	16948	0	0	16948	2515	439	19902	50.05
23	5180	288	0	5468	2068	4966	0	0	5670	5329	-1093	16311	0	0	16311	2393	427	19131	50.05
24	5002	286	0	5288	1886	4147	0	0	5866	5738	-1140	15515	0	0	15515	2275	404	18194	50.02
MUs	123.10	6.85	0.00	129.96	57.60	99.48	0.00	4.68	160.66	157.05	-33.80	405.19	0.00	0.00	405.19	58.77	9.77	473.74	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Jul/2023

Position as on 6.30 Hrs of 23/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
IPP	Adani U-1	660	16/07/2023	00:00		Continued.	Annual Overhaul	07/08/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	25/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/07/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	25/07/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	25/07/2023
MSPGCL	Chandrapur Unit 4	210	18/07/2023	23:49	22/07/2023	15:21	Air heater problem	
MSPGCL	Nasik Unit 4	210	19/07/2023	10:50		Continued.	ID Fan Problem	21/07/2023
MSPGCL	Uran Unit 6	108	19/07/2023	21:11		Continued.	No schedule	
IPP	SWPGPL U-3	135	21/07/2023	01:54		Continued.	Non-availability of linkage coal stock and due to continuous rains.	
MSPGCL	Parli Unit 6	250	21/07/2023	23:44		Continued.	BTL,(Converted into Zero schedule wef 23:00hrs dated 23.07.23)	
MSPGCL	Paras Unit 3	250	22/07/2023	12:15		Continued.	Due to boiler drum LHS main hole door gasket leakage	27/07/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Jul/2023

Position as on 6.30 Hrs of 23/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 4	210	22/07/2023	15:43	22/07/2023	17:14	DUE TO CVSM FAILURE	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 23/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LR Outages/Trippings							
710 LR (TIRODA CKT - 1) REACTOR @ KORADI 3	IntraState	23/07/2023	20:17	23/07/2023	23:53	T	On REF Protection. Protection cable IR found low; cable replaced.
765 KV LINE Outages/Trippings							
TIRORA - KORADI 3 CKT - 1	IntraState	23/07/2023	10:49	23/07/2023	20:17	PO	Installation of Bird Flight Divertor- In reference to the Hon'ble High Court, Nagpur Order dated 05th January 2022
TIRORA - KORADI 3 CKT - 1	IntraState	23/07/2023	10:49	23/07/2023	20:17	PO	INSTALLATION OF BIRD FLIGHT DIVERTOR- IN REFERENCE TO THE HONBLE HIGH COURT, NAGPUR ORDER DATED 05TH JANUARY 2022
TIRODA - KORADI 3 CKT - 2	IntraState	23/07/2023	21:52		Continued.	HT	Found one monkey is trapped in live conductor of 765KV tiroda-koradi-iii-2 And struggling to escape from the conductor.
TIRORA - KORADI 3 CKT - 1	IntraState	23/07/2023	21:52		Continued.	T	Tripped without indication at koradi-3 end only.
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20			PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR	IntraState	06/07/2023	08:38			PO	1. Maintenance and alignment work of Bus-1, Bus-2 Aus. Bus And HCB Isolator. 2. Maintenance of CB, CT and Synch CVT.
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
PADGHE - KALWA CKT - 2	IntraState	22/07/2023	05:51	22/07/2023	08:30	EO	Y ph CT hot spot (195) deg
KHADKA-AURANGABAD (WALUJ)	IntraState	22/07/2023	23:52		Continued.	HT	For voltage management
PADGHE - KALWA CKT - 1	IntraState	23/07/2023	05:25	23/07/2023	07:59	EO	29C bus isolator R-ph & B-ph (CT side) clamp hot spot R-ph (119) & B-ph (61.9) deg
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	17/07/2023	13:04			PO	1.Replacement of HV CB under LES Scheme. 2.ICT will be in service through TBC.
95 MVA STN TF - II @KORADI 2	IntraState	21/07/2023	22:56	22/07/2023	18:40	T	General electric trip.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 23/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/11.5KV STATION TRANSFORMER - 1 @ TIRORA	IntraState	22/07/2023	09:43			HT	Planned outage in RC1 row No. 14
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	22/07/2023	12:28	22/07/2023	17:37	EO	29A isolator mechanism box replacement /overhauling work
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	22/07/2023	15:05	22/07/2023	16:31	T	tripping due to ingress of moisture in relay wiring
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55	22/07/2023	14:00	HT	For load management
GHODBUNDER - GORAI	IntraState	22/07/2023	00:24	22/07/2023	05:32	PO	For Safety Purpose while erection of U girder at P153 - P154LHS under metro 09 work
VERSOVA - GHODBUNDER	IntraState	22/07/2023	00:39	22/07/2023	06:00	PO	For Safety Purpose while erection of U girder at P153 - P154LHS under metro 09 work
PUSAD - WARDHA (PG)	IntraState	22/07/2023	05:30	22/07/2023	16:34	T	Tripped on Distance protection
POPHLI PEDHMBE LINE- 1	IntraState	22/07/2023	08:40	22/07/2023	15:30	T	Tripped on Distance Protection.
HINJAWADI I- CHINCHWAD	IntraState	22/07/2023	08:50	22/07/2023	20:40	PO	On 22.07.2023 Saturday 1. Erection of Location 161 - 4 sections with 450 Ton crane 2. Erection of Location 162 - Last 1 section with 180 Ton crane On 23.07.2023 Sunday 1. Erection of Location 161 - Last 2 segments with 450 Ton Crane
AJINKYATARA-SATARA MIDC	IntraState	22/07/2023	10:05	22/07/2023	17:02	PO	1.R & B Ph CT to Line isolator jump replacement work & Quarterly maintenance work at 220kV Satara MIDC S/Stn. 2.Replacement of line isolator Y Ph damaged dropping conductor at 220kV Ajinkyatara S/Stn.
AURANGABAD (WALUJ)-BHENDA	IntraState	22/07/2023	10:23	22/07/2023	16:48	PO	Jumper replacement work
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	10:58	22/07/2023	14:00	PO	For Tree cutting work between Loc. 180B & 181A
PALGHAR - NALASOPARA	IntraState	22/07/2023	12:13	22/07/2023	18:15	EO	Replacement of damaged conductor between loc no.184-185 B-ph.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	22/07/2023	14:30	22/07/2023	17:07	PO	For Tree cutting work between Loc. No. 201A-201B
TROMBAY - KALWA	IntraState	22/07/2023	14:37			PO	Outage is required for safety purpose by M/s KVTL during stringing of 400KV Khargar-Vikhroli line between loc no. AP 59- AP 60 & 61-62 by M/s KVTL.
TROMBAY - MULUND	IntraState	22/07/2023	14:38	22/07/2023	18:40	PO	Outage is required for safety purpose by M/s KVTL during stringing of 400KV Khargar-Vikhroli line between loc no. AP 59- AP 60 & 61-62 by M/s KVTL.
VERSOVA - GHODBUNDER	IntraState	22/07/2023	15:07	22/07/2023	15:52	EO	For attending , Bus Isolator operating motor stuck issue.
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
GHODBUNDER - GORAI	IntraState	23/07/2023	00:18	23/07/2023	05:25	PO	For Safety Purpose while erection of U girder at P150 - P151LHS under metro 09 work
VERSOVA - GHODBUNDER	IntraState	23/07/2023	00:31	23/07/2023	05:28	PO	For Safety Purpose while erection of U girder at P150 - P151LHS under metro 09 work
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 23/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33 KV 50 MVA PTR 2 @ BHENDA	IntraState	22/07/2023	10:02	22/07/2023	14:22	PO	Quarterly Maintenance Work.
220/132 KV 150 MVA ICT-2 @BHENDA	IntraState	22/07/2023	10:03	22/07/2023	14:22	PO	Quarterly Maintenance Work.
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	IntraState	22/07/2023	12:00	22/07/2023	13:48	EO	Saturday 22.07.2023 12:00 to 14:00Hrs To attend Tap change problem(ICT tap stuckup while tap change)
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	IntraState	22/07/2023	14:53	22/07/2023	17:14	PO	Red hot attending work.(Images attached h/w)
220 KV BUSBAR Outages/Trippings							
AUXILIARY BUS @ PHALTAN MIDC-220 KV	IntraState	16/07/2023	10:02			PO	For Gantry replacement from AH type to AF type
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage