

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Sep/2016 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	57.607	2265.509	1) Gujrat	-4.391	4.752
2) Hydro	9.558	183.700	2) Madhya Pradesh	13.383	200.986
3) Gas	6.494	150.988	3) Chattisgarh	8.720	127.270
Total MSPGCL	73.659	2600.197	4) Maharashtra Net	86.721	1768.629
B) 1) APML	61.812	1279.831	5) Goa (Amona)	-0.412	-12.102
2) JSWEL	19.382	435.587	6) TAPS 1&2 Injection	7.671	168.634
3) VIPL	11.497	247.290	7) RGPPL Injection	11.739	262.808
4) RPL(AMT)	0.000	65.208	8) Pench (MS)	0.920	20.737
5) WPCL	4.840	97.291	9) Pench (Excess)	-0.920	-20.737
6) PGPL	0.000	80.445	Total	122.511	2500.240
7) Other IPP	2.512	55.471	a) Mumbai Schedule	19.335	411.000
C) 1) TPCL Thermal	13.386	269.139	b) Mumbai Drawl	22.508	538.672
2) TPCL Hydro	5.965	111.461	c) MSEDCL Bilateral *	29.487	587.512
3) TPCL Gas	4.016	92.689	Include PX	-1.650	-46.220
4) R-INFRA Thermal	10.317	225.771	d) Mumbai Bilateral *	19.335	410.486
D) STATE			Include PX	0.096	27.312
1) Thermal	181.353	4941.097	Include Standby	0.000	0.514
(A1+C1+C4+(B1-B6))			H) ENERGY CATERED (MUs)		
2) Hydro	15.523	295.161	1) MSEDCL	294.210	7305.371
3) Gas	10.510	324.122	2) Mumbai Discoms	56.192	1237.737
4) Wind	19.736	462.991	TOTAL STATE	350.402	8543.108
6) SOLAR	0.769	19.492			
TOTAL STATE	227.891	6042.863			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	2537	2309	2580	2355
MSPGCL Hydro	548	401	1145	253
MSPGCL Gas	276	259	263	278
MSPGCL Total Generation	3361	2969	3988	2886
Central Sector Receipt	5536	5588	5739	3692
WIND	624	1016	844	1156
CPP / IPP Thermal	4501	3948	4512	3734
CPP / IPP Gas	0	0	0	0
SOLAR	74	21	0	0
Exchange with Mumbai	-1077	-1272	-1006	-520
MSEDCL DEMAND MET	13019	12270	14077	10948
Load Shedding	0	0	0	0
MSEDCL DEMAND	13019	12270	14077	10948
TPCL GENERATION	1199	1056	1233	670
R-INFRA GENERATION	434	402	504	403
MUMBAI DEMAND	2710	2730	2743	1593
STATE DEMAND MET	15729	15000	16820	12541
STATE DEMAND	15729	15000	16820	12541
Frequency (Hz)	49.99	49.99	49.99	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 13.00 Hrs	49.83 Hz at 19.04 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 22/Sep/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	10.83	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	51.03	0	0
Unit 8	9.63	232.50	452	350
Total	9.63	294.36		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	6.80	0	0
Unit 4	0.00	93.04	0	0
Unit 5	0.00	136.14	0	0
Total	0.00	235.98		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.03	91.80	192	111
Unit 4	4.20	71.75	188	163
Unit 5	8.56	194.72	385	340
Unit 6	0.00	176.83	0	0
Unit 7	8.72	185.15	385	340
Unit 8	0.00	146.45	0	0
Total	25.50	866.71		
Paras				
Unit 3	0.00	92.20	0	0
Unit 4	4.99	102.63	243	181
Total	4.99	194.83		
Khaparkheda				
Unit 1	0.00	45.01	0	0
Unit 2	0.00	62.12	0	0
Unit 3	0.00	70.68	0	0
Unit 4	0.00	68.43	0	0
Unit 5	9.07	225.46	500	0
Total	9.07	471.70		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.19	90.56	197	160
Unit 5	4.22	90.60	196	165
Total	8.41	181.16		
Uran				
All Units	6.49	150.99	279	259
Total	6.49	150.99		
PGPL				
Unit 1	0.00	51.09	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	0.00	29.35	0	0
Total	0.00	80.44		
PENCH (MS)				
Pench (MS)	0.92	20.74	54	21
Total	0.92	20.74		
Koyna				
Stage 1-2	2.34	64.20	420	40
Stage 4	0.88	27.09	448	0
Stage 3	1.95	28.01	160	0
Total	5.18	119.30		
Hydro				
KDPH	0.78	11.02	33	32
VTRNA	0.90	3.70	58	0
TILLARI	0.37	6.51	62	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.48	9.95	80	0
RNGR+BHTSA	0.38	1.43	16	15
BHANDARDRA	0.34	5.52	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.61	7.14	35	22
GHATGHAR	0.51	19.13	125	0
Total	4.38	64.40		
Wind				
Total	19.74	462.99	0	0
Total	19.74	462.99		
CPP				
APML(Mus)	61.81	1279.83	0	0
JSWEL(Mus)	19.38	435.59	0	0
VIPL(Mus)	11.50	247.29	0	0
RPLAMT(Mus)	0.00	65.21	0	0
WPCL(Mus)	4.84	97.29	0	0
Other(Mus)	2.51	55.47	0	0
Total	100.04	2180.68		
SOLAR				
Total	0.77	19.49	0	0
Total	0.77	19.49		
Tata				
Trombay 5	8.35	156.82	482	314
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.49	58.24	115	64
Trombay 7B	1.52	34.45	68	51
Trombay 8	5.04	112.32	243	190
TATA Hydro	5.96	111.46	387	12
Total	23.37	473.29		
R-INFRA				
1-2	10.32	225.77	510	401
Total	10.32	225.77		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	0.00	20.78
Koradi 9	0.00	0.00
Koradi 10	0.00	0.00
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	57.61	2265.51
MSPGCL Thml+Gas	64.10	2416.50
MSPGCL Hydro	9.56	183.70

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	73.66	2600.20
Koyna 1,2 & 4 Total	3.23	91.29
State Total	227.89	6042.86

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 22/Sep/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2390	123	267	2780	1231	3837	0	0	4606	4016	-639	11225	0	11225	1832	13057	50.01
2	2386	123	268	2777	1214	3737	0	0	4087	3903	-591	11040	0	11040	1654	12694	50.01
3	2355	253	278	2886	1156	3734	0	0	3257	3692	-520	10948	0	10948	1593	12541	50.00
4	2390	283	276	2949	1042	3731	0	0	3611	3786	-517	10991	0	10991	1553	12544	50.02
5	2421	144	276	2841	865	3720	0	0	4217	4271	-526	11171	0	11171	1562	12733	50.01
6	2415	199	260	2874	834	3823	0	0	5115	4874	-596	11809	0	11809	1698	13507	49.99
7	2509	262	276	3047	837	3929	0	0	5186	5158	-537	12434	0	12434	1816	14250	49.97
8	2568	319	268	3155	766	4202	0	7	5220	5276	-724	12682	0	12682	2080	14762	50.00
9	2537	392	279	3208	694	4364	0	38	5346	5569	-859	13014	0	13014	2304	15318	50.02
10	2537	548	276	3361	624	4501	0	74	5415	5536	-1077	13019	0	13019	2710	15729	49.99
11	2648	490	276	3414	520	4487	0	104	5408	5343	-1071	12797	0	12797	2868	15665	50.00
12	2585	413	273	3271	438	4489	0	94	5445	5393	-1332	12353	0	12353	2957	15310	50.00
13	2560	233	268	3061	490	4326	0	106	5416	5456	-1468	11971	0	11971	2930	14901	49.99
14	2387	182	274	2843	635	4266	0	103	5415	5266	-1311	11802	0	11802	2775	14577	50.01
15	2318	198	264	2780	840	4218	0	105	5428	5341	-1304	11980	0	11980	2779	14759	50.00
16	2311	183	260	2754	893	4054	0	64	5340	5182	-1310	11637	0	11637	2766	14403	50.00
17	2314	289	274	2877	999	3849	0	46	4976	5463	-1255	11979	0	11979	2742	14721	49.95
18	2309	401	259	2969	1016	3948	0	21	5142	5588	-1272	12270	0	12270	2730	15000	49.99
19	2501	775	277	3553	1064	4304	0	0	5750	5848	-1252	13517	0	13517	2728	16245	49.97
20	2580	1145	263	3988	844	4512	0	0	5592	5739	-1006	14077	0	14077	2743	16820	49.99
21	2369	672	275	3316	647	4498	0	7	5607	6039	-910	13597	0	13597	2605	16202	49.99
22	2099	1066	264	3429	727	4483	0	0	5463	5673	-914	13398	0	13398	2435	15833	50.00
23	2096	530	264	2890	700	4523	0	0	5386	5177	-773	12517	0	12517	2245	14762	49.96
24	2022	335	279	2636	660	4508	0	0	5047	4922	-744	11982	0	11982	2087	14069	49.99
MUs	57.61	9.56	6.49	73.66	19.74	100.04	0.00	0.77	121.48	122.51	-22.51	294.21	0.00	294.21	56.19	350.40	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Sep/2016

Position as on 6.30 Hrs of 23/Sep/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08	22/09/2016	13.27	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Koyana Unit 8	80	19/08/2016	11.00		Continued.	High Vibration On LGB & UGB.	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Nasik Unit 3	210	28/08/2016	21.45		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16	
IPP	RPL(AMT) U-2	270	12/09/2016	00.03		Continued.	Zero Schedule by MSEDCL	
PGPL	PGPL U2	126	14/09/2016	00.16		Continued.	Due To No Shedule.	
PGPL	PGPL U1	262	14/09/2016	00.20		Continued.	Due To No Shedule.	
IPP	RPL(AMT) U-1	270	14/09/2016	23.55		Continued.	Zero Schedule by MSEDCL	
IPP	RPL(AMT) U-4	270	15/09/2016	18.09		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Bhusawal Unit 4	500	15/09/2016	23.59		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Bhusawal Unit 3	210	16/09/2016	00.02		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Koradi Unit 7	210	16/09/2016	00.06		Continued.	Zero Schedule by MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Sep/2016

Position as on 6.30 Hrs of 23/Sep/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 1	210	17/09/2016	13.39		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Khaparkheda Unit 2	210	17/09/2016	13.43		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Bhusawal Unit 5	500	17/09/2016	13.51		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Khaparkheda Unit 3	210	17/09/2016	20.40		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Khaparkheda Unit 4	210	17/09/2016	20.48		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Paras Unit 3	250	18/09/2016	14.58	23/09/2016	01.15	Air heater problem	
MSPGCL	Uran Unit 6	108	18/09/2016	23.42		Continued.	Maintenance work	
MSPGCL	Chandrapur Unit-8	500	19/09/2016	18.43		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 6	500	19/09/2016	22.37	23/09/2016	23.53	Boiler Tube Leakage	
IPP	JSW (J) U4	300	21/09/2016	23.46	22/09/2016	21.08	Condensor Cleaning	
MSPGCL	Parli Unit 7	250	22/09/2016	13.27	22/09/2016	13.47	Unit does not synchd.in Grid only Dynamic Testing purpose.	
MSPGCL	Parli Unit 7	250	22/09/2016	13.47		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Khaparkheda Unit 5	500	22/09/2016	20.48		Continued.	Boiler Tube Leakage	
IPP	JSW (J) U3	300	23/09/2016	10.50	23/09/2016	15.55	G T Tripped.	
IPP	JSW (J) U4	300	23/09/2016	10.50	23/09/2016	13.31	G T Tripped.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Sep/2016

Statement-VII

Position as on 6.30 Hrs of 23/Sep/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	19/09/2016	08.38		Continued.	PO	Annual Maintenance Work
Chandrapur - Padghe Hvdc Pole 2	IntraState	23/09/2016	08.40		Continued.	PO	Annual Maintenance Work
400 KV LINE Outages/Trippings							
Dhule Sar'Sarovar II	InterState	20/09/2016	22.04		Continued.	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	21/09/2016	16.27	22/09/2016	06.38	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	22/09/2016	02.49	22/09/2016	06.59	T	Over Voltage
Parli(MS)-Parli (PG) I	InterState	22/09/2016	13.26	22/09/2016	16.06	EO	To attend Hot Spot
Kolhapur Solapur(PG) I	InterState	22/09/2016	16.09		Continued.	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	23/09/2016	01.43	23/09/2016	06.45	T	Over Voltage
Kolhapur Solapur (PG) II	InterState	23/09/2016	23.57		Continued.	T	Over Voltage
Ektuni-Bableswhar ckt II	IntraState	01/08/2016	09.53		Continued.	HT	To control Padgha-BBLSR L/L
Karad-Jaigad - I	IntraState	16/09/2016	11.27		Continued.	EO	Attending Hot Spot, Line RFC @ 14.19 Hrs.
karad -kolhapur-I	IntraState	17/09/2016	03.43		Continued.	T	Over Voltage,B Pole of Breaker Bust.
Khadka-Aurangabad (Waluj)	IntraState	19/09/2016	15.14		Continued.	HT	Over Voltage
New Koyna - Dabhol-I	IntraState	21/09/2016	09.05		Continued.	PO	String repl.work (RFC 19.02Hrs)
Lonikand I - Koyna stage-IV	IntraState	22/09/2016	00.31	22/09/2016	06.28	HT	Over Voltage
Chandrapur-II - Nanded	IntraState	22/09/2016	02.54	22/09/2016	18.26	T	Over Voltage
Padghe - Kharghar	IntraState	22/09/2016	11.16	22/09/2016	18.23	EO	To attend Hot Spot
Lonikand I - Koyna stage-IV	IntraState	22/09/2016	23.40	23/09/2016	09.01	HT	Over Voltage
Koradi-Bhusawal	IntraState	23/09/2016	20.18	23/09/2016	20.42	T	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	23/09/2016	23.53		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	20/08/2016	11.06		Continued.	PO	Shifted on TBC, by hot line jumper open for construction of kudas bay ektuni CKT-2 will remain off during this outage period.
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	22/09/2016	07.17	22/09/2016	09.09	EO	To attend Hot Spot
400/220KV 500MVA ICT1@koradi 2	IntraState	22/09/2016	08.56	22/09/2016	12.58	T	Differential protection
400/220/33 Kv 315 MVA ICT I @Babhleshwar	IntraState	23/09/2016	05.22	23/09/2016	09.38	T	Bucholz Protection Optd
400/220kv 315 Mva ICT III @Karad	IntraState	23/09/2016	13.58	23/09/2016	19.03	PO	B Ph Isolator Job Replacement Work.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/09/2016	00.00		Continued.	HT	No schedule from Karnataka(H/T from Talandage end)
Mudshingi - Chikodi	InterState	01/09/2016	00.00		Continued.	HT	No schedule from Karnataka(H/T from Chikodi end)
Mahalakshmi Amona	InterState	22/09/2016	06.19	22/09/2016	06.32	T	Tripped at Amona end only
Tillari Amona	InterState	22/09/2016	06.19	22/09/2016	06.32	T	Tripped at Amona end only
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Bableswhar - Alephata	IntraState	26/08/2016	20.54		Continued.	HT	Hand tripped.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 22/Sep/2016

Statement-VII

Position as on 6.30 Hrs of 23/Sep/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Theur-Jejuri	IntraState	22/09/2016	06.15	22/09/2016	13.22	T	Distance Protection
Kalyani - Baramati Agro	IntraState	22/09/2016	07.30	22/09/2016	22.55	PO	LILO arrangement of Shirsuphal
Bhigwan- Kurkumbh	IntraState	22/09/2016	07.30	22/09/2016	02.18	PO	LILO arrangement of Shirsuphal
Badnera - Amravati	IntraState	22/09/2016	08.38	22/09/2016	16.17	PO	Tan Delta Measurment of CTs
Pophali - Pedambe II	IntraState	22/09/2016	08.50	22/09/2016	18.10	PO	Routine Maintenance Work
Lonand-Baramati	IntraState	22/09/2016	09.05	22/09/2016	16.52	PO	Routine Maintenance Work
K'Kheda- Suryalakshmi	IntraState	22/09/2016	09.09	22/09/2016	15.10	PO	Attending Oil Leakage
Siemens - Mahape	IntraState	22/09/2016	10.02	22/09/2016	18.22	PO	Routine Maintenance Work
Uran - Apta II	IntraState	22/09/2016	10.22	22/09/2016	16.55	EO	To attend Hot Spot
Deepnagar Bambhori	IntraState	22/09/2016	14.07		Continued.	T	Distance Protection
Osmanabad - Barshi	IntraState	22/09/2016	14.46	22/09/2016	15.13	T	Distance Protection
Paranda-Barshi	IntraState	22/09/2016	14.46	22/09/2016	15.10	T	Distance Protection
Colourchem - Temghar	IntraState	23/09/2016	08.20	23/09/2016	12.15	PO	Attending Hot Spot
Pophali - Nerale	IntraState	23/09/2016	08.30	23/09/2016	17.15	PO	Distance Protection
Dhamangaon New - Badnera	IntraState	23/09/2016	08.56	23/09/2016	15.47	PO	Measurment of Breaker Timing.
Kalmeshwar-Pandhurna	IntraState	23/09/2016	10.53	23/09/2016	21.22	PO	Maintenance Work.
Kharghar - Tss Panvel	IntraState	23/09/2016	11.30	23/09/2016	13.40	PO	Line Signature Ananlysis.
chandrapur-Tadali	IntraState	23/09/2016	13.51	23/09/2016	14.71	HT	Sparking on Main Bus Side Isolator.
Ongc Panvel - Tss Panvel	IntraState	23/09/2016	13.55	23/09/2016	20.05	PO	Line Signature Ananlysis.
Parli 2 (Girwali)- Parbhani	IntraState	23/09/2016	14.10	23/09/2016	15.15	T	Distance Protection
Hingoli- Girawali	IntraState	23/09/2016	14.10	23/09/2016	21.35	T	Distance Protection
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	23/09/2016	20.01		Continued.	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 KV 100MVA ICT @ Kawlewadi	IntraState	23/09/2016	08.38	23/09/2016	19.50	PO	Work of PRV Replacement of ICT.
220/132 Kv 200 Mva Bbl Ict 2 @Beed	IntraState	23/09/2016	09.25	23/09/2016	17.02	T	CLM Alarm Opted & Smoke Detected.
220/132 Kv 200 Mva Cgl Ptr No 5 @Parvati	IntraState	23/09/2016	10.00	23/09/2016	17.25	PO	OLTC Overhauling & CT Tandelta
220/132 Kv 200 Mva Bbl Ict 4 @Padegaon	IntraState	23/09/2016	10.16	23/09/2016	18.06	PO	Half yearly maintenance work
220/132 kv 200MVA ICT II @ Girwali	IntraState	23/09/2016	14.12	23/09/2016	17.34	PO	Oil Topup in OLTC Tank.
220/132 kv 200 MVA ICT- I @ Nanded	IntraState	23/09/2016	14.24	23/09/2016	15.11	PO	Replacement of Damaged Insulator.
132 KV LINE Outages/Trippings							
Raimoha - Pathardi	IntraState	22/09/2016	17.18		Continued.	T	Distance Protection
Umri - Kundalwadi	IntraState	22/09/2016	19.43	22/09/2016	20.10	T	Distance Protection
100 KV LINE Outages/Trippings							
Vasai-Ii - Vasai 2 Line	IntraState	13/08/2016	08.53		Continued.	HT	ICT Problem.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage