

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Sep/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	108.748	2476.221	1) Gujrat	10.999	204.053
2) Hydro	7.780	262.594	2) Madhya Pradesh	7.276	72.808
3) Gas	2.190	59.374	3) Chattisgarh	3.780	78.890
Total MSPGCL	118.718	2798.189	4) Maharashtra	147.279	3319.098
B) 1) APLM	58.639	1390.013	5) Goa (Amona)	-1.113	-26.332
2) JSWEL	17.135	398.812	Total	168.221	3648.517
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.565	717.889
4) RPL(AMT)	16.343	359.580	b) Mumbai Drawl	34.454	791.870
5) SWPGPL	5.100	97.997	c) MSEDCL Bilateral *	72.084	1228.483
6) Other IPP	5.350	124.245	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.555	717.680
C) 1) TPCL Thermal	9.840	249.312	Include PX	0.000	0.000
2) TPCL Hydro	4.480	117.889	Standby	0.010	0.210
3) TPCL Gas	0.000	13.433	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.311	197.728	1) MSEDCL	384.571	8501.230
D) STATE			2) Mumbai Discoms	56.085	1370.233
1) Thermal	228.466	5293.908	3) Other Discoms	8.929	198.123
(A1+C1+C4+(B1-B6))			TOTAL STATE	449.585	10069.586
2) Hydro (A2+C2)	12.260	380.483			
3) Gas (A3+B7+C3)	2.190	72.807			
4) Wind	30.049	484.415			
6) SOLAR	8.399	189.455			
TOTAL STATE	281.364	6421.068			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4601	4475	5052	4499
MSPGCL Hydro	209	221	833	173
MSPGCL Gas	90	92	92	93
MSPGCL Total Generation	4900	4788	5977	4765
Central Sector Receipt	8752	7621	6213	5442
WIND	1145	1600	1642	1116
CPP / IPP Thermal	4323	4158	5458	4138
CPP / IPP Gas	0	0	0	0
SOLAR	586	97	0	0
Exchange with Mumbai	-1680	-1648	-1212	-953
MSEDCL DEMAND MET	17609	16206	17678	14224
Load Shedding	0	0	0	0
MSEDCL DEMAND	17609	16206	17678	14224
TPCL GENERATION	529	655	983	496
AEML GENERATION	283	323	461	284
MUMBAI DEMAND	2492	2626	2656	1733
OTHER DISCOM DEMAND	417	410	400	284
STATE DEMAND MET	20518	19242	20734	16241
STATE DEMAND	20518	19242	20734	16241
Frequency (Hz)	50.02	49.94	50.04	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 13:03 Hrs	49.72 Hz at 14:18 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 22/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	8.99	218.21	406	352
Unit 9	9.38	11.98	458	360
Unit 10	9.61	222.15	435	369
Total	27.98	491.69		
Bhusawal				
Unit 3	2.69	47.62	140	80
Unit 4	7.84	180.64	385	280
Unit 5	0.00	37.41	0	0
Total	10.52	265.67		
Parli				
Unit 6	4.03	93.76	213	150
Unit 7	3.88	76.04	205	140
Unit 8	3.56	81.07	170	134
Total	11.47	250.87		
Chandrapur				
Unit 3	3.09	63.25	159	120
Unit 4	3.04	65.66	155	116
Unit 5	5.86	115.24	285	205
Unit 6	6.52	120.18	310	235
Unit 7	7.17	122.73	340	235
Unit 8	0.00	49.00	0	0
Unit 9	7.64	205.31	413	273
Total	33.33	741.36		
Paras				
Unit 3	4.12	95.45	230	140
Unit 4	0.00	86.15	0	0
Total	4.12	181.60		
Khaparkheda				
Unit 1	1.86	57.03	120	0
Unit 2	0.00	38.82	0	0
Unit 3	3.26	73.38	170	127
Unit 4	3.17	64.58	162	124
Unit 5	7.20	177.29	400	274
Total	15.49	411.10		
Nasik				
Unit 3	0.00	32.57	0	0
Unit 4	2.96	39.53	139	112
Unit 5	2.87	61.84	134	107
Total	5.83	133.93		
Uran				
All Units	2.19	59.37	94	89
Total	2.19	59.37		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	11.93	0	0
Total	0.00	11.93		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.62	49.48	275	35
Stage 4	1.22	41.32	483	0
Stage 3	0.62	23.99	160	0
Total	3.46	114.79		
Hydro				
KDPH	0.43	4.82	18	18
VTRNA	0.78	16.77	61	0
TILLARI	0.00	10.11	0	0
BHIRA T.R.	0.42	9.08	73	0
SMLHY_PTN	2.69	90.28	120	105
GHATGHAR	0.00	4.81	0	0
Total	4.32	135.87		
Wind				
Total	30.05	484.42	0	0
Total	30.05	484.42		
CPP				
APML(Mus)	58.64	1390.01	0	0
JSWEL(Mus)	17.14	398.81	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	16.34	359.58	0	0
SWPGPL-Mus	5.10	98.00	0	0
Other(Mus)	5.35	124.24	0	0
Total	102.57	2370.65		
SOLAR				
Total	8.40	189.46	0	0
Total	8.40	189.46		
Tata				
Trombay 5	6.57	167.79	380	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	8.68	0	0
Trombay 7B	0.00	4.76	0	0
TATA Hydro	4.48	117.89	426	71
Trombay 8	3.27	81.52	177	132
Total	14.32	380.63		
AEML				
DTPS U-1&2	7.31	197.73	461	283
Total	7.31	197.73		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	108.75	2476.22	MSPGCL Total	118.72	2798.19
			MSPGCL Thml+Gas	110.94	2535.60	Koyna 1,2 & 4 Total	2.84	90.80
			MSPGCL Hydro	7.78	262.59	State Total	281.36	6421.07

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 22/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4344	168	91	4603	1238	4182	0	0	5872	5804	-1039	14459	0	14459	1936	329	16724	50.02
2	4414	171	92	4677	1139	3844	0	0	5663	5755	-967	14141	0	14141	1811	307	16259	50.01
3	4499	173	93	4765	1116	4138	0	0	5377	5442	-953	14224	0	14224	1733	284	16241	50.01
4	4453	175	92	4720	972	4245	0	0	5490	5672	-921	14399	0	14399	1686	289	16374	49.99
5	4633	169	92	4894	962	4268	0	0	5853	6050	-917	14950	0	14950	1703	307	16960	49.98
6	4972	189	92	5253	1082	4513	0	0	6559	6684	-981	16232	0	16232	1833	319	18384	49.97
7	5019	512	93	5624	1099	5070	0	37	6914	7202	-1132	17540	0	17540	2007	360	19907	49.98
8	4894	207	92	5193	1102	4887	0	223	8089	8117	-1354	17778	0	17778	2210	390	20378	50.02
9	4601	209	90	4900	1145	4323	0	586	8361	8752	-1680	17609	0	17609	2492	417	20518	50.02
10	4306	258	90	4654	1107	4237	0	956	8094	8690	-1914	17317	0	17317	2715	413	20445	50.01
11	4205	383	89	4677	1053	3959	0	1038	7753	8612	-2028	16909	0	16909	2835	402	20146	49.98
12	4243	585	89	4917	1051	3749	0	1219	7463	7837	-2054	16333	0	16333	2859	386	19578	50.01
13	4415	461	90	4966	1008	3858	0	1178	7231	7183	-2017	15776	0	15776	2785	400	18961	50.04
14	4260	303	89	4652	1135	3734	0	1143	7307	7204	-1848	15626	0	15626	2634	394	18654	50.06
15	4254	273	89	4616	1056	3601	0	927	7620	7701	-1809	15695	0	15695	2629	397	18721	49.92
16	4301	220	90	4611	1334	3949	0	635	7479	7544	-1773	15898	0	15898	2651	402	18951	50.01
17	4301	219	91	4611	1538	4190	0	354	7686	7345	-1616	16017	0	16017	2580	405	19002	50.02
18	4475	221	92	4788	1600	4158	0	97	7595	7621	-1648	16206	0	16206	2626	410	19242	49.94
19	5025	921	92	6038	1713	4800	0	6	6765	6811	-1487	17476	0	17476	2673	405	20554	49.98
20	5052	833	92	5977	1642	5458	0	0	6176	6213	-1212	17678	0	17678	2656	400	20734	50.04
21	4688	364	92	5144	1544	4705	0	0	6835	6825	-1378	16444	0	16444	2498	396	19338	50.03
22	4648	342	92	5082	1539	4343	0	0	6577	6803	-1370	16003	0	16003	2335	394	18732	50.00
23	4433	258	92	4783	1512	4290	0	0	6152	6446	-1246	15412	0	15412	2170	373	17955	50.00
24	4313	166	94	4573	1362	4066	0	0	5871	5908	-1110	14448	0	14448	2028	351	16827	49.99
MUs	108.75	7.78	2.19	118.72	30.05	102.57	0.00	8.40	164.78	168.22	-34.45	384.57	0.00	384.57	56.08	8.93	449.59	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 22/Sep/2022

Position as on 6.30 Hrs of 23/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	14/09/2022	05:36		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	14/09/2022	05:50		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	14/09/2022	21:39		Continued.	ID Fan Problem	25/09/2022
MSPGCL	Khaparkheda Unit 2	210	17/09/2022	13:00		Continued.	wet coal	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59		Continued.	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	29/09/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Sep/2022

Position as on 6.30 Hrs of 23/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 5	500	19/09/2022	22:30	23/09/2022	17:18	Boiler Tube Leakage	24/09/2022
MSPGCL	Khaparkheda Unit 1	210	22/09/2022	09:09	22/09/2022	16:14	Furnace Pressure High	22/09/2022
MSPGCL	Khaparkheda Unit 3	210	23/09/2022	22:04		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 23/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY - 705 OF EKTUNI-AKOLA II ckt-1 @ EKTUNI	IntraState	22/09/2022	10:54	22/09/2022	19:31	PO	Diagnostic Testing of CB & Routine Maintenance
400 KV TIEBAY Outages/Trippings							
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	13/09/2022	21:00		Continued.	T	Reason awaited
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KORADI 2-WARDHA (PG)	InterState	21/09/2022	08:55		Continued.	PO	Diversion of 400 kV Koradi-Wardha Line through 6 nos of Newly constructed tower of POWERGRID. Configuration of 400 kV Koradi Bays at Wardha shall remain the same. MSETCL 400 kV IEPL-Warora Line shall be in non- A/R Mode for safety precautions
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38	22/09/2022	10:10	T	Y Phase Ground Fault
KHADKA-AURANGABAD (WALUJ)	IntraState	21/09/2022	21:52	22/09/2022	09:12	HT	For Voltage control
LONIKAND I - KOYNA STAGE-IV	IntraState	22/09/2022	09:45	22/09/2022	17:40	PO	PID Faulty disc insulator replacement work & Cold line washing work
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	22/09/2022	11:16	22/09/2022	18:59	PO	Cold Line Washing work to be carried out in view of frequent tripping of line.
KHADKA-AURANGABAD (WALUJ)	IntraState	22/09/2022	19:39	23/09/2022	08:50	HT	HT for Overvoltage Control
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	23/09/2022	09:15	23/09/2022	18:53	PO	Cold Line Washing work to be carried out in view of frequent tripping of line.
CHANDRAPUR-PARLI CKT-3	IntraState	23/09/2022	10:27	23/09/2022	18:36	PO	Hardware Tightening & Fitting Work
LONIKAND I -JEJURI	IntraState	23/09/2022	18:46	23/09/2022	21:45	EO	For Attending hot spot on R-ph 29C PGI of 400kV Jejuri Bay (Temp � 107 ˚C)
KHADKA-AURANGABAD (WALUJ)	IntraState	23/09/2022	20:16		Continued.	HT	HT for Overvoltage Control
400 KV ICT Outages/Trippings							
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	22/09/2022	10:30	22/09/2022	21:40	PO	Annual bay Maintenance and Testing Work
400/220/33 KV 315 MVA ICT - 2 @ KORADI	IntraState	22/09/2022	11:41	22/09/2022	19:16	PO	Testing and commissioning work of New 400kV Siemens make CB for ICT-2 HV
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	23/09/2022	09:45	23/09/2022	17:22	PO	For attending hot spot at R ph BPI clamp of spare ICT which is now in service through RRS for ICT-I .Temp-150 degree, Also Tan delta & capacitance measurement of 400 kV & 220 kv CTs,winding,bushing of ICTs.
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ BABHALESHWAR	IntraState	22/09/2022	11:53	22/09/2022	19:23	PO	Testing of BUS BAR Protection
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	23/09/2022	13:17	23/09/2022	17:57	EO	Rectification work of hot spots and damaged
EKLAHARE (OCR) - PADGHE	IntraState	19/09/2022	08:40		Continued.	HT	H/T TO CONTROL LINE LOADING OF BBLR
MAHALAXMI - BACKBAY	IntraState	22/09/2022	00:34	22/09/2022	02:00	PO	FOR RELAY TESTING

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 23/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY - CARNAC - 7	IntraState	22/09/2022	08:43	22/09/2022	12:45	PO	for 220 KV breaker pole removal of Trombay Carnac-7
BUS SECTIONIZER @ BIDRI	IntraState	22/09/2022	09:00	22/09/2022	12:08	PO	For CB timing, CRM & tan delta testing work
MUMEWADI -HALKARNI 1 LINE	IntraState	22/09/2022	09:45	22/09/2022	13:28	PO	For TAN DELTA Testing of CT,Relay testing & Bay equip.Maintenance Work.
KARAD - NERLE	IntraState	22/09/2022	10:11	22/09/2022	17:09	PO	For attending hot spot at R ph wave trap Bottom palm(Temp-120degree),R ph 29D Isolator palm towards Cb side temp-126 degree. Also as per instructions of Hon ED(Operation),Demo is arranged for various testing kits by M/s MKS ,Bangaluru on 22.09.2022 at EHV PC O&M Zone, Karad
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	IntraState	22/09/2022	13:22	22/09/2022	18:17	PO	Half yearly maintenance
BHIRA - KARANJADE 8	IntraState	22/09/2022	13:25	22/09/2022	16:39	PO	CVT and relay testing work at Bhira generating station
MUMEWADI -HALKARNI 2 LINE	IntraState	22/09/2022	14:20	22/09/2022	17:22	PO	For TAN DELTA Testing of CT,Relay testing & Bay equip.Maintenance Work.
TALANDGE - BIDRI	IntraState	23/09/2022	09:15	23/09/2022	17:44	PO	For CB timing, CRM & Tan delta testing
EKLAHARA(OCR)-RAYMOND	IntraState	23/09/2022	10:34	23/09/2022	12:50	EO	To attend red hot
SATANA - GANGAPUR	IntraState	23/09/2022	10:36	23/09/2022	10:56	T	TRIPPED ON DISTANCE PROTECTION
CREEK SIDE BUS @ KALWA	IntraState	23/09/2022	11:26	23/09/2022	18:08	PO	Routine Maintenance works.
BAPGAON - KALWA	IntraState	23/09/2022	12:15	23/09/2022	14:05	EO	Shifting of 220KV Bapgaon-Kalwa line on TBC Bay for own 245Kv CB Y Phase top palm nut-bolt hotspot attending work.
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	23/09/2022	16:36	23/09/2022	17:02	EO	RAISING SF6 GAS PRESSURE
CHINCHWAD-2 - TELCO	IntraState	23/09/2022	22:20		Continued.	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to theconstruction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
CHAKAN - CHINCHWAD 2	IntraState	23/09/2022	22:35		Continued.	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to theconstruction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33KV 25MVA TF NO.2 @ SAYNE	IntraState	15/09/2022	15:40		Continued.	PO	Work of Replacement of 220/33kv 25 MVA TF2 by 220/33kv 50MVA BHEL TF
220/132-110KV 200MVA ICT 2 @ MIRAJ	IntraState	21/09/2022	10:00	22/09/2022	15:10	PO	OLTC Overhauling work
220/33 KV 125MVA TF-3 @ BORIVALI (AEML)	IntraState	21/09/2022	10:23	22/09/2022	01:08	PO	33kv Cable connection at TR-3 end and Sw. No. 10 & Stability test.
220/33KV 50MVA PTR 1 @ KURKUMBH	IntraState	22/09/2022	09:05	22/09/2022	12:47	PO	RELAY TESTING & DIAGNOSTIC TESTING WORK.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 22/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 23/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33 KV 25MVA PTR NO 2 @ BHIGWAN	IntraState	22/09/2022	10:00	22/09/2022	13:09	PO	MAINTENANCE WORK
220/33KV 50MVA PTR -2 @ KURKUMBH	IntraState	22/09/2022	13:11	22/09/2022	16:45	PO	RELAY TESTING & DIAGNOSTIC TESTING WORK
220/132KV 100MVA PTR 2 @ KHAREPATAN	IntraState	22/09/2022	16:35	23/09/2022	06:45	T	ICT 1 bursted due to which cable of ICT 2 was also burnt
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/22 KV 50 MVA PTR 2 @ ANANDNAGAR	IntraState	23/09/2022	10:00	23/09/2022	19:55	PO	PTR 2 Diagnostics testing work
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	IntraState	23/09/2022	10:02	23/09/2022	18:30	PO	Quarterly Maintenance Work
220/22 KV 50 MVA PTR 2 @ MAHAD	IntraState	23/09/2022	10:32	23/09/2022	13:50	PO	Hotspot attending work & Diagnostic testing work.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	23/09/2022	14:42	23/09/2022	15:39	EO	Loc No:56 (Moverment of Crane under the 110KV line for 400KV Tower Erection work in Mankhurd)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage