

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Oct/2021 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	132.361	2644.910	1) Gujrat	-2.769	-191.295
2) Hydro	19.081	553.433	2) Madhya Pradesh	15.328	181.919
3) Gas	4.611	109.727	3) Chattisgarh	7.310	107.900
Total MSPGCL	156.053	3308.070	4) Maharashtra	152.324	3209.305
B) 1) APML	55.288	1253.179	5) Goa (Amona)	-1.317	-24.283
2) JSWEL	14.634	399.948	Total	170.876	3283.546
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.605	576.234
4) RPL(AMT)	19.154	346.845	b) Mumbai Drawl	32.368	598.844
5) SWPGPL	5.668	117.387	c) MSEDCL Bilateral *	43.134	868.443
6) Other IPP	9.345	131.204	Include PX	7.562	179.066
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.605	576.120
C) 1) TPCL Thermal	14.101	341.906	Include PX	8.642	78.162
2) TPCL Hydro	2.778	98.561	Standby	0.000	0.114
3) TPCL Gas	3.838	71.908	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.892	232.680	1) MSEDCL	413.015	8560.130
D) STATE			2) Mumbai Discoms	62.977	1343.901
1) Thermal	260.443	5468.059	TOTAL STATE	475.992	9904.031
(A1+C1+C4+(B1-B6))					
2) Hydro	21.859	651.994			
(A2+C2)					
3) Gas	8.449	181.635			
(A3+B7+C3)					
4) Wind	5.421	157.475			
6) SOLAR	8.944	161.320			
TOTAL STATE	305.116	6620.483			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5391	5375	5801	5484
MSPGCL Hydro	452	633	1257	276
MSPGCL Gas	236	224	221	154
MSPGCL Total Generation	6079	6232	7279	5914
Central Sector Receipt	8462	7823	6266	6581
WIND	119	114	232	475
CPP / IPP Thermal	4267	4658	5234	3853
CPP / IPP Gas	0	0	0	0
SOLAR	1204	1000	0	0
Exchange with Mumbai	-1815	-1818	-1219	-1046
MSEDCL DEMAND MET	18316	18009	17792	15777
Load Shedding	0	0	0	0
MSEDCL DEMAND	18316	18009	17792	15777
TPCL GENERATION	833	758	1236	687
AEML GENERATION	500	467	477	335
MUMBAI DEMAND	3148	3043	2932	2068
STATE DEMAND MET	21464	21052	20724	17845
STATE DEMAND	21464	21052	20724	17845
Frequency (Hz)	49.85	49.92	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 13.03 Hrs	49.68 Hz at 11.49 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 22/Oct/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	1.26	64.46	125	0
Unit 7	0.00	0.00	0	0
Unit 8	11.29	256.56	507	454
Unit 9	11.22	184.20	501	452
Unit 10	11.77	168.30	510	460
Total	35.53	673.52		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	7.26	184.76	340	280
Unit 5	7.26	129.44	345	265
Total	14.52	314.20		
Parli				
Unit 6	1.91	1.91	212	0
Unit 7	4.50	95.79	230	158
Unit 8	4.26	91.21	209	152
Total	10.66	188.91		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	3.70	53.36	162	135
Unit 5	9.30	114.55	420	300
Unit 6	0.00	98.28	0	0
Unit 7	9.19	165.12	405	359
Unit 8	10.45	195.74	451	413
Unit 9	10.14	192.67	441	397
Total	42.78	819.72		
Paras				
Unit 3	4.13	93.86	204	145
Unit 4	4.07	37.91	199	140
Total	8.19	131.77		
Khaparkheda				
Unit 1	0.00	44.83	0	0
Unit 2	3.11	68.11	155	115
Unit 3	3.55	75.77	158	139
Unit 4	3.54	77.21	166	127
Unit 5	7.20	170.44	330	280
Total	17.39	436.35		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.27	80.45	180	117
Unit 5	0.00	0.00	0	0
Total	3.27	80.45		
Uran				
All Units	4.61	109.73	243	143
Total	4.61	109.73		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.53	11.16	24	17
Total	0.53	11.16		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.10	116.45	480	35
Stage 4	6.51	219.28	1000	0
Stage 3	2.19	72.26	240	0
Total	12.80	408.00		
Hydro				
KDPH	0.43	0.65	18	18
VTRNA	0.00	4.15	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.20	7.01	77	0
SMLHY_PTN	5.18	121.09	222	208
GHATGHAR	0.48	12.54	125	0
Total	6.28	145.44		
Wind				
Total	5.42	157.48	0	0
Total	5.42	157.48		
CPP				
APML(Mus)	55.29	1253.18	0	0
JSWEL(Mus)	14.63	399.95	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.15	346.84	0	0
SWPGPL-Mus	5.67	117.39	0	0
Other(Mus)	9.34	131.20	0	0
Total	104.09	2248.56		
SOLAR				
Total	8.94	161.32	0	0
Total	8.94	161.32		
Tata				
Trombay 5	9.30	230.08	477	285
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.37	43.17	114	67
Trombay 7B	1.47	28.74	66	52
Trombay 8	4.80	111.83	220	167
TATA Hydro	2.78	98.56	377	0
Total	20.72	512.38		
AEMIL				
DTPS U-1&2	9.89	232.68	501	315
Total	9.89	232.68		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	132.36	2644.91	MSPGCL Total	156.05	3308.07
			MSPGCL Thml+Gas	136.97	2754.64	Koyna 1,2 & 4 Total	10.61	335.73
			MSPGCL Hydro	19.08	553.43	State Total	305.12	6620.48

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 22/Oct/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5465	313	144	5922	478	3901	0	0	6607	6779	-1233	15847	0	15847	2392	18239	50.00
2	5488	284	144	5916	514	3884	0	0	6422	6573	-1048	15839	0	15839	2218	18057	49.99
3	5484	276	154	5914	475	3853	0	0	6631	6581	-1046	15777	0	15777	2068	17845	49.99
4	5580	322	146	6048	394	3828	0	0	6604	6742	-995	16017	0	16017	1980	17997	50.00
5	5537	531	145	6213	367	3812	0	0	6570	6704	-971	16125	0	16125	1948	18073	49.99
6	5547	1297	145	6989	328	3875	0	0	6675	7250	-978	17464	0	17464	1997	19461	49.86
7	5710	1917	156	7783	240	3867	0	31	6870	6943	-917	17947	0	17947	2059	20006	49.98
8	5690	1954	145	7789	239	3790	0	273	7150	7458	-1056	18493	0	18493	2224	20717	50.04
9	5430	1450	143	7023	161	3858	0	647	7623	7831	-1439	18081	0	18081	2513	20594	50.05
10	5455	885	230	6570	167	3851	0	1068	8158	8284	-1734	18206	0	18206	2802	21008	50.06
11	5236	953	229	6418	136	3949	0	1043	8321	8525	-1757	18314	0	18314	3044	21358	50.03
12	5391	452	236	6079	119	4267	0	1204	8462	8462	-1815	18316	0	18316	3148	21464	49.85
13	5215	877	226	6318	54	4077	0	1207	8192	7996	-1783	17869	0	17869	3124	20993	49.90
14	5331	706	225	6262	91	4470	0	1188	7711	7376	-1647	17740	0	17740	2986	20726	50.01
15	5375	633	224	6232	114	4658	0	1000	7801	7823	-1818	18009	0	18009	3043	21052	49.92
16	5491	806	225	6522	87	4716	0	774	7599	7601	-1801	17899	0	17899	3105	21004	49.98
17	5623	788	236	6647	127	4752	0	415	7309	7164	-1514	17591	0	17591	3053	20644	49.96
18	5585	754	227	6566	156	4958	0	86	6914	6730	-1390	17106	0	17106	3004	20110	49.97
19	5815	890	229	6934	210	5182	0	8	6483	6577	-1290	17621	0	17621	2997	20618	49.96
20	5801	1257	221	7279	232	5234	0	0	6210	6266	-1219	17792	0	17792	2932	20724	50.03
21	5672	592	241	6505	228	4993	0	0	6181	6224	-1154	16796	0	16796	2743	19539	49.99
22	5552	350	243	6145	186	4746	0	0	6326	6277	-1226	16128	0	16128	2608	18736	49.98
23	5442	403	154	5999	148	4748	0	0	6151	6379	-1243	16031	0	16031	2520	18551	50.02
24	5446	391	143	5980	170	4820	0	0	6279	6331	-1294	16007	0	16007	2469	18476	49.99
MUs	132.36	19.08	4.61	156.05	5.42	104.09	0.00	8.94	169.25	170.88	-32.37	413.01	0.00	413.01	62.98	475.99	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Oct/2021

Position as on 6.30 Hrs of 23/Oct/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Parli Unit 6	250	26/08/2021	21.06	22/10/2021	03.20	Annual Overhaul	
MSPGCL	Chandrapur Unit 3	210	04/09/2021	23.58		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 6	500	17/10/2021	18.40		Continued.	Boiler Tripped On Total Air Flow less than 30%.(Converted to AOH 00:00 hrs 18.10.2021)	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	SWPGPL U-4	135	05/08/2021	03.04		Continued.	Turbine Vibration High.	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Bhusawal Unit 3	210	18/09/2021	03.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 5	210	19/09/2021	20.50		Continued.	Coal Shortage.	
IPP	RPL(AMT) U-2	270	29/09/2021	01.15		Continued.	Coal Shortage	
IPP	RPL(AMT) U-1	270	05/10/2021	22.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	14/10/2021	22.04		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 1	210	17/10/2021	14.14		Continued.	Poor Coal Receipt.	
MSPGCL	Koradi Unit 6	210	22/10/2021	08.08	22/10/2021	14.20	Turbine governing problem.	
MSPGCL	Parli Unit 6	250	22/10/2021	10.19	22/10/2021	11.16	MS TEMP LOW.	
MSPGCL	Koyna Unit 8	80	22/10/2021	12.10	22/10/2021	17.40	Replacement of governor oil pump.	
MSPGCL	Parli Unit 6	250	22/10/2021	12.29	22/10/2021	15.40	H2 Gas temp.high	
MSPGCL	Koradi Unit 6	210	22/10/2021	17.21		Continued.	Reheater tube leakage.	
IPP	JSW (J) U4	300	22/10/2021	21.45		Continued.	Due to no schedule.	
MSPGCL	Uran Unit 6	108	22/10/2021	22.22	23/10/2021	08.46	Gas shortage.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Oct/2021

Statement-VII

Position as on 6.30 Hrs of 23/Oct/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Ektuni-Akola II Ckt 2	IntraState	22/10/2021	13.55	23/10/2021	13.02	HT	vEmergency outage required of 765KV-AKOLA (2)-EKTUNI-2 for Reactor changeover activity due to Y-ph Buchholz alarm is persisting in 703 Line Reactor at Ektuni SS.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Chakan Talegaon(Pg)	InterState	21/10/2021	16.20	22/10/2021	01.34	EO	To attend Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	11/10/2021	12.33		Continued.	PO	Height raising/shifting work of S/C 400kv Waluj- Bhusawal line for Samruddhi Mahamarg. ie. 1) Dismantling of loc no. 125 (D+6). 126 (D+6).
Jejuri- Koynastage-IV	IntraState	22/10/2021	01.48	22/10/2021	05.38	PO	Chemical washing of Insulator
Chandrapur-II - Nanded ckt II	IntraState	22/10/2021	15.58	22/10/2021	21.44	HT	To attend Broken Conductor strands between Location No. 87-88 & 95-96.
Jejuri- Koynastage-IV	IntraState	22/10/2021	22.56	23/10/2021	05.37	PO	Reactor chemical washing.
400 KV ICT Outages/Trippings							
400/220 Kv 500 MVA ICT 3 @KOLHAPUR-III (TALANDGE)	IntraState	21/10/2021	17.04	22/10/2021	01.36	PO	Replacement of CB Isolator
400/220 KV 500MVA ICT II @ Nanded	IntraState	21/10/2021	22.00	22/10/2021	00.33	EO	To attend Hot Spot
400/220/33 Kv 500 Mva ICT III @Aurangabad (Waluj)	IntraState	22/10/2021	12.00	22/10/2021	18.53	EO	DIAGNOSTIC TESTING WORK.
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	22/10/2021	14.30	22/10/2021	19.14	EO	Attending Hot Spot
400/220 KV 500MVA ICT II @ Nanded	IntraState	22/10/2021	22.00	22/10/2021	00.33	PO	Attending Hot Spot
400/220 Kv 500 MVA ICT 3 @KOLHAPUR-III (TALANDGE)	IntraState	22/10/2021	22.15	22/10/2021	22.43	HT	Hot spot isolator.
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	23/10/2021	18.06		Continued.	HT	LV CT replacement of R,Y,B due to high Tan D of Y ph.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Boisar Tarapur	InterState	20/10/2021	09.14		Continued.	PO	Line Maintenance work
WARDHA WARDHA (PG) (DEOLI)	InterState	22/10/2021	05.52	22/10/2021	06.15	HT	To Control Overdrawal
BADNERA - WARDHA (PG) (Deoli)	InterState	22/10/2021	05.54	22/10/2021	06.15	HT	To Control Overdrawal
Borivali - Tarapur	InterState	22/10/2021	08.55	22/10/2021	18.37	PO	Line Maintenance work
Khaparkheda-Butibori 3	InterState	22/10/2021	11.54	22/10/2021	17.21	PO	Testing Work
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	16/10/2021	13.34		Continued.	EO	CB Compressor Overhauling Work.
KORADI 2 - KAULEWADA CKT - I	IntraState	21/10/2021	21.33	22/10/2021	06.42	T	Distance Protection
KORADI 2 - KAULEWADA CKT - II	IntraState	21/10/2021	21.33	22/10/2021	23.30	T	Distance Protection
Padghe - Jindal	IntraState	21/10/2021	23.27	22/10/2021	03.02	PO	To attend Hot Spot
Kandalgaon - Pirangut	IntraState	22/10/2021	01.48	22/10/2021	04.47	EO	To attend Hot Spot
Bhugaon-WardhaPG (Deoli)	IntraState	22/10/2021	05.49	22/10/2021	06.11	HT	To Control Overdrawal
WARDHA - WARDHA (PG) (Deoli)	IntraState	22/10/2021	05.52	22/10/2021	06.15	HT	To control over drawal.
Alephata-Pargaon(Kathapur)	IntraState	22/10/2021	08.53	22/10/2021	17.10	PO	245 kv CB poles overhauling work and general maintenance of CB.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Oct/2021

Statement-VII

Position as on 6.30 Hrs of 23/Oct/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Vankuswade - Kdph	IntraState	22/10/2021	09.10	22/10/2021	18.30	PO	245 kV CB poles overhauling work and general maintenance of CB.
Balapur-Akola li	IntraState	22/10/2021	09.14	22/10/2021	17.00	PO	Diagnostic testing work.
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	22/10/2021	09.35	22/10/2021	16.50	PO	maintenance work
Apta - Taloja	IntraState	22/10/2021	09.46	22/10/2021	18.27	PO	Replacement of old deteriorated top & middle phase conductor at Loc no. 638 to 640.
Nagothane - Ipcl	IntraState	22/10/2021	09.54	22/10/2021	19.03	PO	Earth wire replacement work and emergency tree cutting work
Karad - Vita Ckt- I	IntraState	22/10/2021	10.37	22/10/2021	14.21	PO	For extension of New PT Protection core.
Yeotmal- Pusad	IntraState	22/10/2021	12.35	22/10/2021	12.44	EO	Distance Protection
KORADI 2 - KAULEWADA CKT - I	IntraState	22/10/2021	14.33	22/10/2021	22.17	T	Safety point of view.
Kalwa-Salsette-IV	IntraState	23/10/2021	06.00	23/10/2021	09.00	PO	Emergency Tree Trimming.
Butibori-Indorama	IntraState	23/10/2021	07.23	23/10/2021	11.17	T	B/C R PH Burst At Indorama End.
Vankuswade - Kdph	IntraState	23/10/2021	09.10	23/10/2021	15.15	PO	Work Of Providing & Fixing Of double Jumping at various cut point locations.
Badnera - Nandgaonpeth	IntraState	23/10/2021	09.31	23/10/2021	12.56	PO	For Diagnostic Testing & maintenance Work.
Talange-Hamidwada	IntraState	23/10/2021	09.36	23/10/2021	16.52	PO	Quarterly Maintenance Work. Diagnostic Testing.
Trombay Salsette 1 Backbay	IntraState	23/10/2021	10.02	23/10/2021	12.53	PO	Remove Cross Jumpers Provided Earlier For Formation of 220KV Trombay Salsette 2 Dharavi 9 Line.
Trombay-Salsette II	IntraState	23/10/2021	10.11	23/10/2021	13.22	PO	Remove Cross Jumpers Provided Earlier For Formation of 220KV Trombay Salsette 2 Dharavi 9 Line.
karad - Dasgaon	IntraState	23/10/2021	10.43	23/10/2021	13.02	PO	Fixing Of Repair Sleeves at loc no.197 R & 193 B PH.
Nadgaonpeth-Amravati	IntraState	23/10/2021	13.02	23/10/2021	17.09	EO	Diagnostic Testing Work.
Chinchwad-Hinjewadi I	IntraState	23/10/2021	14.54	23/10/2021	23.19	T	Distance Protection
Trombay - Kalwa	IntraState	23/10/2021	20.23		Continued.	HT	E/O outage of bus section-1@trombay to replace jumper of B-ph bus isolator of TATA tie-2.
TROMBAY (M) - TROMBAY (T) CKT -2	IntraState	23/10/2021	20.48		Continued.	HT	E/O outage of bus section-1@trombay to replace jumper of B-ph bus isolator of TATA tie-2.
220 KV ICT Outages/Trippings							
220/22 Kv 50 Mva Cgl Ptr 4 @Kamba	IntraState	22/10/2021	08.25	22/10/2021	17.40	PO	CT Tan delta, Bushing Tan delta, Winding Tan delta, and other bay maintenance activity and 220KV GO CGL make BKR overhauling work by agency.
220/22 Kv 50 Mva Bb Ptr 4 @Temghar	IntraState	22/10/2021	09.59	22/10/2021	16.30	PO	For height raising work of Buffer wall and Diagnostic Testing work.
220/100 Kv 200 MVA ICT-IV@Kalwa	IntraState	22/10/2021	11.07	22/10/2021	21.52	EO	Attending Hot Spot
220/132 Kv 200 Mva Vijai Ict 1 @Eklahre (Gcr)	IntraState	22/10/2021	11.10	22/10/2021	18.31	PO	Replacement of faulty suspension string
220/132 Kv 100 Mva Ict 2 @Paranda	IntraState	22/10/2021	16.20	22/10/2021	19.15	PO	Testing Work
220/132 Kv 100mva Cgl Ptr No 6 @Chinchwad	IntraState	23/10/2021	09.41	23/10/2021	19.48	PO	Diagnostic Testing & half Yearly Maintenance Work Of CT.
220/132 Kv 200 Mva Emco Ict 2	IntraState	23/10/2021	10.40	23/10/2021	15.50	EO	Attending Hot Spot

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 22/Oct/2021

Statement-VII

Position as on 6.30 Hrs of 23/Oct/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
@Raymond (Nasik 2)							
220/132 Kv 100 Mva Cgl lct 1 @Virur	IntraState	23/10/2021	11.15	23/10/2021	13.00	PO	For Reconfirmation Of Tan Delta Values Of LV B-PH Bushing Earlier Measured on DT-28.07.2021 & The value Came 0.659% (Rising Trend).
220/100 Kv 200 MVA ICT-IV@Kalwa	IntraState	23/10/2021	14.33	23/10/2021	17.18	EO	Air leakage HV Side Y phase CB.
220/132 Kv lct 2 200 Mva @Parbhani	IntraState	23/10/2021	15.35	23/10/2021	18.38	HT	LV Side ABT Meter reading not Shown.
220/100kV 200MVA ICT @ Ogalewadi	IntraState	23/10/2021	21.30		Continued.	T	Differential protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage