

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 22/Nov/2021 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 142.551        | 3118.912        | 1) Gujrat                      | -4.517         | -134.699         |
| 2) Hydro            | 10.899         | 236.688         | 2) Madhya Pradesh              | 7.594          | 134.969          |
| 3) Gas              | 3.391          | 115.351         | 3) Chattisgarh                 | 0.000          | 72.220           |
| <b>Total MSPGCL</b> | <b>156.841</b> | <b>3470.951</b> | 4) Maharashtra                 | 158.023        | 3379.589         |
| B) 1) APLM          | 53.043         | 1144.280        | 5) Goa (Amona)                 | -0.959         | -33.934          |
| 2) JSWEL            | 11.950         | 298.019         | <b>Total</b>                   | <b>160.141</b> | <b>3418.145</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 31.565         | 621.511          |
| 4) RPL(AMT)         | 20.345         | 460.602         | b) Mumbai Drawl                | 31.273         | 627.291          |
| 5) SWPGPL           | 7.143          | 156.762         | c) MSEDCL Bilateral *          | 40.196         | 1011.450         |
| 6) Other IPP        | 34.482         | 634.543         | Include PX                     | 4.165          | 213.929          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 31.565         | 621.479          |
| C) 1) TPCL Thermal  | 13.477         | 269.856         | Include PX                     | 17.376         | 369.962          |
| 2) TPCL Hydro       | 5.002          | 84.183          | Standby                        | 0.000          | 0.032            |
| 3) TPCL Gas         | 1.879          | 72.731          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 9.658          | 214.773         | 1) MSEDCL                      | 419.804        | 9396.195         |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 61.289         | 1268.833         |
| 1) Thermal          | 292.649        | 6297.747        | <b>TOTAL STATE</b>             | <b>481.093</b> | <b>10665.028</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 15.901         | 320.871         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 5.270          | 188.082         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 1.691          | 298.802         |                                |                |                  |
| 6) SOLAR            | 5.441          | 141.382         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>320.952</b> | <b>7246.884</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6104                      | 5385                  | 6651                      | 5116                      |
| MSPGCL Hydro             | 315                       | 657                   | 1322                      | 261                       |
| MSPGCL Gas               | 140                       | 135                   | 140                       | 143                       |
| MSPGCL Total Generation  | 6559                      | 6177                  | 8113                      | 5520                      |
| Central Sector Receipt   | 8241                      | 8239                  | 6064                      | 5986                      |
| WIND                     | 37                        | 65                    | 83                        | 69                        |
| CPP / IPP Thermal        | 5501                      | 4834                  | 5903                      | 4850                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 685                       | 606                   | 0                         | 0                         |
| Exchange with Mumbai     | -1597                     | -1394                 | -1232                     | -1137                     |
| <b>MSEDCL DEMAND MET</b> | <b>19426</b>              | <b>18527</b>          | <b>18931</b>              | <b>15288</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 19426                     | 18527                 | 18931                     | 15288                     |
| TPCL GENERATION          | 1073                      | 1072                  | 1154                      | 518                       |
| AEML GENERATION          | 351                       | 500                   | 500                       | 367                       |
| <b>MUMBAI DEMAND</b>     | <b>3021</b>               | <b>2966</b>           | <b>2886</b>               | <b>2022</b>               |
| STATE DEMAND MET         | 22447                     | 21493                 | 21817                     | 17310                     |
| <b>STATE DEMAND</b>      | <b>22447</b>              | <b>21493</b>          | <b>21817</b>              | <b>17310</b>              |
| Frequency (Hz)           | 50.03                     | 49.97                 | 49.96                     | 50.01                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.16 Hz at 05.02 Hrs | 49.8 Hz at 17.55 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 22/Nov/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.24         | 75.62         | 175      | 115      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 14.27        | 159.50        | 630      | 454      |
| Unit 9             | 13.27        | 284.49        | 582      | 435      |
| Unit 10            | 12.66        | 275.05        | 560      | 418      |
| <b>Total</b>       | <b>43.44</b> | <b>794.66</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 70.28         | 0        | 0        |
| Unit 4             | 8.92         | 197.10        | 450      | 280      |
| Unit 5             | 9.00         | 214.34        | 445      | 280      |
| <b>Total</b>       | <b>17.93</b> | <b>481.73</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 53.06         | 0        | 0        |
| Unit 7             | 3.95         | 88.92         | 230      | 137      |
| Unit 8             | 3.97         | 91.27         | 205      | 154      |
| <b>Total</b>       | <b>7.92</b>  | <b>233.25</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.98         | 54.32         | 140      | 117      |
| Unit 4             | 3.07         | 69.26         | 138      | 121      |
| Unit 5             | 7.34         | 177.94        | 330      | 295      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 6.88         | 173.94        | 303      | 248      |
| Unit 8             | 8.98         | 203.59        | 415      | 275      |
| Unit 9             | 8.80         | 210.40        | 421      | 273      |
| <b>Total</b>       | <b>38.04</b> | <b>889.45</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 3.69         | 37.24         | 220      | 134      |
| Unit 4             | 3.72         | 88.20         | 223      | 140      |
| <b>Total</b>       | <b>7.41</b>  | <b>125.44</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.06         | 59.38         | 155      | 120      |
| Unit 2             | 3.12         | 70.76         | 170      | 120      |
| Unit 3             | 3.24         | 71.40         | 155      | 125      |
| Unit 4             | 3.21         | 75.79         | 167      | 121      |
| Unit 5             | 8.64         | 202.23        | 460      | 285      |
| <b>Total</b>       | <b>21.28</b> | <b>479.55</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.01         | 41.06         | 138      | 118      |
| Unit 5             | 3.52         | 73.77         | 186      | 118      |
| <b>Total</b>       | <b>6.53</b>  | <b>114.84</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 3.39         | 115.35        | 153      | 135      |
| <b>Total</b>       | <b>3.39</b>  | <b>115.35</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.09         | 7.08          | 32       | 0        |
| <b>Total</b>       | <b>0.09</b>  | <b>7.08</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 3.51          | 67.58          | 500      | 40       |
| Stage 4         | 1.47          | 32.91          | 467      | 0        |
| Stage 3         | 1.03          | 21.99          | 160      | 0        |
| <b>Total</b>    | <b>6.01</b>   | <b>122.48</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 1.58           | 0        | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.28          | 4.67           | 80       | 0        |
| SMLHY_PTN       | 4.61          | 105.30         | 201      | 182      |
| GHATGHAR        | 0.00          | 2.65           | 0        | 0        |
| <b>Total</b>    | <b>4.89</b>   | <b>114.20</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 1.69          | 298.80         | 0        | 0        |
| <b>Total</b>    | <b>1.69</b>   | <b>298.80</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 53.04         | 1144.28        | 0        | 0        |
| JSWEL(Mus)      | 11.95         | 298.02         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 20.34         | 460.60         | 0        | 0        |
| SWPGPL-Mus      | 7.14          | 156.76         | 0        | 0        |
| Other(Mus)      | 34.48         | 634.54         | 0        | 0        |
| <b>Total</b>    | <b>126.96</b> | <b>2694.21</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 5.44          | 141.38         | 0        | 0        |
| <b>Total</b>    | <b>5.44</b>   | <b>141.38</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 8.58          | 166.39         | 474      | 255      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.03          | 43.58          | 49       | 0        |
| Trombay 7B      | 0.85          | 29.15          | 41       | 0        |
| Trombay 8       | 4.89          | 103.46         | 219      | 167      |
| TATA Hydro      | 5.00          | 84.18          | 442      | 0        |
| <b>Total</b>    | <b>20.36</b>  | <b>426.77</b>  |          |          |
| <b>AEMIL</b>    |               |                |          |          |
| DTPS U-1&2      | 9.66          | 214.77         | 501      | 331      |
| <b>Total</b>    | <b>9.66</b>   | <b>214.77</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 142.55      | 3118.91       | MSPGCL Total        | 156.84      | 3470.95       |
|                |             |         | MSPGCL Thml+Gas | 145.94      | 3234.26       | Koyna 1,2 & 4 Total | 4.98        | 100.50        |
|                |             |         | MSPGCL Hydro    | 10.90       | 236.69        | State Total         | 320.95      | 7246.88       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 22/Nov/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5355        | 241   | 142  | 5738   | 108  | 4849      | 0    | 0     | 6527        | 5999        | -1366                | 15328                 | 0                    | 15328                     | 2268             | 17596           | 50.06         |
| 2                  | 5210        | 234   | 142  | 5586   | 87   | 4832      | 0    | 0     | 6441        | 6185        | -1231                | 15459                 | 0                    | 15459                     | 2122             | 17581           | 50.01         |
| 3                  | 5116        | 261   | 143  | 5520   | 69   | 4850      | 0    | 0     | 6376        | 5986        | -1137                | 15288                 | 0                    | 15288                     | 2022             | 17310           | 50.01         |
| 4                  | 4996        | 234   | 143  | 5373   | 97   | 4863      | 0    | 0     | 6391        | 6198        | -1053                | 15478                 | 0                    | 15478                     | 1924             | 17402           | 49.99         |
| 5                  | 5592        | 244   | 143  | 5979   | 82   | 4986      | 0    | 0     | 6319        | 6148        | -1042                | 16153                 | 0                    | 16153                     | 1899             | 18052           | 50.03         |
| 6                  | 5997        | 256   | 143  | 6396   | 65   | 5027      | 0    | 0     | 6360        | 6373        | -1103                | 16758                 | 0                    | 16758                     | 1955             | 18713           | 50.02         |
| 7                  | 6037        | 819   | 153  | 7009   | 56   | 5041      | 0    | 10    | 6762        | 6586        | -1118                | 17584                 | 0                    | 17584                     | 2028             | 19612           | 49.97         |
| 8                  | 6361        | 787   | 143  | 7291   | 60   | 5783      | 0    | 101   | 6636        | 6528        | -1145                | 18618                 | 0                    | 18618                     | 2199             | 20817           | 50.02         |
| 9                  | 6252        | 366   | 142  | 6760   | 46   | 5855      | 0    | 313   | 7139        | 7096        | -1248                | 18822                 | 0                    | 18822                     | 2499             | 21321           | 50.04         |
| 10                 | 5990        | 605   | 141  | 6736   | 37   | 5491      | 0    | 607   | 7818        | 7758        | -1481                | 19148                 | 0                    | 19148                     | 2812             | 21960           | 49.99         |
| 11                 | 6104        | 315   | 140  | 6559   | 37   | 5501      | 0    | 685   | 8308        | 8241        | -1597                | 19426                 | 0                    | 19426                     | 3021             | 22447           | 50.03         |
| 12                 | 5989        | 308   | 138  | 6435   | 36   | 5148      | 0    | 904   | 8397        | 8181        | -1662                | 19042                 | 0                    | 19042                     | 3073             | 22115           | 50.02         |
| 13                 | 5921        | 470   | 135  | 6526   | 38   | 4952      | 0    | 808   | 7914        | 7631        | -1643                | 18312                 | 0                    | 18312                     | 3045             | 21357           | 50.01         |
| 14                 | 5931        | 334   | 136  | 6401   | 44   | 5048      | 0    | 750   | 7845        | 7287        | -1409                | 18121                 | 0                    | 18121                     | 2936             | 21057           | 50.02         |
| 15                 | 5385        | 657   | 135  | 6177   | 65   | 4834      | 0    | 606   | 8088        | 8239        | -1394                | 18527                 | 0                    | 18527                     | 2966             | 21493           | 49.97         |
| 16                 | 6109        | 277   | 137  | 6523   | 87   | 4932      | 0    | 456   | 7821        | 7487        | -1320                | 18165                 | 0                    | 18165                     | 2975             | 21140           | 49.98         |
| 17                 | 6117        | 658   | 137  | 6912   | 82   | 4986      | 0    | 179   | 7024        | 7082        | -1228                | 18013                 | 0                    | 18013                     | 2927             | 20940           | 49.95         |
| 18                 | 6288        | 713   | 139  | 7140   | 90   | 5529      | 0    | 22    | 6189        | 5953        | -1172                | 17562                 | 0                    | 17562                     | 2844             | 20406           | 49.95         |
| 19                 | 6651        | 1322  | 140  | 8113   | 83   | 5903      | 0    | 0     | 6089        | 6064        | -1232                | 18931                 | 0                    | 18931                     | 2886             | 21817           | 49.96         |
| 20                 | 6696        | 695   | 142  | 7533   | 69   | 5975      | 0    | 0     | 6145        | 5556        | -1137                | 17996                 | 0                    | 17996                     | 2779             | 20775           | 49.98         |
| 21                 | 6372        | 360   | 141  | 6873   | 77   | 5962      | 0    | 0     | 6157        | 5854        | -1231                | 17535                 | 0                    | 17535                     | 2638             | 20173           | 49.97         |
| 22                 | 6109        | 263   | 142  | 6514   | 76   | 5835      | 0    | 0     | 6424        | 5786        | -1393                | 16818                 | 0                    | 16818                     | 2526             | 19344           | 50.00         |
| 23                 | 5954        | 237   | 152  | 6343   | 84   | 5576      | 0    | 0     | 6518        | 5990        | -1443                | 16550                 | 0                    | 16550                     | 2482             | 19032           | 50.02         |
| 24                 | 6019        | 243   | 142  | 6404   | 116  | 5205      | 0    | 0     | 6460        | 5933        | -1488                | 16170                 | 0                    | 16170                     | 2463             | 18633           | 50.00         |
| MUs                | 142.55      | 10.90 | 3.39 | 156.84 | 1.69 | 126.96    | 0.00 | 5.44  | 166.15      | 160.14      | -31.27               | 419.80                | 0.00                 | 419.80                    | 61.29            | 481.09          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 22/Nov/2021**

**Position as on 6.30 Hrs of 23/Nov/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                       | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                        |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 17/10/2021   | 18.40        |            | Continued. | Boiler Tripped On Total Air Flow less than 30%.(Converted to AOH 00:00 hrs 18.10.2021) |               |
| IPP                   | Adani U-4               | 660      | 10/11/2021   | 23.58        |            | Continued. | Capital Overhauling                                                                    |               |
| IPP                   | JSW (J) U2              | 300      | 19/11/2021   | 01.26        |            | Continued. | Zero schedule.                                                                         |               |
| MSPGCL                | Koyna STG-IV Unit-4     | 250      | 22/11/2021   | 09.55        |            | Continued. | Annual Overhaul                                                                        |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                        |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                   |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                   |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                 |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                 |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                  |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                          |               |
| MSPGCL                | Nasik Unit 3            | 210      | 30/08/2021   | 22.51        |            | Continued. | Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021            |               |
| IPP                   | JSW (J) U1              | 300      | 02/09/2021   | 08.41        |            | Continued. | Turbine vibrations high.                                                               |               |
| MSPGCL                | Uran Unit A0            | 120      | 10/09/2021   | 01.54        |            | Continued. | Turbine bearing Vabration high                                                         |               |
| MSPGCL                | Uran Unit 5             | 108      | 07/11/2021   | 23.28        |            | Continued. | Turbine problem.                                                                       |               |
| IPP                   | RPL(AMT) U-4            | 270      | 16/11/2021   | 00.00        |            | Continued. | Coal Shortage                                                                          |               |
| MSPGCL                | Parli Unit 6            | 250      | 17/11/2021   | 14.37        |            | Continued. | Clinker formation                                                                      |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 21/11/2021   | 11.06        |            | Continued. | Withdrawn due to Drum Pressure Sensing line leakage attending work.                    |               |
| MSPGCL                | Uran Unit 6             | 108      | 21/11/2021   | 18.45        | 23/11/2021 | 00.01      | Gas shortage                                                                           |               |
| TPC-G                 | Trombay 7B              | 60       | 22/11/2021   | 22.52        | 23/11/2021 | 03.53      | Gas shortage                                                                           |               |
| TPC-G                 | Trombay 7A              | 120      | 22/11/2021   | 22.58        | 23/11/2021 | 01.01      | Gas shortage                                                                           |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Nov/2021**

**Statement-VII**

Position as on 6.30 Hrs of 23/Nov/2021

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                               |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                |
| Chandrapur - Padghe HvdC Pole 2                   | IntraState                | 22/11/2021   | 16.33        |            | Continued. | PO          | Annual Maintenance Work Of HVDC Pole 2 equipment & line.                                                                                       |
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                       |
| Koradi Bhilai                                     | InterState                | 13/11/2021   | 09.49        |            | Continued. | PO          | Work At Bhilai end.                                                                                                                            |
| Pune(GIS)-A'bad(Waluj) Ckt 1                      | IntraState                | 15/11/2021   | 10.18        |            | Continued. | HT          | To control Mumbai line loading.                                                                                                                |
| Jejuri- Koynastage-IV                             | IntraState                | 22/11/2021   | 22.50        | 23/11/2021 | 01.54      | HT          | Attending Hot Spot                                                                                                                             |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                                |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 22/11/2021   | 09.03        | 22/11/2021 | 15.42      | PO          | Quarterly Maintenance Work                                                                                                                     |
| 400/220/33 Kv 500 MVA ICT-I @Lonikand 2           | IntraState                | 22/11/2021   | 21.04        | 22/11/2021 | 22.34      | EO          | Attending Hot Spot                                                                                                                             |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                                                    |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                                         |
| EKLAHARE (OCR) Nasik - Navsari I                  | InterState                | 22/11/2021   | 09.54        | 22/11/2021 | 16.06      | PO          | Annual Maintenance Work                                                                                                                        |
| REL Borivali Aarey Line                           | IntraState                | 18/11/2021   | 09.20        |            | Continued. | PO          | Under MMRC Line Diversion scheme for Metro-3 project 220kV Outdoor termination of 220kV AEML Aarey and overhead connection at MMRC pylon yard. |
| Sawantwadi-Bidri                                  | IntraState                | 21/11/2021   | 22.08        |            | Continued. | HT          | Over Voltage                                                                                                                                   |
| Wadkhali(GIS)-JSW Cement                          | IntraState                | 22/11/2021   | 08.25        | 22/11/2021 | 10.08      | PO          | For relay testing work.                                                                                                                        |
| Kandalgaon - ONGC Panvel                          | IntraState                | 22/11/2021   | 10.28        | 22/11/2021 | 18.35      | PO          | For replacement of existing earth wire by new OPGW from loc no.603 to 640.                                                                     |
| Dhule - Dondaicha Ckt                             | IntraState                | 22/11/2021   | 10.45        | 22/11/2021 | 18.10      | PO          | Replacement of flashover Disc Insulator string.                                                                                                |
| Walchandnagar-Bhigwan                             | IntraState                | 22/11/2021   | 11.00        | 22/11/2021 | 14.02      | PO          | Replacement of flashover string at loc no. 64.                                                                                                 |
| Eklahara(Gcr)(Nasik)- Bableshtar 2                | IntraState                | 22/11/2021   | 11.48        | 22/11/2021 | 12.37      | T           | Distance Protection                                                                                                                            |
| EKLAHRE (GCR)Nashik-Airoli Knowledge Park         | IntraState                | 22/11/2021   | 11.56        | 22/11/2021 | 12.39      | HT          | H/T only from Nasik end. To control line loading of BBLR-1 ckt.                                                                                |
| Sadawaghapur Karad Ckt 2                          | IntraState                | 22/11/2021   | 12.20        | 22/11/2021 | 14.27      | EO          | trip circuit faulty indication persist. Need to check trip circuit.                                                                            |
| Karad(400kv) -Mudshingi Ckt 2-Tak                 | IntraState                | 22/11/2021   | 12.40        | 22/11/2021 | 13.24      | T           | Distance Protection                                                                                                                            |
| Salsette - Saki 7                                 | IntraState                | 22/11/2021   | 16.55        | 22/11/2021 | 18.54      | T           | Distance Protection                                                                                                                            |
| Pophali - Nerale                                  | IntraState                | 23/11/2021   | 03.05        |            | Continued. | T           | Distance Protection                                                                                                                            |
| <b>220 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                                |
| 220/132-110/11kv 200MVA ICT 1 @Miraj              | IntraState                | 22/11/2021   | 09.36        | 22/11/2021 | 15.22      | PO          | Tan delta measurement of HV & LV bushing, winding & CT Etc.                                                                                    |
| 220/132 Kv 200 MVA ICT-I @Malegaon                | IntraState                | 22/11/2021   | 11.48        | 22/11/2021 | 11.48      | T           | Only H.V side tripped with out indication.                                                                                                     |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage