

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 22/Dec/2021 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	153.453	2990.398	1) Gujrat	-9.266	-155.578
2) Hydro	6.952	162.539	2) Madhya Pradesh	2.903	28.114
3) Gas	5.763	105.073	3) Chattisgarh	6.010	127.920
Total MSPGCL	166.168	3258.010	4) Maharashtra	137.606	2967.019
B) 1) APML	67.280	1318.474	5) Goa (Amona)	-1.196	-36.629
2) JSWEL	12.295	309.444	Total	136.057	2930.846
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.559	543.863
4) RPL(AMT)	26.921	571.052	b) Mumbai Drawl	26.812	589.388
5) SWPGPL	7.681	170.313	c) MSEDCL Bilateral *	50.297	1083.779
6) Other IPP	40.025	820.345	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.559	543.863
C) 1) TPCL Thermal	7.335	176.723	Include PX	0.000	1.590
2) TPCL Hydro	4.831	94.570	Standby	0.000	0.000
3) TPCL Gas	2.153	65.772	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.843	212.791	1) MSEDCL	428.575	8894.617
D) STATE			2) Mumbai Discoms	50.971	1139.238
1) Thermal	324.833	6569.540	3) Other Discoms	9.919	214.910
(A1+C1+C4+(B1-B6))			TOTAL STATE	489.465	10248.765
2) Hydro	11.783	257.109			
(A2+C2)					
3) Gas	7.916	170.845			
(A3+B7+C3)					
4) Wind	1.516	190.701			
6) SOLAR	7.363	129.730			
TOTAL STATE	353.411	7317.925			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	7149	6520	7194	5126
MSPGCL Hydro	261	275	245	233
MSPGCL Gas	232	242	236	241
MSPGCL Total Generation	7642	7037	7675	5600
Central Sector Receipt	7038	6717	5296	5135
WIND	61	62	85	41
CPP / IPP Thermal	6822	6733	6964	5606
CPP / IPP Gas	0	0	0	0
SOLAR	1033	1130	41	0
Exchange with Mumbai	-1404	-1477	-1052	-1006
MSEDCL DEMAND MET	15081	14321	12315	9845
Load Shedding	0	0	0	0
MSEDCL DEMAND	15081	14321	12315	9845
TPCL GENERATION	747	630	977	345
AEML GENERATION	497	485	497	366
MUMBAI DEMAND	2648	2592	2526	1717
OTHER DISCOM DEMAND	359	346	394	325
STATE DEMAND MET	23840	22794	21535	17093
STATE DEMAND	23840	22794	21535	17093
Frequency (Hz)	50.03	49.99	49.98	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 22.01 Hrs	49.76 Hz at 06.26 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 22/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.50	78.88	185	115
Unit 7	0.00	0.00	0	0
Unit 8	14.70	301.59	651	468
Unit 9	15.25	167.92	660	453
Unit 10	13.54	287.54	611	450
Total	46.98	835.93		
Bhusawal				
Unit 3	3.25	42.92	170	115
Unit 4	8.34	189.96	435	280
Unit 5	8.86	190.32	465	280
Total	20.45	423.20		
Parli				
Unit 6	4.25	34.03	250	147
Unit 7	4.26	18.09	248	144
Unit 8	4.12	69.81	205	151
Total	12.63	121.93		
Chandrapur				
Unit 3	3.67	46.63	177	126
Unit 4	3.50	68.72	170	115
Unit 5	7.79	115.03	380	285
Unit 6	8.53	165.98	435	279
Unit 7	7.49	170.36	360	255
Unit 8	8.84	200.49	405	283
Unit 9	9.24	202.60	430	279
Total	49.07	969.81		
Paras				
Unit 3	4.29	94.00	240	140
Unit 4	4.20	95.84	227	137
Total	8.49	189.84		
Khaparkheda				
Unit 1	0.00	24.87	0	0
Unit 2	0.00	25.46	0	0
Unit 3	0.00	27.06	0	0
Unit 4	0.00	20.47	0	0
Unit 5	9.31	209.27	450	277
Total	9.31	307.13		
Nasik				
Unit 3	3.30	37.66	190	119
Unit 4	0.00	33.17	0	0
Unit 5	3.23	71.72	188	117
Total	6.53	142.55		
Uran				
All Units	5.76	105.07	254	225
Total	5.76	105.07		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.46	3.55	40	0
Total	0.46	3.55		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.78	49.17	295	35
Stage 4	0.41	17.74	209	0
Stage 3	0.47	15.61	80	0
Total	2.66	82.52		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.06	0	0
TILLARI	0.00	6.53	0	0
BHIRA T.R.	0.24	5.57	77	0
SMLHY_PTN	4.05	67.86	193	145
GHATGHAR	0.00	0.00	0	0
Total	4.29	80.02		
Wind				
Total	1.52	190.70	0	0
Total	1.52	190.70		
CPP				
APML(Mus)	67.28	1318.47	0	0
JSWEL(Mus)	12.30	309.44	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.92	571.05	0	0
SWPGPL-Mus	7.68	170.31	0	0
Other(Mus)	40.02	820.34	0	0
Total	154.20	3189.63		
SOLAR				
Total	7.36	129.73	0	0
Total	7.36	129.73		
Tata				
Trombay 5	7.34	154.92	449	255
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.18	39.18	49	49
Trombay 7B	0.98	26.60	41	40
Trombay 8	0.00	21.80	0	0
TATA Hydro	4.83	94.57	440	0
Total	14.32	337.06		
AEML				
DTPS U-1&2	9.84	212.79	497	322
Total	9.84	212.79		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	153.45	2990.40	MSPGCL Total	166.17	3258.01
			MSPGCL Thml+Gas	159.22	3095.47	Koyna 1,2 & 4 Total	2.19	66.91
			MSPGCL Hydro	6.95	162.54	State Total	353.41	7317.92

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 22/Dec/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5126	233	241	5600	41	5606	0	0	5356	5135	-1006	15051	0	15051	1717	325	17093	49.98
2	5146	292	253	5691	43	5627	0	0	5310	5279	-923	15427	0	15427	1596	290	17313	49.95
3	5537	221	243	6001	42	5629	0	0	5255	4779	-843	15343	0	15343	1513	265	17121	49.97
4	5736	213	243	6192	39	5563	0	0	5214	5052	-810	15763	0	15763	1477	273	17513	49.99
5	5956	219	252	6427	66	5686	0	0	5305	5013	-812	16080	0	16080	1489	300	17869	49.99
6	6089	220	243	6552	85	6296	0	0	5451	5307	-873	17045	0	17045	1571	322	18938	49.99
7	6706	220	254	7180	49	6805	0	4	5280	5201	-736	18160	0	18160	1686	343	20189	49.88
8	7222	530	242	7994	57	6881	0	71	5513	5446	-775	19324	0	19324	1868	350	21542	49.98
9	7263	308	241	7812	52	6834	0	311	6308	6079	-1014	19694	0	19694	2175	380	22249	50.04
10	6804	439	247	7490	55	6814	0	612	6864	6908	-1152	20363	0	20363	2429	364	23156	50.02
11	7183	691	237	8111	65	6872	0	815	6813	6711	-1349	20868	0	20868	2604	357	23829	50.01
12	7149	261	232	7642	61	6822	0	1033	7025	7038	-1404	20833	0	20833	2648	359	23840	50.03
13	6520	275	242	7037	62	6733	0	1130	7149	6717	-1477	19856	0	19856	2592	346	22794	49.99
14	6093	283	228	6604	61	6661	0	1064	7083	6911	-1490	19466	0	19466	2463	345	22274	50.01
15	6272	292	228	6792	56	6714	0	919	7136	7220	-1541	19799	0	19799	2463	361	22623	50.02
16	6715	328	225	7268	63	6786	0	771	6646	6579	-1445	19657	0	19657	2455	365	22477	49.98
17	6946	301	236	7483	43	6928	0	442	6006	5774	-1252	19053	0	19053	2452	365	21870	49.99
18	7098	247	230	7575	72	6953	0	150	5344	5008	-1018	18376	0	18376	2469	364	21209	50.01
19	7194	245	236	7675	85	6964	0	41	5519	5296	-1052	18615	0	18615	2526	394	21535	49.98
20	7159	335	248	7742	107	6926	0	0	4964	4807	-1158	18033	0	18033	2456	391	20880	49.95
21	6868	204	240	7312	114	6855	0	0	4812	4296	-1179	17012	0	17012	2309	386	19707	50.00
22	5584	203	238	6025	78	6028	0	0	5401	5219	-1163	15816	0	15816	2167	371	18354	50.02
23	5630	205	247	6082	72	5607	0	0	5393	5252	-1211	15451	0	15451	1997	351	17799	50.05
24	5457	187	237	5881	48	5612	0	0	5314	5030	-1129	15114	0	15114	1852	328	17294	50.05
MUs	153.45	6.95	5.76	166.17	1.52	154.20	0.00	7.36	140.46	136.06	-26.81	430.20	0.00	430.20	50.97	8.30	489.47	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 22/Dec/2021

Position as on 6.30 Hrs of 23/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 4	210	08/12/2021	21:00		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 3	210	09/12/2021	00:01		Continued.	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 1	210	09/12/2021	00:56		Continued.	CHP coal feeding problem	
MSPGCL	Nasik Unit 4	210	11/12/2021	21:22		Continued.	withdrawn against case 4 to dhariwal	
MSPGCL	Uran Unit B0	120	23/12/2021	10:45	23/12/2021	23:14	main lubrication oil tank level transmitter fault	
MSPGCL	Uran Unit 8	108	23/12/2021	10:47	23/12/2021	11:30	boiler trip	
MSPGCL	Parli Unit 7	250	23/12/2021	12:50	23/12/2021	15:47	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 22/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 23/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
PARLI(MS) - PARLI (PG) CKT -1	InterState	22/12/2021	12:00	22/12/2021	21:37	PO	For Bay AMP works
AKOLA - KHADKA (BHUSAWAL)	IntraState	11/12/2021	09:34	23/12/2021	19:16	PO	for replacement of 400 KV Damage Main Bus (1&2) section of Akola & Aurangabad bay
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadruple CB. 3) Measurement of Timing, DCRM and CRM of CB.
JAIGAD - KARAD CKT - 2	IntraState	21/12/2021	21:07	22/12/2021	09:44	HT	HT OV
MAIN BUS - 2 @ LAMBOTI	IntraState	22/12/2021	11:35	22/12/2021	17:28	PO	400kV Main Bus II, 406-89B Isolator Alignment Work
JAIGAD - KARAD CKT - 1	IntraState	22/12/2021	22:40	23/12/2021	09:04	HT	Handtripped for controlling system Over voltage
LONIKAND I - KOYNA STAGE-IV	IntraState	22/12/2021	23:29	23/12/2021	08:51	HT	Hand Tripped for controlling System Over voltage
KHADKA-AURANGABAD	IntraState	23/12/2021	07:17		Continued.	PO	For Reconnection of Live 400 KV Main Bus-1&2 section jumpers of 400 KV Akola & Aurangabad section after replacement of damaged bus section
KARAD - LONIKAND I	IntraState	23/12/2021	09:19		Continued.	PO	Distance Protection relay (M-1) replacement under MTAMC Project. Existing relay ABB REL521 & new relay Siemens 7SA52
KARAD - LONIKAND I	IntraState	23/12/2021	09:19		Continued.	PO	PID faulty disc insulator replacement work and cold line washing work
KARAD - LONIKAND I	IntraState	23/12/2021	09:19		Continued.	PO	Half yearly bay maintenance and DT work. Diagnostic testing and maintenance work.
KORADI - KHADKA	IntraState	23/12/2021	09:22	23/12/2021	18:28	PO	For Reconnection of Live 400 KV Main Bus-1&2 section jumpers of 400 KV Akola & Aurangabad section (i.e re-connection of jumpers between Koradi and Aurangabad bay) by Hot line unit Jalgaon for hot man clearance
JAIGAD - KARAD CKT - 2	IntraState	23/12/2021	22:49		Continued.	HT	HT for Overvoltage
400 KV ICT Outages/Trippings							
400/220/33 KV 500 MVA ICT - 2 @ NANDED	IntraState	23/12/2021	12:48	23/12/2021	18:23	PO	ANNUAL BUSHING & WINDING TAN-D AND BAY MAINTENANCE.
220 KV MAINBAY Outages/Trippings							
MAIN BAY(208) OF 220KV-SOLAPUR-FUTURE 1 @SOLAPUR (PG)-220 KV	InterState	20/12/2021	17:22		Continued.	PO	reorientation work along with the disconnection of 220KV Bale-Tuljapur line at Loc.NO. 37 and establishment of link between Solapur PG to 220KV Bale substation will be carried out by utilizing D/C portion of Solapur PG -Bale line and jumpering work at substation end.
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	23/12/2021	22:09		Continued.	EO	Attending hot spot at atloc no.80 (Bottom Y-Ph-Nalasopara side,Temp-106)& (Bottom R-ph PGCIL Side,Temp-115)
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01		Continued.	HT	air leakage in CB

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 22/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 23/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
SOLAPUR(BALE) - TULJAPUR	IntraState	20/12/2021	10:54		Continued.	PO	Outage is required 1. Testing & communication work of line and bay at both substation (Bale & PGCIL) 2. Jumpering work at loc 37 on 220kV PGCIL Bale Line 3. Shifting of WT, CC & LMU (in existing Tuljapur bay) at 220kV Bale Substaion.
PARANDA-BARSHI	IntraState	22/12/2021	09:31	22/12/2021	15:45	PO	Outages is required for Quarterly Maintenance
ADLABS - PEDAMBE	IntraState	22/12/2021	09:57	22/12/2021	18:55	PO	1) Emergency tree cutting at Loc.No.205-206,209-211,233-234,301-302,309-311,325-326,403-406 and other line maintenance work
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	22/12/2021	10:21	22/12/2021	15:35	PO	For replacement of flashover polymer insulator at Loc.No.16-New line (Top phase). Emergency tree cutting and other routine maintenance work.
TROMBAY - MULUND	IntraState	22/12/2021	10:25	22/12/2021	17:47	PO	Online Shifting of 220 kv Trombay line from 220 kV Bus-1 to 220 kV Bus-2 through Center breaker-1 for BUS-1 DEAD Purpose for 220 KV Bus Coupler Isolator BUS-1 Side Isolator Alignment work. And TF-4 29 A isolator Alignment work.
KALWA - MULUND 1	IntraState	22/12/2021	10:25	22/12/2021	17:34	PO	Online Shifting of 220 kv Kalwa-1 line from 220 kV Bus-1 to 220 kV Bus-2 through Center breaker-1 for BUS-1 DEAD Purpose for 220 KV Bus Coupler Isolator BUS-1 Side Isolator Alignment work. And Kalwa-1 line 29 A isolator and TF-4 29 A isolator Alignment work.
RANJANGAON - U TECH SUGAR CKT	IntraState	22/12/2021	10:50	22/12/2021	17:40	T	Distance Protection
MAIN BUS SECTION - 1 @ EKLAHARE (GCR)	IntraState	22/12/2021	12:18	22/12/2021	17:50	PO	for attending hotspot &diagnostic testing work
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	22/12/2021	15:50	23/12/2021	01:37	PO	For routine maintenance work and emergency tree cutting work.
ALKUD - VITA	IntraState	23/12/2021	09:40	23/12/2021	17:40	PO	Providing & fixing of suspension clamps at various locations
PHALTAN MIDC - CSSK BHAVANI NAGAR	IntraState	23/12/2021	10:33	23/12/2021	17:46	PO	REPLACEMENT OF FLASHOVER DISC @ LOC NO.78
KHARGHAR - TOPWORTH	IntraState	23/12/2021	10:53	23/12/2021	18:23	PO	For painting of tower in CBD Belapur creek, providing of OPGW at missing span between Loc.No.655 to 662. Other routine maintenance work.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 22/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 23/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	23/12/2021	22:42		Continued.	T	Distance Trip z-1 15 km from AKP, 7.5 KAmP
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/33 KV 50 MVA PTR 3 @ SONKAR	IntraState	22/12/2021	08:33	22/12/2021	12:40	PO	1.OLTC extra pipe connected for oil sample 2.OLTC Oil Top up 3.Damaged jumper replacement of 33 KV Bus section-3
220/22-22 KV 50 MVA PTR 4 @ MULUND	IntraState	22/12/2021	09:12	22/12/2021	18:17	PO	1. Diagnostic testing work. 2. Transformer painting work
220/33 KV 50 MVA 1 PTR @ SHIRSUPHAL	IntraState	22/12/2021	10:00	22/12/2021	14:25	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK
220/22 KV 50 MVA PTR 1 @ WADKHAL (GIS)	IntraState	22/12/2021	10:44	22/12/2021	15:40	PO	For bushing tandelta, SFRA, DFR and renovation of existing earthpit, cold welding for attending oil leakage.
220/33 KV 50 MVA 2 PTR @ SHIRSUPHAL	IntraState	22/12/2021	14:40	22/12/2021	17:40	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK
220/22 KV 50 MVA PTR 2 @ WADKHAL (GIS)	IntraState	22/12/2021	15:52	22/12/2021	19:06	PO	For Bushing tandelta, SFRA, DFR and renovation of existing earthpit, cold welding for attending oil leakage.
220/22-22 KV 50 MVA PTR 4 @ MULUND	IntraState	23/12/2021	09:22	23/12/2021	18:25	PO	1. Diagnostic testing work. 2. Transformer painting work
220/132 KV 200MVA ICT NO 1 @ THEUR	IntraState	23/12/2021	10:30	23/12/2021	18:32	PO	1) Annual maintenance work 2) OLTC diverter switch overhauling work by agency 3) NIFPS CTR maintenance 4) Diagnostic Testing work
220/33KV 50MVA PTR 1 @ KATHAPUR	IntraState	23/12/2021	12:10	23/12/2021	14:10	PO	CT tandelta measurement and Half Yearly Maintenance for T/F no.I and attending redhot at income for T/F no.II
220/33KV 50MVA PTR 2 @ KATHAPUR	IntraState	23/12/2021	14:20	23/12/2021	15:30	PO	CT tandelta measurement and Half Yearly Maintenance for T/F no.I and attending redhot at income for T/F no.II
132 KV LINE Outages/Trippings							
DHARANI - NEPANAGAR	InterState	22/12/2021	11:50	22/12/2021	17:36	PO	Diagnostics Testing & Routine maint.
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	22/12/2021	09:19	22/12/2021	16:06	PO	ATTENDING HOT SPOT

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage