

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Sep/2016 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	57.204	2322.713	1) Gujrat	-3.355	1.397
2) Hydro	8.558	192.258	2) Madhya Pradesh	15.092	216.078
3) Gas	6.464	157.452	3) Chattisgarh	9.660	136.930
Total MSPGCL	72.226	2672.423	4) Maharashtra Net	85.227	1853.856
B) 1) APML	64.557	1344.388	5) Goa (Amona)	-0.504	-12.606
2) JSWEL	19.306	454.893	6) TAPS 1&2 Injection	7.649	176.283
3) VIPL	11.540	258.830	7) RGPPL Injection	10.757	273.565
4) RPL(AMT)	0.000	65.208	8) Pench (MS)	0.867	21.604
5) WPCL	4.287	101.578	9) Pench (Excess)	-0.867	-21.604
6) PGPL	0.000	80.445	Total	123.659	2623.899
7) Other IPP	2.550	58.021	a) Mumbai Schedule	19.459	430.458
C) 1) TPCL Thermal	13.833	282.972	b) Mumbai Drawl	22.679	561.351
2) TPCL Hydro	6.601	118.062	c) MSEDCL Bilateral *	28.878	616.389
3) TPCL Gas	4.054	96.743	Include PX	-1.926	-48.146
4) R-INFRA Thermal	10.127	235.898	d) Mumbai Bilateral *	19.459	429.944
D) STATE			Include PX	0.339	27.651
1) Thermal	183.404	5124.501	Include Standby	0.000	0.514
(A1+C1+C4+(B1-B6))			H) ENERGY CATERED (MUs)		
2) Hydro	15.159	310.320	1) MSEDCL	288.257	7593.628
3) Gas	10.518	334.640	2) Mumbai Discoms	57.294	1295.031
4) Wind	12.058	475.049	TOTAL STATE	345.551	8888.659
6) SOLAR	0.753	20.245			
TOTAL STATE	221.892	6264.755			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	2535	2615	2640	2281
MSPGCL Hydro	632	171	745	221
MSPGCL Gas	276	261	267	267
MSPGCL Total Generation	3443	3047	3652	2769
Central Sector Receipt	5974	5348	5491	4123
WIND	287	201	730	439
CPP / IPP Thermal	4502	4180	4599	4095
CPP / IPP Gas	0	0	0	0
SOLAR	42	113	0	0
Exchange with Mumbai	-946	-1262	-979	-489
MSEDCL DEMAND MET	13302	11627	13493	10937
Load Shedding	0	0	0	0
MSEDCL DEMAND	13302	11627	13493	10937
TPCL GENERATION	1256	1272	1261	713
R-INFRA GENERATION	508	416	506	403
MUMBAI DEMAND	2710	2950	2746	1605
STATE DEMAND MET	16012	14577	16239	12542
STATE DEMAND	16012	14577	16239	12542
Frequency (Hz)	49.98	49.96	50.01	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 18.03 Hrs	49.85 Hz at 09.44 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 23/Sep/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	10.83	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	51.03	0	0
Unit 8	12.93	245.43	660	483
Total	12.93	307.29		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	6.80	0	0
Unit 4	0.00	93.04	0	0
Unit 5	0.00	136.14	0	0
Total	0.00	235.98		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.04	95.84	195	106
Unit 4	4.16	75.91	185	163
Unit 5	8.88	203.60	385	354
Unit 6	0.00	176.83	0	0
Unit 7	9.01	194.16	407	345
Unit 8	0.00	146.45	0	0
Total	26.08	892.80		
Paras				
Unit 3	4.70	96.90	250	0
Unit 4	5.19	107.82	250	186
Total	9.89	204.72		
Khaparkheda				
Unit 1	0.00	45.01	0	0
Unit 2	0.00	62.12	0	0
Unit 3	0.00	70.68	0	0
Unit 4	0.00	68.43	0	0
Unit 5	0.00	225.46	0	0
Total	0.00	471.70		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.14	94.71	198	164
Unit 5	4.15	94.75	194	164
Total	8.30	189.46		
Uran				
All Units	6.46	157.45	286	259
Total	6.46	157.45		
PGPL				
Unit 1	0.00	51.09	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	0.00	29.35	0	0
Total	0.00	80.44		
PENCH (MS)				
Pench (MS)	0.87	21.60	53	20
Total	0.87	21.60		
Koyna				
Stage 1-2	2.38	66.57	415	40
Stage 4	0.24	27.33	107	0
Stage 3	1.74	29.74	160	0
Total	4.35	123.65		
Hydro				
KDPH	0.83	11.85	35	34
VTRNA	0.43	4.13	57	0
TILLARI	0.36	6.88	61	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.46	10.41	80	0
RNGR+BHTSA	0.38	1.81	16	16
BHANDARDRA	0.17	5.69	8	7
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.98	8.12	52	39
Ghatghar	0.59	19.72	250	0
Total	4.20	68.61		
Wind				
Total	12.06	475.05	0	0
Total	12.06	475.05		
CPP				
APML(Mus)	64.56	1344.39	0	0
JSWEL(Mus)	19.31	454.89	0	0
VIPL(Mus)	11.54	258.83	0	0
RPLAMT(Mus)	0.00	65.21	0	0
WPCL(Mus)	4.29	101.58	0	0
Other(Mus)	2.55	58.02	0	0
Total	102.24	2282.92		
SOLAR				
Total	0.75	20.24	0	0
Total	0.75	20.24		
Tata				
Trombay 5	8.74	165.56	480	313
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.52	60.76	120	63
Trombay 7B	1.53	35.98	69	50
Trombay 8	5.09	117.42	241	193
TATA Hydro	6.60	118.06	387	5
Total	24.49	497.78		
R-INFRA				
1-2	10.13	235.90	509	379
Total	10.13	235.90		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
Chandrapur 9	0.00	20.78	MSPGCL Thermal	57.20	2322.71	MSPGCL Total	72.23	2672.42
Koradi 9	0.00	0.00	MSPGCL Thml+Gas	63.67	2480.16	Koyna 1,2 & 4 Total	2.62	93.90
Koradi 10	0.00	0.00	MSPGCL Hydro	8.56	192.26	State Total	221.89	6264.76
Parli 8	0.00	0.00						

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 23/Sep/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2070	221	263	2554	675	4300	0	0	5101	4803	-649	11683	0	11683	1842	13525	49.99
2	2143	216	265	2624	592	4063	0	0	4488	4337	-569	11047	0	11047	1729	12776	49.97
3	2227	231	277	2735	466	3879	0	0	3867	4496	-491	11085	0	11085	1644	12729	49.97
4	2281	221	267	2769	439	4095	0	0	4260	4123	-489	10937	0	10937	1605	12542	49.98
5	2273	221	277	2771	465	4220	0	0	4625	4430	-577	11309	0	11309	1615	12924	49.98
6	2302	221	278	2801	417	4226	0	0	5146	4983	-649	11778	0	11778	1718	13496	49.99
7	2445	303	278	3026	456	4307	0	0	5226	5359	-641	12507	0	12507	1907	14414	49.95
8	2512	429	276	3217	347	4400	0	11	5297	5297	-659	12613	0	12613	2188	14801	49.98
9	2581	412	267	3260	292	4499	0	46	5391	5773	-839	13031	0	13031	2444	15475	49.98
10	2535	632	276	3443	287	4502	0	42	5427	5974	-946	13302	0	13302	2710	16012	49.98
11	2504	858	264	3626	258	4406	0	70	5458	5692	-1185	12867	0	12867	2977	15844	49.99
12	2625	486	269	3380	202	4162	0	97	5446	5319	-1214	11946	0	11946	3005	14951	49.95
13	2615	171	261	3047	201	4180	0	113	5456	5348	-1262	11627	0	11627	2950	14577	49.96
14	2561	157	271	2989	320	4208	0	121	5381	4991	-1330	11299	0	11299	2799	14098	49.97
15	2290	147	260	2697	444	4109	0	104	5281	5300	-1342	11312	0	11312	2828	14140	49.97
16	2263	187	261	2711	695	4119	0	91	5133	5244	-1358	11502	0	11502	2816	14318	49.98
17	2282	147	272	2701	811	4218	0	45	4995	5000	-1325	11450	0	11450	2795	14245	49.95
18	2290	461	265	3016	843	4163	0	13	5105	5065	-1312	11788	0	11788	2772	14560	49.97
19	2490	724	259	3473	856	4399	0	0	5644	5894	-1244	13378	0	13378	2755	16133	49.97
20	2640	745	267	3652	730	4599	0	0	5407	5491	-979	13493	0	13493	2746	16239	50.01
21	2451	407	275	3133	749	4448	0	0	5367	5480	-1008	12802	0	12802	2625	15427	49.96
22	2270	557	264	3091	553	4260	0	0	5215	5533	-992	12445	0	12445	2438	14883	49.97
23	2272	224	286	2782	412	4244	0	0	5042	5114	-851	11701	0	11701	2266	13967	49.97
24	2282	180	266	2728	548	4234	0	0	4456	4613	-768	11355	0	11355	2120	13475	50.01
MUs	57.20	8.56	6.46	72.23	12.06	102.24	0.00	0.75	122.21	123.66	-22.68	288.26	0.00	288.26	57.29	345.55	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Sep/2016

Position as on 6.30 Hrs of 24/Sep/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Koyna Unit 8	80	19/08/2016	11.00		Continued.	High Vibration On LGB & UGB.	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Nasik Unit 3	210	28/08/2016	21.45		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16	
IPP	RPL(AMT) U-2	270	12/09/2016	00.03		Continued.	Zero Schedule by MSEDCL	
PGPL	PGPL U2	126	14/09/2016	00.16		Continued.	Due To No Shedule.	
PGPL	PGPL U1	262	14/09/2016	00.20		Continued.	Due To No Shedule.	
IPP	RPL(AMT) U-1	270	14/09/2016	23.55		Continued.	Zero Schedule by MSEDCL	
IPP	RPL(AMT) U-4	270	15/09/2016	18.09		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Bhusawal Unit 4	500	15/09/2016	23.59		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Bhusawal Unit 3	210	16/09/2016	00.02		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Koradi Unit 7	210	16/09/2016	00.06		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Khaparkheda Unit 1	210	17/09/2016	13.39		Continued.	Zero Schedule by MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Sep/2016

Position as on 6.30 Hrs of 24/Sep/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 2	210	17/09/2016	13.43		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Bhusawal Unit 5	500	17/09/2016	13.51		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Khaparkheda Unit 3	210	17/09/2016	20.40		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Khaparkheda Unit 4	210	17/09/2016	20.48		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Paras Unit 3	250	18/09/2016	14.58	23/09/2016	01.15	Air heater problem	
MSPGCL	Uran Unit 6	108	18/09/2016	23.42		Continued.	Maintenance work	
MSPGCL	Chandrapur Unit-8	500	19/09/2016	18.43		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 6	500	19/09/2016	22.37	23/09/2016	23.53	Boiler Tube Leakage	
MSPGCL	Parli Unit 7	250	22/09/2016	13.47		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Khaparkheda Unit 5	500	22/09/2016	20.48		Continued.	Boiler Tube Leakage	
IPP	JSW (J) U3	300	23/09/2016	10.50	23/09/2016	15.55	G T Tripped.	
IPP	JSW (J) U4	300	23/09/2016	10.50	23/09/2016	13.31	G T Tripped.	
MSPGCL	Koyna Unit 11	80	24/09/2016	03.20		Continued.	Stator Earth Fault	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Sep/2016

Statement-VII

Position as on 6.30 Hrs of 24/Sep/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	19/09/2016	08.38		Continued.	PO	Annual Maintenance Work
Chandrapur - Padghe Hvdc Pole 2	IntraState	23/09/2016	08.40		Continued.	PO	Annual Maintenance Work
400 KV LINE Outages/Trippings							
Dhule Sar'Sarovar II	InterState	20/09/2016	22.04		Continued.	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	22/09/2016	16.09		Continued.	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	23/09/2016	01.43	23/09/2016	06.45	T	Over Voltage
Kolhapur Solapur (PG) II	InterState	23/09/2016	23.57		Continued.	T	Over Voltage
Ektuni-Bableshtar ckt II	IntraState	01/08/2016	09.53		Continued.	HT	To control Padgha-BBLSR L/L
Karad-Jaigad - I	IntraState	16/09/2016	11.27		Continued.	EO	Attending Hot Spot, Line RFC @ 14.19 Hrs.
karad -kolhapur-I	IntraState	17/09/2016	03.43		Continued.	T	Over Voltage,B Pole of Breaker Bust.
Khadka-Aurangabad (Waluj)	IntraState	19/09/2016	15.14		Continued.	HT	Over Voltage
New Koyna - Dabhol-I	IntraState	21/09/2016	09.05		Continued.	PO	String repl.work (RFC 19.02Hrs)
Lonikand I - Koyna stage-IV	IntraState	22/09/2016	23.40	23/09/2016	09.01	HT	Over Voltage
Koradi-Bhusawal	IntraState	23/09/2016	20.18	23/09/2016	20.42	T	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	23/09/2016	23.53		Continued.	HT	Over Voltage
Chandrapur-II - Nanded	IntraState	24/09/2016	00.39	24/09/2016	07.02	T	Over Voltage
Parly(MS)- Nanded	IntraState	24/09/2016	01.11	24/09/2016	06.34	T	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	20/08/2016	11.06		Continued.	PO	Shifted on TBC, by hot line jumper open for construction of kudus bay ektuni CKT-2 will remain off during this outage period.
400/220/33 Kv 315 MVA ICT I @Babhleshwar	IntraState	23/09/2016	05.22	23/09/2016	09.38	T	Bucholz Protection Optd
400/220kv 315 Mva ICT III @Karad	IntraState	23/09/2016	13.58	23/09/2016	19.03	PO	B Ph Isolator Job Replacement Work.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/09/2016	00.00		Continued.	HT	No schedule from Karnataka(H/T from Talandage end)
Mudshingi - Chikodi	InterState	01/09/2016	00.00		Continued.	HT	No schedule from Karnataka(H/T from Chikodi end)
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Bableshtar- Alephata	IntraState	26/08/2016	20.54		Continued.	HT	Hand tripped.
Deepnagar Bambhori	IntraState	22/09/2016	14.07		Continued.	T	Distance Protection
Colourchem - Temghar	IntraState	23/09/2016	08.20	23/09/2016	12.15	PO	Attending Hot Spot
Pophali - Nerale	IntraState	23/09/2016	08.30	23/09/2016	17.15	PO	Distance Protection
Dhamangaon New - Badnera	IntraState	23/09/2016	08.56	23/09/2016	15.47	PO	Measurment of Breaker Timing.
Kalmeshwar-Pandhurna	IntraState	23/09/2016	10.53	23/09/2016	21.22	PO	Maintenance Work.
Kharghar - Tss Panvel	IntraState	23/09/2016	11.30	23/09/2016	13.40	PO	Line Signature Ananlysis.
chandrapur-Tadali	IntraState	23/09/2016	13.51	23/09/2016	14.71	HT	Sparking on Main Bus Side Isolator.
Ongc Panvel - Tss Panvel	IntraState	23/09/2016	13.55	23/09/2016	20.05	PO	Line Signature Ananlysis.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Sep/2016

Statement-VII

Position as on 6.30 Hrs of 24/Sep/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Hingoli- Girawali	IntraState	23/09/2016	14.10	23/09/2016	21.35	T	Distance Protection
Parli 2 (Girwali)- Parbhani	IntraState	23/09/2016	14.10	23/09/2016	15.15	T	Distance Protection
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	23/09/2016	20.01		Continued.	T	Distance Protection
Kandalgaon - Koyna	IntraState	24/09/2016	00.05		Continued.	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 KV 100MVA ICT @ Kawlewadi	IntraState	23/09/2016	08.38	23/09/2016	19.50	PO	Work of PRV Replacement of ICT.
220/132 Kv 200 Mva Bbl Ict 2 @Beed	IntraState	23/09/2016	09.25	23/09/2016	17.02	T	CLM Alarm Opted & Smoke Detected.
220/132 Kv 200 Mva Cgl Ptr No 5 @Parvati	IntraState	23/09/2016	10.00	23/09/2016	17.25	PO	OLTC Overhauling & CT Tandelata
220/132 Kv 200 Mva Bbl Ict 4 @Padegaon	IntraState	23/09/2016	10.16	23/09/2016	18.06	PO	Half yearly maintenance work
220/132 kv 200MVA ICT II @ Girwali	IntraState	23/09/2016	14.12	23/09/2016	17.34	PO	Oil Topup in OLTC Tank.
220/132 kv 200 MVA ICT- I @ Nanded	IntraState	23/09/2016	14.24	23/09/2016	15.11	PO	Replacement of Damaged Insulator.
132 KV LINE Outages/Trippings							
Raimoha - Pathardi	IntraState	22/09/2016	17.18		Continued.	T	Distance Protection
100 KV LINE Outages/Trippings							
Vasai-Ii - Vasai 2 Line	IntraState	13/08/2016	08.53		Continued.	HT	ICT Problem.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage