

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Feb/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	133.347	3531.022	1) Gujrat	-7.290	-179.746
2) Hydro	28.192	379.369	2) Madhya Pradesh	7.510	132.219
3) Gas	3.613	176.409	3) Chattisgarh	6.460	150.620
Total MSPGCL	165.152	4086.800	4) Maharashtra	195.902	3392.303
B) 1) APLM	46.479	1439.809	5) Goa (Amona)	-1.589	-32.819
2) JSWEL	14.867	332.860	Total	200.993	3462.577
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.433	471.957
4) RPL(AMT)	25.513	623.875	b) Mumbai Drawl	29.150	534.327
5) SWPGPL	9.332	195.665	c) MSEDCL Bilateral *	131.685	1679.254
6) Other IPP	40.404	932.046	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.433	471.360
C) 1) TPCL Thermal	11.230	211.390	Include PX	0.000	0.000
2) TPCL Hydro	4.452	87.055	Standby	0.000	0.597
3) TPCL Gas	0.186	78.820	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.800	189.260	1) MSEDCL	482.206	10752.028
D) STATE			2) Mumbai Discoms	51.818	1100.853
1) Thermal	287.972	7455.927	3) Other Discoms	8.586	191.354
(A1+C1+C4+(B1-B6))			TOTAL STATE	542.610	12044.235
2) Hydro	32.644	466.424			
(A2+C2)					
3) Gas	3.799	255.229			
(A3+B7+C3)					
4) Wind	8.608	208.604			
6) SOLAR	8.594	195.473			
TOTAL STATE	341.617	8581.657			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5597	5459	5783	5456
MSPGCL Hydro	1368	1654	1650	399
MSPGCL Gas	144	152	145	161
MSPGCL Total Generation	7109	7265	7578	6016
Central Sector Receipt	10347	9942	7748	7413
WIND	202	114	455	298
CPP / IPP Thermal	5617	5457	5608	5556
CPP / IPP Gas	0	0	0	0
SOLAR	1166	1075	0	0
Exchange with Mumbai	-1673	-1636	-1217	-797
MSEDCL DEMAND MET	22513	21976	19902	18347
Load Shedding	0	0	0	0
MSEDCL DEMAND	22513	21976	19902	18347
TPCL GENERATION	705	589	1012	397
AEML GENERATION	282	284	283	284
MUMBAI DEMAND	2660	2509	2512	1478
OTHER DISCOM DEMAND	386	369	397	263
STATE DEMAND MET	25559	24854	22811	20088
STATE DEMAND	25559	24854	22811	20088
Frequency (Hz)	49.97	49.98	50.01	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 18.02 Hrs	49.83 Hz at 16.44 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 23/Feb/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.03	86.69	180	140
Unit 7	0.00	0.00	0	0
Unit 8	12.81	316.32	570	474
Unit 9	0.00	268.33	0	0
Unit 10	11.24	288.82	510	449
Total	28.08	960.16		
Bhusawal				
Unit 3	0.00	64.29	0	0
Unit 4	8.87	70.77	395	350
Unit 5	10.70	228.79	490	420
Total	19.56	363.85		
Parli				
Unit 6	3.66	90.37	170	144
Unit 7	3.55	91.18	187	140
Unit 8	3.48	87.02	178	72
Total	10.69	268.57		
Chandrapur				
Unit 3	4.38	63.53	186	170
Unit 4	4.10	53.93	177	150
Unit 5	7.55	169.63	325	287
Unit 6	3.44	123.62	385	0
Unit 7	9.31	191.74	414	352
Unit 8	0.00	213.08	0	0
Unit 9	9.79	228.60	426	390
Total	38.57	1044.13		
Paras				
Unit 3	0.00	104.31	0	0
Unit 4	2.62	105.15	238	0
Total	2.62	209.45		
Khaparkheda				
Unit 1	3.48	74.12	155	130
Unit 2	3.32	45.94	155	130
Unit 3	4.17	88.80	195	140
Unit 4	4.15	78.48	177	166
Unit 5	10.96	244.39	490	420
Total	26.08	531.75		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.15	81.26	190	140
Unit 5	3.58	71.86	171	125
Total	7.74	153.12		
Uran				
All Units	3.61	176.41	163	141
Total	3.61	176.41		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.30	5.01	41	0
Total	0.30	5.01		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.28	67.64	440	35
Stage 4	12.34	92.47	989	0
Stage 3	3.48	34.60	240	0
Total	20.10	194.70		
Hydro				
KDPH	0.43	13.64	18	18
VTRNA	0.00	14.56	0	0
TILLARI	0.52	10.79	58	0
BHIRA T.R.	0.20	4.64	77	0
SMLHY_PTN	6.93	131.26	294	276
GHATGHAR	0.00	9.79	0	0
Total	8.09	184.67		
Wind				
Total	8.61	208.60	0	0
Total	8.61	208.60		
CPP				
APML(Mus)	46.48	1439.81	0	0
JSWEL(Mus)	14.87	332.86	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.51	623.88	0	0
SWPGPL-Mus	9.33	195.66	0	0
Other(Mus)	40.40	932.05	0	0
Total	136.60	3524.26		
SOLAR				
Total	8.59	195.47	0	0
Total	8.59	195.47		
Tata				
Trombay 5	7.50	127.24	400	259
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.11	47.96	45	0
Trombay 7B	0.08	30.86	38	0
TATA Hydro	4.45	87.06	426	0
Trombay 8	3.73	84.15	220	130
Total	15.87	377.26		
AEMIL				
DTPS U-1&2	6.80	189.26	286	282
Total	6.80	189.26		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	133.35	3531.02	MSPGCL Total	165.15	4086.80
			MSPGCL Thml+Gas	136.96	3707.43	Koyna 1,2 & 4 Total	16.62	160.11
			MSPGCL Hydro	28.19	379.37	State Total	341.62	8581.66

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 23/Feb/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5359	343	160	5862	400	5673	0	0	7770	7416	-930	18121	0	18121	1695	300	20116	49.99
2	5553	343	151	6047	343	5689	0	0	7452	7334	-819	18312	0	18312	1584	282	20178	49.99
3	5539	350	151	6040	350	5684	0	0	7447	7487	-804	18473	0	18473	1504	284	20261	50.00
4	5456	399	161	6016	298	5680	0	0	7474	7413	-797	18347	0	18347	1478	263	20088	49.96
5	5464	603	151	6218	411	5662	0	0	7660	7609	-797	18808	0	18808	1476	295	20579	50.02
6	5425	1433	161	7019	476	5667	0	0	7719	7559	-901	19483	0	19483	1583	337	21403	50.03
7	5434	1559	152	7145	629	5769	0	0	8262	7995	-784	20400	0	20400	1741	354	22495	50.00
8	5456	1649	163	7268	574	5759	0	117	8787	8666	-778	21216	0	21216	1948	390	23554	50.00
9	5531	2041	151	7723	373	5801	0	458	8000	8271	-973	21260	0	21260	2230	393	23883	50.03
10	5531	1531	149	7211	482	5738	0	807	9532	9688	-1223	22319	0	22319	2459	384	25162	50.01
11	5567	1143	156	6866	311	5735	0	1049	10365	10451	-1537	22474	0	22474	2647	401	25522	50.02
12	5597	1368	144	7109	202	5748	0	1166	10394	10347	-1673	22513	0	22513	2660	386	25559	49.97
13	5528	1375	143	7046	125	5727	0	1231	10149	9682	-1685	21750	0	21750	2624	376	24750	49.99
14	5538	1441	143	7122	107	5613	0	1101	9726	9802	-1615	21748	0	21748	2494	382	24624	50.01
15	5459	1654	152	7265	114	5585	0	1075	9868	9961	-1636	21995	0	21995	2509	369	24873	49.98
16	5465	1825	143	7433	94	5579	0	830	9922	9959	-1664	21864	0	21864	2542	367	24773	49.98
17	5479	1721	141	7341	126	5643	0	533	9272	8898	-1431	20729	0	20729	2554	381	23664	49.96
18	5552	1646	144	7342	134	5683	0	213	8320	8211	-1290	19897	0	19897	2528	396	22821	50.01
19	5694	1415	142	7251	251	5721	0	14	7615	7445	-1201	19087	0	19087	2500	394	21981	49.99
20	5783	1650	145	7578	455	5735	0	0	7864	7748	-1217	19902	0	19902	2512	397	22811	50.01
21	5754	968	154	6876	537	5756	0	0	7567	7562	-1379	18967	0	18967	2373	385	21725	49.99
22	5742	664	148	6554	629	5669	0	0	7269	7404	-1446	18442	0	18442	2216	368	21026	49.98
23	5744	655	149	6548	617	5624	0	0	7030	7152	-1347	18241	0	18241	2055	353	20649	49.97
24	5697	416	159	6272	570	5655	0	0	7204	7167	-1223	18093	0	18093	1906	348	20347	50.01
MUs	133.35	28.19	3.61	165.15	8.61	136.60	0.00	8.59	202.67	201.23	-29.15	482.44	0.00	482.44	51.82	8.59	542.84	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 23/Feb/2022

Position as on 6.30 Hrs of 24/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
IPP	JSW (J) U4	300	14/02/2022	16:08		Continued.	No Schedule	
IPP	RPL(AMT) U-3	270	16/02/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 6	500	16/02/2022	23:20	23/02/2022	11:25	Turbine bearing Vibration high	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-2	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Koyna Unit 9	80	19/02/2022	10:50		Continued.	Stator Earth Fault	
MSPGCL	Bhusawal Unit 3	210	20/02/2022	22:03		Continued.	Coal Shortage	
MSPGCL	Uran Unit 6	108	21/02/2022	00:37		Continued.	Gas shortage	
IPP	Adani U-2	660	21/02/2022	01:11		Continued.	APH-B support bearing abnormal sound	
MSPGCL	Chandrapur Unit 8	500	21/02/2022	04:40	24/02/2022	06:09	Furnace Pressure High	
MSPGCL	Koradi Unit 9	660	21/02/2022	12:42		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit A0	120	21/02/2022	21:57		Continued.	Gas shortage	
MSPGCL	Uran Unit 5	108	21/02/2022	21:57		Continued.	Gas shortage	
MSPGCL	Paras Unit 3	250	22/02/2022	15:45		Continued.	Boiler Tube Leakage	
IPP	Adani U-5	660	22/02/2022	22:14	24/02/2022	07:35	Furnace Pressure High	
TPC-G	Trombay 7B	60	23/02/2022	02:12		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Feb/2022

Position as on 6.30 Hrs of 24/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 7A	120	23/02/2022	02:22		Continued.	Gas shortage	
MSPGCL	Paras Unit 4	250	23/02/2022	13:45		Continued.	Boiler Tube Leakage	
MSPGCL	Parli Unit 8	250	24/02/2022	01:00		Continued.	Coal Shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 23/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 24/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Tripping							
MAIN BAY (710) OF TIRORA CKT - 1 @ KORADI 3	IntraState	24/02/2022	09:23			PO	Annual Maintenance of Bay Equipments
400 KV TBC Outages/Tripping							
TBC @ LONIKAND	IntraState	22/02/2022	12:30			EO	400 kV B ph CT replacement due to oil leakage.
400 KV LR Outages/Tripping							
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	23/02/2022	10:15	23/02/2022	19:40	PO	retrofitting of line reactor trip relay (with reset facility)
400 KV LINE Outages/Tripping							
KARAD - SOLAPUR (PG)	InterState	22/02/2022	08:50				Commissioning of 400 kV 80 MVar Kanohar make line shunt reactor with allied equipments under LE scheme
LAMBOTI - SOLAPUR (PG)	InterState	23/02/2022	09:49	23/02/2022	19:30	PO	Faulty string replacement
THAPTI TANDA - WALUJ	IntraState	01/02/2022	13:01			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
DEEPNAGAR - THAPTI TANDA	IntraState	01/02/2022	13:11			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	04/02/2022	14:43			HT	H/T TO CONTROL 400KV TALEGAON PG -CHAKAN LINE LOADING.
NEW KOYNA - STAGE IV CKT - 2	IntraState	19/02/2022	10:01			PO	C.B. Overhauling work Shitting on TBC
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	23/02/2022	07:21	23/02/2022	18:08	PO	for replacement of polymer insulator by Long Rod porcelain insulator.
DHULE- - BABLESHWAR - II	IntraState	23/02/2022	08:49	23/02/2022	12:58	PO	For PG isolator maint work
PADGHE - NAGOTHANE CKT - 2	IntraState	23/02/2022	09:28	23/02/2022	19:47	PO	1) PG isolator replacement work of 29C bus under LES scheme. Yph PG isolator structure is damaged. 2) MTAMC work 3) Bay maint work
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	24/02/2022	07:21			PO	For replacement of polymer Insulator by Porecelain Long Rod Insulator
PADGHE - NAGOTHANE CKT - 2	IntraState	24/02/2022	09:17			PO	1) PG isolator replacement work of 29C bus under LES scheme. Yph PG isolator structure is damaged. 2) MTAMC work 3) Bay maint work
400 KV ICT Outages/Tripping							
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	21/02/2022	11:40			PO	1) ICT Painting Work 2)Diagnostic Testing Work 3) Routine Maintenance Work
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	21/02/2022	11:40	23/02/2022	17:23	PO	220kV CB overhauling work by Online TBC Shifting of 220kV CB

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 24/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 MVA 400/220 KV ICT - II @ CHANDRAPUR 2	IntraState	23/02/2022	09:14	23/02/2022	19:29	PO	Daignostic testing and allied bay maintenance work
220 KV TBC Outages/Trippings							
TBC @ VERSOVA (AEML)	IntraState	23/02/2022	09:08	23/02/2022	17:33		Annual maintenance of TBC. Opportunity availed during outage of Ghodbunder-Versova Line outage.
TBC @ GHODBUNDER	IntraState	23/02/2022	09:18	23/02/2022	16:24		Annual maintenance availing opportunity outage during Outage of 220kV Ghodbunder-Versova Line outage.
TBC @ GHODBUNDER	IntraState	24/02/2022	07:38				Annual maintenance on opportunity outage of 220kV Ghodbunder-Gorai Line outage.
220 KV LINE Outages/Trippings							
JEUR - SOLAPUR PG	InterState	23/02/2022	10:32	23/02/2022	18:23	PO	An outage is required for Quarterly maintenance . During ouatge JEUR - SOLAPUR PG and JEUR - TEMBHURNI LINE CB hand tripped from JEUR END
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
GOREGAON - AAREY CKT - 2	IntraState	15/02/2022	09:20			PO	Under MMRC Line Diversion scheme for Metro-3 project 220kV Outdoor termination of 220kV AEML Aarey and overhead connection at MMRC pylon yard .
BORIVALI - TARAPUR	IntraState	18/02/2022	09:16			PO	1. Dismantling of existing loc.no. 37, erection proposed on loc.37a & 38a. 2.Railway crossing stringing between loc.no.36 & 37a-38a-38
BOISAR II - TARAPUR	IntraState	18/02/2022	09:33			PO	1. Dismantling of existing loc.no. 37, erection proposed on loc.37a & 38a. 2.Railway crossing stringing between loc.no.36 & 37a-38a-38
GHODBUNDER - GORAI	IntraState	20/02/2022	03:56			PO	Project activity 1) Modification / relocation of existing tower no LS 275 to 277 at Mira Road for Metro 09 Project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantliing of existing towers. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable
VERSOVA - GHODBUNDER	IntraState	20/02/2022	04:00			PO	Project activity 1) Modification / relocation of existing tower no LS 275 to 277 at Mira Road for Metro 09 Project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantliing of existing towers. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable
ALKUD - MENDHEGIRI CKT - 2	IntraState	21/02/2022	10:45	23/02/2022	18:25	PO	Line maintenance work by M/s Suzlon
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	22/02/2022	10:16			PO	GETCO WORK. SHIFTING OF EXI. 220KV NAVSARI - NASIK LINE NO 1 & 2 (D/C)CROSSING AT NHSRCL PRO.CH:- 233/720 (EXI. CROSSING CH:- 233/895)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 24/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	22/02/2022	10:17			PO	GETCO WORK. SHIFTING OF EXI. 220KV NAVSARI - NASIK LINE NO 1 & 2 (D/C)CROSSING AT NHRCL PRO.CH:- 233/720 (EXI. CROSSING CH:- 233/895)
TROMBAY - SALSETTE CKT - 1	IntraState	22/02/2022	23:15	23/02/2022	06:09	PO	MERTO-4 WORK
TROMBAY SALSETTE LINE-2	IntraState	22/02/2022	23:15	23/02/2022	06:19	PO	METRO-4 WORK
KALWA SALSETTE - 3	IntraState	23/02/2022	06:28	23/02/2022	08:42	PO	TREE TRIMMING
MAIN BUS - 1 @ AAREY	IntraState	23/02/2022	09:00	23/02/2022	11:00	PO	R phase jumper normalisation of 220kv AEML Aarey to Goregaon Line-2
NEW KOYNA - POPHALI	IntraState	23/02/2022	09:12	23/02/2022	22:08	PO	For replacement of electro mechanical back up relay by siemens numerical relay
VITA - GHATNANDRE	IntraState	23/02/2022	10:40	23/02/2022	16:40	PO	String replacement at various locations
MAIN BUS @ JEUR	IntraState	23/02/2022	11:30	23/02/2022	18:23	PO	An outage is required for Quarterly maintenance
ADLABS - PEDAMBE	IntraState	23/02/2022	11:48	23/02/2022	18:35	PO	1) Fixing of middle & bottom phase cross arms & stringing of conductor of both circuit (erection of new tower at loc no. 92 against old rusted tower) & dismantling of old tower at Loc. No. 92. 2) Loc no. 94, 95, 96 new tower erection against rusted tower.
PEDAMBE-KALAMBANI(TSS)	IntraState	23/02/2022	12:09	23/02/2022	15:44	PO	1) Fixing of middle & bottom phase cross arms & stringing of conductor of both circuit (erection of new tower at loc no. 92 against old rusted tower) & dismantling of old tower at Loc. No. 92. 2) Loc no. 94, 95, 96 new tower erection against rusted tower.
NEW KOYNA - PEDAMBE	IntraState	23/02/2022	14:41	23/02/2022	18:40	T	R-ph 1.22KA 92 KM
KANDALGAON - KOYNA (POPHALI)	IntraState	23/02/2022	14:42	23/02/2022	15:21	T	Overload
LONAND-BARAMATI	IntraState	23/02/2022	14:56	23/02/2022	16:50	HT	Overload
PEDAMBE-KALAMBANI(TSS)	IntraState	23/02/2022	15:55			T	TRIPPED ON DIST. PROTN.
HINJAWADI I- CHINCHWAD	IntraState	23/02/2022	20:32	23/02/2022	23:36	EO	To attend re hot spots observed for Y and B phase mid spans between tower location 158A-159.
TROMBAY SALSETTE LINE-2	IntraState	23/02/2022	23:27	24/02/2022	05:56	PO	METRO-4 WORK
TROMBAY - SALSETTE CKT - 1	IntraState	23/02/2022	23:27	24/02/2022	05:51	PO	MERTO-4 WORK
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	15/02/2022	18:50	23/02/2022	17:45	HT	abnormal sparking noise
220/22 KV 50 MVA PTR 2 @ LONIKAND	IntraState	22/02/2022	11:40	23/02/2022	18:30	PO	ATTENDING HOT SPOT ON 29A ISO B-PH BUS SIDE BY HOT LINE TEAM
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	23/02/2022	11:07	23/02/2022	13:10	PO	Outage is required for Quarterly Maintenance

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 24/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT 2 @ CHAKAN PHASE II	IntraState	24/02/2022	09:22			PO	Diagnostic testing and Relay testing work.
132 KV LINE Outages/Trippings							
KANHAN-MANSAR	IntraState	23/02/2022	12:05	23/02/2022	17:50	PO	Routine Maintenance work.
SOLAPUR 2(BALE)-NALDURG	IntraState	23/02/2022	15:35	23/02/2022	19:10	PO	for DI replacement work at loc.no. 61 Rphase,53 R& jumper nut bolt tightening at 16
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	23/02/2022	09:06	23/02/2022	17:53	PO	DFCC PROJECT WORK
KALYAN KALWA SALSETTE 2	IntraState	23/02/2022	18:19	23/02/2022	22:03	PO	DFCC PROJECT WORK
KALYAN KALWA SALSETTE 1	IntraState	24/02/2022	08:18			PO	FOR DFCC PROJECT WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage