

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Feb/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.671	3571.183	1) Gujrat	3.982	-50.224
2) Hydro	20.166	332.119	2) Madhya Pradesh	2.860	89.186
3) Gas	3.249	105.223	3) Chattisgarh	4.200	104.230
Total MSPGCL	183.086	4008.525	4) Maharashtra	173.705	3920.471
B) 1) APLM	75.764	1691.122	5) Goa (Amona)	-1.099	-30.860
2) JSWEL	23.462	465.856	Total	183.648	4032.803
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.581	678.056
4) RPL(AMT)	27.947	695.282	b) Mumbai Drawl	39.125	812.005
5) SWPGPL	7.352	184.325	c) MSEDCL Bilateral *	77.337	1661.864
6) Other IPP	45.299	980.081	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.559	677.604
C) 1) TPCL Thermal	11.663	190.066	Include PX	0.000	0.000
2) TPCL Hydro	3.030	89.343	Standby	0.022	0.452
3) TPCL Gas	0.000	31.445	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.545	227.943	1) MSEDCL	520.045	11607.224
D) STATE			2) Mumbai Discoms	64.363	1350.799
1) Thermal	361.703	8005.858	3) Other Discoms	10.140	228.620
(A1+C1+C4+(B1-B6))			TOTAL STATE	594.548	13186.643
2) Hydro	23.196	421.462			
(A2+C2)					
3) Gas	3.249	136.668			
(A3+B7+C3)					
4) Wind	6.321	227.093			
6) SOLAR	16.431	362.762			
TOTAL STATE	410.900	9153.843			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6648	6701	6806	6597
MSPGCL Hydro	1607	262	1781	599
MSPGCL Gas	134	125	133	137
MSPGCL Total Generation	8389	7088	8720	7333
Central Sector Receipt	8823	9575	6676	6493
WIND	106	103	333	276
CPP / IPP Thermal	7662	7101	7589	7271
CPP / IPP Gas	0	0	0	0
SOLAR	1996	2259	0	0
Exchange with Mumbai	-1881	-2037	-1513	-1470
MSEDCL DEMAND MET	24641	23643	21347	19489
Load Shedding	0	0	0	0
MSEDCL DEMAND	24641	23643	21347	19489
TPCL GENERATION	791	659	977	507
AEML GENERATION	497	492	500	491
MUMBAI DEMAND	3169	3188	2990	2468
OTHER DISCOM DEMAND	454	446	458	414
STATE DEMAND MET	28264	27277	24795	22371
STATE DEMAND	28264	27277	24795	22371
Frequency (Hz)	50.02	50.00	49.97	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.28 Hz at 18.04 Hrs	49.7 Hz at 22.08 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 23/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.94	98.00	210	175
Unit 8	13.84	314.84	589	563
Unit 9	13.01	302.83	571	496
Unit 10	13.60	280.12	602	531
Total	45.40	995.79		
Bhusawal				
Unit 3	3.58	76.62	165	130
Unit 4	10.18	236.22	460	355
Unit 5	11.31	234.78	490	420
Total	25.06	547.62		
Parli				
Unit 6	0.00	97.35	0	0
Unit 7	5.67	71.12	259	180
Unit 8	3.75	80.17	174	137
Total	9.42	248.65		
Chandrapur				
Unit 3	3.72	82.51	165	130
Unit 4	3.35	69.43	148	120
Unit 5	0.00	76.31	0	0
Unit 6	9.51	196.53	425	295
Unit 7	0.00	0.00	0	0
Unit 8	11.82	260.15	500	477
Unit 9	11.47	176.26	494	455
Total	39.87	861.19		
Paras				
Unit 3	4.75	113.65	231	146
Unit 4	5.65	130.53	249	207
Total	10.40	244.18		
Khaparkheda				
Unit 1	0.00	41.96	0	0
Unit 2	3.48	64.49	151	129
Unit 3	4.08	85.91	186	155
Unit 4	4.51	76.64	192	183
Unit 5	11.36	247.73	500	445
Total	23.43	516.72		
Nasik				
Unit 3	4.12	85.61	180	157
Unit 4	1.98	4.52	165	0
Unit 5	0.00	66.90	0	0
Total	6.10	157.03		
Uran				
All Units	3.25	105.22	141	125
Total	3.25	105.22		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	9.46	41	0
Total	0.15	9.46		
Koyna				
Stage 1-2	5.53	87.44	525	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	7.49	92.63	771	0
Stage 3	2.67	38.36	320	0
Total	15.69	218.43		
Hydro				
KDPH	0.47	16.44	36	18
VTRNA	1.12	15.05	60	0
TILLARI	0.43	9.36	58	0
BHIRA T.R.	0.16	5.41	40	0
SMLHY_PTN	2.14	53.34	94	82
GHATGHAR	0.00	4.64	0	0
Total	4.32	104.23		
Wind				
Total	6.32	227.09	0	0
Total	6.32	227.09		
CPP				
APML(Mus)	75.76	1691.12	0	0
JSWEL(Mus)	23.46	465.86	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	27.95	695.28	0	0
SWPGPL-Mus	7.35	184.32	0	0
Dhariwal	4.53	26.62	213	144
IEPL	5.58	120.34	262	193
Other(Mus)	35.18	833.12	0	0
Total	179.82	4016.67		
SOLAR				
Total	16.43	362.76	0	0
Total	16.43	362.76		
Tata				
Trombay 5	7.64	95.69	457	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	17.51	0	0
Trombay 7B	0.00	13.94	0	0
TATA Hydro	3.03	89.34	290	9
Trombay 8	4.02	94.38	230	129
Total	14.69	310.85		
AEML				
DTPS U-1&2	10.54	227.94	500	302
Total	10.54	227.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.67	3571.18	MSPGCL Total	183.09	4008.52
			MSPGCL Thml+Gas	162.92	3676.41	Koyna 1,2 & 4 Total	13.02	180.07
			MSPGCL Hydro	20.17	332.12	State Total	410.90	9153.84

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 23/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6536	140	138	6814	471	7569	0	0	6883	6833	-1439	19870	0	19870	2306	378	22554	49.99
2	6502	144	140	6786	504	7430	0	0	7277	7033	-1362	20037	0	20037	2110	354	22501	49.98
3	6546	144	138	6828	523	7405	0	0	7302	7095	-1269	20261	0	20261	1982	321	22564	49.99
4	6570	149	140	6859	448	7380	0	0	7292	7134	-1207	20280	0	20280	1920	334	22534	49.97
5	6555	245	139	6939	370	7502	0	0	7399	7418	-1198	20670	0	20670	1924	361	22955	50.00
6	6557	1183	140	7880	361	7828	0	0	6631	6668	-1123	21245	0	21245	2083	369	23697	50.01
7	6595	1711	141	8447	284	7913	0	3	6651	6802	-1076	21979	0	21979	2269	394	24642	50.01
8	6577	1831	141	8549	298	7889	0	284	6705	7085	-1112	22577	0	22577	2445	416	25438	50.03
9	6644	1825	139	8608	132	7880	0	956	6753	7230	-1341	23008	0	23008	2730	457	26195	50.05
10	6661	1647	135	8443	122	7847	0	1557	7544	7918	-1608	23824	0	23824	2969	455	27248	50.02
11	6648	1607	134	8389	106	7662	0	1996	8285	8823	-1881	24641	0	24641	3169	454	28264	50.02
12	6657	901	131	7689	113	7363	0	2134	9153	9429	-2034	24246	0	24246	3221	448	27915	50.02
13	6701	262	125	7088	103	7101	0	2259	9623	9575	-2037	23643	0	23643	3188	446	27277	50.00
14	6741	264	132	7137	97	7055	0	2181	9376	9403	-2122	23306	0	23306	3026	445	26777	50.04
15	6634	264	129	7027	96	7014	0	2035	9738	9781	-2221	23297	0	23297	3025	435	26757	49.99
16	6584	693	129	7406	90	7202	0	1583	9406	9300	-2227	22902	0	22902	3085	452	26439	49.97
17	6688	1104	132	7924	107	7410	0	1039	8595	8498	-2072	22452	0	22452	3144	454	26050	49.95
18	6735	758	132	7625	147	7549	0	393	8286	7923	-2016	21154	0	21154	3112	467	24733	50.02
19	6737	1253	134	8124	311	7628	0	11	6683	6539	-1757	20385	0	20385	3095	471	23951	49.99
20	6806	1781	133	8720	333	7589	0	0	6518	6676	-1513	21347	0	21347	2990	458	24795	49.97
21	6856	869	133	7858	345	7553	0	0	6819	6666	-1718	20248	0	20248	2841	456	23545	50.01
22	6806	242	139	7187	383	7509	0	0	6655	6669	-1719	19576	0	19576	2696	453	22725	49.99
23	6738	550	138	7426	301	7275	0	0	6569	6657	-1603	19625	0	19625	2565	431	22621	49.96
24	6597	599	137	7333	276	7271	0	0	6439	6493	-1470	19489	0	19489	2468	414	22371	50.01
MUs	159.67	20.17	3.25	183.09	6.32	179.82	0.00	16.43	182.58	183.65	-39.12	520.06	0.00	520.06	64.36	10.12	594.55	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Feb/2023

Position as on 6.30 Hrs of 24/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	22/02/2023
IPP	SWPGPL U-2	135	08/02/2023	00:01		Continued.	Bag Filter replacement work	02/03/2023
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05		Continued.	Boiler validity work	27/02/2023
TPC-G	Bhira PSU	150	15/02/2023	04:30	23/02/2023	18:58	Tunnel 1 inspection,RM Trials, Calibration and testing work.	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	28/02/2023
MSPGCL	Nasik Unit 4	210	01/02/2023	19:24	23/02/2023	07:15	NASHIK TPS U#4 TOLLING FROM DATED 02.02.2023 at 03.43 A.M	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Uran Unit 6	108	15/02/2023	13:13		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	15/02/2023	16:54		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 1	210	21/02/2023	02:49	24/02/2023	04:07	Air heater problem	24/02/2023
MSPGCL	Parli Unit 6	250	21/02/2023	20:15		Continued.	Air heater problem	28/02/2023
TPC-G	Trombay 7A	120	21/02/2023	20:26		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	22/02/2023	22:05		Continued.	Boiler Tube Leakage	24/02/2023
IPP	RPL(AMT) U-2	270	23/02/2023	11:01		Continued.	Gas shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 24/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (409) OF AURANGABAD AND GT - 4 @ DEEPNAGAR	IntraState	20/02/2023	12:48	23/02/2023	18:00	PO	For servicing & overhauling of 400kV AREVA make C.B. Mechanism
400 KV TBC Outages/Trippings							
BUS COUPLER @ AURANGABAD (WALUJ)	IntraState	23/02/2023	14:13	23/02/2023	17:10	EO	To attend Hotspot on 89B Bph PG Isolator IPS pad clamp
400 KV MAINBAY Outages/Trippings							
MAIN BAY (414) OF 500 MVA ICT - 2 @ DEEPNAGAR	IntraState	24/02/2023	10:59			PO	For servicing & overhauling of 400kV AREVA make ICT-2 Main C.B. Mechanism
400 KV LINE Outages/Trippings							
PADGHE - KALWA CKT - 1	IntraState	20/02/2023	14:26			PO	1) CB pole Overhauling work as Bph pole SF6 gas contents SO2 beyond permissible limit . 2) Replacement of B bus PG isolator under LES scheme as HTLS conductor work in progress of Kalwa line 3) 400kV Kalwa -1 in service through TBC
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36			HT	HAND TRIPPED FOR LOAD MANAGEMENT
BUS BAR PROTECTION @ JEJURI	IntraState	23/02/2023	11:40	23/02/2023	22:00	PO	Annual bus bar protection testing
KORADI - KHADKA	IntraState	23/02/2023	15:08	23/02/2023	18:52	PO	For string replacement work
AKOLA-NANDGAONPETH (RPL-AMT)	IntraState	24/02/2023	10:48			PO	DCRM, Tandelta & routine maintenance work
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	23/02/2023	10:02	23/02/2023	18:52	PO	(1)Diff. relay testing work. (2) Bay maintenance work.
400/220 KV 500 MVA ICT @ ALKUD	IntraState	23/02/2023	20:15	23/02/2023	22:38	EO	To attend hot spot at Y phase LV side bushing
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	24/02/2023	11:36			PO	Diagnostic testing & Relay testing work & Routine maint. Work ICT & CTR, CT oil leakage attending work
400/220/33 KV 500 MVA ICT - 2 @ NANDED	IntraState	24/02/2023	11:50			PO	Diagnostic Testing Works as per test Frequency
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	24/02/2023	12:34			PO	Diagnostic testing work of CB & Routine Maintenance
220 KV TBC Outages/Trippings							
TBC @ KADEGAON	IntraState	23/02/2023	11:20	23/02/2023	17:10	PO	Replacement of R Ph CT
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ LONIKAND II	IntraState	23/02/2023	11:58	23/02/2023	13:45	PO	Diagnostic Testing Work
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work.
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 24/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
KARAD - DASGAON	IntraState	22/02/2023	00:00			PO	For Erection & stringing of In-line Narrow Base Multi circuit towers (Loc. No. 146 to 148) of new 220 KV Karad & Koyana line..
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	22/02/2023	06:12	24/02/2023	02:30	PO	Outage is required for safety purpose for:1) Erection of CTT Monopole in between Loc No- 398 & 399 of 220KV Kalwa-Bapgaon Line for the work of newly proposed substation of M/s.Estela Enterprises Pvt.Ltd.2) The monopole will be erected in line with cross-arm, in between both the Towers and 220 KV Kalwa Bapgaon line will charged through newly erected Monopole Tower after maintaining the sufficient distance from existing line.
BAPGAON - KALWA	IntraState	22/02/2023	06:15	24/02/2023	02:20	PO	1) Erection of CTT Monopole in between Loc No- 398 & 399 for the work of newly proposed substation of M/s.Estela Enterprises Pvt.Ltd.2) The monopole will be erected in line with cross-arm, in between both the Towers and 220 KV Kalwa Bapgaon line will charged through newly erected Monopole Tower after maintaining the sufficient distance from existing line.
KHARGHAR - TOPWORTH	IntraState	22/02/2023	08:27			PO	Erection of Gantry & Beam at Proposed Panvel Timber Market and making connectivity of OPGW to KhandeshwarGIS.
KHARGHAR - TSS PANVEL	IntraState	22/02/2023	09:26			PO	Erection of Granty & beam at proposed Panvel Timber Market and making connectivity of OPGE to Khandeshwar GIS.
KALWA - COLOURCHEM	IntraState	22/02/2023	15:24	23/02/2023	04:24	T	TRIPPED ON DISTANCE PROTECTION
TROMBAY SALSETTE LINE-2	IntraState	22/02/2023	23:02	23/02/2023	02:34	PO	400 KV KVPTL WORK
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	23/02/2023	07:14	23/02/2023	10:07	PO	Emergency tree branches trimming in span 40-41
VANKUSWADE - KDPH	IntraState	23/02/2023	09:30	23/02/2023	23:20	PO	Work of land/hill cutting between loc no.54-55 & 86-87 due to low ground clearance beside & below the line conductor
NANDED 2 (WAGHALA) - PARBHANI	IntraState	23/02/2023	11:12	23/02/2023	17:25	PO	Flas over disc replacement work on location 137,91,85- R-Y-B Phase.
DAHANU - GHODBUNDER CKT - 1	IntraState	23/02/2023	16:42	23/02/2023	18:57	EO	Outage required for erection of monopole (Project Work)
TROMBAY - SALSETTE CKT - 1	IntraState	23/02/2023	23:06	24/02/2023	02:21	PO	400KVPTL work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 24/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TALANDGE - BIDRI	IntraState	24/02/2023	09:20			PO	For Reconductoring of 400 KV Kolhapur- Kolhapur -1 (PGCIL) Moose conductor with HTLS conductor for system improvement
TALANDGE - SAWANTWADI	IntraState	24/02/2023	09:32			PO	For Reconductoring of 400 KV Kolhapur- Kolhapur -1 (PGCIL) Moose conductor with HTLS conductor for system improvement
CHEMBUR (AEML) - NERUL (M)	IntraState	24/02/2023	11:50			PO	For Diagnostic and R & M work and to check Non operation of Auto-reclose of Nerul-Chembur (Adani) line by Testing Team, Kalwa at Nerul end.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	24/02/2023	12:31				Replacement of R ph flashover string at loc No. 185 BY HOT LINE UNIT
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 200 MVA PTR NO 6 @ PARVATI	IntraState	23/02/2023	09:17	23/02/2023	18:40		220kV Bus Side Isolator Alignment Work, 220kV PTs Tan Delta, Fitting of Gas Collection Device to ICT 2, Half Yearly Maintenance and OLTC overhaul of PTR No. 1
220/132-110 KV 100 MVA ICT 2	IntraState	23/02/2023	10:58	23/02/2023	14:00	PO	Diagnostic Testing Work
220/22 KV 50 MVA PTR 1 @ RANJANGAON	IntraState	23/02/2023	11:20	23/02/2023	19:10	PO	220kV A& B- Bus Isolator alignment & Breaker overhauling work with co-ordination of hot line unit team
220/132kV 100MVA ICT - 2 @ KALWAN	IntraState	23/02/2023	12:30	23/02/2023	19:10		Routine Maintenance & Testing work
220/33 KV 25MVA PTR NO 2 @ BHIGWAN	IntraState	23/02/2023	12:50	23/02/2023	14:35	PO	for winding and bushing tan delta work by mobile testing batch pune & qtrly maint work.
220/33 KV 50 MVA PTR NO 1 @ BHIGWAN	IntraState	23/02/2023	15:40	23/02/2023	18:11	PO	winding and bushing tan delta & qtrly maint work at 220KV Bhigwan S/S.
132 KV BUSBAR Outages/Trippings							
BUSBAR PROTECTION @ EKLAHARE (GCR)	IntraState	24/02/2023	10:43				220kV and 132kV LBB Relay Testing
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
KALWA KALYAN	IntraState	24/02/2023	08:24			PO	Project Work-For Runwal Project Line diversion work
KARANJADE - BHOKARPADA	IntraState	24/02/2023	08:55			PO	TREE TRIMMING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage