

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Mar/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	151.377	3701.321	1) Gujrat	1.026	95.258
2) Hydro	8.948	201.929	2) Madhya Pradesh	14.015	282.201
3) Gas	6.969	155.734	3) Chattisgarh	5.280	107.020
Total MSPGCL	167.294	4058.984	4) Maharashtra	200.969	4085.657
B) 1) APML	73.452	1449.304	5) Goa (Amona)	-2.526	-43.036
2) JSWEL	26.856	609.990	Total	218.764	4527.100
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.933	692.984
4) RPL(AMT)	30.029	647.063	b) Mumbai Drawl	31.040	774.072
5) SWPGPL	12.173	271.937	c) MSEDCL Bilateral *	101.576	2276.322
6) Other IPP	31.332	983.394	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.933	692.984
C) 1) TPCL Thermal	14.991	252.524	Include PX	0.000	0.000
2) TPCL Hydro	4.910	98.675	Standby	0.000	0.000
3) TPCL Gas	4.018	82.246	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.260	210.017	1) MSEDCL	547.556	12239.093
D) STATE			2) Mumbai Discoms	66.219	1417.529
1) Thermal	351.470	8125.550	3) Other Discoms	10.757	248.592
(A1+C1+C4+(B1-B6))			TOTAL STATE	624.532	13905.214
2) Hydro	13.858	300.604			
3) Gas	10.987	237.980			
4) Wind	12.283	303.484			
6) SOLAR	17.170	396.397			
TOTAL STATE	405.768	9364.015			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5940	6078	6466	6315
MSPGCL Hydro	422	509	1298	220
MSPGCL Gas	284	280	289	297
MSPGCL Total Generation	6646	6867	8053	6832
Central Sector Receipt	9824	9716	8634	8518
WIND	430	246	593	613
CPP / IPP Thermal	7295	7355	7408	7138
CPP / IPP Gas	0	0	0	0
SOLAR	2123	1533	0	0
Exchange with Mumbai	-1687	-1631	-1266	-813
MSEDCL DEMAND MET	24144	23595	22918	21941
Load Shedding	0	0	0	0
MSEDCL DEMAND	24144	23595	22918	21941
TPCL GENERATION	925	982	1183	1023
AEML GENERATION	497	500	500	498
MUMBAI DEMAND	3109	3113	2949	2334
OTHER DISCOM DEMAND	487	491	504	347
STATE DEMAND MET	27740	27199	26371	24622
STATE DEMAND	27740	27199	26371	24622
Frequency (Hz)	49.95	49.95	49.95	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 06.02 Hrs	49.76 Hz at 20.06 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 23/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.21	88.14	190	145
Unit 8	13.60	310.96	599	494
Unit 9	13.67	225.90	592	557
Unit 10	0.00	189.91	0	0
Total	31.48	814.91		
Bhusawal				
Unit 3	3.68	79.65	180	120
Unit 4	2.00	194.18	390	0
Unit 5	0.00	158.78	0	0
Total	5.67	432.62		
Parli				
Unit 6	4.47	94.18	247	140
Unit 7	4.58	92.85	248	140
Unit 8	4.71	74.83	250	145
Total	13.76	261.86		
Chandrapur				
Unit 3	3.45	75.71	157	120
Unit 4	3.78	68.81	175	124
Unit 5	8.98	192.59	420	280
Unit 6	8.00	192.48	440	0
Unit 7	9.62	189.67	466	305
Unit 8	9.98	218.51	425	378
Unit 9	11.62	234.51	495	465
Total	55.44	1172.28		
Paras				
Unit 3	5.35	126.65	243	201
Unit 4	5.19	130.62	255	107
Total	10.54	257.28		
Khaparkheda				
Unit 1	4.12	85.94	175	165
Unit 2	4.09	92.27	195	150
Unit 3	4.04	88.44	178	162
Unit 4	3.98	92.53	191	155
Unit 5	10.78	243.83	475	425
Total	27.02	603.00		
Nasik				
Unit 3	3.74	21.33	172	131
Unit 4	3.73	82.43	175	128
Unit 5	0.00	55.61	0	0
Total	7.47	159.38		
Uran				
All Units	6.97	155.73	301	275
Total	6.97	155.73		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	2.33	30	0
Total	0.04	2.33		
Koyna				
Stage 1-2	2.17	43.20	470	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.35	31.68	308	0
Stage 3	0.76	16.92	160	0
Total	4.28	91.80		
Hydro				
KDPH	0.86	19.87	36	36
VTRNA	0.92	15.02	61	0
TILLARI	0.32	10.91	64	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.13	59.56	98	80
GHATGHAR	0.44	4.77	125	0
Total	4.67	110.13		
Wind				
Total	12.28	303.48	0	0
Total	12.28	303.48		
CPP				
APML(Mus)	73.45	1449.30	0	0
JSWEL(Mus)	26.86	609.99	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.03	647.06	0	0
SWPGPL-Mus	12.17	271.94	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.96	130.39	215	190
Other(Mus)	26.37	769.82	0	0
JPL	0.00	83.18	0	0
Total	173.84	3961.69		
SOLAR				
Total	17.17	396.40	0	0
Total	17.17	396.40		
Tata				
Trombay 5	10.06	166.70	471	271
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.50	50.13	108	68
Trombay 7B	1.52	32.12	65	53
TATA Hydro	4.91	98.68	425	69
Trombay 8	4.93	85.83	221	130
Total	23.92	433.44		
AEML				
DTPS U-1&2	11.26	210.02	501	290
Total	11.26	210.02		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	151.38	3701.32	MSPGCL Total	167.29	4058.98
			MSPGCL Thml+Gas	158.35	3857.06	Koyna 1,2 & 4 Total	3.52	74.88
			MSPGCL Hydro	8.95	201.93	State Total	405.77	9364.02

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 23/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6624	350	296	7270	521	7186	0	0	8798	8609	-1378	21796	0	0	21796	2684	412	24892	49.97
2	6647	269	297	7213	559	7210	0	0	8694	8484	-832	22261	0	0	22261	2493	373	25127	50.01
3	6315	220	297	6832	613	7138	0	0	8957	8518	-813	21941	0	0	21941	2334	347	24622	50.00
4	6170	214	297	6681	641	7251	0	0	8750	8626	-753	22105	0	0	22105	2222	341	24668	49.97
5	6481	219	297	6997	643	7260	0	0	9003	8892	-745	22686	0	0	22686	2187	361	25234	49.99
6	6572	225	298	7095	665	7355	0	0	9550	9100	-802	23019	0	0	23019	2268	394	25681	50.03
7	6569	216	301	7086	655	7377	0	24	9466	9372	-744	23349	0	5	23349	2329	421	26099	50.02
8	6620	220	299	7139	492	7370	0	413	9053	9044	-1000	23012	0	1	23012	2384	446	25842	50.06
9	6418	211	297	6926	449	7374	0	1065	8830	9016	-1395	22975	0	0	22975	2592	460	26027	50.00
10	6020	157	292	6469	457	7363	0	1686	9170	9112	-1543	23065	0	0	23065	2874	479	26418	49.94
11	5940	422	284	6646	430	7295	0	2123	9682	9824	-1687	24144	0	0	24144	3109	487	27740	49.95
12	5959	723	284	6966	280	7388	0	2346	9533	9194	-1759	23925	0	0	23925	3211	490	27626	50.01
13	5815	601	275	6691	166	7086	0	2383	9559	9404	-1750	23507	0	0	23507	3195	473	27175	50.01
14	5682	262	277	6221	126	6591	0	2254	9685	9910	-1672	22962	0	0	22962	3074	468	26504	50.01
15	5933	245	283	6461	166	6960	0	2037	9981	9829	-1654	23323	0	0	23323	3119	476	26918	49.96
16	6078	509	280	6867	246	7355	0	1533	9932	9716	-1631	23595	0	0	23595	3113	491	27199	49.95
17	6331	519	281	7131	390	7384	0	959	9627	9806	-1541	23637	0	0	23637	3053	492	27182	49.97
18	6319	300	285	6904	466	7301	0	326	9798	9474	-1350	22620	0	0	22620	2987	501	26108	49.99
19	5755	496	287	6538	483	7158	0	21	9275	9886	-1369	22218	0	0	22218	2936	499	25653	49.99
20	6466	1298	289	8053	593	7408	0	0	8748	8634	-1266	22918	0	0	22918	2949	504	26371	49.95
21	6547	450	291	7288	664	7269	0	0	8889	8929	-1327	22353	0	0	22353	2870	470	25693	49.97
22	6453	383	294	7130	795	7273	0	0	8404	8615	-1400	21940	0	0	21940	2802	473	25215	49.97
23	6782	233	293	7308	875	7271	0	0	8426	8402	-1367	22033	0	0	22033	2737	456	25226	49.94
24	6881	206	295	7382	908	7219	0	0	8672	8368	-1262	22172	0	0	22172	2697	443	25312	49.97
MUs	151.38	8.95	6.97	167.29	12.28	173.84	0.00	17.17	220.48	218.76	-31.04	547.56	0.00	0.01	547.56	66.22	10.76	624.53	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out due to 132KV BBLSR-Rahuri Line

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Mar/2024

Position as on 6.30 Hrs of 24/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 5	210	19/03/2024	17:40		Continued.	Withdrawn On Tolling.	
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-1	125	11/03/2024	18:40		Continued.	GM Link Fault	28/03/2024
MSPGCL	Uran Unit 6	108	12/03/2024	20:15		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Koradi Unit-10	660	17/03/2024	11:05	24/03/2024	19:54	Boiler Tube Leakage	24/03/2024
MSPGCL	Bhusawal Unit 5	500	22/03/2024	09:58		Continued.	Boiler Tube Leakage	25/03/2024
MSPGCL	Bhusawal Unit 4	500	22/03/2024	14:23	23/03/2024	16:19	Boiler Board tripped.	25/03/2024
MSPGCL	Chandrapur Unit 6	500	23/03/2024	17:36	23/03/2024	19:31	PA Board Failure	23/03/2024
Total Capacity MSPGCL		2513						
IPP								
IPP	RPL(AMT) U-5	270	11/03/2024	03:00	23/03/2024	03:07	Air heater problem	23/03/2024
IPP	JSW (J) U1	300	24/03/2024	00:06		Continued.	CW duct leakage.	29/03/2024
Total Capacity IPP		570						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3403						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Mar/2024

Position as on 6.30 Hrs of 24/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
IPP	JPL Unit 2	150	20/03/2024	00:00		Continued.	Non availability of schedule	
IPP	JPL Unit 1	150	22/03/2024	00:00		Continued.	Non availability of schedule	
Total Capacity IPP		1288						
Total Capacity FORCED OUTAGE DUE TO NO PPA		1288						

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 24/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	19/03/2024	12:23			PO	Major maintenance of GIS bay no.18
PADGHE - BOISAR (PG)	InterState	23/03/2024	13:05	23/03/2024	14:06	T	Tripped on distance protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35	23/03/2024	01:01	PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar-Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	22/03/2024	18:51	23/03/2024	00:09	PO	-
KALWA - KHARGHAR	IntraState	23/03/2024	01:01	23/03/2024	06:19	PO	Outage on temporarily formed 400KV Kalwa-Kharghar-Padgha-1 Line for Removing the tapping arrangement of 400kV Kalwa-Padgha Ckt.1 from (Loc no. 1113) on 400kV Kalwa-Kharghar line (loc no 167) (Tapping carried out on 11.02.2024) & Restore 400KV Kalwa-Kharghar Line & continue the outage on 400kV Kalwa-Padgha Ckt.1 Line.
PADGHE - KALWA CKT - 1	IntraState	23/03/2024	01:01		Continued.	PO	Outage on 400kV Kalwa-Padgha Ckt.1 Line for Removing the tapping arrangement of 400kV Kalwa-Padgha Ckt.1 from (Loc no. 1113) on 400kV Kalwa-Kharghar line (loc no 167) using ERS towers & Restore 400KV Kalwa-Kharghar Line & continue the outage on 400kV Kalwa-Padgha Ckt.1 Line on continuous basis for replacement of proposed balance existing conductor by HTLS Conductor till 25.03.2024.
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	23/03/2024	12:43	23/03/2024	18:08	EO	To attend Broken Earth Wire strands
NAGOTHANE - DABHOL CKT - 2	IntraState	24/03/2024	22:42	24/03/2024	23:16	T	Tripped on distance protection from Dabhol end only.
400 KV ICT Outages/Trippings							
400/220KV 315 MVA ICT - 2 @ BOISAR PG	InterState	24/03/2024	18:21			PO	AMP work, Dia to be kept open at both sides
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 24/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	23/03/2024	14:34	23/03/2024	17:58	EO	Heavy oil Leakage
400/220 KV 500 MVA ICT - 5 @ PADGHE	IntraState	24/03/2024	07:12	24/03/2024	23:52	PO	Outage required on 500MVA ICT No.5 LV side at 400kV Padgha s/stn. for safety purpose for stringing of HTLS conductor of 400kV Kalwa-Padgha-1 line at crossing loc 2A-2B
220 KV MAINBAY Outages/Trippings							
220KV AMALNER - JPL CKT 1	IntraState	23/03/2024	08:14	23/03/2024	16:15	PO	Tower jumper tightness work
220KV AMALNER - JPL CKT 2	IntraState	23/03/2024	17:08	23/03/2024	18:50	PO	Tower Jumper tightness work
220 KV LINE Outages/Trippings							
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kV Karad-Koyana line
ALEPHATA-PARGAON(KATHAPUR)	IntraState	16/03/2024	01:34			HT	Hand Tripped
VITA - MIRAJ	IntraState	22/03/2024	16:53	23/03/2024	00:25	PO	Polymer insulator replacement Work
NEW KOYNA - PEDAMBE	IntraState	23/03/2024	06:00	23/03/2024	06:37	T	Line tripped on Back up protection.
PEDAMBE-KALAMBANI(TSS)	IntraState	23/03/2024	06:00	23/03/2024	07:30	T	Line tripped on distance protection.
WANI-WARORA 1	IntraState	23/03/2024	07:19	23/03/2024	17:35	PO	For fixing of Bird Diverter
220KV CHITEGAON -SAWANGI CKT	IntraState	23/03/2024	11:20	23/03/2024	18:21	PO	To carry out Back up relay retrofitting
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	23/03/2024	11:36	23/03/2024	12:13	PO	Diagnostic testing .
VARKUTI- HIWARWADI	IntraState	23/03/2024	15:19	23/03/2024	23:51	PO	Old Insulator replacement work by long rod at Loc No 166 to 230
220 KV JALKOT - KUMBHARGAON (400 KV) CKT - 2	IntraState	23/03/2024	16:37	23/03/2024	17:16	PO	Tree cutting
MIRAJ - MHAISHAL	IntraState	23/03/2024	16:41	24/03/2024	01:28	PO	Polymer Insulator replacement Work
WANI-WARORA 1	IntraState	24/03/2024	07:18	24/03/2024	17:03	PO	FOR FIXING OF BIRD DIVERTER ON R, Y & B-PH CONDUCTOR & EARTHWIRE BY AGENCY M/S. TRAFOTECH SYSTEM PVT. LTD. MUMBAI
KANDALGAON - PIRANGUT	IntraState	24/03/2024	11:41	24/03/2024	17:45	PO	For fixing of conductor vibration dampers.
VARKUTI- HIWARWADI	IntraState	24/03/2024	14:50		Continued.	PO	Old Insulator replacement work by long rod at Loc No 166 to 230
NEW KOYNA - PEDAMBE	IntraState	24/03/2024	15:23	24/03/2024	16:30	T	Tripped on back up
PEDHAMBE ONI LINE	IntraState	24/03/2024	15:23	24/03/2024	17:45	T	Tripped on distance protection
220 KV ICT Outages/Trippings							
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/132 KV 100 MVA ICT-3 @ BHENDA	IntraState	22/03/2024	23:01	23/03/2024	01:06	PO	Annual Diagnostic Testing work Buswhing,CT, winding TanD and CB CRM timing work with the help of Mobile testing Unit Nashik.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 24/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33 KV 50 MVA PTR 1 @ BHENDA	IntraState	23/03/2024	10:22	23/03/2024	10:22	PO	Annual Diagnostic Testing work for Bushing,CT, winding TanD and CB CRM and Timing with the help of Mobile testing Unit Nashik.
220/33 KV 50 MVA PTR 2 @ BHENDA	IntraState	23/03/2024	10:30	23/03/2024	12:28	PO	Annual Diagnostic Testing work for Bushing,CT, winding TanD and CB CRM and Timing with the help of Mobile testing Unit Nashik.
220/33KV 100MVA TF No.1 @ BOTHE	IntraState	23/03/2024	11:40	23/03/2024	16:52	PO	Hot Spot attending work at LV Y Ph CT
220/33 KV 50 MVA PTR 3 @ BHENDA	IntraState	23/03/2024	12:54	23/03/2024	16:50	PO	Annual Diagnostic Testing work for Bushing,CT, winding TanD and CB CRM and Timing with the help of Mobile testing Unit Nashik.
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	24/03/2024	10:00	24/03/2024	16:22	PO	Repaired RET 670 Relay installation & commissioning and bay maintenance work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KOLSHET - BMC - BORIVALI (T) - BORIVALI (M)	IntraState	23/03/2024	08:43	23/03/2024	21:56	PO	installation of Safety Platform at BMC end
KOLSHET - BMC - BORIVALI (T) - BORIVALI (M)	IntraState	24/03/2024	09:55	24/03/2024	23:07	PO	installation of Safety Platform at BMC end

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage