

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Apr/2020 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	62.399	1372.531	1) Gujrat	10.609	234.016
2) Hydro	29.943	420.258	2) Madhya Pradesh	12.775	343.591
3) Gas	6.759	159.232	3) Chattisgarh	7.540	174.550
Total MSPGCL	99.101	1952.021	4) Maharashtra	124.466	2875.727
B) 1) APMIL	73.174	1461.641	5) Goa (Amona)	0.000	0.000
2) JSWEL	18.487	361.572	Total	155.390	3627.884
3) VIPL	0.000	0.000	a) Mumbai Schedule	21.833	417.143
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	24.141	371.989
5) WPCL	5.488	126.222	c) MSEDCL Bilateral *	56.000	1221.593
6) Other IPP	7.512	185.705	Include PX	34.650	782.081
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	21.833	417.143
C) 1) TPCL Thermal	6.669	255.308	Include PX	5.098	137.438
2) TPCL Hydro	4.790	96.998	Standby	0.000	0.000
3) TPCL Gas	4.412	79.189	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.163	239.595	1) MSEDCL	361.194	7787.152
D) STATE			2) Mumbai Discoms	49.175	1043.076
1) Thermal	182.892	4002.574	TOTAL STATE	410.369	8830.228
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	34.733	517.256			
3) Gas (A3+B7+C3)	11.171	238.421			
4) Wind	18.556	275.703			
6) SOLAR	7.627	168.393			
TOTAL STATE	254.979	5202.347			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	2417	2435	2512	2694
MSPGCL Hydro	1282	1217	988	1165
MSPGCL Gas	279	277	285	289
MSPGCL Total Generation	3978	3929	3785	4148
Central Sector Receipt	7509	7810	5654	5763
WIND	497	753	972	952
CPP / IPP Thermal	4287	4245	4400	4386
CPP / IPP Gas	0	0	0	0
SOLAR	1033	636	0	0
Exchange with Mumbai	-1082	-1037	-963	-923
MSEDCL DEMAND MET	16222	16336	13848	14326
Load Shedding	0	0	0	0
MSEDCL DEMAND	16222	16336	13848	14326
TPCL GENERATION	556	703	864	707
AEML GENERATION	375	373	376	377
MUMBAI DEMAND	2013	2113	2203	2007
STATE DEMAND MET	18235	18449	16051	16333
STATE DEMAND	18235	18449	16051	16333
Frequency (Hz)	50.04	49.99	49.99	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.25 Hz at 18.01 Hrs	49.71 Hz at 19.12 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 23/Apr/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	112.89	0	0
Unit 9	0.00	112.84	0	0
Unit 10	0.00	108.90	0	0
Total	0.00	334.63		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	13.91	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	10.34	49.42	480	365
Unit 7	0.00	0.00	0	0
Unit 8	11.12	189.49	470	440
Unit 9	10.69	218.98	470	430
Total	32.14	471.80		
Paras				
Unit 3	5.76	123.53	250	214
Unit 4	5.27	112.01	256	0
Total	11.04	235.54		
Khaparkheda				
Unit 1	0.00	38.21	0	0
Unit 2	0.00	44.42	0	0
Unit 3	4.41	42.40	195	165
Unit 4	4.33	46.28	195	160
Unit 5	10.49	159.25	500	360
Total	19.22	330.56		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.76	159.23	296	268
Total	6.76	159.23		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	4.03	45	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.13	4.03		
Koyna				
Stage 1-2	7.74	124.47	525	50
Stage 4	14.99	163.53	863	359
Stage 3	4.53	59.76	240	80
Total	27.26	347.76		
Hydro				
KDPH	0.89	19.74	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.34	9.63	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.29	4.88	80	0
RNGR+BHTSA	0.31	6.54	13	12
BHANDARDRA	0.45	11.95	32	5
ELDARY	0.00	5.36	0	0
SMLHY_PTN	0.40	14.38	26	14
GHATGHAR	0.00	0.00	0	0
Total	2.68	72.49		
Wind				
Total	18.56	275.70	0	0
Total	18.56	275.70		
CPP				
APML(Mus)	73.17	1461.64	0	0
JSWEL(Mus)	18.49	361.57	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	5.49	126.22	0	0
Other(Mus)	7.51	185.70	0	0
Total	104.66	2135.14		
SOLAR				
Total	7.63	168.39	0	0
Total	7.63	168.39		
Tata				
Trombay 5	6.67	200.48	398	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	48.78	118	116
Trombay 7B	1.60	30.41	68	66
Trombay 8	0.00	54.82	0	0
TATA Hydro	4.79	97.00	410	25
Total	15.87	431.50		
AEML				
DTPS U-1&2	9.16	239.60	501	373
Total	9.16	239.60		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	62.40	1372.53	MSPGCL Total	99.10	1952.02
			MSPGCL Thml+Gas	69.16	1531.76	Koyna 1,2 & 4 Total	22.73	288.00
			MSPGCL Hydro	29.94	420.26	State Total	254.98	5202.35

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 23/Apr/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2746	1473	296	4515	876	4465	0	0	5900	5780	-975	14661	0	14661	2343	17004	50.00
2	2758	1478	277	4513	770	4477	0	0	5778	5947	-1018	14689	0	14689	2213	16902	50.03
3	2757	1328	287	4372	927	4360	0	0	5798	5785	-981	14463	0	14463	2093	16556	50.03
4	2694	1165	289	4148	952	4386	0	0	5749	5763	-923	14326	0	14326	2007	16333	49.99
5	2692	1163	289	4144	1039	4380	0	0	5891	5951	-891	14623	0	14623	1945	16568	49.92
6	2693	1317	290	4300	1008	4399	0	0	6406	6652	-878	15481	0	15481	1930	17411	50.00
7	2728	1400	291	4419	814	4354	0	62	7111	7146	-806	15989	0	15989	1860	17849	50.03
8	2683	1055	289	4027	626	4375	0	263	7131	7197	-825	15663	0	15663	1837	17500	50.02
9	2695	1426	276	4397	609	4385	0	523	6382	6325	-881	15358	0	15358	1901	17259	49.98
10	2765	1501	293	4559	483	4387	0	763	6292	6194	-907	15479	0	15479	1953	17432	49.99
11	2631	1147	271	4049	452	4367	0	941	6760	6844	-1019	15634	0	15634	1996	17630	50.04
12	2417	1282	279	3978	497	4287	0	1033	7404	7509	-1082	16222	0	16222	2013	18235	50.04
13	2417	1548	269	4234	475	4278	0	1015	7373	7374	-1083	16293	0	16293	2034	18327	49.98
14	2453	1108	268	3829	524	4306	0	931	7703	7478	-1130	15938	0	15938	2055	17993	50.03
15	2437	968	278	3683	628	4256	0	865	7692	7709	-1158	15983	0	15983	2119	18102	50.01
16	2435	1217	277	3929	753	4245	0	636	7720	7810	-1037	16336	0	16336	2113	18449	49.99
17	2412	1152	268	3832	660	4328	0	390	7297	7359	-1013	15556	0	15556	2032	17588	50.01
18	2456	1217	281	3954	851	4299	0	164	6225	6346	-1077	14537	0	14537	1930	16467	50.08
19	2539	1053	271	3863	909	4348	0	41	5159	5216	-1027	13350	0	13350	1883	15233	50.03
20	2605	1164	292	4061	817	4376	0	0	5405	5546	-1096	13704	0	13704	2017	15721	49.90
21	2505	1229	273	4007	931	4334	0	0	5402	5514	-1103	13683	0	13683	2094	15777	50.01
22	2512	988	285	3785	972	4400	0	0	5552	5654	-963	13848	0	13848	2203	16051	49.99
23	2630	1035	275	3940	1015	4438	0	0	5746	6226	-1061	14558	0	14558	2255	16813	50.01
24	2739	1529	295	4563	968	4431	0	0	6090	6065	-1207	14820	0	14820	2349	17169	50.02
MUs	62.40	29.94	6.76	99.10	18.56	104.66	0.00	7.63	153.97	155.39	-24.14	361.19	0.00	361.19	49.18	410.37	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Apr/2020

Position as on 6.30 Hrs of 24/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Parli Unit 8	250	23/03/2020	18.00		Continued.	Zero Schedule.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
IPP	JSW (J) U2	300	26/03/2020	00.13		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 7	500	28/03/2020	23.56		Continued.	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Apr/2020

Position as on 6.30 Hrs of 24/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	10/04/2020	20.30		Continued.	Zero Schedule By MSEDCL	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 1	210	22/04/2020	20.45		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Khaparkheda Unit 2	210	22/04/2020	21.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Paras Unit 4	250	23/04/2020	19.29	23/04/2020	21.55	Electrical Protection Operated.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 24/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	21/04/2020	17.20		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	23/03/2020	18.12		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	24/03/2020	20.20		Continued.	HT	Over Voltage
New Koyana - Dabhol-I	IntraState	25/03/2020	18.01		Continued.	T	Over Voltage
Padghe - Nagothane - II	IntraState	07/04/2020	23.58		Continued.	EO	To attend Hot Spot
karad -kolhapur-I	IntraState	18/04/2020	17.44	23/04/2020	11.00	HT	Over Voltage
Chandrapur - Parli	IntraState	19/04/2020	02.20		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Chandrapur-II - Nanded ckt II	IntraState	19/04/2020	02.21		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Babhaleshtar - Padghe-II	IntraState	20/04/2020	09.25		Continued.	PO	Quarterly Maintenance work & Relay Testing, for CVT replacement work (RFC at 21.22 Hrs).
Girwali- Lonikand 2	IntraState	20/04/2020	14.23		Continued.	HT	Controlling loading of Parli Parli (PG D/C line).
Taptitanda Waluj	IntraState	22/04/2020	17.18		Continued.	T	Distance Protection (RFC at 14.08Hrs DT.24-4-20)
karad -kolhapur-II	IntraState	24/04/2020	19.49		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	24/04/2020	21.25		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	25/03/2020	13.59		Continued.	EO	CT Tan Delta High(Kept on Humming at 15.52Hrs DT. 24-4-20)
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	25/03/2020	16.32		Continued.	HT	Maintenance work and ICT out LV side(kept on Humming at 20.10Hrs DT.24-04-20)
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	25/03/2020	17.57		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220/33kv 315mva Ict3 @Lonikand	IntraState	25/03/2020	22.01		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	28/03/2020	18.07		Continued.	HT	Over Voltage
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	17/04/2020	13.19		Continued.	PO	Attending Hot Spot
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	19/04/2020	11.55		Continued.	HT	Over Voltage
400/220 KV 500MVA ICT II @ Nanded	IntraState	23/04/2020	09.22	23/04/2020	15.55	EO	Restore ICT-2 Normalcy.
400/220/33 Kv 315 Mva ICT I @ Akola (M)	IntraState	23/04/2020	19.29	23/04/2020	21.10	T	Distance Protection
400/220/33 Kv 315 MVA ICT-3 @Padghe	IntraState	24/04/2020	18.10		Continued.	T	Y Phase Stub Bus Conductor suspension string broke at Padgha
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BADNERA - WARDHA (PG) (Deoli)	InterState	23/04/2020	06.47	23/04/2020	19.51	PO	Safety Purpose to Carry Out Construction Work of 220Kv Badnera Line.
Borivali - Tarapur	InterState	24/04/2020	06.50	24/04/2020	18.00	T	B Phase Conductor Fall
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 24/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Lonand-Baramati	IntraState	16/02/2020	09.37		Continued.	PO	MSETCL Tower NO.240
							Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand & Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Nadgaonpeth-Amravati	IntraState	23/04/2020	06.31	23/04/2020	09.43	EO	Attending Hot Spot
Deoli(Pgcil)-Badnera	IntraState	23/04/2020	06.47	23/04/2020	19.51	PO	Safety purpose(Construction work)
Ambazari-Abhijeet	IntraState	23/04/2020	09.56	23/04/2020	12.47	PO	Line Signature Analysis.
Badnera-Akola I	IntraState	23/04/2020	10.01	23/04/2020	19.23	PO	Erection of MD+9 Tower At Loc No.9 of 220Kv Badnera-Ner Line Phase.
Badnera-Akola li	IntraState	23/04/2020	10.02	23/04/2020	19.27	PO	Erection of MD+9 Tower At Loc No.9 of 220Kv Badnera-Ner Line Phase.
Talandge-Mudshingi Ckt-I	IntraState	23/04/2020	10.24	23/04/2020	15.15	PO	Flashover Insulator Replacement Work Loc No.295 B-Phase.
Urse-Chinchwad (ST tap)	IntraState	23/04/2020	10.25	23/04/2020	18.09	PO	Shifting 220Kv Urse Line On New T Clamp On 220Kv Bus. For Replace of CT B ph. Y ph LA.
Eklahara(Gcr)(Nasik)- Bableshtar 2	IntraState	23/04/2020	14.02	23/04/2020	15.58	T	Distance Protection
Sawantwadi-Bidri	IntraState	23/04/2020	20.02	23/04/2020	22.21	HT	Over Voltage
Badnera-Akola I	IntraState	24/04/2020	07.38	24/04/2020	19.13	PO	Erection of MD+9 Tower of 220KV Badnera-Ner Line phase
Badnera-Akola li	IntraState	24/04/2020	07.39	24/04/2020	19.13	PO	Erection of MD+9 Tower of 220KV Badnera-Ner Line phase
Deoli(Pgcil)-Badnera	IntraState	24/04/2020	09.15	24/04/2020	19.48	PO	Construction work
Kalwa1- Airoli Knowledge Park	IntraState	24/04/2020	10.55	24/04/2020	12.33	PO	To replace the meter of R Phase LA
Eklahare (Ocr)Nasik - Padghe 2	IntraState	24/04/2020	18.10	24/04/2020	19.27	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
Padghe-Kamba II	IntraState	24/04/2020	18.10	24/04/2020	19.29	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
Padghe - Nalasopara	IntraState	24/04/2020	18.10	24/04/2020	19.28	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
Padghe-Temghar-II	IntraState	24/04/2020	18.10	24/04/2020	19.22	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
220 KV ICT Outages/Trippings							
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS
220/110 Kv 200 Mva Vel Ptr 1 @Kolhapur-li (Mudshingi)	IntraState	21/04/2020	17.50		Continued.	HT	Over Voltage
220/100 kv 200 MVA ICT II @Padghe	IntraState	24/04/2020	18.10	24/04/2020	20.15	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
220/100 Kv 200 MVA ICT IV @Padghe	IntraState	24/04/2020	18.10	24/04/2020	20.12	T	Y Phase Stub Bus Conductor suspension string broke at Padghe

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage